



FE17751


NTIS

One Source. One Search. One Solution.

**COMMERCIAL COMPLEX CONCEPTUAL
DESIGN/ECONOMIC ANALYSIS. OIL AND POWER BY
COED BASED COAL CONVERSION. R AND D REPORT
NO. 114. INTERIM REPORT NO. 1**

PARSONS (RALPH M.) CO., PASADENA, CALIF

SEP 1975



U.S. Department of Commerce
National Technical Information Service

One Source. One Search. One Solution.

NTIS



Providing Permanent, Easy Access to U.S. Government Information

National Technical Information Service is the nation's largest repository and disseminator of government-initiated scientific, technical, engineering, and related business information. The NTIS collection includes almost 3,000,000 information products in a variety of formats: electronic download, online access, CD-ROM, magnetic tape, diskette, multimedia, microfiche and paper.



Search the NTIS Database from 1990 forward

NTIS has upgraded its bibliographic database system and has made all entries since 1990 searchable on www.ntis.gov. You now have access to information on more than 600,000 government research information products from this web site.

Link to Full Text Documents at Government Web Sites

Because many Government agencies have their most recent reports available on their own web site, we have added links directly to these reports. When available, you will see a link on the right side of the bibliographic screen.

Download Publications (1997 - Present)

NTIS can now provides the full text of reports as downloadable PDF files. This means that when an agency stops maintaining a report on the web, NTIS will offer a downloadable version. There is a nominal fee for each download for most publications.

For more information visit our website:

www.ntis.gov



U.S. DEPARTMENT OF COMMERCE
Technology Administration
National Technical Information Service
Springfield, VA 22161



**COMMERCIAL COMPLEX
CONCEPTUAL DESIGN/ECONOMIC ANALYSIS**

OIL AND POWER

BY

COED BASED COAL CONVERSION

R & D REPORT NO. 114 - INTERIM REPORT NO. 1

September 1975

REPRODUCED BY
**NATIONAL TECHNICAL
INFORMATION SERVICE**
U. S. DEPARTMENT OF COMMERCE
SPRINGFIELD, VA. 22161

**FOR THE UNITED STATES
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION
WASHINGTON, D. C. 20545
UNDER CONTRACT NO. E(49-18)-1775**

**The Ralph M. Parsons Company
Pasadena, California 91124**

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

This report has been reproduced directly from the best available copy.

Available from the National Technical Information Service, U. S. Department of Commerce, Springfield, Virginia 22161

COMMERCIAL COMPLEX
CONCEPTUAL DESIGN/ECONOMIC ANALYSIS

OIL AND POWER

BY

COED BASED COAL CONVERSION

R & D REPORT NO. 114 - INTERIM REPORT NO. 1

September 1975

ii

CONTENTS

SECTION 1	INTRODUCTION	1-1
SECTION 2	SUMMARY	2-1
SECTION 3	DESIGN PARAMETERS	3-1
SECTION 4	SUMMARY FACILITY DESCRIPTION	4-1
SECTION 5	PLANT UNIT DESCRIPTIONS	5-1
SECTION 6	PROCESS FLOW DIAGRAMS	6-1
SECTION 7	MATERIAL BALANCE	7-1
SECTION 8	UTILITIES	8-1
SECTION 9	ENERGY BALANCE	9-1
SECTION 10	MAJOR EQUIPMENT SUMMARY	10-1
SECTION 11	ENVIRONMENTAL FACTORS	11-1
SECTION 12	ECONOMICS	12-1
SECTION 13	PROJECTED PLANT PERFORMANCE	13-1
SECTION 14	POTENTIAL IMPROVEMENTS	14-1

APPENDIXES

A	Design Basis	A-1
B	Site Conditions	B-1

FIGURES

4-1	Block Flow Diagram - Conceptual Commercial COED Plant Design	4-3
4-2	Artist's Concept of Conceptual Commercial COED Plant Design	4-5
4-3	Model of Conceptual Commercial COED Plant Design	4-6

CONTENTS (Contd)

FIGURES (Contd)

5-1	Sketch of Mine Plant	5-5
5-2	Illustration of Mine Working Plan	5-6
7-1	Overall Material Balance - Typical Operation for Process Sections	7-2
9-1	Energy Balance - Conceptual Commercial COED Plant Design	9-3
9-2	Thermal Efficiency Based on Export of Fuel Gas	9-5
11-1	Block Flow Diagram - Air Pollution Abatement	11-2
12-1	Project Overall Schedule	12-17
12-2	Fund Drawdown Schedule (Semiannual Basis)	12-19
12-3	Fund Drawdown Schedule - Cumulative	12-20
12-4	Required Product Selling Prices - Typical Gas Analysis	12-43
12-5	Required Product Selling Prices	12-44
12-6	Required Product Selling Prices as a Function of Changes in DCF Rate of Return	12-46
12-7	Sensitivity of Required Selling Prices to Changes in Operating Costs and Capital Investment - Case: Private Ownership - 100% Equity - 10% DCF	12-47
12-8	Sensitivity of Required Selling Prices to Changes in Operating Costs and Capital Investment - Case: Private Ownership - 65% Debt, 9% Interest	12-48
12-9	Sensitivity of Required Selling Prices to Changes in Operating Costs and Capital Investment - Case: Boundary not Taxed - Non profit	12-49
12-10	Sensitivity of Fixed Capital Investment to Variation in Capacity	12-51
12-11	Sensitivity of Required Product Selling Price to Variations in Capacity	12-53

TABLES

8-1	Utility Summary	8-2
10-1	Major Equipment Summary - Unit 10-1 - Coal Mine	10-2
10-2	Major Equipment Summary - Unit 10-2 - Coal Preparation	10-3
10-3	Major Equipment Summary - Unit 11-1 - Pyrolysis and Gasification	10-7

CONTENTS (Contd)

TABLES (Contd)

10-4	Major Equipment Summary - Unit 11-2 - Oil-Vapor Recovery	10-15
10-5	Major Equipment Summary - Unit 12-1 - Oil Filtration . . .	10-18
10-6	Major Equipment Summary - Unit 13-1 - Pyrolysis Gas Treating	10-20
10-7	Major Equipment Summary - Unit 14-1 - Hydrogen Plant . . .	10-22
10-8	Major Equipment Summary - Unit 15-1 Oil Hydrotreating	10-24
10-9	Major Equipment Summary - Steam and Power Generating Plant - Unit 18-1 - Fuel Gas Compression	10-27
10-10	Major Equipment Summary - Unit 18-2 - Power Generation . .	10-28
10-11	Major Equipment Summary - Unit 19-1 - Plant Air and Instrument Nitrogen	10-28
10-12	Major Equipment Summary - Unit 19-2 - Cooling Water	10-29
10-13	Major Equipment Summary - Unit 19-3 - Industrial Water System	10-30
10-14	Major Equipment Summary - Unit 19-4 - Potable and Sanitary Water System	10-32
10-15	Major Equipment Summary - Unit 19-5 - Fire Water System	10-32
10-16	Major Equipment Summary - Unit 19-6 Waste Water Treatment System	10-33
10-17	Major Equipment Summary - Unit 19-7 - Product Storage . . .	10-33
10-18	Major Equipment Summary - Unit 20 - Buildings and General Facilities	10-34
11-1	Sulfur Balance	11-4
11-2	Comparison of Emissions with Standards, Coal Gasification Plant	11-5
11-3	Comparison of Emissions with Standards, Power Generating Plant	11-5
12-1	Estimated Fixed Capital Investment	12-2
12-2	Major Equipment Costs	12-4
12-3	COED Process Plant Catalyst and Chemicals Cost Summary . .	12-8
12-4	Startup Costs	12-10
12-5	Estimate of Working Capital Requirement	12-11
12-6	Coal Mine Equipment Replacement Schedule	12-12
12-7	Capital Costs	12-14
12-8	Annual Operating Cost Summary	12-16
12-9	Manpower Summary	12-21

CONTENTS (Contd)

TABLES (Contd)

12-10	Coal Mine Equipment Operating Costs	12-22
12-11	Coal Mine Operating Labor and Supervision	12-23
12-12	Coal Mine Maintenance Labor and Supervision	12-25
12-13	Coal Preparation Operating and Maintenance Labor	12-26
12-14	Process Plant Operating Labor	12-27
12-15	Process Plant Maintenance Labor	12-28
12-16	Power Plant Labor	12-28
12-17	Offsites Chemical Cost Summary	12-30
12-18	Offsites Labor	12-31
12-19	Contribution of Cost Centers to Required Revenue	12-33
12-20	Cash Flow Case Evaluation - Private Ownership - 100% Equity	12-34
12-21	Cash Flow Case Evaluation - Private Ownership - 65% Debt Financing at 9%	12-37
12-22	Cash Flow Case Evaluation - Boundary Case - Nonprofit - Not Taxed	12-40

ABBREVIATIONS

av	average
bbl	barrels
bp	boiling point
BPD	barrels per day
Btu	British thermal unit
Btu/hr	Btu per hour
CH	channel
CI	cast iron
CS	carbon steel
DTPH	dry tons per hour
eff	efficiency
gpm	gallons per minute
Hdr	header
HHV	higher heating value
hp	horsepower
kV	kilovolt (1,000 volts)
lb/hr	pounds per hour
M	thousand
MAF	moisture and ash free (coal)
MF	moisture free (coal)
MM	million
MW	megawatts
MWe	megawatt electricity
ppm	parts per million
psia	pounds per square inch absolute
psig	pounds per square inch gauge

ROM	run of mine (coal)
scf	standard cubic feet
scfd	standard cubic feet per day
scfh	standard cubic feet per hour
sh	shell
sp gr and S.G.	specific gravity
SS	stainless steel
T	tubes
TDH	tons per day
TPH	tons per hour
TPY	tons per year
wt	weight

SECTION 1

INTRODUCTION

This report presents the results of a preliminary design and economic evaluation for a commercial complex to mine high-sulfur coal and produce low-sulfur synthetic crude oil (syncrude), electrical energy, and sulfur using COED-based pyrolysis technology for the coal conversion portion of the complex.

This work was performed for the Energy Research and Development Administration (ERDA) - Fossil Energy, whose support and guidance in these activities are gratefully acknowledged. From the experience gained during pilot plant operation, the design basis was developed in cooperation with representatives of ERDA and the process development contractor, FMC Corporation.

1.1 OBJECTIVES

The objectives of the work described in this report were to:

- (1) Review the experience obtained during the successful operation of the ERDA-supported COED pilot plant operated by FMC Corporation at Princeton, New Jersey, over the period 1970 through 1974.
- (2) Develop a conceptual design for a commercial COED-based industrial complex including all operations required to mine coal, prepare it by cleaning and washing it, convert it to ecologically clean liquid and gaseous fuels, and convert the gaseous fuels to electrical energy for sale.
- (3) Estimate the economics for the facility to serve as a guide in making decisions regarding future commercial applications of this technology.
- (4) Provide recommendations regarding additional development effort to foster commercial exploitation of the technology.
- (5) Define probable project and financial parameters for design, engineering, procurement, construction, and startup of the complex.

1.2 REPORT ORGANIZATION

A summary of the material contained in this report is presented in Section 2 to aid the reader in rapid assimilation of its contents.

Sections 3 and 4 provide an introduction and orientation for the detailed design information which follows in later sections. The design parameters and design bases used are summarized in Section 3. Section 4 describes the scope and major units included in the complex. An overview of the method of assembling the principal process units and material flows, presented in the form of a block flow diagram, is also included in Section 4, together with an artist's rendition of the complex. Section 5 contains detailed descriptions of the design, and process flow diagrams are presented in Section 6. The overall materials and energy efficiencies are summarized in Sections 7 through 9.

Section 10 summarizes the major equipment items required; this provides a basis for the fixed capital investment and operating cost estimates which follow. Environmental factors that must be considered are detailed in Section 11. The estimated economics for this type of complex is developed in Section 12. Here the fixed capital investment, other capital requirements, operating requirements and operating cost, and projected profitability are presented. Sensitivity factors are also given.

Opinions regarding projected performance of this facility are presented in Section 13 and, finally, recommendations for future design improvements are given in Section 14. These latter two sections summarize the results of an after-the-fact evaluation of probable performance and suggestions for further design work.

SECTION 2

SUMMARY

A conceptual design and economic evaluation for a project to design, engineer, procure, construct, and start up an industrial complex which will mine high-sulfur coal and convert it to low-sulfur syncrude plus electrical energy has been completed. The results are summarized in this report.

This work was done with the support and guidance of the Energy Research and Development Administration - Fossil Energy. The design basis was developed in cooperation with representatives of ERDA and FMC Corporation, the process developer. The design basis utilized data and experience gained during the pilot plant operation.

The scope of the industrial complex consists of a large captive coal mine supplying the feed material to a coal preparation plant, which in turn supplies approximately 25,000 TPD of clean, washed coal to a COED-based pyrolysis coal conversion plant. In the COED facility, the feed coal is converted to 25°API, 0.1% sulfur syncrude plus low-sulfur fuel gases, as well as byproduct sulfur. The fuel gases are fed to a close-coupled electrical power generation plant which produces electricity for export; it also produces steam for captive use in the complex. The complex is a grass roots facility and is conceived to be located in the Eastern Region of the Interior Coal Province. The mine-mouth processing facility meets desired location criteria consisting of significant resource of high-sulfur coal with a large utility/industrial market nearby, with ecological restrictions for direct consumption of the indigenous high-sulfur coal.

This design provides the equipment and operating flexibility to process feed coal with a range of analyses which might be expected over the course of a 20-year operating life, using coal typically mined in the Eastern Region of the U.S. Interior Coal Province. This distinguishes the design from other designs which have been based on a single typical coal analysis and which might be called single feed source or "point" designs. The use of a fixed coal feed rate and variable coal characteristics requires higher fixed capital investment to provide the necessary flexibility; it also results in variable product rates.

The process flowsheets and accompanying heat and material balances which are presented are based on a typical coal analysis which is intermediate between the extreme analyses that might be encountered during the project life. All equipment was sized to handle the range of feed analyses and resulting operating condition adjustments to permit operation at capacity approximately 95% of the onstream time.

For the typical design case, approximately 36,000 TPD of run-of-mine (ROM) coal is mined and processed through a coal preparation plant to produce approximately 27,500 TPD of clean, washed coal feed to the COED pyrolysis plant. Products from the process plant include 28,000 bbl/day of 25°API syn-crude with a maximum sulfur content of 0.1% by weight plus about 830 MW of electrical power for sale. About 750 long tons of sulfur is produced as by-product.

Considerable attention was given to methods of scale-up; the scale-up factor from pilot plant to the conceptual design reported here was of the order of 700. Methods of scale-up were selected to provide efficiency, operability, and process controls.

To develop the conceptual design it was necessary to use extrapolation procedures in certain cases. For these cases, the basic chemical engineering phenomena were examined in detail with the objective of developing a sound basis for the extrapolation and scale-up. An example is that the conceptual design encompasses gasification of pyrolysis-produced char to consume a total of approximately 98% of the carbon contained in the feed coal. This represents an example of extrapolation; in a typical pilot plant run approximately 30% of the carbon was converted in the pyrolysis section. About 6% of the carbon in the resulting pyrolysis-produced char was gasified by reaction with steam and oxygen. This compares with 66% steam-oxygen gasification required in the conceptual plant design described here.

The design represents an assessment of a proposed configuration and potential economics for this type of technology. To accomplish this objective required the use of engineering judgement for the scale-up and the selection of the equipment required to achieve the stated objectives. It also represents an exposition of factors required to integrate the coal conversion plant with a closely coupled electrical power generation facility and a large coal mine. The development of the interfaces between the coal mine, process plant, and power plant has defined a number of the design and operational options which exist for maximizing efficiencies and profitabilities.

Approximately 500 acres should be allocated for the complex site exclusive of the coal mine. Over a 20-year project life, about 42 square miles would be mined. An artist's conceptual drawing of the complex is presented.

The estimated fixed capital investment for the complex is \$1 billion; all estimates are in first-quarter 1974 dollars. The total capital investment is estimated to be \$1.125 billion; this includes the cost of initial raw materials, catalysts and chemicals, allowance for startup and land acquisition and initial working capital.

The population of the complex is estimated to be about 1700. Operating costs are projected to be about \$127 million per year. The required plant revenue

for a 10% discounted cash flow rate of return (DCF) with 65% debt at 9% interest is \$300 million per year. Typical required selling prices for the mixed product slate at 10% DCF, after by-product sulfur credit, are as follows:

<u>Syncrude, \$/bbl</u>	<u>Electricity, mils/kW-hr</u>
10	32
15	25
18	20
26	10

Other cases and sensitivities of required selling prices and profitability to key economic parameters are presented.

A representative project schedule for the design, engineering, construction, and startup is given; a 57-month schedule to mechanical completion is projected, and a probable fund drawdown schedule is presented.

The conceptual commercial COED process plant described herein has been designed to be capable of processing the design feed at the design rate and produce products of design quality and quantity. Where uncertainty in basic information existed, the equipment has been specified to cover this uncertainty.

The design is considered to be workable with the understanding that the estimated costs that are reported here have the probability of being greater than if additional information were available; this is often the case for first-generation plants.

The design of the char gasifiers for high carbon conversion represents an extension of the COED pilot plant experience. Prior experience obtained in the first-stage gasification step in the pilot plant, along with additional available kinetic data, were used to design the commercial-scale units. The results were compared with small-scale experimental work using COED char and a resulting kinetic model developed by the Institute of Gas Technology (IGT) to correlate the data. In addition, IGT was authorized to conduct a two-phase experimental program to investigate conditions required to achieve the specified gasification results. This program was performed under Parsons Subcontract No. 4-SC-5054-3 and consisted of:

Phase I: Thermogravimetric Study.

Phase II: Fluidized-Bed Reactor Gasification in a 6-Inch Diameter Reactor.

The results of the IGT study indicated:

- (1) Using the gasifier reactor sizes specified, the bed temperature should be increased to 1,820°F.

- (2) Additional experimentation should be conducted with the 6-inch gasifier at temperatures to 1,800°F; particular attention should be given to the determination of fluidization velocities necessary to inhibit sintering at the elevated temperature.

Available experience indicates that the beds can be successfully operated at the 1,800°F level. The gasifiers have been designed to permit operation at that temperature.

A number of potential design improvements are presented. These improvements would be expected to improve the economics when successfully reduced to practice.

SECTION 3

DESIGN PARAMETERS

This section describes the raw materials utilized, the products produced, and the basic design parameters/criteria used.

3.1 GENERAL CHARACTERISTICS

A most important characteristic of the design is that it provides the equipment and operating flexibility to process feed coal with a range of analyses which might be expected over the course of a 20-year operating life, using coal typically mined in the Eastern Region of the U.S. Interior Coal Province. This distinguishes the design from other designs which have been based on a single typical coal analysis and which might be called single feed source or point designs. The use of variable feedstock characteristics requires higher fixed capital investment to provide the necessary flexibility and variable product rates. These factors will be referred to during the course of subsequent discussion of characteristics and economics summarized in this report.

In order to characterize the design results, the process flowsheets and accompanying heat and material balances have been based on a "typical" coal analysis which is intermediate between the extreme analyses that might be encountered during the project life. All equipment was sized to handle the range of feed analyses and resulting operating condition adjustments to permit operation at capacity approximately 95% of the onstream time.

3.2 DESIGN BASIS

A detailed summary of the Design Basis developed in the early stage of the work is included as Appendix A. The Design Basis was intended to state the philosophy and data base to be used for the development of the conceptual commercial plant design. The primary objective was a preliminary design in sufficient detail for a budget-type cost estimate for the facility described hereafter.

A number of the key design parameters are summarized in the following paragraphs of this section.

3.3 PLANT LOCATION

The plant was considered to be located in the Eastern Region of the U.S. Interior Coal Province which includes portions of the states of Illinois, Indiana, and Kentucky. The site conditions used for equipment design are summarized in the Basic Design Criteria document presented as Appendix B of this report. The plant complex was to be close to the coal mines and a river.

3.4 SCOPE

The coal conversion complex is a grass roots facility with captive coal mines to supply the necessary feed coal. The electrical power generated is considered supplied to a power grid.

3.5 RAW MATERIALS

The raw materials will consist of the following:

- (1) Coal - Run of mine (ROM) coal will be produced in captive mines. The range of characteristics of washed, ground coal fed to the process plants is given in the following proximate analysis:

<u>Item</u>	<u>Range</u>
Moisture	9.5 to 11.5 wt %, wet basis
Ash	10.45 to 13.95 wt %, dry basis
Volatile Matter	44.15 to 48.65 wt %, MAF basis
Fixed Carbon	55.85 to 51.35 wt %, MAF basis
Heating Value	12,121 to 12,809 Btu/lb, dry basis

Ultimate analysis (weight percent, MAF basis) is as follows:

<u>Item</u>	<u>Range</u>
Carbon	77.35 to 79.85
Hydrogen	5.20 to 5.60
Nitrogen	1.35 to 1.65
Sulfur	2.80 to 5.80
Oxygen	9.20 to 11.20

The above ranges of coal characteristics were considered to include 95% of the coal to be produced in the conceptual coal mine area.

The design is based on a constant coal feed rate of 21,500 tons of moisture- and ash-free (MAF) coal per stream day to the pyrolysis plant. For the typical case, this corresponds to approximately 27,400 TPD of coal as fed.

- (2) Oxygen - 99.5% purity; produced captively by air separation.

(3) Water

- Process water from the river.
- Potable water from wells.

3.6 PRODUCTS

The principal products from the complex consist of syncrude, electrical power, and sulfur. They are presented for three cases in the following table, including maximum, minimum, and an intermediate oil production case corresponding to that described in the process flow diagrams presented later.

<u>Product</u>	<u>Characteristics</u>	<u>Production Rate</u>		
		<u>Max. Oil</u>	<u>Min. Oil</u>	<u>Typical Oil</u>
Syncrude	Approx. 25 API S < 0.1% wt	32,750 BPD	24,000 BPD	28,000 BPD
Electrical	138 kV	270 MW	1,150 MW	830 MW
Sulfur	99.9% pure	750 TPD	800 TPD	765 TPD

Note: Sulfur is expressed in long tons

3.7 PRIMARY PROCESS UNITS

The coal conversion complex will consist of the following units:

- (1) A unit to crush and wash the coal to minus 1/8-in. size.
- (2) Facilities to dry the coal with hot process gas.
- (3) A unit to pyrolyze the coal in a series of fixed fluidized beds using heat liberated in gasifying the residual char. Part of this heat is extracted from the hot gasifier gas, and the remainder is transported from the gasifiers to the pyrolyzers by means of a recirculating stream of char.
- (4) A unit to condense oil from the pyrolysis vapors by cooling in direct contact with cooled raw condensate.
- (5) Facilities to remove fine solids from the intermediate pyrolysis oil; filtration is used in this design.

- (6) A unit to hydrotreat the recovered oil to reduce the sulfur, nitrogen, and oxygen contents; the hydrotreating also saturates unsaturated hydrocarbons and reduces the viscosity.
- (7) A unit to desulfurize pyrolysis gas to produce a clean fuel and recover elemental sulfur.
- (8) A unit to generate low-Btu fuel gas by gasifying the residual char with steam and oxygen.
- (9) A unit to desulfurize the low-Btu fuel gas to produce a clean fuel and recover elemental sulfur.
- (10) An oxygen plant.
- (11) A hydrogen plant.
- (12) A power plant to produce electric power from the pyrolysis gas and low-Btu fuel gas.

3.8 EFFLUENT TREATMENT AND NOISE CONTROL

All effluent streams will be treated so as to meet environmental standards. Disposal of solid waste will be integrated with coal mining to provide haul-away and proper disposal. Equipment will be designed to meet OSHA noise level requirements.

3.9 RAW MATERIAL AND PRODUCT STORAGE

Facilities for a 30-day inventory of coal and products are provided.

SECTION 4

SUMMARY FACILITY DESCRIPTION

This section briefly describes general characteristics of the coal conversion complex; an overall block flow diagram is shown in Figure 4-1. This will provide background for the sections on design and economics.

The complex includes captive coal mines with capacity to produce up to approximately 13 million TPY for 20 years. Units are included which will clean, wash, crush, and size the coal and feed it to the process units.

All necessary facilities for production of oxygen, hydrogen, and all required utilities are included in the design as well as treatment and disposal of solid, liquid, and gas waste streams. The design is based on a site location capable of providing 45,000 acre-feet of water per year for process requirements and utilities makeup. Well water is used for potable and sanitary water.

The land area required for the life of the project for mining required coal is estimated to be about 42 square miles; approximately 500 acres would be allotted to the initial plant complex.

An artist's conceptual drawing of the complex is shown in Figure 4-2. A model of the complex has been constructed; a photograph of this model is presented in Figure 4-3.

4.1 THE PYROLYSIS UNIT

The heart of the coal conversion plant is a multiple-stage pyrolysis unit. The vapors generated in the pyrolysis unit are treated to recover the oil and separate the gas. The oil is filtered to remove solids and then hydrotreated to reduce heteroatom content and viscosity. The resulting product is a low-sulfur synthetic crude oil (syncrude). Pyrolysis gases are treated to remove the acid gases, hydrogen sulfide and carbon dioxide, and then used in the power generation unit. Elemental sulfur is produced as a by-product of the gas cleaning operations.

The pyrolysis section produces a significant amount of char which is, in turn, essentially completely gasified using steam and oxygen. Recycled char and effluent gases from the gasifier supply energy to the pyrolysis section. The gasifier gaseous effluent is then purified and the environmentally acceptable fuel gases are fed to the power plant where electrical energy and steam are produced.

The following legend applies to Figure 4-3, the conceptual model of a COED plant design:

<u>Color</u>	<u>Unit</u>
Black	Coal Preparation
White	Oxygen Production
Orange	Pyrolysis and Gasification
Blue	Hydrogen Production
Green	Oil Treating
Yellow	Gas Treating and Sulfur Recovery
Red	Offsites
Brown	Power Plant

4.2 PLANT CAPACITY

The typical throughput of coal is based on 21,500 TPD of MAF coal; this corresponds to about 24,500 TPD of MF coal and 27,400 TPD of as-is feed coal containing ash and moisture. This throughput will produce the following approximate output rates:

Synthetic Crude Oil	28,000 bbl/day
Electric Power	830 MW
Sulfur	760 LTPD

Because of the varying content of volatile matter, moisture, and ash in the feed coal, the rate of product output will also vary. Oil output is expected to vary from 24,000 to 32,000 bbl/day. Electric power maximum exportable output is about 1,150 MW when volatile matter, moisture, and ash are lowest. Electrical power output will be lowest under conditions of highest expected content of volatile matter, moisture, and ash in the feed coal, at which point steam demand is high. See Section 3 for expected ranges of power production. Efficiency of fuel utilization for electrical generation declines significantly at levels below 825 MW.

4.3 ENERGY BALANCE FACTORS

Gas, which serves as fuel for the power and steam generation unit, is composed of a mix of high-Btu gas (about 890 Btu/scf) from pyrolysis, and low-Btu gas (250 Btu/scf) from char burning. The total heat content of the combined streams is typically 14,200 million Btu/hr. In addition to the electric




Figure 4-1 - Block Flow Diagram -
Conceptual Commercial COED Plant Design




Figure 4-2 - Artist's Concept of Conceptual




Figure 4-3 - Model of Conceptual
COED Plant Design
(for color legend, see page 4-2)

power produced with a typical coal composition, this fuel must also produce 5.2 million lb/hr of steam for captive use in the complex. Approximately 3.7 million lb/hr is required in the process units for mechanical drivers and process use to supplement steam which is produced in these units. In addition, 1.5 million lb/hr is required for power plant fuel gas compressor drives. The heating value of fuel gas required to produce this 5.2 million lb/hr of steam, plus the amount required to produce about 80 MW of power required for captive use in the complex, leaves a net quantity of 7,600 million Btu/hr (IIIIV) for production of electrical power for export.

Page Intentionally Left Blank

SECTION 5

PLANT UNIT DESCRIPTIONS

Descriptions of the separate units which are a part of the COED Conceptual Commercial Plant Design are presented in this section.

The following units are described:

<u>Unit No.</u>	<u>Description</u>	<u>Flowsheet No.</u>	<u>Paragraph No.</u>
10-1	Coal Mine	--	5.1
10-2	Coal Preparation	5054-3-AE-10-2	5.2
11-1	Pyrolysis and Gasification	5054-3-AE-11-1	5.3
11-2	Oil-Vapor Recovery	5054-3-AE-11-2	5.4
12-1	Oil Filtration	5054-3-AE-12-1	5.5
13-1	Pyrolysis Gas Treating	5054-3-AE-13-1	5.6
13-2	Low-Btu Gas Treating	5054-3-AE-13-2	5.7
14-1	Hydrogen Plant	5054-3-AE-14-1	5.8
14-2	Hydrogen Plant Tailgas Desulfurizer	5054-3-AE-14-2	5.9
15-1	Oil Hydrotreating	5054-3-AE-15-1	5.10
16-1	Sulfur Recovery Unit - Pyrolysis Gas	5054-3-AE-16-1	5.11
16-2	Tailgas Treating Unit, from Unit 16-1	5054-3-AE-16-2	5.12
17-1	Oxygen Plant	--	5.13
18-1	Power/Steam Generating Plant	5054-3-AE-18-1	5.14
19-1	Plant Air and Instrument Nitrogen	--	5.15

<u>Unit No.</u>	<u>Description</u>	<u>Flowsheet No.</u>	<u>Paragraph No.</u>
19-2	Cooling Water System	--	5.16
19-3	Industrial Water System	5054-3-AE-19-3	5:17
19-4	Potable and Sanitary Water System	--	5.18
19-5	Fire Water System	--	5.19
19-6	Waste Water Treatment	--	5.20
20	Buildings and General Facilities		

The flowsheets are contained in Section 6. Utilities for each unit are summarized in Section 8, while equipment lists for the separate sections are given in Section 10.

5.1 COAL MINE (UNIT 10-1)

The COED Conceptual Commercial Plant Design includes an integrated strip mine in the Eastern Region Interior (Coal) Province of the United States. Basic criteria established include an average seam thickness of 5 feet, an average thickness of overburden of 60 feet, and a deposit sufficient for a 20-year mine life. The ROM high volatile C bituminous coal (average as mined) is projected to have the following properties:

<u>Item</u>	<u>Wt%</u>
Fixed Carbon	36 ± 10.0
Volatile Matter	13 ± 5.5
Moisture	9 ± 6.5
Ash	24 ± 10.0

Ultimate analysis on a wt%, MAF Basis, is as follows:

<u>Item</u>	<u>Range</u>
Carbon	77.35 - 79.85
Hydrogen	5.20 - 5.60
Nitrogen	1.35 - 1.65
Sulfur	2.80 - 5.80
Oxygen	9.20 - 11.20

A mining plan was formulated, equipment was sized for the mine, and capital and operating costs were estimated. These cost estimates exclude

land acquisition, relocation of railroads, highways, pipelines, buildings, and related items. Cost figures appear in Section 12.

Raw coal production is to average approximately 11,900 MTPY over the 20-year period; this would make the operation among the largest coal mines in the country.

Of particular interest is the method conceived for continuous land reclamation, with topsoil placed back on the surface of the mined-out area, closely following the mining face.

5.1.1 PRODUCTION REQUIREMENTS

Mine production capability required is 35,700 TPD, ROM, 365 day/year operating basis, or 13 MMTYP. Planned production is equal to 330 days equivalent to produce approximately 11,900 MTPY.

Coal density is 1,800 tons per acre-foot.

Assume coal seam is 5 feet thick, not including thin seamlets of shale. The rejects consist of these seamlets and diluting material (mostly shale) from above and below the seam. The seam then produces 9,000 tons/acre; about 4 acres per day would be mined.

Since the mine will be separated into three completely independent units, the unit production will require about 1.33 acres per day or approximately 58,000 square feet per day.

With a stripping width of 180 feet, each unit would then work about 325 lineal feet per day.

5.1.2 MINING PLAN

At the scheduled rate of production, and with an annual average equivalent to 330 days of production, an average of 1,320 acres of coal per year must be mined. Over the assumed 20-year life of the mine, 26,400 acres, or nearly 42 square miles, will be mined out.

Because of the large stripping ratio (12:1 on a volume basis, and 21:1 on a weight basis), and because of present limitations on size of mining equipment, the mine will be divided into three completely separate mining units. Each unit will consist of the following:

- (1) Upper overburden stripping system which will return this material to the top of the spoil piles for reclamation purposes.
- (2) Large stripping shovel able to cast or spoil the lower overburden to allow the mining of the coal seam.

- (3) Rotary drills to facilitate blasting of the lower overburden.
- (4) Loading and hauling equipment for coal removal.
- (5) Auxiliary equipment, such as dozers, loaders, and graders, for supporting each operation.

The three mining units will be supported by a centralized shop and other equipment which will be available where required.

The mine will be rectangular in shape with the washing plant located approximately on the line bisecting the long dimension, and on the surface as close as possible to the pit edge. The primary crusher will be located in the pit with belt conveyors transporting the coal to the washing plant. See Figure 5-1.

The overall mine is laid out such that the long dimension is approximately twice the width. This scheme minimizes haulage distances. The three mining areas are thus separated sufficiently to avoid congestion, but near enough for close supervision.

The actual total mine width is controlled by the width which the stripping shovel will clean - 180 feet. A total of 135 strips equals 4.6 miles; based on the total of 42 square miles of area, the length is then 9.2 miles.

To obtain a balanced coal hauling pattern, the mining areas will be located as shown in the sequence sketches, Figure 5-2. When Area 3 needs the most trucks, Areas 1 and 2 need the least, and vice versa.

5.1.3 MINING SEQUENCE

A. Upper Stripping

The top 20 feet of overburden consists of unconsolidated gravels, sands, and soil. Since it is required that the disturbed or mined-out area be reclaimed to approximately the original surface contour, and that plantings be made on the reclaimed ground, this top overburden and topsoil must be placed on top of the spoiled lower overburden. The topsoils thus replaced will facilitate the growth of the plantings.

Since 43,000 bank (in situ) cubic yards per day of upper overburden must be moved from each mining area, and a linear advance of 325 feet is also required, a highly mobile and productive system is indicated. Of the various systems investigated (including shovel-truck, front-end loader - truck, and bucket-wheel excavator) the most practical and economical is considered to be a Holland loader in combination with a belt-conveyor system.






Figure 5-1 - Sketch of Mine Plant



(NOT DRAWN TO SCALE)

COAL
PREPARATION
PLANT



COAL
PREPARATION
PLANT

Figure 5-2 - Illustration of Mine Working Plan

B. Lower Stripping

To allow for time to drill and blast the limestones and shales, the upper stripping will be kept several days in advance of the lower stripping operation. Since four drills will be required for each mining unit, diesel-powered machines have been selected because of their mobility.

Each mining area is provided with a 140-cubic-yard shovel because of its high productivity and long reach. Since all material must be blasted, draglines would not be practical. The shovel will spoil the material in the adjoining mined-out strip.

C. Coal Mining

Twelve-cubic-yard electric shovels are provided for loading coal into 120-ton bottom dump trucks. The top of the coal bed will first be cleaned by using dozers and front-end loaders, and then the coal will be ripped to facilitate loading with the shovel. A 2-day uncovered reserve of coal will be maintained to allow for cleaning and ripping. Each mining unit is provided with a 10-cubic-yard front-end loader, which can be used for coal loading in addition to cleanup work.

D. Waste Disposal

The stripping shovel removes overburden from the coal and dumps it on the spoil pile in the previously mined-out strip. Dozers are operated on top of the dump area to spread and level off the spoil. After the lower overburden has been levelled, stripped material from the upper overburden, which has been transported by a belt conveyor system, is placed on top and likewise is levelled. Later suitable grasses, plants, and trees will be grown to bring the area back essentially to its original form. Solid waste material from the plant is mixed in with the lower stripping spoil rocks.

E. Preproduction Stripping

In general, starting at a predetermined point near the washing plant, a ramp is developed to the bottom of the coal bed. This ramp will not only serve as access to the mining faces, but will also be used for the belt conveyor installation which will transport the coal from the in-pit crusher to the plant. From the bottom of the ramp, small equipment will be used to develop the required mining faces and to provide adequate area for assembling the large stripping shovels.

The crusher and belt conveyor installations will be installed and completely tested before plant startup.

5.2 COAL PREPARATION (UNIT 10-2)

This unit receives ROM coal and conditions it to be suitable as feed to the pyrolyzing unit. Conditioning consists of grinding and washing to produce 27,400 TPD of cleaned coal of -6 mesh and including about 5.0% free moisture, 5.5% inherent moisture and 10.9% ash. See Drawing 5054-3-AE-10-2.

The general arrangement of the preparation equipment will locate the hopper receiving coal from the mine trucks and the coal breaker at the lower mine level in an area readily available to all mining units. A conveyor will then transport the coal up to ground level and to the raw coal silos located in the preparation plant. Equipment is included to provide a stockpile of 3-inch x 0 unwashed coal to supply 30 days plant operation. Coal can flow either continuously to the stockpile and be reclaimed therefrom, or once the stockpile is established it can be bypassed. Waste material will be returned to the mine in trucks for burial in the mined-out areas. An emergency dump will be located nearby at the mine level in case the preparation plant suffers a shutdown.

Drawing 5054-3-AE-10-2 shows in detail the flow of coal from the mine through the preparation steps to its delivery to the pyrolysis unit. The preparation plant is designed to receive approximately 36 M TPD of wet ROM coal containing an average of 11.7% free moisture from the mine trucks, which dump into a 300-ton ROM hopper 10-2651. Vibrating feeders place the coal on belt conveyor 10-2052, having belt scale and tramp iron magnet, which delivers to a scalping screen 10-2751. Here material over 3-inch size goes to rotary coal breaker 10-2251 which rejects oversize to waste. Three-inch and under coal from both the scalping screen and coal breaker is deposited on belt conveyor 10-2053 which transports the coal from the lower mine level to either of two 10,000-ton raw coal silos 10-2652. Selection of which silo is made by use of reversible conveyor 10-2054. Each silo is equipped with six vibrating feeders, each of which places the coal on one of two belt conveyors 10-2056 equipped with belt scale, tramp iron detector, and automatic belt sampler, from which the coal is delivered to the washing section.

In the washing section, the 3-inch and under coal is fed in two trains first to a Baum-type coal jig 10-2253, where water is added for washing. Screens 10-2752, 10-2753, and 10-2754 receive the effluent and separate the washed coal from water and waste. The 3-inch to 1/4-inch clean coal is carried by conveyors 10-2059 and 10-2060 to two silos 10-2653, having a capacity of 10,000 tons each. The 1/4-inch coal is slurried and pumped by pumps 10-1552 to the cyclone separator section. Two 2-stage, 4-roll crushers 10-2151 reduce the middlings out of the jigs to 3/4-inch x 0.

Coarse waste material is rejected by screen 10-2754 and is conveyed back to the mine for burial by conveyors 10-2066 and 11-2009 (see Drawing 5054-3-AE-11-1).

The minus 3-inch plus 1/4-inch product is conveyed by belt conveyors 10-2059 and 10-2060 to two clean coal silos 10-2653, having a capacity of 10,000 tons each. Coal is withdrawn from these silos by vibrating feeders 10-2061 from which conveyors 10-2062 and 10-2063 carry it over a weigh scale to the clean coal crusher feed bin 10-2654 with a capacity of 1,500 tons. Belt feeders 10-2064 withdraw the coal from the bin and feed one or more of the six Cage Pactor crushers 10-2152 which reduce the particle size to -1/2 inch with approximately 41% below 6 mesh. This material is joined by the 1/4 inch x 0 coal from the cyclone section, and transported by belt conveyor 10-2065 to the drying section of the pyrolysis unit 11-1. Size classification is performed by the dryers in unit 11-1 and oversize material 1/2-inch x 6 mesh

is transported back to the clean coal crusher feed bin by conveyors 11-2007 and 10-2856 (see Drawing 5054-3-AE-11-1), from which it is again ground in the crushers along with the normal flow described above.

The cyclone separation section receives a slurry of 1/4-inch x 0 coal from pump 10-1552 in the washing section and entering first sixteen cyclones 10-2755. Then a series of screens, cyclone separators, and centrifuges produces the dewatered stream of minus 1/4-inch which joins the product flow at the clean coal crusher feed bin as noted previously. The fines and separated water proceed to a 75-foot-diameter thickener 10-2254 from which the fines are pumped to a tailings dam and separated water is pumped to head tank 10-1952 for reuse.

5.3 PYROLYSIS AND CHAR GASIFICATION (UNIT 11-1)

The techniques of pyrolysis and gasification of the residual char are those developed in bench scale and pilot plant operations. The commercial plant has been designed to accommodate the range of coal properties to be expected at various times during the life of the mine. When moisture, ash, and volatile matter contents are high, the amount of heat required for processing is high and the amount of fuel gas produced from the char is low. Each piece of equipment has been sized so that variations in feed coal properties will not cause plant throughput to operate at less than design capacity for more than 5% of the time.

For this design two coal compositions, Cases A and B, have been selected to represent the 95% probable limits of volatile matter, moisture, and ash contents. These are within the limits stated in the Design Basis and are consistent with the conceptual combination of coal field characteristics, mining pattern, and coal preparation plant. An intermediate composition, referred to as a typical case, has been chosen as a basis for the example heat and material balance shown on the Process Flow Diagrams. Yields of oil, gas, and char for these coal compositions are based on data observed in process development unit and pilot plant operations. These compositions of prepared coal are:

<u>Proximate</u>		<u>Case A</u>	<u>Case B</u>	<u>"Typical"</u> <u>Case C</u>
Moisture	wt% wet. basis	9.5	11.5	10.5
Ash	wt% dry basis	10.45	13.95	12.2
Volatile Matter	wt% MAF basis	44.15	48.65	46.4
Fixed Carbon	wt% MAF basis	55.85	51.35	53.6
<u>Ultimate</u>				
Carbon	wt% MAF basis	79.8	77.4	78.6
Hydrogen	wt% MAF basis	5.2	5.6	5.4
Nitrogen	wt% MAF basis	1.5*	1.5*	1.5*
Sulfur	wt% MAF basis	4.3**	4.3**	4.3**
Oxygen	wt% MAF basis	9.2	11.2	10.2
		<u>100.00</u>	<u>100.00</u>	<u>100.00</u>

*Variation in nitrogen content from 1.35 to 1.65 was not dealt with because no item of equipment is dependent upon this variable.

**A separate variability in sulfur content, from 2.8 to 5.8%, is considered applicable to all three above compositions.

5.3.1 PROCESS DESCRIPTION

A description of the operations is best obtained by following the steps on Process Flow Diagram 5054-3-AE-11-1.

Coal received from the cleaning and crushing plant, Unit 10-2, is dried in two stages in dryers 11-2811 and 11-2812 by hot low-Btu gas from the char gasifiers. Gas stream 32 first contributes heat to the hottest pyrolyzer, then to successively lower temperature services until it gives up its last useful heat in drying the fresh coal. Oversized coal is returned to the crushers. Dried coal is passed through three fluidized-bed pyrolysis vessels, 11-1201, 11-1202, and 11-1203, operating at successively higher temperatures. Gas and oil vapor released in pyrolysis are passed to the Oil Vapor Recovery Section, Drawing 5054-3-AE-11-2. The residual char is then gasified by contact with steam and oxygen in three fluidized bed char gasifiers, 11-1204, 11-1205, and 11-1206, to produce a low-Btu fuel gas. Conditions are such that gasification produces all heat needed to dry and pyrolyze the coal.

For the conditions desired in the pyrolyzers, it is necessary to have the coal crushed to a size range of -6 to +325 mesh. The type of crusher most suitable to the required capacity and size range will not reduce all of the feed to -6 mesh in once-through operation without producing a large amount of material finer than 325 mesh. Therefore, the reduction per pass is limited, and the oversize material is separated from the acceptable material and returned to the crushers. An entrained-flow type dryer system serves to separate the oversize particles as well as to warm and dry the acceptable sizes.

Two entrained-flow drying stages are used, with the gas and coal in counterflow between stages. Part of the raw low-Btu fuel gas, which has been cooled in other services to a temperature where its heat content is just sufficient to dry the coal, is used in the second stage dryer (Item 11-2812) for final heating, drying, and classification. Here the last of the coarse coal is dropped out for return to the crushers. Two separation stages are provided to remove the entrained coal from the gas; first an enlarged hopper to disengage the larger particles, then a cyclone to recover particles down to the 325-mesh range.

The gas leaving the second-stage dryer is combined with the rest of the raw low-Btu fuel gas and used in the first stage dryer (11-2811) for initial heating, drying, and classification. Here the largest of the coarse particles are dropped out for return to the crushers. Since the quantity of raw low-Btu fuel gas will vary as the coal composition varies, the first-stage dryer is designed to entrain all of the 6-mesh particles at the velocity provided by the lowest anticipated gas flow rate. Most of the time the first-stage dryer gas will be entraining particles larger than 6 mesh. Therefore, the gas flow rate through the second-stage dryer is regulated so that those particles larger than 6 mesh are dropped out. Equal sized lift pipes have been specified for the two stages so that a large part, but never all, of the gas will be passed through the second stage.

Three stages are used to separate the entrained coal from the gas leaving the first-stage dryer. First is an enlarged hopper to disengage the large particles, secondly a roughing cyclone to recover particles down to the 325-mesh range and combine them with the large particles from second-stage drying, and finally a second-stage cyclone to recover the 325-mesh and finer, down to 10-micron particles. The 10-micron to 325-mesh material is conducted separately to the third-stage pyrolyzer (11-1203) in order to minimize the quantity of fine material passing through the first and second stages of pyrolysis. The finest dust, which escapes the second-stage cyclone, will be collected by wet scrubbing in the raw low-Btu gas scrubber, 11-1101. The resulting slurry is pumped to the gasifiers; this point is described in more detail later.

Moist, crushed coal is delivered to the first-stage dryer by screw conveyors which provide the seal between atmospheric pressure in the feed surge hopper and the pressure in the dryer, up to about 5 psig. Oversize coal which drops to a hopper at the bottom of the dryer is removed by screw conveyors, weighed, and returned by belt to the crushers. Coal is moved forward to the second-stage dryer in a low-velocity, dense-phase fluidized condition by the differential head produced in two legs of a U-tube trap seal. This differential head is produced by a combination of different heights and different densities of the fluidized solids in the two legs. This transport technique is used frequently in this design. The transport U-tubes have been given equipment numbers, listed under Pressure Balance Lines, to distinguish them from ordinary piping connections and have been dimensioned to give proper flow velocities and differential heads. Differential heads in the several seals can range from +13.5 to -20 psi. The short legs vary from 45 to 92 feet in length and the long legs are from 80 to 195 feet long.

Pyrolysis is accomplished in three fluidized beds operating at successively higher temperatures, but at essentially identical pressures. More than three pyrolyzers may be desirable or required for other types of coal, but experimental work indicates that three is an adequate number for the design coal. The typical operating temperatures shown on the Process Flow Diagram are 575°F, 815°F, and 1,050°F for the first, second, and third pyrolyzers, respectively. Mechanical Design temperatures for the vessels are 857°F, 975°F, and 1,100°F to permit use of higher operating temperatures when coal properties would make it desirable.

Heat for the pyrolysis is obtained from the heat released in the gasifiers by the partial oxidation of the char remaining after pyrolysis. A portion of this heat is obtained from the sensible heat of the raw low-Btu fuel gas which is produced in the char gasification step, and part by transporting heat from the char gasifiers to the pyrolyzers by means of a circulating stream of partially reacted char. In the illustrative operation, 1,112 MM Btu/hr is obtained from the gas and 428 MM Btu/hr is obtained from the char circulation. The heat transport by char requires the circulation of 2,094,000 lb/hr of char, which is 1.63 times the fresh char production rate of 1,281,000 lb/hr.

The description of the operation of one pyrolyzer applies to all. Coal from the dryer, or partially pyrolyzed coal from a previous pyrolyzer, is fed to the fluidized bed where it is immediately dispersed throughout the bed. A stream of bed contents is withdrawn, contacted with hot raw low-Btu fuel gas (in lift pipe 11-2816 for example), and returned to the bed to supply the major portion of the heat required. The rest of the heat required is supplied by bringing in hot char from a char gasifier (line 22 for example) at such a rate that the evolution of gas and oil vapor is maintained at a relatively constant rate so that proper fluidization of the bed is maintained. Longer term variation of gas and oil vapor evolution, due to variation in coal composition, is accommodated by adjusting the size distribution of feed coal. This is done by adjusting the crusher speed and the gas flow rate in the second-stage dryer.

Much of the fluidizing gas is generated within each bed, but to assure adequate fluidization at the very bottom of the bed, some gaseous product of pyrolysis (after removal of pyrolysis oil and water) is recycled to the pyrolyzers. In order to feed the proper amount of recycle gas to each pyrolyzer without the usual waste of power by control valves, three separate compressors are provided, under speed control so that only the useful amount of power is drawn from the motive steam line; see oil vapor recovery unit 11-2, paragraph 5.4. Each stream of recycle pyrolysis gas is preheated by contacting with recycle hot char, as in lift pipe No. 11-2813, to increase its entrance velocity. Cyclones and hoppers are used to separate the char from the recycled gas stream. Recycle char which has been used for this purpose and thereby cooled below 1,050°F is then introduced into the first-stage pyrolyzer to counteract any agglomerating tendency of the feed coal.

The char remaining from the pyrolysis is gasified, as in the pilot plant, by reaction with a mixture of oxygen and steam. The function of the first of three fluidized bed gasifiers (char burner 11-1204-1206) is equivalent to the single gasifier (fourth-stage pyrolyzer) of the pilot plant. The second and third beds continue the gasification at the same conditions until the Design Basis level of carbon content is reached. That level was set at 2% of the original carbon in the coal fed to the plant, considered to be a tolerable amount to leave in the ash. At this design point, the concentration of carbon in the ash is about 10%.

Gasification conditions in the char burners are maintained such that: (1) there is always an excess of carbon in the beds, (2) the product gas contains high concentrations of CO and H₂, and (3) the overall reaction is sufficiently exothermic to satisfy the pyrolysis heat requirement. All products leave at reaction temperature, and the beds have negligible heat loss, so the heat of reaction must be balanced by the heat required to bring the reactants up to the reaction temperature. The amount of heat generated in each gasifier bed depends on the amounts of H₂O and O₂ reacted, and these quantities are controlled so that about 55% of the total char gasification takes place in the first gasifier, 30% in the second, and 15% in the third.

*Note that no hot char is needed for the No. 1 pyrolyzer at the conditions used in the typical operation.

In the second and third gasifiers, the char feed comes from a prior gasification stage, already at reaction temperature, and the oxygen temperature is relatively constant, though not controlled. Therefore the desired extent of gasification and the temperature must be controlled by regulating the amounts of steam and water used. It would be possible to balance the heat generated with the heat required to heat the H₂O even if the H₂O were all in the form of steam, but it is preferable to introduce part of the H₂O as water. There is a minimum amount of steam required to dilute the oxygen to avoid hot spots in the bed, and there is a minimum amount of water required to transport the very fine coal dust which escapes the coal dryer cyclones and is caught in the low-Btu fuel gas scrubber. Between these limits, the amounts of steam and water are controllable. The No. 3 gasifier will need approximately the same proportions of oxygen, steam, and water that the No. 2 gasifier requires.

Water and steam supplied to the char gasifiers is primarily the purge water slurry from the raw low-Btu gas scrubber which has been heated in the low-Btu gas trim cooler. In addition, sour waters from the hydrotreater, gas plant, and oil recovery column overhead separator are fed to the char gasifier bed. The use of these waters eliminates the need to purify them; they are therefore not discarded as waste.

The first gasifier differs from the second and third in that it receives feed char at pyrolysis temperature, several hundred degrees below the gasifier temperature. The sensible heat absorbed by this stream is approximately equivalent to the latent heat of the water used to control the temperature in the other gasifiers. This gasifier may not need to have any of its H₂O in the form of liquid but it can take any excess water which the other two gasifiers cannot handle.

The gas produced in the char gasifiers is rich in hydrogen and carbon monoxide but it must be cooled and desulfurized before it can be burned as fuel. Much of its heat content is utilized for drying and pyrolyzing the coal, and some of the excess, 500 MM Btu/hr in the illustrative operation, is used to generate low-pressure steam. After cooling, but before desulfurization, approximately 1/8 of the stream is split off and used as the feedstock for the manufacture of hydrogen for the hydrotreater. After desulfurization, the remaining 7/8 of the gas is used, along with the desulfurized pyrolysis gas, to generate electric power and steam.

The ash from the gasifiers is cooled, moistened, and returned to the mine for backfill. A rotary drum, 11-2401, containing steam generating tubes, is shown as the primary cooler. This choice makes possible the generation of about 7% of the steam required for char gasification. The final cooling is accomplished by spraying the partially cooled ash with enough water (cooling tower blowdown) to moisten it sufficiently to prevent escape of dust during transport back to the mine. The heat in the partially cooled ash is enough to evaporate nearly all of this water, so this design provides for condensing the evaporated water (in scrubber 11-1103) and spraying it as a recycle stream on the now cooled ash to provide the moisture required.

5.4 OIL VAPOR RECOVERY (UNIT 11-2)

The major operations in this portion of the plant are depicted in Drawing 5054-3-AE-11-2.

Raw COED oil is generated as a vapor in the pyrolyzers along with gaseous products. The mixture leaves the pyrolyzers through cyclone separators which remove entrained dust down to a particle size of about 10 microns. The gas and oil vapor from the three pyrolyzers are collected into a manifold (line 3i, Drawing 5054-3-AE-11-1, and line 1, Drawing 5054-3-AE-11-2) and conducted to the Oil Recovery Tower, 11-1151.

In the bottom section of the oil recovery tower, the heaviest of the oil is condensed at about 600°F by direct contact cooling of the 900°F pyrolysis vapor with a circulating stream of condensed oil which is cooled externally to about 400°F. The heat removed is used to generate approximately 30% of the steam required for char gasification.

In the upper section of the tower, another 20% of the oil is condensed at about 375°F, partly by contact with a circulating stream of the intermediate condensate which is cooled externally to about 200°F, and further by contact with overhead condensate at 130°F. In cooling the overhead vapors from about 270°F to 130°F, the lightest 5% of the oil is condensed, along with half the water. All of the heat removed in condensing the intermediate and light oil fractions is rejected to the atmosphere by way of a closed water loop. Design and operation are such to prevent excessive concentration of high melting components in any one fraction.

Net production of uncondensed pyrolysis products is compressed and delivered to the Pyrolysis Gas Treating Section, Drawing 5054-3-AE-13-1.

Also, a small amount of this gas, after compression, is used to make up solution losses of filter pressurization gas in the oil filtration unit (paragraph 5.5). Three streams of pyrolysis gas, large in relation to the size of the net production stream, are used as recycle gas for fluidization of the pyrolysis beds; see Pyrolysis, paragraph 5.3, and Drawing 5054-3-AE-11-1.

The condensed pyrolysis water, containing soluble portions of the light COED oil, H₂S, and other pyrolysis products, is combined with other process waste waters, and utilized in the char gasification step as described in paragraph 5.3.

5.5 OIL FILTRATION (UNIT 12-1)

The light oil does not need to be filtered, and its passage through the filters would aggravate evaporation problems, so it is sent directly to the hydrotreater section (Drawing 5054-3-AE-15-1). The intermediate and heavy oil fractions are combined and sent to the oil filtration section which is depicted in Drawing 5054-3-AE-12-1.

Filter feed is taken from a pair of 8,000-bbl surge tanks. Each filter is fed by its own pump taking oil from the top of a horizontal header between the two tanks. Either tank can be isolated from the system for cleaning.

Each filter is designed to operate 40 hours out of a 48-hour cycle. Approximately 5 inches of precoat are removed during the cycle; the removal rate is 0.002 inch per minute. At the end of the cycle, the feed to the filter is shut off and the precoat rebuilt by feeding precoat slurry which is continuously prepared in precoat tanks 12-1203. Approximately every 20 cycles, the residual precoat and the base coat are removed from the drum and a new base coat applied by adding slurry from base coat tank 12-1204.

The filter cake composed of precoat, base coat, insoluble particles, and containing approximately 50% by weight of product oil is fed to the third stage char gasifier where the oil and residual coal particles are gasified. The resultant ash joins the main ash stream for disposal.

Pyrolysis gas, predominantly methane, is used to pressurize the filters. In sweeping oil through the filter coats, this gas evaporates the more volatile components of the oil. They are condensed when the gas is cooled for recycle compression. The condensate is mixed with filter feed so that its evaporation during the filtration operation does not significantly change the composition of the oil. The gas is cooled just enough so that recompression raises its temperature to or slightly above the filter temperature.

5.6 PYROLYSIS GAS TREATING SECTION (UNIT 13-1)

Refer to Drawing 5054-3-AE-13-1. Raw gas from the oil vapor recovery section (unit 11-2) is first passed through a gas filter/separator, and then to the contactor where the gas is countercurrently washed with DGA (diethylene glycol amine) solution for removal of hydrogen sulfide and carbon dioxide. The overhead gas from the contactor is routed to the knockout section for separation of entrained liquid prior to exporting to the fuel system.

The rich DGA solution from the bottom of the contactor is released to the flash drum for separation of hydrocarbons, vapor, and liquid, and then pumped to the regenerator through the rich/lean exchanger.

The top section of the regenerator column is a cooler designed to cool the acid gas stream rejected from the regeneration section by countercurrent contact with the externally cooled water. The overhead acid gas stream is then passed on to the sulfur recovery unit 16-1 (see paragraph 5.11).

A direct-fired heater is employed for reboiling service for the regenerator. The lean DGA solution from the base of the regenerator column is passed through the rich/lean exchanger, the solution air cooler, and then a level control valve prior to entering the suction of the lean solution pump. The lean solution is further cooled by water circulation in the solution cooler, and then divided into two streams with flow control in each. One stream discharges into the contactor and the other into the wash column of the flash drum.

The solution filter and the reclaimer are provided for solution conditioning. The solution tank provides service for normal operation surge as well as for solution storage. The solution sump is used for collecting drains and drips and for solution makeup. Equipment for injection of corrosion inhibitor and antifoam agent is also provided.

5.7 LOW-BTU GAS TREATING (UNIT 13-2)

The gas treating unit 13-2, depicted on Drawing 5054-3-AE-13-2, is designed to reduce hydrogen sulfide to an odorless level of approximately 1 ppm. The raw low-Btu fuel gas produced in Unit 11-1 is fed to a redox solution contacting device wherein the hydrogen sulfide is absorbed by the redox liquor. After a suitable time, the hydrogen sulfide is oxidized to elemental sulfur and water by the following reaction:



The H_2S free low-Btu gas is transferred to the power plant for utilization as fuel.

The reduced redox solution is transferred to an air blowing tank wherein the contained sulfur is removed as a sulfur froth. The reoxidized redox solution is subsequently recirculated to the redox solution contacting device. The sulfur froth is pumped to a sulfur melter, where the sulfur is melted, separated from the redox solution, and pressured to sulfur product storage. The decanted redox solution from the melter is returned to the system. The sulfur product is 99.9% pure.

5.8 HYDROGEN PLANT (UNIT 14-1)

5.8.1 HYDROGEN PRODUCTION

Flow Diagram 5054-3-AE-14-1 shows the flow sequence for the production of hydrogen. Since the feed gas contains essentially no methane but is high in carbon monoxide only shift conversion is employed without the need for reforming. The feed gas is compressed to 600 psia and preheated to 700°F before entering the first bed of sulfided shift catalyst. A second bed of shift catalyst is used after heat is removed from the effluent stream from the first reactor, to take advantage of the more favorable equilibrium conditions at the lower temperatures. Following the second reactor the gas is cooled to condense the steam before absorption of the acid gases in a catalyzed hot carbonate system. Methanation of residual carbon oxides is used as a method of final purification before product hydrogen is compressed for delivery to the hydrotreater, Unit 15-1 (see paragraph 5.10).

The quality of the product hydrogen to be produced and the quality of the feed gas determines the amount of steam required in the process. End of run conditions are shown on the flowsheet so when operating with fresh catalyst, less steam would be required.

If operating experience indicates that the total sulfur cannot be removed to a tolerable level for methanation by the catalyzed hot carbonate system

referred to above and described in the next paragraph, then a bed of zinc oxide would be added for additional protection.

5.8.2 CATALYZED HOT CARBONATE ACID GAS REMOVAL

This section receives the shift effluent gas as the feed stream. The gas first gives up heat to the hot carbonate reboiler. After separation of steam condensate downstream of the reboiler, the gas is fed to the hot carbonate absorber. The gas is then countercurrently contacted with the hot carbonate solution in the absorber, thereby removing carbon dioxide and hydrogen sulfide from the gas. The treated gas proceeds to the methanation step.

Rich hot carbonate solution, which contains carbon dioxide and hydrogen sulfide absorbed from the gas stream, is routed from the base of the absorber through the hydraulic turbine for horsepower recovery. The solution is then pressured to the hot carbonate regenerator. The reboiler receives heat from the shift effluent as required for stripping carbon dioxide and hydrogen sulfide from the hot carbonate solution. The cooled overhead acid gas stream, containing mostly carbon dioxide and hydrogen sulfide from the regenerator, is routed to sulfur recovery, Unit 14-2 (see paragraph 5.9). The regenerated lean hot carbonate solution from the base of the regenerator is pumped to the top section of the absorber after being cooled, while the semilean solution is pumped to the midsection of the absorber without further cooling.

The other auxiliary items of equipment in this section include a storage tank, filters for removal of particulate matters and degradation materials, and a sump for collecting drains and drips.

5.9 HYDROGEN PLANT TAILGAS DESULFURIZER (UNIT 14-2)

The hydrogen plant tailgas desulfurizer as depicted on Drawing 5054-AE-14-2 is designed to reduce hydrogen sulfide in the effluent to an odorless level (approximately 1 ppm). The tailgas from Unit 14-1 is fed to a redox solution contacting device wherein the hydrogen sulfide is absorbed by the redox liquor. After a suitable time, the hydrogen sulfide is oxidized to elemental sulfur and water in the reaction tank by the following overall reaction:



The H₂S-free tailgas, consisting primarily of CO₂, is vented to the atmosphere.

The reduced redox solution is transferred to an air blowing tank wherein the contained sulfur is removed as sulfur froth. The reoxidized redox solution is subsequently recirculated to a contacting device. The sulfur froth is pumped to a sulfur melter, where the sulfur is melted, separated from the redox solution, and pressured to sulfur product storage. The decanted redox solution from the melter is returned to the system. The sulfur is 99.9% pure.

5.10 OIL HYDROTREATING (UNIT 15-1)

Filtered oil, plus the light 5% of the oil which bypasses the filters, is hydrotreated in a process which is somewhat similar to petroleum hydrotreating. Process Flow Diagram 5054-3-AE-15-1 depicts the process.

The conditions used in this design were found to be effective in COED pilot plant work. Sulfur content is reduced approximately 98%, nitrogen 94% and oxygen 90%. At the same time, the API gravity of the oil is raised from about -5° to about $+25^{\circ}$. Reaction temperature is 650° to 750°F , pressure is 2,335 to 2,420 psig, weight hourly space velocity is 0.3 lb/hr/lb, and hydrogen to oil ratio is 10,400 scf H_2 /bbl. Makeup hydrogen purity supplied to the hydrotreating unit is 94 to 96%.




Fresh oil, line 3, is diluted with recycle oil, line 17, as an aid to temperature control. The combined oil, mixed with part of the hydrogen, is heated to 650°F for entrance to the first reactor. Effluent from the first reactor is cooled by addition of the rest of the hydrogen, and cooled further by heat exchange, generating steam, to 650°F for entrance to the second reactor. Cooling of second and third-stage effluents is by heat exchange, generating steam for power generation. Cooling of fourth-stage effluent is by heat exchange with feed streams, low-pressure steam generation, and cooling water. Hydrotreated product oil is flashed in stages down to 100 psig at which pressure it is stabilized (volatility) for storage and shipment.

The nitrogen content of the pyrolysis oil from the design coal is sufficiently high that the H_2S released in hydrotreating is tied up as NH_4SH , and is dissolved in injected water and removed from the hydrotreater condensing train. The hydrotreater offgas is sufficiently low in sulfur to be used as fuel gas and is mixed with the desulfurized pyrolysis gas in line 2, steam and power generating plant, Drawing 5054-3-AE-18-1. The ammoniacal, sulfidic water is used for temperature control of the char gasifiers, as described in Unit 11-1.

5.11 SULFUR RECOVERY - PYROLYSIS GAS (UNIT 16-1)

A typical Claus type three-stage sulfur recovery unit is shown on Process Flow Diagram 5054-3-AE-16-1. The acid gas from pyrolysis gas treating, Unit 13-1, is fed to a knockout drum for removal of any entrained liquids before entering the external combustion chamber of the reaction furnace.

The chemistry of the process can be described as follows:



The acid gas is one-third oxidized by reaction with air in the combustion chamber; the heat generated from the exothermic reaction produces 150-psig steam in the boiler section of the furnace and 50-psig steam in sulfur condensers No. 1 through No. 4. Sulfur is condensed and drained through a liquid sulfur seal to the sulfur tank.

The cooled gas is reheated and passed to the first stage of the catalytic converter to produce elemental sulfur. The exothermic reaction causes a temperature rise across the converter No. 1 catalyst bed. The hot gas is cooled in sulfur condenser No. 2 by generating low pressure steam and the condensed sulfur flows to the sulfur tank. Entrained sulfur in the gas is removed by a coalescer.

Similarly, for the second and third stages, the cooled gas is reheated in the auxiliary burner, additional sulfur is produced in the converter and the gas is cooled by producing low pressure steam. The condensed sulfur flows to the sulfur tank from each condenser.



Liquid sulfur is pumped from the sulfur tank to sulfur product storage where it is piled in popcorn form until removed for shipment. Tailgas flows to Unit 16-2 for treatment before discharge to the atmosphere.

5.12 TAILGAS TREATING (UNIT 16-2)


In the Sulfur Removal Unit, depicted on Drawing 5054-3-AE-16-2, sulfur recovery unit tailgas may be treated by one of several commercially available processes for reducing the sulfur content of the treated tailgas to an environmentally acceptable level. A sulfur content of less than 100 ppm is achievable by one such process (the Beavon Sulfur Removal Process) and this was used as the basis for the estimates of this study. In the process taken for example, hydrogenation and hydrolysis are used to convert essentially all sulfur compounds to hydrogen sulfide. The gas is then cooled and passed into a contactor, where the hydrogen sulfide is absorbed by the redox liquor and oxidized to elemental sulfur. The purified tailgas is vented to the atmosphere. The reduced redox liquor is reoxidized by contact with air and subsequently recirculated to the absorber. Elemental sulfur is removed in the air-blowing step as a froth. The froth is pumped to a sulfur melter, where the sulfur is melted under pressure, separated from the redox solution, and transferred to sulfur product storage. The decanted redox solution is returned to the system.

The chemical reactions are:

Hydrogenation



Hydrogen Sulfide Extraction



The purified tailgas is odorless and contains typically less than one ppm of H₂S and less than 50 ppm of total sulfur compounds, mainly COS. The sulfur product is yellow and better than 99.9% pure.

5.13 OXYGEN PLANT (UNIT 17-1)

This is a conventional plant which is available from commercial air separation plant suppliers.

The oxygen production facility will consist of six package plants of about 2,200 TPD capacity each, totaling approximately 13,000 TPD. Each plant will include the cold box, distillation columns, heat exchange equipment, air and oxygen compressors, and auxiliary equipment.

Product will be gaseous oxygen of 99.5% purity delivered at 30 psig and approximately ambient temperature.

5.14 POWER AND STEAM GENERATING PLANT (UNIT 18-1)

5.14.1 DESCRIPTION

The steam and electric generation power plant consists of multiple large gas turbine-generator-boiler packages which supply the steam and electric power requirements for the COED process and also produce net electric power for export. The design is shown in Drawing 5054-3-AE-18-1.

The fuel gas streams supplied to the power plant consist of a high-Btu gas stream and a low-Btu gas stream. The high-Btu gas stream arrives at the power plant at 55 psia and 115°F. It is compressed by a steam-turbine-driven two-stage compressor to 265 psia. This is the gas pressure required for gas turbine utilization. The low-Btu fuel gas stream arrives at the power plant at 14.7 psia and 100°F and is compressed in three parallel compressor trains to 265 psia. The high- and low-Btu fuel gas streams are then combined and the resulting fuel gas is fed to the gas turbine power units.

A total of 13 of these gas turbine units are utilized in the power plant. The gas turbine used is a large, simple cycle, single shaft machine that is directly connected to an electrical generator and operates at 3,600 rpm. The functions of the gas turbine are: (1) to produce electric power through its connected generator, and (2) to supply hot gas through its exhaust system to the heat recovery boiler which is fitted to the exhaust of each gas turbine. These boilers are expressly designed for use with a large volume of gas and incorporate extended fin-tube construction. Additionally, duct burners are utilized to increase the energy level of the exhaust gases by the firing of additional fuel in the exhaust gas stream prior to entry into the boiler.

Analysis of the power plant and the possible variations in the quantity of fuel gas supplied indicate that under certain conditions only 10 of the 13 gas turbine units may be operating. At any given time the total steam generated in the heat recovery boiler is used for the steam turbine drives on the power plant fuel gas compressors and for the motive and heating requirements in the various process sections.

A portion of the total power plant electrical generation is tapped for use in the process plant and in the coal mine. The remainder is for export and sale. For this design, the power plant generation can vary from a low of 345 MW to a high of 1,227 MW. This variation results from variations in feed coal composition over the range described in the Design Parameters (Section 3), plus variations in operations of the process plant. The exact power output at any time depends on the quantity and heating value of the high- and low-Btu fuel gas supplied to the power plant and also on the steam requirements of the power plant and process units.

The quantity of fuel gas available to the power plant is a function of the coal composition, with the greatest quantity of gas available when the volatile matter, moisture, and ash in the coal are lowest. When these constituents are highest, the fuel gas available is at its lowest and it may be expedient to supplement with some other fuel during these periods to maintain the electrical output at a more constant level. The output shown on Drawing 5054-3-AE-18-1 is 907 MW which corresponds to the typical case illustrated on all flowsheets (827 MW are available for export).

5.14.2 DESIGN APPROACH

The COED power plant design philosophy was to investigate state-of-the-art and advanced electrical generation systems. The goal was to achieve a power plant design with a high degree of flexibility of operation to accommodate variations of up to 32% in the quantity of fuel energy from the COED process sections, and to utilize the available fuel in as economical a manner as practical.

The analysis of the power plant involves investigation of several power cycle variations and combinations of electrical generation equipment. The two end-point bounding design cases were: (1) the all-simple-steam cycle and (2) the all-gas turbine case. Between these two configurations are several cases involving various combinations of conventional boilers with steam turbine-driven generators and gas turbine/combined cycle units.

Various power plant cycle configurations were analyzed to determine the net electric power available for export and sale after the COED in-house steam and power requirements are satisfied. On this basis, and for operational flexibility, the all-gas turbine generator configuration was chosen as the most desirable power plant configuration for the COED conceptual design.

The all-gas turbine power plant contains only large simple cycle gas turbines, each fitted with waste heat recovery boilers. No combined cycle units are utilized due to the large steam requirements of the process units

and related auxiliary units. The large in-plant steam consumption leaves no net steam for steam turbine-driven generators. In fact, under some conditions, part-load gas turbine operation is required in order to provide sufficient fuel for supplementary firing of the waste heat boilers to satisfy these steam requirements.

The process sections require large quantities of motive and process steam as shown on the Utility Summary in Section 8 of this report. These requirements vary as much as 15% and are highest when fuel supply is lowest. These steam requirements are largely supplied by the power plant. Fuel gas, in excess of in-plant steam generation requirements, is used for electric power generation. An average of about 80 MW of the electrical generation is used within the COED plant and coal mine. The remainder is available for export and sale to neighboring utilities.

5.15 PLANT AIR AND INSTRUMENT NITROGEN (UNIT 19-1)

One motor-driven air compressor with a turbine-driven full capacity spare is provided to furnish 16,000 acfm of 125 psig air for general plant utility use. An air receiver and instrumentation together with distribution system complete the plant air facility.

Nitrogen at 100 psig and dry to minus 40°F dew point is available in ample quantity from the oxygen plant to provide for the pneumatic instrument system. The multiple units in the oxygen plant will assure a reliable supply of nitrogen.

5.16 COOLING WATER SYSTEM (UNIT 19-2)

This system includes six induced draft cooling towers and twelve motor driven pumps to provide 650,000 gpm of 86°F cooling water. The cooling towers have a total capability of about 10 billion Btu/hr at 77°F wet bulb ambient condition. Included are all necessary equipment and facilities for water treatment to inhibit corrosion and the growth of algae.

5.17 INDUSTRIAL WATER SYSTEM (UNIT 19-3)

Water in the amount of some 28,000 gpm (45,000 acre-ft/yr) will be pumped from a river. This design is based on the river being about two miles from the plant site. Following screening, for trash removal, water flows by gravity to a concrete sedimentation basin at the riverbank of about 7 acres, 16 feet deep, which provides about 20 hours residence for settling. The pumps will be mounted in the clear well of this basin.

The entire stream will receive further clarification in two mechanical sludge blanket tanks aided by coagulants and clarifying chemicals.

Makeup for the cooling water system, which constitutes about 87% of the water usage requirement, receives additionally conventional chemical treatment for corrosion inhibition and algae control.

Makeup water for the boilers in the power plant and other areas, about 10% of the total, is filtered and demineralized before joining sour condensate and flowing to the deaerator and thence along with clean condensate to the boilers. The balance of about 3% needed for various process makeup requirements requires no treatment beyond the clarification step.

5.18 POTABLE AND SANITARY WATER SYSTEM (UNIT 19-4)

This water is obtained from a well. A 50-gpm pump and a full capacity standby pump are included to assure reliable supply. A water treatment system to sterilize and otherwise make the water suitable for drinking or other sanitary use is also included. The piping system for this water is galvanized.

5.19 FIREWATER SYSTEM (UNIT 19-5)

The water for this system is supplied by pumps taking suction from the same sedimentation basin at the river as was described in paragraph 5.17 for the industrial water system. The water is delivered to a firewater loop at 100 psig. One electric motor-driven and one steam turbine-driven pump, each with a capacity of 3,000 gpm, provide the 6,000 gpm required. One diesel engine-driven pump of 3,000 gpm provides standby. A steam-driven jockey pump will maintain pressure on the system during periods when there is no demand. Hydrants and monitors connected to the loop are located strategically in all units. Oil product storage tanks are protected by both hydrants and by a foam system.

5.20 WASTE WATER - TREATMENT AND DISPOSITION (UNIT 19-6)

Waste water from process units in the amount of approximately 2,100 gpm will be treated in a manner to render it suitable for discharge back to the river. The sources of the waste water are principally cooling tower blowdown in the amount of about 1,500 gpm, boiler blowdown about 380 gpm, demineralizing system blowdown 200 gpm, and sanitary sewage of 50 gpm. Other waste streams of sour water containing H_2S and COS are being incinerated in the char gasifiers from which the evolved gases are treated for removal of sulfur.

Waste water from coal washing is directed to a tailings pond where the harmless solids settle out, and the clarified water either evaporates or is recycled for dust abatement.

The blowdown from cooling water and boiler systems should require no chemical treatment or filtration before discharge to a lagoon of about 18 acre-feet for evaporation and settling. Waste water from the demineralizer will discharge to this lagoon after acids or caustics have been neutralized. The suspended solids will settle in the lagoon and will be removed for land fill. Decant from the lagoon then flows to a large surge pond of about 130 acre-feet where it is joined by effluent from the sanitary sewage treatment plant and by oily surface runoff water from curbed process areas after passing through a surge pond of about 14 acre-feet, and an API separator for removal of most of the oily material. Storm drainage from nonprocess areas also flows into the large surge pond. Overflow from the surge pond after oil skimming finally discharges to the river during storm water runoff. The estimated 10 ppm BOD in the waste waters is below the level that would require biological treatment. It is therefore judged to be acceptable for discharge to the environment.

Page Intentionally Left Blank

SECTION 6

PROCESS FLOW DIAGRAMS

The flow diagrams for the units described in Section 5 are shown on the drawings contained in this section. A list of these drawings appears on pages 5-1 and 5-2 in Section 5.

These drawings show the process flow, material balances, and characteristics of the major process equipment. Also shown are the control instruments critical for the process.

The flow diagrams for proprietary processes are shown in a simplified form and contain only the material balances in and out of the units.

Page Intentionally Left Blank

10-2756-01 THRU 04
 6 SHALLOW CROSS-
 FLOOR SCREENS
 17MM SCREEN

10-2755-01 THRU 16
 20 DIAP. CYCLOPES
 2 SET-8 EA.

10-2754-01 THRU 03
 20 DIAP. CYCLOPES
 2 SET-8 EA.


10-2753-01 THRU 02
 12 DIAP. CYCLOPES
 2 SET-17 EA.

10-2752-01 THRU 01
 6 DIAP. CYCLOPES
 2 SET-17 EA.

17MM SCREEN


PROCESS FLOW DIAGRAM					
DATE	BY	CHKD	APP'D	REV	DESCRIPTION
9004-3	AE-10-2	D			CONCEPTUAL PLANT DESIGN
9004-3	AE-10-2	D			CONCEPTUAL PLANT DESIGN

NOTES:
 *SYSTEMS IS AND 24 AGE SHOWN FOR DESIGNATION NOT INCLUDED IN WATER ENCLURE.



10-2654-01 LEAN COAL CRUSHER FEED BIN 1,500 TONS	35*	54*	35	36	37	38	39	40	10-2065-01 CENTRIFUGAL CONVEYOR	10-2066-01 CENTRIFUGAL CONVEYOR	10-2067-01 CENTRIFUGAL CONVEYOR	10-2070-01 THRU 03 BELL FEEDERS	10-2254-01 75" DIAP. THICKENER	10-1555-01.02 TALLINGS PUMPS 1 STANDBY	10-1951-01 RECYCLE WATER TANK 200,000 GALS.	10-1556-01.02 RECYCLE WATER PUMPS 1 STANDBY	10-1557-01.02 GLAND WATER PUMPS 1 STANDBY	50
	1.468	17.9	27.2	27.6	17.4	55.7	1,219.5	58.5	SOIDS DTPH	50							15"	
	61.2	956.3	1,763.1	1,763.1	1,763.1	59	4,938.0	134	68 LBS S.G.								16"	
	25	500	4,025.5	5,046.8	1,001	252.8	4,938.0	134	PURELY SOLIDS								500"	
			1.00	1.00	1.00	1.20	1.20	1.20	SLURRY GPH								2,792"	
			172.68	150					TOTAL WATER TPH								12"x3"	
			150						TOTAL WATER TPH									

Page Intentionally Left Blank



LINE NO.	DESCRIPTION	UNIT	QTY	UNIT PRICE	TOTAL PRICE
11.2201	CONDENSER WATER PUMP	1	1	100000	100000
11.2202	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2203	STEAM TURBINE GENERATOR	1	1	500000	500000
11.2204	CONDENSER	1	1	200000	200000
11.2205	CONDENSER COOLING WATER TANK	1	1	100000	100000
11.2206	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2207	CONDENSER WATER PUMP	1	1	100000	100000
11.2208	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2209	CONDENSER WATER PUMP	1	1	100000	100000
11.2210	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2211	CONDENSER WATER PUMP	1	1	100000	100000
11.2212	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2213	CONDENSER WATER PUMP	1	1	100000	100000
11.2214	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2215	CONDENSER WATER PUMP	1	1	100000	100000
11.2216	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2217	CONDENSER WATER PUMP	1	1	100000	100000
11.2218	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2219	CONDENSER WATER PUMP	1	1	100000	100000
11.2220	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2221	CONDENSER WATER PUMP	1	1	100000	100000
11.2222	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2223	CONDENSER WATER PUMP	1	1	100000	100000
11.2224	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2225	CONDENSER WATER PUMP	1	1	100000	100000
11.2226	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2227	CONDENSER WATER PUMP	1	1	100000	100000
11.2228	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2229	CONDENSER WATER PUMP	1	1	100000	100000
11.2230	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2231	CONDENSER WATER PUMP	1	1	100000	100000
11.2232	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2233	CONDENSER WATER PUMP	1	1	100000	100000
11.2234	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2235	CONDENSER WATER PUMP	1	1	100000	100000
11.2236	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2237	CONDENSER WATER PUMP	1	1	100000	100000
11.2238	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2239	CONDENSER WATER PUMP	1	1	100000	100000
11.2240	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2241	CONDENSER WATER PUMP	1	1	100000	100000
11.2242	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2243	CONDENSER WATER PUMP	1	1	100000	100000
11.2244	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2245	CONDENSER WATER PUMP	1	1	100000	100000
11.2246	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2247	CONDENSER WATER PUMP	1	1	100000	100000
11.2248	CONDENSER COOLING WATER PUMP	1	1	100000	100000
11.2249	CONDENSER WATER PUMP	1	1	100000	100000
11.2250	CONDENSER COOLING WATER PUMP	1	1	100000	100000

6-3


B

6-3

A

Page Intentionally Left Blank

Page Intentionally Left Blank



11-2254
 11-2255
 11-2256
 11-2257
 11-2258
 11-2259
 11-2260
 11-2261
 11-2262
 11-2263
 11-2264
 11-2265
 11-2266
 11-2267
 11-2268
 11-2269
 11-2270
 11-2271
 11-2272
 11-2273
 11-2274
 11-2275
 11-2276
 11-2277
 11-2278
 11-2279
 11-2280
 11-2281
 11-2282
 11-2283
 11-2284
 11-2285
 11-2286
 11-2287
 11-2288
 11-2289
 11-2290
 11-2291
 11-2292
 11-2293
 11-2294
 11-2295
 11-2296
 11-2297
 11-2298
 11-2299
 11-2300
 11-2301
 11-2302
 11-2303
 11-2304
 11-2305
 11-2306
 11-2307
 11-2308
 11-2309
 11-2310
 11-2311
 11-2312
 11-2313
 11-2314
 11-2315
 11-2316
 11-2317
 11-2318
 11-2319
 11-2320
 11-2321
 11-2322
 11-2323
 11-2324
 11-2325
 11-2326
 11-2327
 11-2328
 11-2329
 11-2330
 11-2331
 11-2332
 11-2333
 11-2334
 11-2335
 11-2336
 11-2337
 11-2338
 11-2339
 11-2340
 11-2341
 11-2342
 11-2343
 11-2344
 11-2345
 11-2346
 11-2347
 11-2348
 11-2349
 11-2350
 11-2351
 11-2352
 11-2353
 11-2354
 11-2355
 11-2356
 11-2357
 11-2358
 11-2359
 11-2360
 11-2361
 11-2362
 11-2363
 11-2364
 11-2365
 11-2366
 11-2367
 11-2368
 11-2369
 11-2370
 11-2371
 11-2372
 11-2373
 11-2374
 11-2375
 11-2376
 11-2377
 11-2378
 11-2379
 11-2380
 11-2381
 11-2382
 11-2383
 11-2384
 11-2385
 11-2386
 11-2387
 11-2388
 11-2389
 11-2390
 11-2391
 11-2392
 11-2393
 11-2394
 11-2395
 11-2396
 11-2397
 11-2398
 11-2399
 11-2400
 11-2401
 11-2402
 11-2403
 11-2404
 11-2405
 11-2406
 11-2407
 11-2408
 11-2409
 11-2410
 11-2411
 11-2412
 11-2413
 11-2414
 11-2415
 11-2416
 11-2417
 11-2418
 11-2419
 11-2420
 11-2421
 11-2422
 11-2423
 11-2424
 11-2425
 11-2426
 11-2427
 11-2428
 11-2429
 11-2430
 11-2431
 11-2432
 11-2433
 11-2434
 11-2435
 11-2436
 11-2437
 11-2438
 11-2439
 11-2440
 11-2441
 11-2442
 11-2443
 11-2444
 11-2445
 11-2446
 11-2447
 11-2448
 11-2449
 11-2450
 11-2451
 11-2452
 11-2453
 11-2454
 11-2455
 11-2456
 11-2457
 11-2458
 11-2459
 11-2460
 11-2461
 11-2462
 11-2463
 11-2464
 11-2465
 11-2466
 11-2467
 11-2468
 11-2469
 11-2470
 11-2471
 11-2472
 11-2473
 11-2474
 11-2475
 11-2476
 11-2477
 11-2478
 11-2479
 11-2480
 11-2481
 11-2482
 11-2483
 11-2484
 11-2485
 11-2486
 11-2487
 11-2488
 11-2489
 11-2490
 11-2491
 11-2492
 11-2493
 11-2494
 11-2495
 11-2496
 11-2497
 11-2498
 11-2499
 11-2500

11-2501
 11-2502
 11-2503
 11-2504
 11-2505
 11-2506
 11-2507
 11-2508
 11-2509
 11-2510
 11-2511
 11-2512
 11-2513
 11-2514
 11-2515
 11-2516
 11-2517
 11-2518
 11-2519
 11-2520
 11-2521
 11-2522
 11-2523
 11-2524
 11-2525
 11-2526
 11-2527
 11-2528
 11-2529
 11-2530
 11-2531
 11-2532
 11-2533
 11-2534
 11-2535
 11-2536
 11-2537
 11-2538
 11-2539
 11-2540
 11-2541
 11-2542
 11-2543
 11-2544
 11-2545
 11-2546
 11-2547
 11-2548
 11-2549
 11-2550
 11-2551
 11-2552
 11-2553
 11-2554
 11-2555
 11-2556
 11-2557
 11-2558
 11-2559
 11-2560
 11-2561
 11-2562
 11-2563
 11-2564
 11-2565
 11-2566
 11-2567
 11-2568
 11-2569
 11-2570
 11-2571
 11-2572
 11-2573
 11-2574
 11-2575
 11-2576
 11-2577
 11-2578
 11-2579
 11-2580
 11-2581
 11-2582
 11-2583
 11-2584
 11-2585
 11-2586
 11-2587
 11-2588
 11-2589
 11-2590
 11-2591
 11-2592
 11-2593
 11-2594
 11-2595
 11-2596
 11-2597
 11-2598
 11-2599
 11-2600

NO.	DESCRIPTION	QTY.	UNIT	PRICE	TOTAL
1	STEAM TURBINE	1	EA.	100,000.00	100,000.00
2	CONDENSER	1	EA.	50,000.00	50,000.00
3	COOLING WATER PUMP	2	EA.	10,000.00	20,000.00
4	STEAM DISTRIBUTION SYSTEM	1	EA.	15,000.00	15,000.00
5	VALVES	10	EA.	5,000.00	50,000.00
6	PIPING	100	FT.	1,000.00	100,000.00
7	ELECTRICAL	1	EA.	5,000.00	5,000.00
8	LABOR	1	EA.	10,000.00	10,000.00
9	CONTROLS	1	EA.	5,000.00	5,000.00
10	FOUNDATIONS	1	EA.	10,000.00	10,000.00
11	INSULATION	1	EA.	5,000.00	5,000.00
12	PAINT	1	EA.	5,000.00	5,000.00
13	TESTING	1	EA.	5,000.00	5,000.00
14	COMMISSIONING	1	EA.	5,000.00	5,000.00
15	OPERATOR TRAINING	1	EA.	5,000.00	5,000.00
16	MANUALS	1	EA.	5,000.00	5,000.00
17	SPARE PARTS	1	EA.	5,000.00	5,000.00
18	MAINTENANCE	1	EA.	5,000.00	5,000.00
19	REPAIRS	1	EA.	5,000.00	5,000.00
20	OVERHAULS	1	EA.	5,000.00	5,000.00
21	REPLACEMENTS	1	EA.	5,000.00	5,000.00
22	MODIFICATIONS	1	EA.	5,000.00	5,000.00
23	UPGRADES	1	EA.	5,000.00	5,000.00
24	REWORK	1	EA.	5,000.00	5,000.00
25	DEFECTS	1	EA.	5,000.00	5,000.00
26	REWORK	1	EA.	5,000.00	5,000.00
27	DEFECTS	1	EA.	5,000.00	5,000.00
28	REWORK	1	EA.	5,000.00	5,000.00
29	DEFECTS	1	EA.	5,000.00	5,000.00
30	REWORK	1	EA.	5,000.00	5,000.00
31	DEFECTS	1	EA.	5,000.00	5,000.00
32	REWORK	1	EA.	5,000.00	5,000.00
33	DEFECTS	1	EA.	5,000.00	5,000.00
34	REWORK	1	EA.	5,000.00	5,000.00
35	DEFECTS	1	EA.	5,000.00	5,000.00
36	REWORK	1	EA.	5,000.00	5,000.00
37	DEFECTS	1	EA.	5,000.00	5,000.00
38	REWORK	1	EA.	5,000.00	5,000.00
39	DEFECTS	1	EA.	5,000.00	5,000.00
40	REWORK	1	EA.	5,000.00	5,000.00
41	DEFECTS	1	EA.	5,000.00	5,000.00
42	REWORK	1	EA.	5,000.00	5,000.00
43	DEFECTS	1	EA.	5,000.00	5,000.00
44	REWORK	1	EA.	5,000.00	5,000.00
45	DEFECTS	1	EA.	5,000.00	5,000.00
46	REWORK	1	EA.	5,000.00	5,000.00
47	DEFECTS	1	EA.	5,000.00	5,000.00
48	REWORK	1	EA.	5,000.00	5,000.00
49	DEFECTS	1	EA.	5,000.00	5,000.00
50	REWORK	1	EA.	5,000.00	5,000.00

11-2601
 11-2602
 11-2603
 11-2604
 11-2605
 11-2606
 11-2607
 11-2608
 11-2609
 11-2610
 11-2611
 11-2612
 11-2613
 11-2614
 11-2615
 11-2616
 11-2617
 11-2618
 11-2619
 11-2620
 11-2621
 11-2622
 11-2623
 11-2624
 11-2625
 11-2626
 11-2627
 11-2628
 11-2629
 11-2630
 11-2631
 11-2632
 11-2633
 11-2634
 11-2635
 11-2636
 11-2637
 11-2638
 11-2639
 11-2640
 11-2641
 11-2642
 11-2643
 11-2644
 11-2645
 11-2646
 11-2647
 11-2648
 11-2649
 11-2650
 11-2651
 11-2652
 11-2653
 11-2654
 11-2655
 11-2656
 11-2657
 11-2658
 11-2659
 11-2660
 11-2661
 11-2662
 11-2663
 11-2664
 11-2665
 11-2666
 11-2667
 11-2668
 11-2669
 11-2670
 11-2671
 11-2672
 11-2673
 11-2674
 11-2675
 11-2676
 11-2677
 11-2678
 11-2679
 11-2680
 11-2681
 11-2682
 11-2683
 11-2684
 11-2685
 11-2686
 11-2687
 11-2688
 11-2689
 11-2690
 11-2691
 11-2692
 11-2693
 11-2694
 11-2695
 11-2696
 11-2697
 11-2698
 11-2699
 11-2700


6-3

3

Q

3

Page Intentionally Left Blank




STREAM NO.	TYPE	11-1151 L.R.2 OIL RECOVERY TOWER BOTTOMS PUMP	11-1152 L.R.2 OIL RECOVERY TOWER SIDE CUT PUMP/ROUND PUMP	11-1153 L.R.2 OIL RECOVERY TOWER REFLUX PUMP	11-1154 L.R.2 OIL RECOVERY TOWER WATER RECYCULATION PUMP	11-1155 L.R.2 OIL RECOVERY TOWER SOUP WATER PUMP	11-1156 EXHAUSTER RECYCLE COMPRESSOR	11-1157 EXHAUSTER RECYCLE COMPRESSOR	11-1158 EXHAUSTER RECYCLE COMPRESSOR
11	TO	8437.25							
12	TO	398.30							
13	TO	11204.86							
14	TO	3601.36							
15	TO	11.76							
16	TO	22077.51							
17	TO	887.94							
18	TO	2384.72							
19	TO	785.76							
20	TO	401.24							
21	TO	108.41							
22	TO	195.48							
23	TO	240.27							
24	TO	497.11							
25	TO	5788.54	290.04	5097.36	4974.05	5181.28	40000.00	40000.00	40000.00
26	TO	151497.76	70811.61	141169.40	467374.52	18320.38	720000.00	720000.00	720000.00
27	TO	528214.75	47471.79	19651.21	77641.50	1351.46	28474.66	28474.66	28474.66
28	TO	24.12	231.02	53007.43	44241.53	192.86	437.41	437.41	437.41
29	TO		7.67		19.39	140.10	235.02	235.02	235.02
30	TO				10.00	19.20	31.67	31.67	31.67
31	TO								
32	TO								
33	TO								
34	TO								
35	TO								
36	TO								
37	TO								
38	TO								
39	TO								
40	TO								
41	TO								
42	TO								
43	TO								
44	TO								
45	TO								
46	TO								
47	TO								
48	TO								
49	TO								
50	TO								
51	TO								
52	TO								
53	TO								
54	TO								
55	TO								
56	TO								
57	TO								
58	TO								
59	TO								
60	TO								
61	TO								
62	TO								
63	TO								
64	TO								
65	TO								
66	TO								
67	TO								
68	TO								
69	TO								
70	TO								
71	TO								
72	TO								
73	TO								
74	TO								
75	TO								
76	TO								
77	TO								
78	TO								
79	TO								
80	TO								
81	TO								
82	TO								
83	TO								
84	TO								
85	TO								
86	TO								
87	TO								
88	TO								
89	TO								
90	TO								
91	TO								
92	TO								
93	TO								
94	TO								
95	TO								
96	TO								
97	TO								
98	TO								
99	TO								
100	TO								

* Both streams 1 and 5 contain 21,749 lb/hr of gas
 * Sour water in streams 3 contains 106 ppm of H₂S

6-4

B

A



NOTES: (1) ALL FLOW RATES, HEAT DUTIES, COMPOSITIONS, TEMPERATURES AND PRESSURES ARE TYPICAL VALUES. SEE EQUIPMENT SPECIFICATIONS FOR DESIGN CONDITIONS.

UNIT	WATER PRODUCT	WATER	LIQUID PRODUCT	REFUEL	BOTTOMS OVERHEAD	EXCHANGER OUTLET	EXCHANGER INLET	RECYCLE GAS	GAS TO TREATING	COOLER WATER	MAKEUP GAS	FUEL GAS
11-1355-1, 1, 2	5027.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11-1355-1, 2	98739.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11-1351	418240.51	506280.00	2187.48	42.00	400000.00	72000.00	10800.00	1800.00	1800.00	1800.00	1800.00	1800.00
11-1851	18.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11-1852	19.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11-1853	18.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11-1854	19.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00	1080.00

PROCESS FLOW DIAGRAM
UNIT 11-2
OIL VAPOR RECOVERY
CONCEPTUAL COMMERCIAL CODE
THE CHEMICAL PROCESSING
CORPORATION
L&S COMPANY
DATE: 10-10-78

6-4

B

Page Intentionally Left Blank

12-1701-01 & 02
STEAM FEED
VALVE
8000 BBL CAPACITY


12-2901-01 & 02
FILTER FEED
VALVE
8000 BBL CAPACITY

12-2801-01 THRU -20
WATER PRESSURE
CONTROLLER
500 PSI EACH
8" DIA. x 20" LONG

12-1301
COMPRESSOR
SUCTION LOCKER

12-1201
ELEMENT RECORDER
12" O.D. x 50" H

12-1202
COMPRESSOR
SUCTION LOCKER
9'-6" O.D. x 14'-0" H



12-1501-01 THRU -20
FILTER FEED PUMP

12-1901-01
FILTER

12-1902-01 THRU -20
FILTER CAKE
SLURRY PUMP

12-1903-01 & 02
FILTERED OIL
PRODUCT PUMP

12-1904-01 & 02
RECYCLE GAS
COMPRESSOR

12-1905-01 & 02
FILTER CAKE
SLURRY PUMP

12-1906-01 & 02
FILTER CAKE
SLURRY PUMP

STREAM NO.	40 °	44 °	65 °	66 °	68 °	69 °	71 °
K2	-46	.02	1278.06	.93	1279.34	.51	.49
K3	-50	.00	32.97	.05	33.45	.00	.00
K4	-57	.05	401.32	1.20	402.52	.74	.78
K5	-42	.01	248.01	.51	248.52	.03	.15
C1	1.64	.00	1614.40	2.87	1617.27	.07	1.12
C2	-18	.02	138.13	.49	138.62	.02	.11
C3	-18	.01	20.18	.16	20.34	.01	.01
P1	-19	.01	15.08	.20	15.28	.02	.02
P2	-19	.01	15.08	.20	15.28	.02	.02
P3	-19	.01	15.08	.20	15.28	.02	.02
P4	-19	.01	15.08	.20	15.28	.02	.02
P5	-19	.01	15.08	.20	15.28	.02	.02
P6	-19	.01	15.08	.20	15.28	.02	.02
P7	-19	.01	15.08	.20	15.28	.02	.02
P8	-19	.01	15.08	.20	15.28	.02	.02
P9	-19	.01	15.08	.20	15.28	.02	.02
P10	-19	.01	15.08	.20	15.28	.02	.02
P11	-19	.01	15.08	.20	15.28	.02	.02
P12	-19	.01	15.08	.20	15.28	.02	.02
P13	-19	.01	15.08	.20	15.28	.02	.02
P14	-19	.01	15.08	.20	15.28	.02	.02
TOTAL	1059.08	5/19	4245.74	1004.44	4215.41	34.72	2.59
RECYCLE GAS	40211.82	2149.00	7580.43	30101.26	6408.90	6508.02	50.79
RECYCLE OIL	24355.56	1317.52	2386.71	30368.47	654.35	454.35	23.42
FILTERED OIL	306.26	382.28	306.12	319.33	187.44	187.44	18.39
WATER	-61.55	-41.51	17.87	-6.52	14.40	12.44	

*Feed oil contains 5% solids
*Filter cake contains 50% solids
*Not included in stream totals


B

A

BALANCE LINE
BALANCE LINE MUST BE HORIZONTAL
BOTTOM OF TANK WITH BOTTOM OF TANK
BRANKER LINE TO FILLER SUCTION LINE
BRANKER LINE TO PUMP SUCTION MUST BE WITH DISTANCE & NO POCKETING

Page Intentionally Left Blank

12-1701 COMPRESSOR SECTION COOLER
 12-1702 COMPRESSOR SECTION COOLER
 9'-6" I.D. x 14'-0" H.T.
 12-2001 STORAGE BIN
 150 TONS
 12-2002 PRECORT TANK
 BUCKET ELEVATOR
 12-1901 PRECORT TANK
 BUCKET ELEVATOR
 12-1902 PRECORT TANK
 BUCKET ELEVATOR
 12-1903 PRECORT TANK
 BUCKET ELEVATOR
 12-1904 PRECORT TANK
 BUCKET ELEVATOR
 12-1905 PRECORT TANK
 BUCKET ELEVATOR
 25,000 FT³ CAPACITY



NOTES: (1) ALL FLOW RATES, HEAT DUTIES, COMPOSITIONS, TEMPERATURES & PRESSURES ARE TYPICAL VALUES. SEE EQUIPMENT SPECIFICATIONS FOR DESIGN CONDITIONS.

12-1801 RECYCLE GAS COMPRESSOR
 12-1501 & 02 FILTRATED OIL PRODUCT PUMP
 12-1502 & 02 RECYCLE PUMP
 12-1507 & 02 RECYCLE PUMP
 12-1508 & 01 & 02 LIGHT OIL RECYCLE PUMP
 12-1509 & 01 & 02 PRODUCT PUMP

64	65	66	67	68	69	71
PRODUCT	COMPRESSOR	FILTERED OIL	RECYCLE OIL	MIXTURE	WATER	WATER
0.00	1279.34	0.01	0.00	0.00	0.00	0.00
0.00	1.85	0.00	0.00	0.00	0.00	0.00
0.00	1.20	0.00	0.00	0.00	0.00	0.00
0.00	248.19	0.00	0.00	0.00	0.00	0.00
0.00	1615.84	0.00	0.00	0.00	0.00	0.00
0.00	59.70	0.00	0.00	0.00	0.00	0.00
0.00	28.74	0.00	0.00	0.00	0.00	0.00
0.00	18.60	0.00	0.00	0.00	0.00	0.00
0.00	5.83	0.00	0.00	0.00	0.00	0.00
0.00	1.04	0.00	0.00	0.00	0.00	0.00
0.00	1.15	0.00	0.00	0.00	0.00	0.00
0.00	1.00	0.00	0.00	0.00	0.00	0.00
0.00	117.00	0.00	0.00	0.00	0.00	0.00
0.00	120.98	0.00	0.00	0.00	0.00	0.00
0.00	81.23	0.00	0.00	0.00	0.00	0.00
0.00	73.16	0.00	0.00	0.00	0.00	0.00
0.00	126.51	0.00	0.00	0.00	0.00	0.00
0.00	6613.61	0.00	0.00	0.00	0.00	0.00
0.00	64529.20	0.00	0.00	0.00	0.00	0.00
0.00	38268.61	0.00	0.00	0.00	0.00	0.00
0.00	18.48	0.00	0.00	0.00	0.00	0.00
0.00	319.33	0.00	0.00	0.00	0.00	0.00
0.00	18.48	0.00	0.00	0.00	0.00	0.00
0.00	-4.53	0.00	0.00	0.00	0.00	0.00

6-5

DATE	12-10-74	PROJECT NO.	50543-AE(2)-10
DESIGNED BY	W.E.	TYPE OF WORK	CONCEPTUAL DESIGN
CHECKED BY	W.E.	SCALE	AS SHOWN
APPROVED BY	W.E.	SECTION	PLANT DESIGN
DATE	12-10-74	SECTION	PLANT DESIGN


B

Page Intentionally Left Blank

Page Intentionally Left Blank

Page Intentionally Left Blank

Page Intentionally Left Blank



STREAM	1	2	3
Fluids, Mols/Hr.			
CO ₂	73	73	-
H ₂	50681	50681	-
N ₂	702	702	-
H ₂ S	1546	(1 ppm)	-
H ₂ O	8422	8316	-
CO	29071	29071	-
CO	38969	38969	-
CH ₄	839	839	-
Total	130303	129312	
Lb/Hr.	2715023	2661400	
Solids, Lb/HR.			49570
Sulfur			

UNIT CAPACITY 823 Lt/D

NOTE: THIS PROCESS ILLUSTRATED IS ONE OF SEVERAL PROPRIETARY PROCESSES AVAILABLE FOR THE PURPOSE INTENDED.

6-7


DRAWN		PROCESS FLOW DIAGRAM	
CHECK		UNIT-13-2	
PROCESS ENGR		GAS TREATING SECTION	
CH PROC ENGR		LOW BTU GAS TREATMENT	
CH OPER ENGR.		CONCEPTUAL COMMERCIAL COED PLANT DESIGN	
PROJECT ENGR.		THE RALPH M PARSONS	DRAWING NO.
CH DES ENGR.		COMPANY	5054-3-AE-13-2
DATE		LOS ANGELES	REV
			0

0

Page Intentionally Left Blank

Page Intentionally Left Blank

ACID GAS REMOVAL



1. ALL FLOW RATES, TEMPERATURES, HEAT DUTIES, TEMPERATURES, AND PRESSURES ARE TYPICAL VALUES. FEED GAS FROM 506A-3-AE-11-1 HAS ADDITIONAL 27% MOLE% N₂ FOR LOSSES.
2. MATERIAL BALANCE IS ON A MOLES BASIS.
3. UNIT CAPACITY 327 MILLION BPD ON 24 HR BASIS.

HYDROGEN COMPRESSOR

6.8


NOTE: THE ACID GAS REMOVAL INDICATED IS ONE OF THE VALUES AVAILABLE FOR THIS PURPOSE. INTERFERED.

NO.	DESCRIPTION	DATE
1	PROCESS DESIGN	11/10/88
2	CONCEPTUAL DESIGN	11/10/88
3	PRELIMINARY DESIGN	11/10/88
4	Detailed Design	11/10/88
5	Construction	11/10/88
6	Operation	11/10/88
7	Maintenance	11/10/88
8	Shutdown	11/10/88
9	Restart	11/10/88
10	Relief	11/10/88
11	Commissioning	11/10/88
12	Final Design	11/10/88
13	Final Review	11/10/88
14	Final Approval	11/10/88
15	Final Report	11/10/88
16	Final Summary	11/10/88
17	Final Review	11/10/88
18	Final Approval	11/10/88
19	Final Report	11/10/88
20	Final Summary	11/10/88
21	Final Review	11/10/88
22	Final Approval	11/10/88
23	Final Report	11/10/88
24	Final Summary	11/10/88
25	Final Review	11/10/88
26	Final Approval	11/10/88
27	Final Report	11/10/88
28	Final Summary	11/10/88
29	Final Review	11/10/88
30	Final Approval	11/10/88
31	Final Report	11/10/88
32	Final Summary	11/10/88
33	Final Review	11/10/88
34	Final Approval	11/10/88
35	Final Report	11/10/88
36	Final Summary	11/10/88
37	Final Review	11/10/88
38	Final Approval	11/10/88
39	Final Report	11/10/88
40	Final Summary	11/10/88
41	Final Review	11/10/88
42	Final Approval	11/10/88
43	Final Report	11/10/88
44	Final Summary	11/10/88
45	Final Review	11/10/88
46	Final Approval	11/10/88
47	Final Report	11/10/88
48	Final Summary	11/10/88
49	Final Review	11/10/88
50	Final Approval	11/10/88
51	Final Report	11/10/88
52	Final Summary	11/10/88
53	Final Review	11/10/88
54	Final Approval	11/10/88
55	Final Report	11/10/88
56	Final Summary	11/10/88
57	Final Review	11/10/88
58	Final Approval	11/10/88
59	Final Report	11/10/88
60	Final Summary	11/10/88
61	Final Review	11/10/88
62	Final Approval	11/10/88
63	Final Report	11/10/88
64	Final Summary	11/10/88
65	Final Review	11/10/88
66	Final Approval	11/10/88
67	Final Report	11/10/88
68	Final Summary	11/10/88
69	Final Review	11/10/88
70	Final Approval	11/10/88
71	Final Report	11/10/88
72	Final Summary	11/10/88
73	Final Review	11/10/88
74	Final Approval	11/10/88
75	Final Report	11/10/88
76	Final Summary	11/10/88
77	Final Review	11/10/88
78	Final Approval	11/10/88
79	Final Report	11/10/88
80	Final Summary	11/10/88
81	Final Review	11/10/88
82	Final Approval	11/10/88
83	Final Report	11/10/88
84	Final Summary	11/10/88
85	Final Review	11/10/88
86	Final Approval	11/10/88
87	Final Report	11/10/88
88	Final Summary	11/10/88
89	Final Review	11/10/88
90	Final Approval	11/10/88
91	Final Report	11/10/88
92	Final Summary	11/10/88
93	Final Review	11/10/88
94	Final Approval	11/10/88
95	Final Report	11/10/88
96	Final Summary	11/10/88
97	Final Review	11/10/88
98	Final Approval	11/10/88
99	Final Report	11/10/88
100	Final Summary	11/10/88

2

3

Page Intentionally Left Blank



NOTE: THIS PROCESS ILLUSTRATED IS ONE OF SEVERAL PROPRIETARY PROCESSES AVAILABLE FOR THE PURPOSE INTENDED.

6-9

TREAM	1	2	3
fluids, Moles/Hr.			
CO ₂	9204	9204	-
H ₂ S	224	(1 ppm)	-
H ₂ O	1027	637	-
Total	10455	9842	
Lb/Hr.	431211	416580	
Solids, Lb/Hr.			7180
Sulfur			

UNIT CAPACITY 135 Lt/D

PROCESS FLOW DIAGRAM	
UNIT 14-2	
HYDROGEN PLANT TAILGAS	
DESULFURIZER	
CONCEPTUAL COMMERCIAL COED PLANT DESIGN	
THE RALPH M PARSONS	DRAWING NO.
COMPANY	5054-3-AE-14-2
LOS ANGELES	REV
	0

β

Page Intentionally Left Blank

15-1017
 FEED STORAGE
 FROM
 9'-0" I.D. x 25'-0"

15-1401.02.03.04
 FEED PREHEATER
 37'-5" HIBU/HR

15-1201.02.03.04
 NO. 1 REACTOR
 10'-0" I.D. x 21'-6"

15-1216.17.18.19
 NO. 2 REACTOR EFF.-
 10'-0" I.D. x 27'-9"

15-1205.06.07.08
 NO. 2 REACTOR
 10'-0" I.D. x 27'-9"

15-1213.14.15.16
 NO. 3 REACTOR EFF.-
 10'-0" I.D. x 27'-9"

15-1203.04.05.06
 NO. 3 REACTOR
 10'-0" I.D. x 27'-9"


15-1201.02.03.04
 NO. 1 REACTOR
 10'-0" I.D. x 21'-6"

15-1216.17.18.19
 NO. 2 REACTOR EFF.-
 10'-0" I.D. x 27'-9"

15-1205.06.07.08
 NO. 2 REACTOR
 10'-0" I.D. x 27'-9"

15-1213.14.15.16
 NO. 3 REACTOR EFF.-
 10'-0" I.D. x 27'-9"

15-1203.04.05.06
 NO. 3 REACTOR
 10'-0" I.D. x 27'-9"




STREAM NO.	LIGHT OIL FEED	HEAVY OIL FEED	TOTAL FEED	TOTAL TO FURNACE & REACTORS	TOTAL REACTOR EFFLUENT	WASH WATER	TOTAL EFFLUENT TO HP SEPARATOR	QUENCH GAS	RECYCLED HYDROGEN
BY	0.00	0.00	0.00	18666.04	17261.22	0.00	17261.22	4401.90	11410.41
M1	0.00	0.00	0.00	11968.00	10825.25	0.00	10825.25	1372.00	118.00
M2	0.00	0.00	0.00	0.00	300.35	0.00	300.35	0.00	0.00
M3	0.00	0.00	0.00	0.00	244.59	0.00	244.59	0.00	0.00
M4	0.00	0.00	0.00	0.00	1920.10	1000.00	11920.10	17.79	0.00
M5	0.00	0.00	0.00	0.00	58.43	0.00	58.43	31.45	0.00
M6	0.00	0.00	0.00	0.00	639.47	0.00	639.47	201.12	0.00
M7	0.00	0.00	0.00	0.00	113.21	0.00	113.21	108.45	0.00
M8	0.00	0.00	0.00	0.00	71.41	0.00	71.41	0.00	0.00
M9	0.00	0.00	0.00	0.00	61.19	0.00	61.19	11.70	0.00
M10	0.00	0.00	0.00	0.00	127.44	0.00	127.44	0.00	0.00
M11	0.00	0.00	0.00	0.00	64.86	0.00	64.86	0.00	0.00
M12	0.00	0.00	0.00	0.00	478.47	0.00	478.47	3.43	0.00
M13	0.00	0.00	0.00	0.00	684.46	0.00	684.46	0.00	0.00
M14	0.00	0.00	0.00	0.00	603.30	0.00	603.30	0.00	0.00
M15	0.00	0.00	0.00	0.00	1120.15	0.00	1120.15	0.00	0.00
M16	0.00	0.00	0.00	0.00	321.77	2.50	324.27	0.00	0.00
M17	0.00	0.00	0.00	0.00	244.48	0.00	244.48	0.00	0.00
M18	0.00	0.00	0.00	0.00	59.98	0.00	59.98	0.00	0.00
M19	0.00	0.00	0.00	0.00	2.78	0.00	2.78	0.00	0.00
M20	0.00	0.00	0.00	0.00	91.73	0.00	91.73	0.00	0.00
M21	0.00	0.00	0.00	0.00	185.45	0.00	185.45	0.00	0.00
M22	0.00	0.00	0.00	0.00	185.45	0.00	185.45	0.00	0.00
M23	0.00	0.00	0.00	0.00	441.18	0.00	441.18	0.00	0.00
M24	0.00	0.00	0.00	0.00	441.18	0.00	441.18	0.00	0.00
TOTAL	112.19	1004.44	1116.63	76868.57	31916.23	10000.00	43716.23	18098.00	11861.88
L3/HP	18520.37	381018.71	399539.08	964106.72	108596.54	189100.00	127442.23	121442.23	12043.37
PRECD	133.146	21085.71	24400.17	964106.72	108596.54	121442.23	127442.23	121442.23	12043.37
MSI	160.10	379.33	539.43	35.66	31.96	18.02	13092.79	10824.55	2.70
MSI	15.10	-6.52	-5.33				8.51		

Page Intentionally Left Blank

Page Intentionally Left Blank

Page Intentionally Left Blank



FROM 5054-3-AE-13-1 LINE 4


STREAM	1	2	3
Fluids, Moles/hr			
H ₂ S	463	15	8
SO ₂	-	774	774
CO ₂	773	-	-
CH ₄	1	-	877
N ₂	-	54	508
H ₂ O	1291	2182	2182
Total	50797	68780	68780
Solids, LB/HR			
Sulfur			14100

UNIT CAPACITY 418 LT/0

PROCESS FLOW DIA		UNIT 16-1	SULFUR RECOVERY	CONCEPTUAL CONFER	COED PLANT DEST
DRAWN	CHECK				
PROCESS ENGR. CLC					
CH. PROC. ENGR. N&J					
CH. OPER. ENGR.					
PROJECT ENGR. JJJ					
CH. DES. ENGR.					
DATE 10-10-74					
THE RALPH M. PARSONS COMPANY		LOS ANGELES			
		5054-3			

B

A



DRAWN		PROCESS ENGR. C.L.B.		THE RALPH W. PARSONS COMPANY		SERIES NO.	
CHECK		CH. PROC. ENGR. N&T		LOS ANGELES		5054-3-AE-16-1	
PROCESS ENGR. C.L.B.		PROJECT ENGR. J.H.		DATE 10-10-74		REV	
CH. PROC. ENGR. N&T		CH. DES. ENGR.		5054-3-AE-16-1		0	
CH. OPER. ENGR.		CH. DES. ENGR.		5054-3-AE-16-1		0	
PROJECT ENGR. J.H.		DATE 10-10-74		5054-3-AE-16-1		0	
CH. DES. ENGR.		DATE 10-10-74		5054-3-AE-16-1		0	

PROCESS FLOW DIAGRAM
UNIT 16-1
SULFUR RECOVERY UNIT
CONCEPTUAL COMMERCIAL
COED PLANT DESIGN

STREAM	1	2	3
Fluids, Moles/hr			
H ₂ S	463	15	
SO ₂	-	8	
CO ₂	773	774	
CH ₄	1	-	
N ₂	-	877	
H ₂ O	54	508	
Total	1291	2182	
Solids, LB/HR	50797	68780	
Sulfur			14100


UNIT CAPACITY 418 LT/D

6-11


C

B

Page Intentionally Left Blank



HYDROGEN SULFIDE EXTRACTION



HYDROGENATION SECTION

STREAM	(1)	(2)	(3)
Fluids, Mols/Hr.			
H ₂ S	15	(1 ppm.)	-
S ₀₂	8	-	-
CO ₂	774	774	-
H ₂	877	877	-
H ₂ O	508	106	-
Total	2182	1757	740
Solids, Lb/Hr.	68783	60520	
Sulfur			

UNIT CAPACITY 18-1/2 LT/D

6-12

NOTE: THIS PROCESS ILLUSTRATED IS ONE OF SEVERAL PROPRIETARY PROCESSES AVAILABLE FOR THE PURPOSE INTENDED.

DRAWN	PROCESS FLOW DIAGRAM	DRAWING NO.
CHECK	UNIT 16-2	5054-3-AE-16-2
PROCESS ENGR.	TAIL GAS SULFUR REMOVAL	
CH. PROC. ENGR.	CONCEPTUAL COMMERCIAL COED PLANT DESI	
CH. OPER. ENGR.		
PROJECT ENGR.		
CH. DES. ENGR.	THE RALPH M. PARSONS COMPANY	
DATE	LOS ANGELES	


Page Intentionally Left Blank

18-1304-01, 02, 03
STEAM TURBINE
CONDENSERS

18-1302-01, 02, 03
COMPRESSOR
INTERCOOLERS

18-1303
COMPRESSOR
INTERCOOLER

18-1305-01, 02, 03
STEAM TURBINE
CONDENSERS



18-1802-01, 02, 03
LOW BTU FUEL GAS
COMPRESSORS
LOW PRESSURE


18-1803-01, 02, 03
LOW BTU FUEL GAS
COMPRESSORS
HIGH PRESSURE

18-1801
HIGH BTU FUEL
GAS COMPRESSOR

B

A

Page Intentionally Left Blank



9

9


18-1801
HIGH BTU FUEL
GAS COMPRESSOR

18-01, 02, 03
FUEL GAS
PRESSORS
PRESSURE

Page Intentionally Left Blank

18-0851-01 THRU 12
 GAS TURBINE GENERATOR
 BOILER PACKAGE
 LOW PRESSURE STEAM
 Steam Rate: 431,000 LB/HR
 Generator Output: 95,000 KW

18-0852
 GAS TURBINE GENERATOR
 BOILER PACKAGE
 LOW PRESSURE STEAM
 Steam Rate: 431,000 LB/HR
 Generator Output: 95,000 KW




DRAWN	A.M.L.	REV.	0
CHECK		DATE	10-10-74
PROCESS ENGR.	M.K.B.	PROJECT ENGR.	R.P.
CH. PROC ENGR.	D.W.Z.	CH. DES. ENGR.	
CH. OPER ENGR.		THE RALPH M. PARSONS COMPANY	
PROJECT ENGR.		LOS ANGELES	
CH. DES. ENGR.		5054-3-AE-18-1	
DATE	10-10-74		

6-13


E

P



P

A



DESIGNER	INDUSTRIAL WATER SYSTEM SCHEMATIC
UNIT	UNIT 19-3
CONCEPTUAL	CONCEPTUAL
PLANT DESIGN	PLANT DESIGN
DATE	10/11/78
PROJECT NO.	5054-3-NE19-3
REV.	2
DATE	10/11/78
BY	J. J. J.
CHECKED	J. J. J.
APPROVED	J. J. J.

6-14

P

C

Page Intentionally Left Blank

SECTION 7

MATERIAL BALANCE

The overall material balance for the process sections of the complex is depicted in Figure 7-1. The balance is for a typical feed coal composition.

The Figure 7-1 balance reflects the portion of the complex which converts 24,487 TPD of moisture-free coal to a product slate consisting of:

- (1) High-Btu gas ($\approx 890 \frac{\text{Btu}}{\text{scf}}$ HHV)
- (2) Low-Btu gas ($\approx 250 \frac{\text{Btu}}{\text{scf}}$ HHV)
- (3) Syncrude
- (4) Sulfur
- (5) CO_2 + ventgas
- (6) Ash

The total weight of these products for the typical case is 45,080 TPD.

The revenue-producers are syncrude, electricity, and sulfur. The high- and low-Btu gases from the process sections are used to produce the export electricity as well as the steam and electricity required to operate the COED-based complex.




Figure 7-1 - Overall Material Balance - Typical Operation for Process Sections

SECTION 8

UTILITIES

All utilities needed for operation of the COED Conceptual Complex will be produced onsite utilizing a portion of the energy contained in the feed coal. In addition utilities require a significant amount of water for consumption.

The utilities required for all operations in the complex include three types of steam which have the following characteristics: (1) 600 psia/825°F, (2) 165 psia/saturated, and (3) 65 psia/saturated. The electrical requirements include power delivery at 13.8, 4.16 kV, 440 and 120/240 volts, 60 hertz. The cooling water supply is to be at 86°F. Boiler feedwater is also required.

The Utility Summary presented in Table 8-1 tabulates the various utility requirements based on typical feed-coal composition.

In some of the units, condensate is produced during normal operation; this results from condensation of turbine exhaust or heating steam. In other units, steam is generated at one of the pressure-temperature conditions in the course of process stream cooling. These generated quantities are shown in Table 8-1. Approximately 95% of the total steam required will be produced in the power plant. Gas turbines burning gas produced onsite from the coal exhaust through heat recovery boilers which generate steam at 600 psia/825°F and 65 psia saturated. The relatively lesser quantity of 165 psia steam required will be produced by letting down some of the 600 psia steam produced in the oil hydrotreating unit. The balance of this 600 psia saturated steam is superheated in the power plant and added to the 600 psia/825°F system.

Makeup for cooling water, boiler feedwater, and process water is derived from river water and suitably treated onsite as described under Unit 19-3 in Section 5.

Electrical power is generated in the power plant utilizing the gas produced in the process units for fuel (refer to Steam and Power Generating Plant, Unit 18-1 in Section 5).

Table 8-1 - Utility Summary

Unit Number	Unit Description	600-psia Steam at 825°F (lb/hr)	165-psia Steam at Saturation ^c (lb/hr)	65-psia Steam at Saturation (lb/hr)	15-psig Steam at Saturation (lb/hr)	Condensate (lb/hr)	Boiler Feedwater (lb/hr)	Cooling Water (gpm)	Electrical Power (MW)	Fuel Gas (MM Btu/hr)	Water Makeup (gpm)	Type of Water Makeup
Unit 10-1	Coal Mine								16.6			
Unit 10-2	Coal Preparation								2.6			
Unit 11-1	Pyrolysis and Gasification	89,000		343,000		(89,000)		71,900	3.0		500	Cooling Water Blowdown to Process
Unit 11-2	Oil-Vapor Recovery	310,000	6,000			(310,000)		28,000	1.4			
Unit 12-1	Oil Filtration	33,000	1,000	2,000		(33,000)		3,000	0.6			
Unit 13-1	Pyrolysis Gas Treating	44,000		5,000		(44,000)		4,000	1.2	178		
Unit 13-2	Low Btu Gas Treating		77,000						16.1		300	Process Water
Unit 14-1	Hydrogen Plant	997,000	5,500	(20,000)		(376,000)	263,000	27,000	7.8		525	Boiler Feedwater
Unit 14-2	H ₂ Plant Tail Gas		12,000			(720,960) ^d						
Unit 15-1	Oil Hydro-Treating	13,000	500	(133,000)		180,000	344,000	10,000	2.0	128	690	Boiler Feedwater
Unit 16-1	S ₂ Recovery	(200,000) ^{a,b}	(22,000)	10,000	(3,000)	(13,000)	27,000		0.4		55	Boiler Feedwater
Unit 16-2	Pyrolysis Gas Treating of 16-1 Tail Gas		(11,000)	10,700			12,000		1.0	20	25	Boiler Feedwater
Unit 17-1	Oxygen Plant	1,960,000	35,000	32,000		(1,960,000)		258,000			15	Process Water
Unit 18-1	Power Plant	1,500,000				(1,500,000)	1,000,000	207,000			2,000	Boiler Feedwater
Cooling Tower Pumps									15.0			
Utilities & Offsites							280,000 ^e	24,000 ^g	12.3			
Total Consumed		4,946,000	137,000	402,700		180,000	1,926,000	24,500	80.0	326	28,800	
Total Generated		200,000 ^a	33,000	153,000	3,000	4,325,000						
Total Net Required		4,946,000	104,000	249,700			1,926,000	24,500	80.0	326	28,800	
Total Net Generated					3,000	4,145,000		609,000				
Total Circulated												

^aAt saturation (not included in total).

^bNumbers in parentheses indicate "generated".

^cTaken from 600-psia saturation (see footnote a).

^dProcess condensate requiring desaturation only (not included in total).

^eBoiler blowdown makeup.

^fConsumed.

^gCooling tower makeup.

SECTION 9

ENERGY BALANCE

The overall energy balance is illustrated in Figure 9-1. All values are based on a typical coal feed and will vary as the characteristics of the coal vary.


Figure 9-1 indicates that of the 25,433 MM Btu/hr energy input from the coal, 15,329 Btu/hr or approximately 60% is consumed within the complex. Energy value of the products for export are also indicated; these total 10,104 MM Btu/hr or approximately 40% of the total energy input. The contributors are:

<u>Product</u>	<u>Energy Content (MM Btu/hr)</u>	<u>%</u>	
		<u>Feed Coal</u>	<u>Product</u>
COED Syncrude Oil	7,005	28	69
Electrical Power	2,823	11	28
Sulfur	<u>276</u>	<u>1</u>	<u>3</u>
Total	10,104	40	100

Note that the production of electrical power represents about 28% of the exported energy. The energy efficiency for the process of converting fuel gas to electricity for this case is approximately 35%.

Figure 9-2 depicts the estimated thermal efficiency for the process section. The results indicate a thermal efficiency of approximately 58% for the conversion of feed coal to syncrude, fuel gas, and sulfur.

Page Intentionally Left Blank




ENERGY DISTRIBUTION	MILLION BTU/HR, HHV	%
ENERGY SOURCE	25,433	100.0
COAL		
ENERGY CONSUMED IN MFG		
MINING AND PREPARATION	551	2.2
OXYGEN	2,682	10.6
COED	5,707	22.4
POWER HOUSE	6,389	25.1
TOTAL	15,329	60.3
ENERGY VALUE OF PRODUCT		
COED OIL	7,005	27.5
EXPORT POWER	2,823	11.1
SULFUR	276	1.1
TOTAL	10,104	39.7

Figure 9-1 - Energy Balance - Conceptual Commercial COED Plant Design

Preceding page blank

Page Intentionally Left Blank



ALL FIGURES ARE MM BTU/HR, HHV

$$\text{THERMAL EFFICIENCY} = \frac{7,597 + 7,005 + 254}{25,433} = 58.4\%$$

a) GAS FOR IN-HOUSE STEAM REQUIRED: $\frac{4,970}{0.85 \text{ EFF}} = 5,850$

b) GAS FOR IN-HOUSE ELECTRIC POWER REQUIRED: $\frac{80 \text{ MW} \times 3,413}{0.35 \text{ EFF}} = 780$

Figure 9-2 - Thermal Efficiency
Based on Export of Fuel Gas

Page Intentionally Left Blank