

Structural Development Study No. 10  
Ranney Water System Versus Intake Structure

Table of Contents

1.0 Introduction

2.0 Summary

3.0 Design Basis

4.0 Cost Estimate

5.0 Recommendation

Appendix I: Water Supply System

Appendix II: Structural Engineering Study

Appendix III: Surface (Raw) Water and Ranney Collector  
Well (Ground) Water Analysis Reports

## Ranney Water System Versus Intake Structure

### 1.0 Introduction

The purpose of this study is to evaluate two types of water supply systems which could be used for the project. One type is a surface (raw) water intake system, and the second type is a Ranney Collector well (ground) water system. This system could be either radial collectors or Infiltration Galleries, see Appendix I. Fluor has completed a construction cost estimate for a surface (raw) water intake system. A similar estimate is provided by the Ranney Company for their systems.

### 2.0 Summary

It is determined that the Ranney collector well (ground) water system is the most economical system for the project. This conclusion holds for a required flow rate of either 19,000 or 11,000 gallons per minute (gpm).

### 3.0 Design Basis

A comparison is made between the two water supply systems and their respective treatment processes necessary for supplying boiler feed-water makeup to the steam plant. See Figures A or B for respective treatment of raw water from an intake structure or ground water from a Ranney Well. See appendix III for water analysis reports.

The primary differences between the two treatment processes is in the clarification and demineralization treatment requirements. Raw water requires clarification due to a high suspended solids content, ground water does not require clarification. Raw water requires less demineralization treatment than ground water due to higher dissolved solids content in ground water. For additional information, see appendix II.


### 4.0 Cost Estimate

A cost comparison between a surface (raw) water intake system and a Ranney collector well (ground) water system is presented in Tables 1 and 2 for two water flowrate requirements. These cost estimates do not include units common to both treatment processes unless there is a difference in sizes. Table 3 lists the units included in each process treatment and Table 4 summarizes those units that are included.

## 5.0 Recommendation

It is determined that the estimated cost of the Ranney collector well (ground) water system and process treatment is \$55.3 MM for a required flowrate of 19 M gpm; within the limitation defined in the cost estimate above. Similarly the estimated cost of an alternate surface (raw) water intake system is \$69.9 MM. For a required flowrate of 11 M gpm the respective estimated cost are \$35.4 MM and \$45.6 MM. On the basis of relative cost Fluor recommends the use of the Ranney collector well (ground) water system for this project.

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT




NOTE: 1. USING INTAKE STRUCTURE - RAW WATER

USE OF ABSTRACTS OF REPERT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



KUYERAWA	FIG. A TRI-STATE
KUYERAWA	WATER MANAGEMENT PROCESS
M. MARTIN	BLOCK FLOW DIAGRAM
J. SHIFF	
NONE	835504-00-2-9000 1



USE OF BALLPARKS & APPROX. DATA  
 IN THIS DIAGRAM IS FOR INFORMATION ONLY  
 AND IS NOT TO BE USED AS A BASIS FOR  
 DESIGN OR CONSTRUCTION.

NOTE: 1. USING RANNEY WELL GROUND WATER



K. UYERAKI	FIG. 2 TRI-STATE	
K. J. BURMAN	WATER MANAGEMENT PROCESS	
M. MARTIN	BLOCK FLOW DIAGRAM	
J. SIMP		
NONE	835504-00-2-9001	1

**TABLE 1  
EVALUATED COST ESTIMATE: SURFACE (RAW) WATER INTAKE SYSTEM**

UNIT	FLOWRATE = 19,000 GPM					FLOWRATE = 11,000 GPM				
	EQUIPMENT COST, \$	LABOR COST, \$	POWER COST, \$	CHEMICAL COST, \$	TOTAL \$	EQUIPMENT COST, \$	LABOR COST, \$	POWER COST, \$	CHEMICAL COST, \$	TOTAL \$
SURFACE H <sub>2</sub> O INTAKE STRUCTURE	—	—	—	—	2,640,000	—	—	—	—	2,640,000
POTABLE H <sub>2</sub> O CLARIFIER	51,340	54,200	—	—	—	21,200	14,100	—	—	—
RAW WATER CLARIFIER	2,400,000	1,600,000	660,000	181,820	—	1,515,500	1,010,900	381,920	104,900	—
CLARIFIED WATER RBS	7,247,500	9,644,300	83,600	—	—	4,945,600	6,581,100	48,100	—	—
SAND FILTER	377,600	251,700	24,200	—	—	230,400	158,900	11,440	—	—
FILTERED WATER RESERVOIR	3,356,700	4,466,700	474,760	—	—	2,060,400	2,741,700	267,960	—	—
BACKWASH SUPERNATANT COLLECTION SUMP	150,000	100,000	3,520	—	—	150,000	100,000	8,800	—	—
BFW TREATMENT <sup>1</sup>	—	—	—	93,420	—	—	—	—	54,090	—
<b>TOTAL, \$</b>	<b>13,583,140</b>	<b>16,096,900</b>	<b>1,246,080</b>	<b>275,240</b>		<b>8,931,100</b>	<b>10,606,100</b>	<b>718,520</b>	<b>158,990</b>	
TOTAL DIRECT FIELD COST (DFC)	29,680,040					19,537,200				
TOTAL PROJECT COST (PC) = 1.94 (DFC)	57,779,278					37,902,168				
TOTAL ANNUAL COST (AC)						1,521,320				
EVALUATED ANNUAL COST (EAC) = 5.77 (AC)						8,778,016				
TOTAL COST = PC + EAC + INTAKE						68,961,294				
						45,605,401				

USE 3% DISCOUNT OF PROJECT DATA  
 IS SUBJECT TO THE COLLECTION OF THE  
 WATER RATE AT THE POINT OF THIS REPORT

**NOTE: 1. BOILER FEEDWATER TREATMENT UNITS HAVE NOT BEEN INCLUDED IN COST SUMMARIES FOR EQUIPMENT, LABOR OR POWER BECAUSE THEY WILL BE EQUIVALENT FOR BOTH THE SURFACE (RAW) WATER INTAKE SYSTEM AND THE RANNEY WELL (GROUND) WATER SYSTEM.**



K. UYENAMA	TRI-STATE COST ESTIMATE TABLE 1
K. UYENAMA	
P. MARTIN	
J. SHIPP	
NONE	B35504-00-2-9002

**TABLE 2**  
**EVALUATED COST ESTIMATE: RANNEY COLLECTOR WELL (GROUND) WATER SYSTEM**

UNIT	FLOWRATE: 19,000 GPM					EQUIPMENT COST \$	LABOR COST \$	POWER COST \$	CHEMICAL COST \$	TOTAL \$
	EQUIPMENT COST \$	LABOR COST \$	POWER COST \$	CHEMICAL COST \$	TOTAL \$					
RANNEY WELL STRUCTURE					7830,000					4,198,000
SAND FILTER	1,132,800	785,300	660,000	114,830		715,300	476,900	381,920	66,250	
FILTERED H <sub>2</sub> O RESERVOIR	7,247,500	9,644,300	972,520			4,945,600	4,681,100	512,160		
BFW TREATMENT 1				157,200					91,030	
TOTALS, \$	8,980,900	10,599,500	1,632,520	272,030		5,660,900	7,058,000	894,080	157,280	
TOTAL DIRECT FIELD COST (DFC)	10,779,800					12,718,900				
TOTAL PROJECT COST (PC) = 1.94 (DFC)	36,492,812					24,674,666				
TOTAL ANNUAL COST (AC)			1,904,550					1,051,360		
EVALUATED ANNUAL COST (EAC) = 1.57 (AC)			1,098,254					606,637		
TOTAL COST = PC + EAC + WELL					55,292,066					35,439,113

USE OF EQUIPMENT IS RESTRICTED AND IS SUBJECT TO THE RESTRICTIONS ON THE BIDDING PAGE AT THE FRONT OF THIS OFFER.

NOTE: 1. BOILER FEEDWATER TREATMENT UNITS HAVE NOT BEEN INCLUDED IN COST SUMMARIES FOR EQUIPMENT, LABOR OR POWER BECAUSE THEY WILL BE EQUIVALENT FOR BOTH THE SURFACE (RAW) WATER INTAKE SYSTEM AND THE RANNEY



CHECKED REVISIONS APPROVED DATE	TRI-STATE COST ESTIMATE TABLE 2
NONE	895504-00-2-9003 1

Table 3

Units Lists: Raw Water Intake Versus Ground Water System

<u>Units</u>	<u>Ground Water System</u>	<u>Raw Water Intake</u>
Raw water potable H <sub>2</sub> O clarifier		X
Sand Filter (Potable)	X	X
A.C. Filter (Potable)	X	X
Potable H <sub>2</sub> O Storage	X	X
Raw Water Clarifier		X
Sand Filter	X	X *
Sludge Thickener	X	X
Sludge Collection Sump	X	X
Sludge Dewatering	X	X
Backwash Supernatant Collection Sump		
Clarified H <sub>2</sub> O Reservoir		X
Filtered H <sub>2</sub> O Reservoir	X	X *
A.C. Filter	X	X
Demineralizer	X	X
Mixed Bed Polisher	X	X
BFW Storage Tank	X	X
Condensate Mixed Bed Polisher	X	X
Treated Condensate Storage Tank	X	X
Neutralizing Sump	X	X
Steam Generator	X	X

\*Unit sizes differ between the two systems



Table 4

Units Included In Cost Estimate

Cost estimate for:

- . Ranney Well
- . Intake Structure
- . Raw Water Clarifier
- . Sand Filter (Diff. Sizes)
- . Back Wash Supernatant Collection Sump
- . Clarified Water Reservoir
- . Filtered Water Reservoir
- . Potable Water Clarifier
- . BFW Treatment

Cost estimates for units is provided for two flowrates:


- . 19,000 GPM - Raw Water Required
- . 11,000 GPM - Raw Water Required

**TRI-STATE SYNFUELS COMPANY**  
Indirect Coal Liquefaction Plant  
Western Kentucky

**FLUOR ENGINEERS AND CONSTRUCTORS, INC.**  
Contract 835504

**APPENDIX I**  
**Water Supply Systems**

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT




## RANNEY Radial Collectors

Proven by hundreds of installations around the world, the Ranney Radial Collector is the outstanding engineering development of modern day ground water acquisition. Horizontal screens radiate from the central caisson collecting water from the surrounding strata, utilizing either induced infiltration or ground water storage as the source of supply. Yields from existing installations range from 700 gpm to 20,000 gpm, depending upon the aquifer characteristics.

A single unit exceeds the yield of several conventional vertical wells. This improves pumping efficiency and requires less maintenance, pumping equipment, pipeline and overall land acquisition. Ranney's methods of construction and flexibility of design have made this type of installation superior in all environmental applications.

Ranney Collectors develop a supply of water from a given site, of a quality and quantity often not economically obtainable by conventional methods.

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



## RANNEY Raw Water Intakes


The Ranney Raw Water Intake features an onshore pumping station, utilizing Ranney's proven caisson design. The onshore caisson is gravity-fed through one or more intake lines which are supplied by one or more intake screens located in the surface water source. Except for the pumping facility, this complete intake system has NO MOVING PARTS.

The intake screens can be equipped with an air or water backwash system, if necessary, and the screens can be easily replaced. Therefore the amount of required maintenance to a Ranney unit is negligible.

The Environmental Protection Agency in its "Development document for best technology available for the location, design, construction and capacity of cooling water intake structures for minimizing adverse environmental impact", dated April, 1976, page 77, describes this type of "fixed-screen intake" as follows:

"In this manner large quantities of water may be handled at what may be substantially less cost and greater fish protection effectiveness than presently used conventional screens".

Intake capacities vary from a few hundred gallons per minute to hundreds of thousands of gallons per minute. This intake offers low capital cost, low operating cost, maximum dependability and security, ease and convenience of operation, as well as being environmentally sound.




## RANNEY Infiltration Galleries

Where ground water and surface water sources are not feasible due to quality or quantity limitations, Ranney Infiltration Galleries have proven most effective.

These infiltration galleries are permeable, horizontal or inclined conduits into which water can infiltrate from an overlying or adjacent source. They are constructed below the water table in an area where there is sufficient recharge to offset the pumping rate, and where the permeability of the natural soils is sufficient to transmit this quantity of water to the gallery under the existing head conditions.


The gallery consists of a typical Ranney caisson with one or more large diameter screens located beneath the adjacent water source. Need for further filtration, in most cases, is eliminated resulting in high capital savings and lower operational expenditures. The Ranney gallery requires only limited area . . . important in crowded industrial centers, and can be installed for only a fraction of the cost of conventional sand filtration plants. Ranney's gallery was engineered to meet special natural conditions and complete Ranney's facilities for all major water development programs.



USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

ELEVATION

RANNEY RAW WATER INTAKE



RANNEY COLLECTOR WELL (TYPICAL)

**TRI-STATE SYNFUELS COMPANY**  
Indirect Coal Liquefaction Plant  
Western Kentucky

**FLUOR ENGINEERS AND CONSTRUCTORS, INC.**  
Contract 835504

**APPENDIX II**

**Structural Engineering Study**

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

## APPENDIX II

TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract 835504  
May 19, 1981

### STRUCTURAL ENGINEERING STUDY

#### RANNEY WATER SYSTEM VERSUS INTAKE STRUCTURE

##### 1.0 GENERAL

This study will provide a comparison of a Ranney Water System versus an alternate surface water intake structure.

##### 2.0 WORK DEFINITION

2.1 The Ranney Water System shall be one of the following:

- 2.1.1 Radial Collectors: Horizontal screens radiate from a central caisson collecting water from the surrounding strata, utilizing either induced infiltration or ground water storage as the source of supply.
- 2.1.2 Raw Water Intakes: The onshore pumping station and caisson is gravity fed through one or more intake lines which are supplied by one or more intake screens located in the surface water source.
- 2.1.3 Infiltration Galleries: Permeable horizontal or inclined conduits are constructed below the water table in an area where the permeability of the natural soil is sufficient to transmit this quantity of water to the gallery under the existing head conditions.

The optimum Ranney Water System will be selected and an estimated construction cost provided as part of the Ranney Hydrogeological Survey, Fluor Inquire NO. k003-0-835504-7JB.

2.2 Alternate surface water intake structures to be evaluated by Fluor shall be the following:

- 2.2.1 Onshore pump-house with deep shaft and tunnel under river to intake structure projecting up thru the river bottom to a velocity cap.
- 2.2.2 Onshore pump-house with shallow shaft and tunnel through the side of the river bank, and above the river bottom, with intake screens.
- 2.2.3 Above water tressel and pump platform with submerged pumps suspended in the river.

The optimum alternate surface water intake structure will be selected and a cost comparison made with the optimum Ranney Water System. Final recommendation will be based on total cost and quality of the water.

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
SOURCE PAGE AT THE FRONT OF THIS REPORT

TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract 835504

STRUCTURAL ENGINEERING STUDY (Continued)

3.0 DELIVERABLE TO TRI-STATE

A formal report that contains the following:

- 3.1 Capital cost estimates.
- 3.2 Operating cost estimates
- 3.3 General descriptions of proposed intake structure.

4.0 SCHEDULE

It is estimated that the proposed work will be completed as follows:

- 4.1 Ranney Water System: 3 months after award of contract (NO. k003-0-835504-7JB).
- 4.2 Alternate Surface water intake structures: 4 months after authorization to proceed.

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract B38804

APPENDIX III

Surface (Raw) Water and Ranney Collector Well  
(Ground) Water Analysis Reports

USE OF ENCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
SOURCE PAGE AT THE FRONT OF THIS REPORT

## WATER QUALITY

During the initial constant rate test in January, 1982, two water samples were taken from the pumping well (PW), one after 3 hours and one after 24 hours of pumping, and sent to an independent laboratory for analysis. In addition, a water sample was obtained from observation wells installed above the clay separating layer (R-2 shallow) and below the clay (R-2 deep), to observe any differences in water quality. In general, the water above this clay layer appeared to be of a slightly better quality with regard to Total Dissolved Solids and, particularly the iron and manganese concentrations. For this reason, and others previously discussed, it was decided to re-install the observation wells and pumping well above the clay layer and perform a second test of the aquifer.

During the second constant rate test, in April, 1982, three water samples were taken from the pumping well at one hour, thirty-one hours and seventy-four hours after pumping began. These samples and one obtained from the Ohio River were submitted to an independent testing laboratory for analysis. The results of these analyses and those conducted during the first test pumping are included in Appendix C for reference. The water quality appears of the calcium-magnesium-bicarbonate type which is fairly typical of ground water along the Ohio River with moderate amounts of iron and manganese. The saturation index of +0.12 indicates a tendency for the water to deposit calcium carbonate, rather than be corrosive. This is further indicated by a generally neutral pH. Past experience has indicated that under long-term pumping at increased pumping rates it is anticipated that concentrations of

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT

some constituents, such as Hardness and Dissolved Solids, can be expected to decrease as increased infiltration is induced from the Ohio River.

Development of a ground water system has many advantages over a surface water supply, some of which include:

1. More uniform physical and chemical water quality with time causing less variance in treatment procedures.
2. Very low in suspended solids generally requiring no filtration or clarification.
3. Warmer water temperature in winter possibly leading to less problems with water line breakages.
4. Cooler water temperatures in the summer.
5. A more protected supply, less susceptible to pollution or contamination.
6. Very low or no harmful bacterial levels in ground water.
7. Because of the adsorptive, ion exchange capacities and slow filtration characteristics of the aquifer, levels of organic chemicals are generally less in ground water than in surface water.

Considering all of the ramifications, a ground water supply appears to be more advantageous especially from an overall quality aspect for the proposed plant. It appears that the ground water supply may require slight additional softening to reduce hardness, however it is anticipated that continued pumping at higher pumping rates may reduce the levels of hardness and several other constituents observed here. Although less softening may be required in treatment of the surface water, extensive clarification processes will be required, especially during periods of high flow in the river with greater sediment loads.

**TRI-STATE SYNFUELS COMPANY**  
Indirect Coal Liquefaction Plant  
Western Kentucky

**FLUOR ENGINEERS AND CONSTRUCTORS, INC.**  
Contract 836804

**SURFACE (RAW) WATER**  
**ANALYSIS REPORTS**


USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

OHIO RIVER  
WATER QUALITY AT SELECTED LOCATIONS

SITE.....	A	B	C	D	E	F	G
SAMPLE DATE....	10/26/79	10/9/81	2/5/81	3/3/78	11/6/78	6/79	6/1/78
Calculated CO <sub>2</sub>	13	6	1	10	3	19	12
Phenol Alkalinity as CaCO <sub>3</sub>	0	0	0	0	0	0	
Total Alkalinity as CaCO <sub>3</sub>	60	90	38	94	82	84	75
Total Hardness as CaCO <sub>3</sub>	166	156	216	420	210	220	135
Carbonate " " "	60	90	38	94	82	84	
Non-Carbonate " " "	106	66	178	326	128	136	
Calcium Hardness as CaCO <sub>3</sub>	106	100	110	160	138	100	
Calcium as Ca	42	40	44	64	55	40	
Magnesium Hardness as CaCO <sub>3</sub>	124	56	106	260	72	120	
Magnesium as Mg	36	16	30	75	21	35	
Chlorides as Cl	23	56	28	55	36	27	20.5
Total Iron as Fe	4.36	.17	2.85	2.30	.11	2.24	
Manganese as Mn	0.11			.67	0.0	.03	
Sulfates as SO <sub>4</sub>	205	95			85		
Zinc as Zn	.03						
Total Dissolved Solids	318				204		
pH	6.87	7.4	7.67	7.21	7.69	6.88	
Carbonate as CO <sub>3</sub>	0		0			0	
Bicarbonate as HCO <sub>3</sub>	90		38			84	
Hydroxides as OH	0		0			0	
Specific Conductance (umhos/cm)	360			345			
Stability Index	7.14	6.81			7.16		

• see attachment 6 for locations

• From Ranney see "Ranney  
Collector well (Ground) Water  
analysis Report dated March 8, 1982



**Directions for use of the computer:**

- A Determine the total miles traveled and the gallons of gas needed to refill tank.
- B Use a straight edge and line-up (connect) both of these figures on the appropriate upper and lower horizontal scales. (The red line illustrates the procedure.)
- C Read off the miles per gallon where the straight-edge line intersects the center diagonal scale.



USE OF SUBSTITUTION OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE SOURCE PAGE AT THE POINT OF THIS REVIEW

The United States, Canada, Puerto Rico, the Virgin Islands, and Bermuda have been divided into more than 122 telephone areas, each identified by a 3 digit Area Code number. In some cases an area code number starts a state boundary. State and province boundaries are shown that follow.

808  
809  
810  
811  
812  
813  
814  
815  
816  
817  
818  
819  
820  
821  
822  
823  
824  
825  
826  
827  
828  
829  
830  
831  
832  
833  
834  
835  
836  
837  
838  
839  
840  
841  
842  
843  
844  
845  
846  
847  
848  
849  
850  
851  
852  
853  
854  
855  
856  
857  
858  
859  
860  
861  
862  
863  
864  
865  
866  
867  
868  
869  
870  
871  
872  
873  
874  
875  
876  
877  
878  
879  
880  
881  
882  
883  
884  
885  
886  
887  
888  
889  
890  
891  
892  
893  
894  
895  
896  
897  
898  
899  
900  
901  
902  
903  
904  
905  
906  
907  
908  
909  
910  
911  
912  
913  
914  
915  
916  
917  
918  
919  
920  
921  
922  
923  
924  
925  
926  
927  
928  
929  
930  
931  
932  
933  
934  
935  
936  
937  
938  
939  
940  
941  
942  
943  
944  
945  
946  
947  
948  
949  
950  
951  
952  
953  
954  
955  
956  
957  
958  
959  
960  
961  
962  
963  
964  
965  
966  
967  
968  
969  
970  
971  
972  
973  
974  
975  
976  
977  
978  
979  
980  
981  
982  
983  
984  
985  
986  
987  
988  
989  
990  
991  
992  
993  
994  
995  
996  
997  
998  
999  
1000

808 Atlantic Time Zone  
809 Eastern Time Zone  
810 Central Time Zone  
811 Mountain Time Zone  
812 Pacific Time Zone

Gulf of Mexico



# THE RANNEY COMPANY

DIVISION OF *Layne*-NEW YORK COMPANY, INC.

Received

NOV 18 1981

*John G. Shipp*

2 NORTH STATE STREET • P. O. BOX 72 • WESTERVILLE, OHIO 43081 • (614) 882-3104

November 13, 1981

Fluor Engineers and Constructors, Inc.  
3333 Michelson Drive  
Irvine, California 92730  
Attention: Mr. John Shipp

RE: RANNEY HYDROGEOLOGICAL SURVEY  
FLUOR CONTRACT NO. 835504-0-K003

Dear John:

We have listed below the results of a water analysis on a sample taken from the Ohio River in the vicinity of Henderson. We are in the process of having a water sample analyzed that was taken from TW-5 at the test drilling site. More representative samples of the local ground water will be obtained and analyzed during the test pumping procedures. The sample was taken June, 1979.

<u>PARAMETER</u>	<u>OHIO RIVER</u>
Calculated CO <sub>2</sub>	19. ✓
Phenol Alkalinity as CaCO <sub>3</sub>	0.
Total Alkalinity as CaCO <sub>3</sub>	84.
Caustic Alkalinity as CaCO <sub>3</sub>	0.0
Carbonate as CO <sub>3</sub>	0.
Bicarbonate as HCO <sub>3</sub>	84.
Hydroxide as OH	0.
Total Hardness as CaCO <sub>3</sub>	220.
Carbonate Hardness as CaCO <sub>3</sub>	84.
Non-Carbonate Hardness as CaCO <sub>3</sub>	136.
Calcium Hardness as CaCO <sub>3</sub>	100.
Calcium as Ca	40.
Magnesium Hardness as CaCO <sub>3</sub>	120.
Magnesium as Mg	35.
Chlorides as Cl	-27.
Total Iron as Fe	2.24
Manganese as Mn	0.03
pH Value	6.88

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

The above results are expressed as mg/l except pH.

I hope this information is helpful. We will have more representative samples analyzed as they become available.

RANNEY COLLECTORS      INTAKE PUMP STATIONS      HYDROLOGIC EVALUATION  
RECHARGE SYSTEMS      LARGE DIAMETER CAISSONS



Fluor Engineers and Constructors, Inc.  
Irvine, California  
Mr. John Shipp


-2-

November 13, 1981

Please let us know if you have any further questions or require any additional information.

Very truly yours,

THE RANNEY COMPANY

  
\_\_\_\_\_  
Henry C. Hunt

HCH/blw

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT

**TRI-STATE SYNFUELS COMPANY**  
Indirect Coal Liquefaction Plant  
Western Kentucky

**FLUOR ENGINEERS AND CONSTRUCTORS, INC.**  
Contract B35504

**RANNEY COLLECTOR WELL (GROUND)**

**WATER ANALYSIS REPORTS**

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



# THE RANNEY COMPANY

DIVISION OF *Layne*-NEW YORK COMPANY, INC.

RECEIVED  
MAY 17 1982  
ATD CONTRACTS DEPT.

2 NORTH STATE STREET • P. O. BOX 72 • WESTERVILLE, OHIO 43081 • (614) 882-3104

May 12, 1982

Fluor Engineers and Constructors, Inc.  
Advanced Technology Division  
Post Office Box C11944  
Santa Ana, California 92711

Attention: Mr. W. Jack Buckamier  
Senior Contracts Engineer

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

REFERENCE: PRELIMINARY REPORT  
DETAILED PUMP TESTING  
FLUOR CONTRACT NO. 835504-0-K004

Gentlemen:

The test pumping procedures at Site 6 have been completed and some preliminary observations presented herein. The survey area tested indicated a very good potential for ground water development and Site 6, in particular, indicated a higher yield under test conditions than most sites along the Ohio River.

In order to develop the preliminary design for a Collector well system in the study area to produce long term reliable yields of 12,000 or 18,000 gallons per minute (gpm), the yield determinations were based on anticipated minimum conditions of low river stage, water temperature and took into account the effect that well interference would have in the system. Utilizing minimum condition values is critical to ensure that the minimum yield requirements can be satisfied at all times.

Under test conditions, the yield from a Collector well at Site 6 would approximate 6,000 gpm. However, under minimum conditions, this yield would be reduced somewhat. The anticipated yields from Collector wells located at the other sites can only be approximated at this time, and are estimated to be slightly less than 6,000 gpm. These yields will be more closely determined following test pumping at each site as construction plans progress.

Based upon these determinations, it appears that a yield of 12,000 gpm can be developed from a system of three Ranney Collector wells. Correspondingly, it appears that a yield of 18,000 gpm can be obtained from a series of five Collector wells. As further testing at the individual sites is accomplished, there exists a possibility that each of these systems can be reduced by one Collector

RANNEY COLLECTORS      INTAKE PUMP STATIONS      HYDROLOGIC EVALUATION  
RECHARGE SYSTEMS      LARGE DIAMETER CAISSONS

Fluor Engineers and Constructors, Inc.  
Mr. W. Jack Buckamier -2-

May 12, 1982

well, as results dictate. For the purpose of system cost comparison, three and five Collector wells should be used and prospective sites (in order of preference) would be: Sites 6, 2, 5, 1 and 4.

\* The estimated cost to design and construct a system to produce 18,056 gpm consisting of five Ranney Collector wells is about \$6,200,000.00, and for a system to produce 12,000 gpm from three Ranney Collector wells, is about \$3,720,000.00. Detailed test pumping at prospective Collector sites is estimated to cost \$65,000.00 per site.

In our previous correspondence of December 18, 1981, we outlined the preliminary design for an intake to produce 18,056 gpm. From present indications, there appears to be sufficient river water depth in the vicinity of Site 3 to retain that site as the tentative Intake location. The estimated cost to design and construct a Ranney Surface Water Intake to produce up to 18,500 gpm is about \$2,200,000.00.

Please find attached copies of the water quality analyses from the samples collected during the recent test pumping procedures. More detailed comments pertaining to these analyses and the anticipated water quality from a Collector well system will be provided in the final report. It is anticipated, from past experiences, that the water produced from a Collector well system can be of a more consistent temperature and quality, potentially resulting in a more simplified water treatment design.

Should you have any questions in this regard, please do not hesitate to contact us. We hope that the information supplied is sufficient for your project planning at this point. More detailed determinations will be included in the final report.

Thank you for this opportunity to be of service.

Very truly yours,

THE RANNEY COMPANY

Henry C. Hunt  
Henry C. Hunt

HCH/blw

Enclosures

$$\begin{aligned} & \left[ \begin{array}{l} 18,056 : 6,200,000 + 5(65,000) = 6,525,000 \\ 12,000 : 3,720,000 + 3(65,000) = 3,915,000 \end{array} \right. \end{aligned}$$

$$\begin{aligned} \text{TOTAL PROJECT COST} &= 1.2 (2,200,000) = 2,640,000 \\ &= 1.2 (6,525,000) = 7,830,000 \\ &= 1.2 (3,915,000) = 4,698,000 \end{aligned}$$

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



**AQUA ASSOCIATES INC.**

*Analytical Chemistry and Bacteriology*

1275 Bloomfield Avenue  
Building 1  
P.O. Box 1251  
Fairfield, N.J. 07006  
(201) 227-0422

N.J. DEP. CERTIFIED LABORATORY #07066

**ANALYSIS REPORT:**

Date 5/5/82  
Laboratory No. B1592W  
Date Sampled 4/27/82  
Location Tri State Synfuels  
Henderson, Kentucky  
Source Pumping well after  
74 hours pumping

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Attn: Henry Hunt

pH	<u>7.1</u> Units	Total Hardness,	<u>360</u> mg/l
Color	<u>0</u> Units	CaCO <sub>3</sub>	
Turbidity	<u>10</u> Units	Calcium Hardness	<u>244</u> mg/l
Conductivity	<u>642</u> Micromhos/ cm.	CaCO <sub>3</sub>	
Total Dissolved Solids	<u>513.6</u> mg/l	Magnesium Hardness	<u>116</u> mg/l
Total Alkalinity,	<u>324</u> mg/l	CaCO <sub>3</sub>	
CaCO <sub>3</sub>		Iron, as Fe	<u>0.56</u> mg/l
Carbonate Alkalinity	<u>0</u> mg/l	Manganese, as Mn	<u>&lt;0.01</u> mg/l
CaCO <sub>3</sub>		Copper, as Cu	<u>0.16</u> mg/l
Bicarbonate Alkalinity	<u>324</u> mg/l	Silica, as SiO <sub>2</sub>	<u>11.3</u> mg/l
CaCO <sub>3</sub>		Nitrate, as N	<u>0.9</u> mg/l
Hydroxide Alkalinity	<u>0</u> mg/l	Saturation Index	<u>+0.12</u>
CaCO <sub>3</sub>			
Chloride, as Cl	<u>6</u> mg/l		
Sulfate, as SO <sub>4</sub>	<u>54</u> mg/l		
Fluoride as F	<u>0.22</u> mg/l		
Phosphate, as PO <sub>4</sub>	<u>0.21</u> mg/l		

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Andrew Pappas Director



**AQUA ASSOCIATES INC.**

*Analytical Chemistry and Bacteriology*

1275 Bloomfield Avenue  
Building 1  
P.O. Box 1251  
Fairfield, N.J. 07006  
(201) 227-0422

N.J. DEP. CERTIFIED LABORATORY #07066

**ANALYSIS REPORT:**

Date 5/6/82  
Laboratory No. 81611W  
Date Sampled 4/24/82  
Location Tri State Synfuels  
Henderson, Kentucky  
Source Pumping Well @ 1 Hour

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Attn: Henry Hunt

pH	<u>7.3</u> Units	Total Hardness,	<u>298</u> mg/l
Color	<u>0</u> Units	CaCO <sub>3</sub>	
Turbidity	<u>11</u> Units	Calcium Hardness	<u>170</u> mg/l
Conductivity	<u>640</u> Micromhos/ cm.	CaCO <sub>3</sub>	
Total Dissolved Solids	<u>512</u> mg/l	Magnesium Hardness	<u>128</u> mg/l
Total Alkalinity,	<u>164</u> mg/l	CaCO <sub>3</sub>	
CaCO <sub>3</sub>		Iron, as Fe	<u>1.24</u> mg/l
Carbonate Alkalinity	<u>0</u> mg/l	Manganese, as Mn	<u>&lt;0.01</u> mg/l
CaCO <sub>3</sub>		Copper, as Cu	<u>0.2</u> mg/l
Bicarbonate Alkalinity	<u>164</u> mg/l	Silica, as SiO <sub>2</sub>	<u>8.4</u> mg/l
CaCO <sub>3</sub>		Nitrate, as N	<u>2.3</u> mg/l
Hydroxide Alkalinity	<u>0</u> mg/l		
CaCO <sub>3</sub>			
Chloride, as Cl	<u>12</u> mg/l		
Sulfate, as SO <sub>4</sub>	<u>44</u> mg/l		
Fluoride as F	<u>0.15</u> mg/l		
Phosphate, as PO <sub>4</sub>	<u>0.26</u> mg/l		

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Andrew Pappe Director  
Andrew Pappe M.S. (Chemistry) M.S. (Civil Engineering)

**AQUA ASSOCIATES INC.**

*Analytical Chemistry and Bacteriology*

1275 Bloomfield Avenue  
 Building 1  
 P.O. Box 1251  
 Fairfield, N.J. 07006  
 (201) 227-0422

N.J. DEP. CERTIFIED LABORATORY #07066

**ANALYSIS REPORT:**

Date 5/6/82  
 Laboratory No. 81594A  
 Date Sampled 4/24/82  
 Location Tri State Synfuels  
Henderson, Kentucky  
 Source Ohio River @ 1 hour

The Ranney Co.  
 P.O. Box 72  
 Westerville, Ohio 43081

Attn: Henry Hunt

pH	<u>7.3</u> Units	Total Hardness,	<u>150</u> mg/l
Color	<u>35</u> Units	CaCO <sub>3</sub>	
Turbidity	<u>54</u> Units	Calcium Hardness	<u>80</u> mg/l
Conductivity	<u>331</u> Micromhos/ cm.	CaCO <sub>3</sub>	
Total Dissolved Solids	<u>265</u> mg/l	Magnesium Hardness	<u>70</u> mg/l
Total Alkalinity,	<u>120</u> mg/l	CaCO <sub>3</sub>	
CaCO <sub>3</sub>		Iron, as Fe	<u>0.12</u> mg/l
Carbonate Alkalinity	<u>0</u> mg/l	Manganese, as Mn	<u>0.3</u> mg/l
CaCO <sub>3</sub>		Copper, as Cu	<u>0.19</u> mg/l
Bicarbonate Alkalinity	<u>120</u> mg/l	Silica, as SiO <sub>2</sub>	<u>6.3</u> mg/l
CaCO <sub>3</sub>		Nitrate, as N	<u>3.4</u> mg/l
Hydroxide Alkalinity	<u>0</u> mg/l		
CaCO <sub>3</sub>			
Chloride, as Cl	<u>22</u> mg/l		
Sulfate, as SO <sub>4</sub>	<u>65</u> mg/l		
Fluoride as F	<u>0.05</u> mg/l		
Phosphate, as PO <sub>4</sub>	<u>0.26</u> mg/l		

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

Andrew Pappachen Director  
 Andrew Pappachen, M.S. (Chemistry) M.S. (Envl. Engineering)



**AQUA ASSOCIATES INC.**

*Analytical Chemistry and Bacteriology*

1275 Bloomfield Avenue  
Building 1  
P.O. Box 1251  
Fairfield, N.J. 07006  
(201) 227-0422

N.J. DEP. CERTIFIED LABORATORY #07066

**ANALYSIS REPORT:**

Date 5/5/82  
Laboratory No. 81593W  
Date Sampled 4/25/82  
Location Tri State Synfuels  
Henderson Kentucky  
Source Pumping Well @ 31 Hrs  
7:00 pm

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Attn: Henry Hunt

pH	<u>7.1</u> Units	Total Hardness,	<u>376</u> mg/l
Color	<u>0</u> Units	CaCO <sub>3</sub>	
Turbidity	<u>11</u> Units	Calcium Hardness	<u>232</u> mg/l
Conductivity	<u>634</u> Micromhos/ cm.	CaCO <sub>3</sub>	
Total Dissolved Solids	<u>507</u> mg/l	Magnesium Hardness	<u>144</u> mg/l
Total Alkalinity,	<u>332</u> mg/l	CaCO <sub>3</sub>	
CaCO <sub>3</sub>		Iron, as Fe	<u>0.3</u> mg/l
Carbonate Alkalinity	<u>0</u> mg/l	Manganese, as Mn	<u>&lt;0.01</u> mg/l
CaCO <sub>3</sub>		Copper, as Cu	<u>&lt;0.01</u> mg/l
Bicarbonate Alkalinity	<u>332</u> mg/l	Silica, as SiO <sub>2</sub>	<u>10</u> mg/l
CaCO <sub>3</sub>		Nitrate, as N	<u>1.0</u> mg/l
Hydroxide Alkalinity	<u>0</u> mg/l		
CaCO <sub>3</sub>			
Chloride, as Cl	<u>10</u> mg/l		
Sulfate, as SO <sub>4</sub>	<u>50</u> mg/l		
Fluoride as F	<u>0.22</u> mg/l		
Phosphate, as PO <sub>4</sub>	<u>0.34</u> mg/l		

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Andrew Pappas Director





# THE RANNEY COMPANY

DIVISION OF *Layne*-NEW YORK COMPANY, INC.

2 NORTH STATE STREET · P. O. BOX 72 · WESTERVILLE, OHIO 43081 · (614) 882-3104

March 8, 1982

*Received*

MAR 11 1982

Fluor Engineers and Constructors, Inc.  
Advanced Technology Division  
Post Office Box C11944  
Santa Ana, California 92711  
Attention: Mr. John Shipp

REFERENCE: GROUND WATER AND RIVER WATER QUALITY  
TRI-STATE SYNFUELS PLANT  
GENEVA, KENTUCKY  
FLUOR CONTRACT NO. 835504-0-K004

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Dear Mr. Shipp:

Please find enclosed graphs regarding water quality trends at locations along the Ohio and Mississippi Rivers as requested. We have also enclosed information regarding Ohio River quality at seven locations along the Ohio (indicated as A-6 on the enclosed map) a price list and analysis schedule from Aqua Associates, Inc., and a schedule of required constituents (Exhibit A) for testing.

The enclosed graphs (Attachments 1-4) illustrate the water quality trends for a Collector well and a test pumping well along the Mississippi River and a series of seven Collector wells along the Ohio River. These graphs depict changes in the ground water quality and the trends indicate that the ground water quality approaches that observed in the adjacent river with time.

The water quality analyses shown in the table as Attachment 5 were obtained from the sites indicated on the location map (Attachment 6), and indicate variations in concentrations of certain parameters; even between stations which are fairly close together. You mentioned that the river water quality data obtained by your Process Department had indicated some variations at sampling stations, both seasonally and otherwise. As we discussed, fluctuations in river water quality have indicated that ground water source can often provide a supply of more consistent quality, facilitating a more fixed treatment system. It is anticipated that levels of turbidity and color observed during preliminary testing will be much lower or eliminated in the final installation.

From the enclosed price list, (Attachment 7) the cost to conduct the complete list

RANNEY COLLECTORS      INTAKE PUMP STATIONS      HYDROLOGIC EVALUATION  
RECHARGE SYSTEMS      LARGE DIAMETER CAISSONS

Fluor Engineers and Constructors, Inc.  
Mr. John Shipp

-2-

March 8, 1982

of analyses listed on Fluor Exhibit A would be in excess of \$400.00. The parameter analyzed on the samples collected during the previous test pumping are identified on the price list as the "Complete Test Package" for \$45.00. These parameters are those generally tested in water sample analyses during similar hydrogeological surveys, and any additional required parameters would be considered an extra to the original contract. Our current schedule for obtaining water samples during the final test pumping is to collect a pumped water sample one hour, twenty-four hours and seventy-two hours after pumping began. One river water sample will also be collected; making a total of four samples to be collected and tested during the final test. Should you desire additional samples to be collected during the test, please advise. We would expect to add a standard fifteen percent mark-up on the cost of additional required analyses to cover our handling costs.

Please let us know if you have any questions in this regard, and please notify us which analyses you would like included during our final testing. We anticipate starting the final test on or before March 17, 1982, site conditions permitting, and completion of field testing procedures by March 26, 1982.

We hope that the weather and river conditions in the next several weeks will be favorable and permit us to complete the field procedures on schedule. We are anxious to complete this phase and prepare our analyses.

Thank you for your assistance in this matter.

Very truly yours,

THE RANNEY COMPANY

*Henry C. Hunt*  
Henry C. Hunt

HCH/blw

Enclosures (Attachments 1-7)

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Time, in WEEKS






Fig. 16 : RIVER / GROUND-WATER HARDNESS CORRELATION .  
City of Quincy, Illinois

USE OR DISSEMINATION OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE SOURCE PAGE OF THE FRONT OF THIS REPORT




- 47 -

Attachment 1



— COLLECTOR WATER  
 - - - MISSISSIPPI RIVER WATER

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT





1949 1950 1951 1952 1953 1954 1955 1956 1957 1958 1959

USE OF ENCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT


MINERAL CHARACTERISTICS  
OF WATER PUMPAGE AND RIVER STAGE  
AT  
HORIZONTAL WATER COLLECTOR  
CENTRAL FIBRE PRODUCTS CO.  
GUNNY, ILLINOIS

Attachment 3

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT



DATE	TEMP.	TURB.	TOTAL SOLIDS	HAZ.	CHL.	CO <sub>2</sub>	Ca	Mg	Fe	Mn	Na+K	Cl	SO <sub>4</sub>	CO <sub>3</sub>	SiO <sub>2</sub>	PHOSPH.	AMMONIA	NITRATES
3-6-23	57	210	95	200	34	800	31	43	27	0.50	12.5							
10-23-24	52	141	100	101	130	2.0	65	47	0.50	0.5								
11-15-24	70	74	61	109	61	750	5.0	30	90	0.10	7.0							



RAHNEY METHOD WATER SUPPLIES, INC.  
 1418 E. 10th St., COLUMBUS, O.  
 BEHAVIOR OF RAHNEY WATER COLLECTORS  
 MOHANA DRILLANCE WORKS  
 CHARLESTON, INDIANA  
 DRAWN BY J.E. APPROVED BY [Signature]  
 DATE - FEB 12, 1937

TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract 835504

ATTACHMENTS 5 & 6

See "Surface (raw) Water  
Analysis Reports"

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Aqua Associates, Inc.  
P.O. Box 1251  
West Caldwell, New Jersey 07006

12011 221-0422  
Attachment 7

ANALYSES AND PRICE LIST

COMPLETE TEST PACKAGE (\$45)

Total Dissolved Solids	Total Hardness, as CaCO <sub>3</sub>
Total Alkalinity, as CaCO <sub>3</sub>	Calcium Hardness, as CaCO <sub>3</sub>
Carbonate Alkalinity, as CaCO <sub>3</sub>	Magnesium Hardness, as CaCO <sub>3</sub>
Bicarbonate Alkalinity, as CaCO <sub>3</sub>	Conductivity
Hydroxides, as OH	Iron, as Fe
Chloride, as Cl ✓	Manganese, as Mn
Sulfate, as SO <sub>4</sub> ✓	Copper, as Cu
Fluoride, as F <sup>-</sup>	Silica, as SiO <sub>2</sub>
Phosphate, as PO <sub>4</sub>	Color, PCS
pH	Turbidity, NTU

ADDITIONAL ANALYSES AVAILABLE

CHEMICAL

<u>Heavy Metals</u>	<u>Price per Analysis (\$)</u>
Aluminum	10.00
Antimony	10.00
Arsenic	15.00
Beryllium	10.00
Barium	10.00
Cadmium	10.00
Calcium	10.00 ✓
Chromium	10.00
Cobalt	10.00
Lead	10.00
Magnesium	10.00 ✓
Mercury	20.00
Molybdenum	10.00
Nickel	10.00
Platinum	20.00
Potassium	10.00
Selenium	20.00
Silver	10.00
Sodium	10.00 ✓
Tin	10.00
Tungsten	15.00
Zinc	10.00

(All metal analyses performed by Atomic  
Absorption Spectrophotometry.)

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



<u>Physical and Inorganic</u>	<u>Price per Analysis (\$)</u>
Saturation Index	15.00
Salinity	5.00
Acidity	5.00
Bromide	10.00
Chlorine Demand	15.00
Cyanide	15.00
Nitrogen, Ammonia	10.00
Nitrogen, Organic	15.00
Nitrite	10.00
Dissolved Oxygen	10.00
Phosphate, Total	10.00
Phosphorous, Total	15.00
Sulfide	10.00
Sulfite	10.00
 <u>Organic</u>	
Grease and Oil	20.00
Organic Volatile Acid	20.00
BOD (Biochemical Oxygen Demand)	15.00
COD (Chemical Oxygen Demand)	15.00
Phenol	15.00
Surfactant (Detergent)	15.00
TOC (Total Organic Carbon)	20.00

Minimum order for additional analyses — \$30.00  
(Without \$45.00 Package Analyses)

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE DESCRIPTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



# THE RANNEY COMPANY

DIVISION OF *Layne*-NEW YORK COMPANY, INC.

2 NORTH STATE STREET • P. O. BOX 72 • WESTERVILLE, OHIO 43081 • (614) 882-3104

February 4, 1982

Fluor Engineers and Constructors, Inc.  
Advanced Technology Division  
Post Office Box C11944  
Santa Ana, California 92711  
Attention: Mr. John Shipp

RECEIVED  
FEB 13 1982  
John G. Shipp

REFERENCE: DETAILED TEST PUMPING  
GENEVA, KENTUCKY  
FLUOR CONTRACT NO. 835504-0-K004  
PROGRESS REPORT

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Dear Mr. Shipp:

Since we are now delayed in the completion of our work by high river conditions, we believe this is an appropriate point to summarize our work to date.

To date, we have constructed one observation well (R-3) at Site 4 and six observation wells at Site 6 plus the conversion of the original test well to an observation well. The pumping well at Site 6 has been installed and a step test and a 24-hour constant rate test run. The site and area appear encouraging from a quantity and quality standpoint, however, the pump test data to date is too inconclusive to accurately compute anticipated well yield at Site 6 (or the other sites) or to finalize design of a Collector well at the site.

The cause of the problem is a geological sequence not previously identified in available investigative reports for the area; whereby the aquifer, while appearing continuous in many holes, is apparently split by a clay layer into two zones. The lower zone, from 106 feet below grade to bedrock, appears less productive and slightly more mineralized, particularly with respect to iron and manganese, than the upper zone, which extends from 60 to 98 feet.

This condition first became apparent as a clay layer observed in logging the test well (R-3) at Site 4. Hoping that the clay layer was site specific, we moved the test to Site 6 and after the installation of two observation wells realized that similar geologic conditions existed at this site. Subsequently, five observation wells and a test pumping well were installed in the lower zone, while a sixth observation well was installed in the upper zone to observe water level differentials between the two zones. Pumping tests were conducted and indicated a differential of over 3 feet between the upper and lower zones. The preliminary indications are that the lower aquifer is of sufficiently low capacity and quality that it should

RANNEY COLLECTORS      INTAKE PUMP STATIONS      HYDROLOGIC EVALUATION  
RECHARGE SYSTEMS      LARGE DIAMETER CAISSONS

Fluor Engineers and Constructors, Inc.  
Mr. John Shipp

-2-

February 4, 1982

not be utilized in the final design.

Consequently, this means that the observation and test pumping wells must be re-set in the upper zone of materials and a second pump test conducted. We had initiated these procedures when high river conditions flooded the work site and delayed our work. We are prepared to resume the testing procedures as river conditions permit. We should complete the second test approximately two weeks after we can return to the site and we will prepare a preliminary letter report one week after testing is complete and a final report three weeks following. We are following river conditions daily and will restart as soon as the site begins to drain. At this writing, the approximate river elevation at Site 6 is 358 feet, MSL and rising (average site ground elevation is 356.0). Current forecasts by the National Weather Service in that area predict the rising river to crest on or about February 7, 1982. We will keep you advised of conditions and updated scheduling in this regard.


We are enclosing water analyses collected during the initial pumping test. We are sorry about the delay, but feel the steps taken have been necessary to provide a thorough, competent, and professional analysis in view of the unexpected, changed site conditions. We are confident that this is the approach you contemplated when the project was awarded and the quality of analysis necessary for your project design. Except for a few days break over the Christmas holidays, work at the project has been continuous; including some double shift and weekend overtime scheduling during the project in an attempt to avoid the high river conditions.

Thank you for your assistance and patience in this matter. We feel that the modifications made during this survey, based upon our field findings, will facilitate a more accurate and comprehensive analysis at the selected site to be utilized in your system planning.

Please let us know if you have any questions in this regard or if we can be of additional assistance prior to submittal of our reports.

Very truly yours,

THE RANNEY COMPANY

  
Henry C. Hunt

HCH/blw

Enclosure

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT

# Aqua Associates, Inc.

Complete Water Sampling and Analysis

P. O. Box 1251, West Caldwell, New Jersey 07006 (201) 227-0422

NEW JERSEY STATE DEPT. HEALTH APPROVED LABORATORY  
Licensed: Water Supply System Operators (W-1)  
Water Treatment Plant Operators (T-1)  
Sewage Treatment Plant Operators (S-1) ✓

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Date: 1/27/82

Laboratory No. 81522W

## WATER ANALYSES REPORT

Sample Taken From: Henderson, Ky.

Source: Well R2 Deep Other \_\_\_\_\_

Date Sample Taken: 1/20/82

PH	<u>7.3</u> Units	Total Hardness, CaCO <sub>3</sub>	<u>312</u> mg/L
Color	<u>20</u> Units	Calcium Hardness, CaCO <sub>3</sub>	<u>196</u> mg/L
Turbidity	<u>30</u> Units	Magnesium Hardness, CaCO <sub>3</sub>	<u>116</u> mg/L
Conductivity	<u>591</u> micromhos/cm.	Iron, as Fe	<u>3.25</u> mg/L
Total Dissolved Solids	<u>473</u> mg/L	Manganese, as Mn	<u>0.5</u> mg/L
Total Alkalinity, CaCO <sub>3</sub>	<u>72</u> mg/L	Copper as Cu	<u>0.01</u> mg/L
Carbonate Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L	Silica, as SiO <sub>2</sub>	<u>1.7</u> mg/L
Bicarbonate Alkalinity, CaCO <sub>3</sub>	<u>72</u> mg/L	Nitrate as N	<u>0.8</u> mg/L
Hydroxide Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L		_____
Chloride, as Cl	<u>0</u> mg/L		_____
Sulfate, as SO <sub>4</sub>	<u>6</u> mg/L		_____
Fluoride as F	<u>0.69</u> mg/L		_____
Phosphate, as PO <sub>4</sub>	<u>0.2</u> mg/L		_____

Andrew Pappachen.  
Andrew Pappachen, Director

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

# Aqua Associates, Inc.

Complete Water Sampling and Analysis

P. O. Box 1251, West Caldwell, New Jersey 07065 (201) 227-0422

NEW JERSEY STATE DEPT. HEALTH APPROVED LABORATORY  
Licensed: Water Supply System Operators (W-1)  
Water Treatment Plant Operators (T-1)  
Sewage Treatment Plant Operators (S-1)

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Date: 1/27/82

Laboratory No. 81523W

## WATER ANALYSES REPORT

Sample Taken From: Henderson, Ky.

Source: Well R2 Shallow Other \_\_\_\_\_

Date Sample Taken: 1/20/82

pH	<u>7.15</u> Units	Total Hardness, CaCO <sub>3</sub>	<u>308</u> mg/L
Color	<u>10</u> Units	Calcium Hardness, CaCO <sub>3</sub>	<u>184</u> mg/L
Turbidity	<u>23.5</u> Units	Magnesium Hardness, CaCO <sub>3</sub>	<u>124</u> mg/L
Conductivity	<u>570</u> micromhos/cm.	Iron, as Fe	<u>1.21</u> mg/L
Total Dissolved Solids	<u>456</u> mg/L	Manganese, as Mn	<u>0.16</u> mg/L
Total Alkalinity, CaCO <sub>3</sub>	<u>64</u> mg/L	Copper as Cu	<u>0.01</u> mg/L
Carbonate Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L	Silica, as SiO <sub>2</sub>	<u>1.8</u> mg/L
Bicarbonate Alkalinity, CaCO <sub>3</sub>	<u>64</u> mg/L	Nitrate as N	<u>0.5</u> mg/L
Hydroxide Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L		_____
Chloride, as Cl	<u>4</u> mg/L		_____
Sulfate, as SO <sub>4</sub>	<u>11</u> mg/L		_____
Fluoride as F	<u>0.7</u> mg/L		_____
Phosphate, as PO <sub>4</sub>	<u>0.1</u> mg/L		_____

*Andrew Pappachen*

Andrew Pappachen, Director

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
INSIDE PAGE OF THE FRONT OF THIS REPORT

1-29-82

# qua Associates, Inc.

Complete Water Sampling and Analysis

P. O. Box 1251, West Caldwell, New Jersey 07006 (201) 227-0422

NEW JERSEY STATE DEPT. HEALTH APPROVED LABORATORY  
Licensed: Water Supply System Operators (W-1)  
Water Treatment Plant Operators (T-1)  
Sewage Treatment Plant Operators (S-1)

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Date: 1/27/82

Laboratory No. 81520W

## WATER ANALYSES REPORT

Sample Taken From: Henerson, Ky.

Source: Well y Other P.W. after 3 Hours pumping

Date Sample Taken: 1/18/82

Color	<u>6.9</u> Units	Total Hardness, CaCO <sub>3</sub>	<u>320</u> mg/L
Turbidity	<u>10</u> Units	Calcium Hardness, CaCO <sub>3</sub>	<u>216</u> mg/L
Conductivity	<u>12</u> Units	Magnesium Hardness, CaCO <sub>3</sub>	<u>104</u> mg/L
Total Dissolved Solids	<u>610</u> micromhos/cm.	Iron, as Fe	<u>0.86</u> mg/L
Total Alkalinity, CaCO <sub>3</sub>	<u>488</u> mg/L	Manganese, as Mn	<u>0.07</u> mg/L
Carbonate Alkalinity, CaCO <sub>3</sub>	<u>68</u> mg/L	Copper as Cu	<u>&lt;0.01</u> mg/L
Bicarbonate Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L	Silica, as SiO <sub>2</sub>	<u>2.2</u> mg/L
Hydroxide Alkalinity, CaCO <sub>3</sub>	<u>68</u> mg/L	Nitrate as N	<u>0.2</u> mg/L
Chloride, as Cl	<u>0</u> mg/L		
Sulfate, as SO <sub>4</sub>	<u>2</u> mg/L		
Fluoride as F	<u>23</u> mg/L		
Phosphate, as PO <sub>4</sub>	<u>0.71</u> mg/L		
	<u>0.22</u> mg/L		

*Andrew Pappachen*  
Andrew Pappachen, Director

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT

# Aqua Associates, Inc.

P. O. Box 1251, West Caldwell, New Jersey 07086 (201) 227-9422

Complete Water Sampling and Analysis

NEW JERSEY STATE DEPT. HEALTH APPROVED LABORATORY  
Licensee: Water Supply System Operators (W-1)  
Water Treatment Plant Operators (T-1)  
Sewage Treatment Plant Operators (S-1)

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Date: 1/27/82

Laboratory No. 81521W

## WATER ANALYSES REPORT

Sample Taken From: Henderson, Ky.

Source: Well x Other P.W. 24 Hours pumping

Date Sample Taken: 1/19/82

pH	<u>7.05</u> Units	Total Hardness, CaCO <sub>3</sub>	<u>332</u> mg/L
Color	<u>0</u> Units	Calcium Hardness, CaCO <sub>3</sub>	<u>216</u> mg/L
Turbidity	<u>7.9</u> Units	Magnesium Hardness, CaCO <sub>3</sub>	<u>116</u> mg/L
Conductivity	<u>615</u> micromhos/cm.	Iron, as Fe	<u>0.78</u> mg/L
Total Dissolved Solids	<u>492</u> mg/L	Manganese, as Mn	<u>0.15</u> mg/L
Total Alkalinity, CaCO <sub>3</sub>	<u>68</u> mg/L	Copper as Cu	<u>&lt;0.01</u> mg/L
Carbonate Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L	Silica, as SiO <sub>2</sub>	<u>2.1</u> mg/L
Bicarbonate Alkalinity, CaCO <sub>3</sub>	<u>68</u> mg/L	Nitrate as N	<u>1.2</u> mg/L
Hydroxide Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L		
Chloride, as Cl	<u>5</u> mg/L		
Sulfate, as SO <sub>4</sub>	<u>21</u> mg/L		
Fluoride as F	<u>0.71</u> mg/L		
Phosphate, as PO <sub>4</sub>	<u>0.09</u> mg/L		

*Andrew Pappachen*  
Andrew Pappachen, Director

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT



# THE RANNEY COMPANY

DIVISION OF *Layne*-NEW YORK COMPANY, INC.

2 NORTH STATE STREET • P. O. BOX 72 • WESTERVILLE, OHIO 43081 • (614) 882-3104

December 31, 1981

Fluor Engineers & Constructors, Inc. (ATD)  
Post Office Box C11944  
Santa Ana, California 92711  
Attention: Mr. John Shipp

REFERENCE: WATER QUALITY ANALYSIS: SITE 6

Dear Mr. Shipp:

Please find attached copy of water analysis for a sample obtained from Site 6, as Attachment A. This sample was obtained using a construction pump in the temporary pumping well installed at site of TH-6.

As we discussed, several of the parameters shown; i.e. color and turbidity, as shown, may be somewhat misleading to your process department. It is anticipated that these two values were recorded artificially high due to iron oxidizing in the water sample prior to testing (the sample was reportedly clear when collected). Water samples from Collector well installations have indicated that color and turbidity values are typically negligible.

It is also anticipated that the concentrations of several other parameters (e.g. iron, hardness) may approach the levels observed in the Ohio River, as the percentage of water induced from the river increases with time. An example of this is shown as Attachment B, which outlines a declining hardness trend with time from a vertical well (PW) and a Ranney Collector well located along the Mississippi River.

I hope this information is useful to your process department. More representative samples will be obtained and analyzed during the test pumping procedures. This information will be contained in our final report under Fluor Contract No. 835504-0-K004.

Please let us know if you have any questions in this regard or desire any further information at this time.

Very truly yours,

THE RANNEY COMPANY

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

*Henry C. Hunt*  
Henry C. Hunt

HCH/blw  
Enclosures

RANNEY COLLECTORS      INTAKE PUMP STATIONS      HYDROLOGIC EVALUATION  
RECHARGE SYSTEMS      LARGE DIAMETER CAISSONS



# Aqua Associates, Inc.

P. O. Box 1251, West Caldwell, New Jersey 07090 (201) 227-9622

Complete Water Sampling and Analysis

NEW JERSEY STATE DEPT. HEALTH APPROVED LABORATORY  
Licensed: Water Supply System Operators (W-1)  
Water Treatment Plant Operators (T-1)  
Sewage Treatment Plant Operators (S-1)

The Ranney Co.  
P.O. Box 72  
Westerville, Ohio 43081

Date: 12/21/81

Laboratory No. 81ARRV

## WATER ANALYSES REPORT

Sample Taken From: Tri State Syn Fuel Henderson, Ky.

Source: Well  Other

Date Sample Taken: 12/21/81

pH	<u>7.1</u> Units	Total Hardness, CaCO <sub>3</sub>	<u>110</u> mg/L
Color	<u>10</u> Units	Calcium Hardness, CaCO <sub>3</sub>	<u>182</u> mg/L
Turbidity	<u>60</u> Units	Magnesium Hardness, CaCO <sub>3</sub>	<u>128</u> mg/L
Conductivity	<u>54</u> micromhos/cm.	Iron, as Fe	<u>5.4</u> mg/L
Total Dissolved Solids	<u>43.3</u> mg/L	Manganese, as Mn	<u>0.12</u> mg/L
Total Alkalinity, CaCO <sub>3</sub>	<u>66</u> mg/L	Copper as Cu	<u>0.15</u> mg/L
Carbonate Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L	Silica, as SiO <sub>2</sub>	<u>2.8</u> mg/L
Non-carbonate Alkalinity, CaCO <sub>3</sub>	<u>66</u> mg/L	Nitrate as N	<u>0.5</u> mg/L
Hydroxide Alkalinity, CaCO <sub>3</sub>	<u>0</u> mg/L		
Chloride, as Cl	<u>3.9</u> mg/L		
Sulfate, as SO <sub>4</sub>	<u>4.9</u> mg/L		
Fluoride as F	<u>1.02</u> mg/L		
Phosphate, as PO <sub>4</sub>	<u>0.41</u> mg/L		

Andrew Pappachan  
Andrew Pappachan, Director

ATTACHMENT #1

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

Time, in WEEKS




Fig. 16 : RIVER / GROUND-WATER HARDNESS CORRELATION .  
City of Quincy, Illinois

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

Attachment B

TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract 835504

SUPPORT MATERIAL

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
INSIDE PAGE AT THE FRONT OF THIS REPORT

TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract 835504

Structural Development Study Number 10  
Ranney Water System Versus Intake Structure

Support Material - Table of Contents

- Appendix A Intake Structure Designed by Fluor including request for Cost Estimate
- Appendix B Cost Estimate for Intake Structure designed by Fluor
- Appendix C River Stage Data and U. S. Army Corps of Engineers Ohio River Profiles
- Appendix D Permit Applications from U. S. Army Corps of Engineers
- . Barge Facility design sketches
  - . Pipeline design sketches
  - . Water Intake design sketches
- Appendix E Ranney Water System - Preliminary Design Criteria and Budget Cost Estimates
- Appendix F Rough Order of Magnitude Estimate of Installed and Operating Cost on Raw Water Treatment System versus Ground Water Treatment System

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

TRI-STATE SYNFUELS COMPANY  
Indirect Coal Liquefaction Plant  
Western Kentucky

FLUOR ENGINEERS AND CONSTRUCTORS, INC.  
Contract 835504

APPENDIX A

Intake Structure Designed By Fluor  
Including Request for Cost Estimate

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

↓ FLUOR

INTEROFFICE CORRESPONDENCE

To: MIKE NORMAN

Date: July 28, 1981

Location: AT2-D1-V9

Reference: 835504-SO

From: J. G. SHIPP

Client: Tri-State

Location: AT2-D1-E12

Subject: WATER INTAKE STRUCTURE  
COST ESTIMATE

Please provide a cost estimate for the attached water intake structure and summary as follows:

<u>ITEM</u>	<u>DESCRIPTION</u>	<u>VOLUME</u>	<u>COST CRITERIA</u>	<u>TOTAL COST</u>
Pump House	Concrete	27.2 CY		
	Concrete Block	1659		
	Roof			
	W8x21	1890 lb.		
	W8x15	1350 lb.		
	Deck	900 S.F.		
	Builtup roof	707 S.F.		
	Steel Reinf.			
	# 8	2808 L.G.		
	# 5	1404 L.F.		
Concrete Cassion	Structure Above Elevation 381'			
	Concrete	341.3 CY		
	Excavation	465.4 CY		
6' Diam. Jacked Pipe	Steel Reinf. #9	31,862 L.F.		
	From Elev. 381' to Elev. 305' 20' O.D. W/Conc. Plug in bottom			
6' Diam. Jacked Pipe	6' Diam Concrete Pipe	370 L.F		
	Excavation	387.5 CY		
	Materials to Jack through (Length=370')			
	1. Little Resistance			
2. Moderate Resistance				
3. Firm Resistance				

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

▼ FLUOR

INTEROFFICE CORRESPONDENCE CONTINUATION

July 28, 1981

<u>ITEM</u>	<u>DESCRIPTION</u>	<u>VOLUME</u>	<u>COST CRITERIA</u>	<u>TOTAL COST</u>
Velocity Cap	Concrete	17.3 CY		
	.25" Screen	144 S.F.		
	12' -0 Square Box on River Bottom			
	1. Construction Cost of Coffar			
	2. Cost of Structure			
Electrical	See Item A			134,000
Pumps & Motors	See Item B	2 units @ \$136.807 each		273,614
Total Cost of water Intake Structure				

If you have any questions please contact me on ext. 5097  
Please arrange to return estimate by August 28, 1981.

*JGShipp*  
J. G. Shipp


JGS/pp

attachments

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

FLUOR  
 CALCULATIONS and SKETCHES

DATE 7-7-51  
 CONT. NO. 833-04  
 BY J.H. CHK'D  
 SHEET NO. 5K-1



USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

FORM 8-550 Rev. 4/59  
 PRINTED IN U.S.A.




↓ FLUOR  
CALCULATIONS and SKETCHES

DATE 7-7-51  
CONT. NO. X 3:537  
BY J.H. CHK'D  
SHEET NO. 24-2

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

FORM E-200 REV. 4/49  
PRINTED IN U.S.A.



USE OF DISCREETION OF ENGINEER  
AND NO LIABILITY FOR THIS DRAWING

N. P. EL. 342

L. N. EL. 325

To ← L. 319' (319' - 319')

EL. 319'

2.5" SCREEN

RIVER B. M. EL. VARIES  
(316'-318')

CONCRETE BOX

1'-0" TYR


12' FR. SIDE

CONCRETE PIPE  
6' DIAM.

FLUOR  
 CALCULATIONS and SKETCHES

DATE 7-7-81  
 CONT. NO. 835587  
 BY [Signature] CHK'D  
 SHEET NO. S1-3

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



1/2" TYPE A INEPCO  
 STEEL DECK  
 22 GA.  
 (TYP).....

PLAN 1.00 - 1st floor

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT


↓ FLUOR  
 CALCULATIONS and SKETCHES

DATE 7-7-51  
 CONT. NO. 835530  
 BY F. F. CHK'D  
 SHEET NO. 5A-4


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32

FORM 8-66 REV. 4/69  
 PRINTED IN U.S.A.



PLAN SLAB (Pump house)



SECTION A-A

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29


↓ FLUOR  
CALCULATIONS and SKETCHES

DATE 7-7-81

CONT. NO. 830.02

BY T.H. CHK'D

SHEET NO. SK-5



SECTION B-B.

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

6'6" 0"

FORM E-880 REV. 4/88  
PRINTED IN U.S.A.

▼ FLUOR  
CALCULATIONS and SKETCHES

DATE 8-13-81  
CONT. NO. 835304  
BY JEP CHK'D  
SHEET NO. 1 of 2

MATERIAL TAKEOFF

ITEM		Unit	Volume
CONCRETE CASSIONS	$[\frac{\pi(22')^2}{4} - \frac{\pi(18.33')^2}{4}] [3.81 - 3.05] / 27$	CY	327.2
Plug	$[\frac{\pi(22')^2}{4} (2')] / 27$	CY	14.1
FLOOR SLAB	$[\frac{\pi(30')^2}{4} \times 1'] / 27$	CY	26.2
Columns	$[\frac{\pi(1.5')^2}{4} \times 15'] / 27$	CY	1.0
INTAKE SCREEN	$[2(12 \times 9 \times 1) + 2(10 \times 9 \times 1) + (10 \times 10 \times 1) - (\frac{\pi(6')^2}{4} \times 1)] / 27$	CY	17.3
PIPE (6' DIAM)	144	SF	144
		LF	370'
Excavation CASSIONS	$[\frac{\pi(20')^2}{4} \times 40'] / 27$	CY	465.4
6' DIAM PIPE	$[\frac{\pi(6')^2}{4} \times 370'] / 27$	CY	387.5
CONCRETE BLOCK (8" x 8" x 16")	1474.4 SF / .88 SF BLOCK	unit	1659
ROOF			
WBX21	6 @ 15' : 6 x 15 x 21	lb.	1890 ✓
WBX15	12 @ 9.5' : 12 x 7.5 x 15	lb.	1350 ✓
DECK	TYPE: INRYCO 1 1/2" - A - 22 ga.		
	30 x 30	SF.	900 ✓
Built up Rod	$\pi(30')^2 / 4$	SF	707 ✓
STEEL REINFC. SLAB			
	#8 - 26 x 54 x 2	LF	2808 ✓
	#5 - 26 x 27 x 2	LF	1404 ✓

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

FORM 8-88-1  
 PRINTED  
 100

▼ FLUOR  
CALCULATIONS and SKETCHES

DATE \_\_\_\_\_  
 CONT. NO. 885500  
 BY J.E.H. CHK'D \_\_\_\_\_  
 SHEET NO. 2 of 2

		<u>Unit</u>	<u>Total</u>
<u>STEEL REINFORCING</u>			
<u>CASSION</u>	HORIZONTAL #9: $153 \times [2\pi(11.66 + 10.17)]$ VERTICAL #9: $[68 \times 80] \times 2$	LF. LF.	20,982 ✓ 10,850 ✓

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29

L I E A I I T

Final Estimate  
per [unclear] Station

TR 5152  
July 20, 1961  
ED COOK


INCOMING LINE  
NOT INCLUDED IN ESTIMATE

OCB  
(ON CIRCUIT BREAKER)

2000KVA  
69-4.16KV  
BUS DUCT.

OUTDOOR

INDOOR




ONE LINE [unclear]



SPACE

HPS LT'S

25'-0"



USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

PLAN

ITEM (A)

Elec. Est.  
pumping station

The State  
July 23, 1951

Rough Estimate Only  
Based on similar figures for Hampshire

Major Equip.	100,000.-
Sw. G1.	
X- form.	
O.C.B.	
etc.	
Minor Equip.	6000.-
G's.	
Weggs.	
etc.	
Sub Total	106,000.-

Man hours for  
Installation  
800 hrs.

800 hrs x \$35 / hrs = 28000.-  
TOTAL 134,000.-\*

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

\* Estimate assumes power comes from utility source at the  
pumping station & not from other plant switch yard



ITEM (13)

Back cover - Information - See Page 10

<u>HP</u>	<u>Voltage</u>	<u>Phase</u>	<u>Enclosure</u>
1/2 → 700	460V	3	TEFC
750 → 1000	4160V	↓	WP-I
APPROX 1000	17.8 kV @ 460V	↓	WP-II

Break HP.

No. 70. 25 - Who ever you  
 Flow - 18,000 GPM  
 T.D.H. = 137 feet

AT 2-D1-E16  
 James Harris  
 Y5095

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

- 1 operating
- 1 spare
- 36" Goulds
- vertical turbine type
- to - like arrangement or enclosed
- line shaft
- bottom support req'd.

PRICE

<u>ITEM</u>	<u>AMT</u>
PUMP	81,909
MOTOR	54,898
total length	66'
STRAIGHT	
EXP. PACK	-
TOTAL EACH	\$136,807
QUANTITY	# 2
TOTAL	\$273,614
715-81 D. Walker	
EXP	778
NETTC	80%
CONTAINING WATER	No
Goulds - VIT	
36CHL 880 RPM	
NPSHR ~ 27'	
DELIVERY ~ 40 wks.	
MOTOR ~ 900 H.P.C	
900 RPM.	
MATL ~ C.I./BRZ.	

4 FLUOR  
INFO-MEMO

TO: JOHN SHIPP. DATE: 8/17/81  
ACTION: AT2-D1-E12 REFERENCE: 835504-SO.  
FROM: BOB CUSTOMER: TRI-STATE  
LOCATION: A4-1-101 (975-3628) SUBJECT: PUMP HOUSE

JOHN:

ENCLOSED - MY IDEAS ON PUMP HOUSE & INTAKE  
INSTALLATION FOR COMMENTS

ANY CHANGES, QUESTIONS ETC. GIVE ME A CALL.  
ESTIMATE TO FOLLOW LATER.

SIGNED: BOB SEEDS.

PLEASE REPLY HERE

TO: DATE:

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

SIGNED:

NOTE: INDIVIDUAL ORIGINATING MEMO RETAINS THIRD COPY.  
FORWARDING FIRST AND SECOND.  
ADDRESSEE REPLIES AND RETURNS ORIGINAL TO ORIGINATOR.

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

### FLUOR CALCULATIONS and SKETCHES

DATE 2/16/81  
CONT. NO. 235221-50  
BY SEAP CND  
SHEET NO. 1 OF 3


**TRI-STATE**

## WATER INTAKE STRUCTURE

01  
02  
03  
04  
05  
06  
07  
08  
09  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29

A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

FORM 480U REV. 4/80  
PRINTED IN U.S.A.



### CONSTRUCTION PLAN

#### PUMP HOUSE

1. BENCH BANK TO EL 345± TO PROVIDE FLAT AREA FOR CONSTRUCTION EQUIP.
2. DRIVE SHEET PILES TO ELEV. 293±
3. EXCAVATE INSIDE SHEET PILES W/ CRANE & BUCKET
4. PLACE 2' C.R. BED (CONT. DEWATERING ROAD DURING CONST PERIOD)
5. PLACE 20' Ø CASSON & PUMP HOUSE (CASSON CAST-IN-PLACE, SLIP FORM OR JUMP FORM)
6. PULL SHEET PILES & BACK FILL

#### G1 INTAKE LINE

ASSUME PIPE WILL BE JACKED FROM INTAKE BOX TO PUMP HOUSE.

#### AT INTAKE

- (BARGE MOUNTED EQUIPMENT)
1. DRIVE SHEET PILES TO ELEV 299±
  2. EXCAVATE TO EL 309-2'
  3. PLACE 2' C.R. BED.
  4. JACK G1 PIPE TO PUMP HSE 370'
  5. PLACE CONC. INTAKE BOX
  6. BACK FILL TO EL 318±
  7. PULL SHEET PILES
  8. PLACE FILTER CLOTH & RIP-RAP.

NOTE EXCAVATION  
A. BACKFILL ETC.  
BY BARGE MOUNTED  
CRANE & BUCKET  
ABOVE ASSUMES  
THAT ALL EXCAVATED  
MATERIAL IS EARTH  
NO ROCK

FLUOR

CALCULATIONS and SKETCHES

DATE 3/16/81

CONT. NO. 835504-50

BY SEARS CHK'D

SHEET NO. 2 of 3

TRI-STATE

WATER INTAKE STRUCTURE

PUMP HOUSE STRUCTURE

EXCAVATION

BENCH ASSUME 100' x 5' DEEP AVG :  $100' \times 5' / 27 = 1852$

1850 CY

CAISSON  $0.7854(36^2)(44')/27 = 1659$

1660 CY

CRUSHED ROCK BED  $0.7854(36^2)(2)/27 = 75$

75 CY.

SHEET PILES  $36\pi \times 52 = 5881' \times 38PF / 2000 = 111.7'$

118.0 TON.

BACKFILL  $0.7854(36^2 - 23.7^2) 44' / 27 = 939$   
(57655)

940 CY.

CONCRETE

PUMP HSE FLOOR  $0.7854(30^2)(1) / 27 = 26.2$  CY

26.2 CY.

CAISSON  $21.83\pi(1.83) / 27 = 4.65$  CY/LF  $\times 78' = 362.7$  CY

362.7 CY

BOTTOM PLUG  $0.7854(20^2)(2) / 27 = 23.3$  CY

23.3 CY

PUMP HOUSE  $(0.7854(30^2) = 7075F$

ROOF 3 PLY COMPO & GRAVEL

7075F

2" RIGID BOARD INSULATION

7075F

1/2" x 22GA STEEL DECK

7075F

GRAVEL STOP 30π

95LF

ROOF STEEL W8x21  $\frac{30}{2} \sim 90LF \times 21$

1890

W8x15  $\frac{12}{3} \sim 36 \times 15$

1440

CENTER POST 6" SCH 40 PIPE 16' x 19LF

300

CAP R - 2' x 1/2" R  $0.7854(2^2)(20.4PSF)$

64

BASE R 12" x 1/2" R

16

3710  
370  
4080  
1100%

2.0 TONS

WALLS 8" CONC BLOCK  $30\pi \times 16' = 1508F$

1510SF

LIGHTING

7075F

HVAC

7075F

DOOR PR 6' x 7'

1 EA.

ENTRANCE STAIRS (36' VERT) (ALLOW)

2 TON.

LANDING SAY. 5' x 10' x 25PSF

1.3 TON

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

FORM E-680  
PRINTED IN U.S.A.  
4/80

TRI-STATE

WATER INTAKE STRUCTURE

INTAKE


1	EXCAVATION	$20'(60')(318-30)/27 = 489 \text{ cy}$	490 cy
2	SHEET PILES	$2(20+60) = 160 \text{ LF} \times 46' = 7360 \text{ SF} \times 28 \text{ PSF} / 2000 = 1328$	140 TONS
3	CRUSHED ROCK BED	$20(60)(2)/27 = 88.9$	90 cy
4	BACKFILL	$490 - 90 - [(21^2)(10^3)/27] = 347 \text{ cy}$	350 cy
5	INTAKE SILT PROTECTION (AROUND CONC INLET BOX)	$75' \times 75' = 5625 \text{ SF}$	
6	FILTER CLOTH	$72^2 - 12^2 = 5040 \text{ SF} + 10\% \text{ LAPS}$	5500 SF
7	RIP-RAP	$5040 \text{ SF} (1)/27 = 187 \text{ cy}$	190 cy

CONCRETE

11	INLET BOX WALL	$44 \times 10 \times 1 = 440$	} $584 / 27 = 21.6 \text{ cy}$	21.6 cy
12	BOTT	$12^2 \times 1 = 144$		

STEEL COVER - 10.5' SQ = 110 SF

1" MESH SCREEN



6" PRESTRESSED PIPE (JACKED IN PLACE) 370 LF

6" ID x 5 1/4" WALL 1623 PLF (AMERON)  $1623 \text{ PLF} (370') / 2000 = 300 \text{ T}$

NOTE EXCAVATION ASSUMED PER EXCAVATION (SURRY) DETAIL (SH #1) PUMP INTO POND @ INTAKE END OR PUMP TO SHORE

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

**TRI-STATE SYNFUELS COMPANY**  
Indirect Coal Liquefaction Plant  
Western Kentucky

**FLUOR ENGINEERS AND CONSTRUCTORS, INC.**  
Contract 835504

**APPENDIX B**

**Cost Estimate for Intake Structure  
Designed by Fluor**

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



INFO-MEMO

TO: JOHN SHIPP DATE: 8-26-81  
 ATTENTION: AT2-D1-E12 REFERENCE:  
 FROM: DON HARRIS CUSTOMER: TRI STATE FUELS  
 LOCATION: AT2 D1 V10 SUBJECT:

THE COMPLETE SELL PRICE FOR  
THE WATER INTAKE STRUCTURE, INCLUDING  
SUB CONTRACTED CONSTRUCTION, FIELD SUPERVISION  
AND QC AND HOME OFFICE ENGINEERING  
IS \$1,751,000.

LET ME KNOW IF YOU HAVE  
FURTHER QUESTIONS

SIGNED Don R Harris

PLEASE REPLY HERE

TO: \_\_\_\_\_ DATE: \_\_\_\_\_

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTIONS ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT

SIGNED \_\_\_\_\_

NOTE - INDIVIDUAL ORIGINATING MEMO RETAINS THIRD COPY, FORWARDING FIRST AND SECOND.  
 ADDRESSEE REPLIES AND RETURNS ORIGINAL TO ORIGINATOR.

# COST ESTIMATE

▼ FLUOR

CLIENT TRI-STATE SPINNELS DESCRIPTION WATER INTAKE PROP. NO. \_\_\_\_\_  
 LOCATION HENDERSON, KY STRUCTURE W.O. NO. \_\_\_\_\_  
 PROJECT COAL GASIFICATION PLANT CONT. NO. 835504 MADE BY BF  
 APPROVED BSC

A/C NO.	ITEM & DESCRIPTION	MANHOURS	ESTIMATED COST			
			LABOR	SUB-CONTRACTS	MATERIALS	TOTAL
	COMPLETE WATER INTAKE, STD INCL. PUMP HSE CASING, JACKED PIPE, VELOCITY CAISSONS, ELECTRIC PUMPS & MOTORS			1268 000		1268 000
	CONST. SUP. O.C. CONTRACT ADMIN COSTS INCURRED	2240	33 600			33 600
	<b>DIRECT FIELD COSTS</b>		33 600	1268 000		1301 600
90-00	International Expense					
91-00	Temporary Construction Facilities					
92-00	Constr. Services, Supplies & Expense					
93-00	Field Staff, Subsistence & Expense					33 600
94-00	Craft Benefits, Payroll Burdens & Insur.					
95-10	Equipment Rental					
95-50	Small Tools					
99-40	Field Staff Overhead Costs					
	<b>INDIRECT FIELD COSTS</b>					33 600
	<b>TOTAL FIELD COSTS</b>					1335 200
96-00	Home Office Construction					
	Project Engineering					
	Process Engineering					
	Design					
	Purchasing					
	Business Services					
97-00	Office Expense	1773				
98-00	Office Payroll Burdens	DFC				
99-50	Office Overhead Costs					
	<b>TOTAL OFFICE COSTS</b>					221 272
	<b>TOTAL FIELD &amp; OFFICE COSTS</b>					1556 472
99-30	Sales Tax					
99-10	Escalation					
99-20	Contingency 10%					155 647
	<b>TOTAL</b>					1712 119
99-50	Fee					38 912
	<b>TOTAL PROJECT</b>					1751 031
				549		1175.1 000

USE OF DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE HOME PAGE AT THE FRONT OF THIS REPORT

PRINTED IN



CLIENT: IRI STATE

# CONSTRUCTION COSTS

1 FLOOR

LOCATION: HENDERSON KY

WATER INTAKE STRUCTURE

C.O. NO. \_\_\_\_\_ JOB NO. 8355-21

PROJECT: COAL GASIFICATION PLANT

## SUMMARY

MADE BY SEARS APVD. \_\_\_\_\_

A/C NO.	ITEM & DESCRIPTION	QUAN.	UNIT	MANHOURS			COST UNIT			COSTS ( )				
				PER UNIT	TOTAL	RATE	LABOR	SUB CONTR.	MAT'L	LABOR	SUB CONTRACT	MATERIAL	TOTAL	
	<u>SUMMARY</u>													
	STRUCTURE ABOVE ELEV 381 (PUMP HOUSE)												48000	
	CONCRETE CAISSON												334000	
	8' JACKETED PIPE												333000	
	VELOCITY CAP												145000	
	ELECTRICAL												134000	
	PUMPS & MOTORS												274000	
													1,268,000	

USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT.

CLIENT KY STATE

CONSTRUCTION COSTS

FLOOR

LOCAT. HENDERSON KY

WATER INTAKE STRUCTURE

C.O. NO. \_\_\_\_\_ JOB NO. 835504

PROJECT COAL GASIFICATION PLANT

STRUCTURE ABOVE EL 381

MADE BY SMBS APVD. \_\_\_\_\_

A/C NO.	ITEM & DESCRIPTION	QUAN.	UNIT	MANHOURS			COST/UNIT			COSTS ( )				
				PER UNIT	TOTAL	RATE	LABOR	SUB CONTR.	MAT'L	LABOR	SUB CONTRACT	MATERIAL	TOTAL	
	30' X 16' HIGH PUMP HOUSE	~	107	SF										
	<u>ROOF</u>													
	4 PLY COMPO & GRAVEL	107	SF					100				710		
	2" RIGID BOARD INSULATION	107	SF					080				570		
	1/2" x 22GA GALV STEEL DECK	107	SF					170				1200		
	GRAVEL STOP	95	LF					500				480		
	ROOF STEEL (LIGHT)	2.0	TON					2000				4000		
	<u>WALLS</u>													
	8" REINF CONC. BLOCK	1510	SF					600				9060		
	FLOOR SLAB (ELEVATED)													
	STRUCTURAL CONCRETE	26.2	CY					600				15720		
	ENTRANCE DOOR PR 6' X 7'	1	EA					600				600		
	DO STAIRS STEEL	2	TON					2200				4400		
	DO LANDING DO 5' X 10'	1.3	TON					2200				2860		
	<u>PAINTING</u>													
	CONC. BLOCK 1 SEAL 2 FINISH 3 COAT	3020	SF					065				1960		
	STR STEEL 2+2+1.3 2 COAT	5.3	TON					130				690		
	<u>ELECTRICAL LIGHTING</u>													
	HVAC (WALL UNITS)	107	SF					500				3540		
		2	EA					800				1600		
												47390		
										SAY		48000		
	$\$ 48000 / 107 \text{ SF} = \$ 6790 / \text{SF}$													

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

CLIENT TRI-STATE

**CONSTRUCTION COSTS**

FLUOR

LOCATI HENDERSON KY.

WATER INTAKE STRUCTURE  
CAISSON - EL 305 TO 331'

C.O. NO. \_\_\_\_\_ JOB NO. 835504

PROJECT COAL GASIFICATION PLANT

MADE BY SEARS APVD. \_\_\_\_\_

A/C NO.	ITEM & DESCRIPTION	QUAN.	UNIT	MANHOURS			COST/UNIT			COSTS ( _____ )				
				PER UNIT	TOTAL	RATE	LABOR	SUB CONTR.	MAT'L	LABOR	SUB CONTRACT	MATERIAL	TOTAL	
	CAISSON 20' I.D. X 1'-0" WALL X 8' LONG													
	<u>EXCAVATION</u>													
	CUT BENCH (BULL DOZER)	1850	CY					3.00				5550		
	CAISSON PIT (CLAMSHELL)	1660	CY					5.50				9130		
	BACKFILL (COMP. 8" LIFTS)	940	CY					6.80				6380		
	CRUSHED ROCK BED	75	CY					10.00				750		
	SHEET PILES PZ35 (5900SF) (DRIVE, PULL & SALVAGE)	118	TON					4.00				47200		
	SHEET PILE WALERS	47200	#					2.0%				9440		
	<u>CONCRETE</u>													
	CAISSON 20' I.D. X 1'-0" WALL X 78'	363	CY					6.00				217.800		
	BOTTOM PLUG 20' Ø X 2' THK	24	CY					6.00				14,400		
	PUMPING PIT. ALLOW	3	Mo					6000				18000		
	MOBILIZATION & DEMOB	ALLOW										5000		
												333660		
										USE		334,000		

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE COVER PAGE AT THE FRONT OF THIS REPORT

LOCATI HENDERSON KY

WATER INTAKE STRUCTURE

C.O. NO. \_\_\_\_\_ JOB NO. 835504-5

PROJECT COAL GASIFICATION PLANT .. 6" CONCRETE PIPE INLET

MADE BY SEARS APVD. \_\_\_\_\_

A/C NO.	ITEM & DESCRIPTION	QUAN.	UNIT	MANHOURS			COST/UNIT			COSTS ( _____ )				
				PER UNIT	TOTAL	RATE	LABOR	SUB CONTR.	MAT'L	LABOR	SUB CONTRACT	MATERIAL	TOTAL	
	CONCRETE PIPE WATER INTAKE (JACKED INTO PLACE)													
	6' I.D. CONCRETE PIPE	370	LF					900			333,000			

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

CLIENT CI-STATE  
 LOCATIC HENDERSON KY  
 PROJECT COAL GASIFICATION PLANT

**CONSTRUCTION COSTS**  
**WATER INAKE STRUCTURE**  
**VELOCITY CAP**

C.O. NO. \_\_\_\_\_ JOB NO. 835504-S  
 MADE BY SEARS APVD. \_\_\_\_\_

A/C NO.	ITEM & DESCRIPTION	QUAN.	UNIT	MANHOURS			COST/UNIT			COSTS ( )		
				PER UNIT	TOTAL	RATE	LABOR	SUB CONTR.	MAT'L	LABOR	SUB CONTRACT	MATERIAL
	<b>VELOCITY CAP - WATER INLET</b>											
	<b>EXCAVATION</b>											
	INSIDE SHEET PILES (CLAMHELL)	490	CY					550				2700
	CRUSHED ROCK BED	90	L					1000				900
	BACKFILL (COMP 3" LIFTS)	350	L					680				2380
	SHEET PILES P238 (7360 SF)	140	TON					400				56000
	DRIVE, PULL & SALVAGE SHEET PILE WALKERS	56M	\$					20%				11200
	<b>WATER INLET - SILT PROTECTION</b>											
	FILTER CLOTH	5500	SF					030				2750
	RIP-RAP	190	CY					40				7600
	CONCRETE INLET BOX	22	CY					600				13200
	12' x 10' HIGH WALLS											
	INLET BOX COVER (110 SF)	1	EA									2200
	2" GARY GRATING W/ 1/4" MESH SCREEN											
	PUMPING PIT (ALLOW)	3	MO					6000				18000
	MOBILIZATION & DEMOS	ALLOW										5000
	<b>MISCELLANEOUS</b>											
	BARGE RENTAL \$3000/MO	3	MO					6000				18000
	1 CRANE 1-MO TR = 2 EA											
	CREW BOAT	3	MO					1000				3000
	DIVER \$250/DAY	10	DAYS					250				2500
	NOTE: ABOVE ASSUMES THAT 6" CONG. PIPE WILL BE JACKED FROM THIS END											
												145,430
									USE			145,000

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE PRICE PAGE AT THE FRONT OF THIS REPORT

FLUOR

CALCULATIONS and SKETCHES

DATE 8/16/81

CONT. NO. 835504-50


BY SEARS CHK'D

SHEET NO. 1 OF 3

TRI-STATE

WATER INTAKE STRUCTURE

11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36



CONSTRUCTION PLAN

PUMP HOUSE

1. BENCH BANK TO EL 345± TO PROVIDE FLAT AREA FOR CONSTRUCTION EQUIP.
2. DRIVE SHEET PILES TO ELEV. 299±
3. EXCAVATE INSIDE SHEET PILES W/ CRANE & BUCKET.
4. PLACE 2' C.R. BED (CONT. DEWATERING BED DURING CONST PERIOD)
5. PLACE 20'Ø CAISSON & PUMP HOUSE (CAISSON CAST-IN-PLACE, SLIP FORM OR JUMP FORM)
6. PULL SHEET PILES & BACK FILL

6"Ø INTAKE LINE

ASSUME PIPE WILL BE JACKED FROM INTAKE BOX TO PUMP HOUSE:

AT INTAKE

- (BARGE MOUNTED EQUIPMENT)
1. DRIVE SHEET PILES TO ELEV. 299±
  2. EXCAVATE TO EL 309-2'
  3. PLACE 2' C.R. BED.
  4. JACK 6" PIPE TO PUMP HSE 370'
  5. PLACE CONC. INTAKE BOX
  6. BACK FILL TO EL 318±
  7. PULL SHEET PILES
  8. PLACE FILTER CLOTH & RIP-RAP

NOTE EXCAVATION & BACKFILL ETC. BY BARGE MOUNTED CRANE & BUCKET.

ABOVE ASSUMES THAT ALL EXCAVATED MATERIAL IS EARTH - NO ROCK.

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

FORM E-400 PRINTED IN U.S.A.

↓ FLUOR

CALCULATIONS and SKETCHES

DATE 5/16/81

CONT. NO. 836504-50

BY SEARS CNK'D

SHEET NO. 2 OF 3

TRI-STATE

WATER INTAKE STRUCTURE

PUMP HOUSE STRUCTURE

EXCAVATION

BENCH ASSUME 100'Ø x 5' DEEP AVG  $100^2 \times 5' / 27 = 1852$

1850 CY

CAISSON  $0.7854(36^2)(44') / 27 = 1659$

1660 CY

CRUSHED ROCK BED  $0.7854(36^2)(2) / 27 = 75$

75 CY.

SHEET PILES  $30\pi \times 52 = 5881\text{SF} \times 38\text{PF} / 2000 = 111.7\text{T}$

118.0 TON.

BACKFILL  $0.7854(36^2 - 23.7^2) 44' / 27 = 939\text{CY}$   
(5765SF)

940 CY.

CONCRETE

PUMP HSE FLOOR  $0.7854(30^2)(1) / 27 = 26.2\text{CY}$

26.2 CY.

CAISSON  $21.83\pi(1.83) / 27 = 4.65\text{CY/LF} \times 78' = 362.7\text{CY}$

362.7 CY

BOTTOM PLUG  $0.7854(20^2)(2) / 27 = 23.3\text{CY}$

23.3 CY

PUMP HOUSE  $(0.7854(30^2)) = 707\text{SF}$

ROOF 4 PLY COMPO & GRAVEL

707 SF.

2" RIGID BOARD INSULATION

707 SF.

1 1/2" x 22GA STEEL DECK

707 SF.

GRAVEL STOP 30π

95 SF.

ROOF STEEL W8 x 21  $\frac{30}{2} \sim 90\text{LF} \times 21$  1820

W8 x 15  $\frac{12}{2} \sim 96 \times 15$  1440

CENTER POST 6" SCH 40 PIPE 16' x 19PLF 300

CAP R - 2"Ø x 1/2" R 0.7854(2^2)(20.4PSF) 64

BASE R 12"Ø x 1/2" R 16

3710 SF  
370  
4080 SF  
+100%

2.0 TONS

WALLS 8" CONC BLOCK  $30\pi \times 16' = 1508\text{SF}$

1510 SF.

LIGHTING

707 SF.

HVAC

707 SF.

DOOR PR 6'0" x 7'0"

1 EA.

ENTRANCE STAIRS (36' VERT) (ALLOW)

2 TON.

LANDING SAY. 5' x 10' x 25PSF

1.3 TON.

PAINTING CONCRETE BLOCK 1510SF x 2 SIDES

3020 SF

STRUCTURAL STEEL

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

TRI-STATE

WATER INTAKE STRUCTURE

INTAKE


1	<u>EXCAVATION</u> <sup>1200SF</sup> $20'(60')(318-30)/27 = 489 \text{ cy}$	490 cy
2	<u>SHEET PILES</u> $2(20+60) = 160 \text{ LF} \times 46' = 7360 \text{ SF} \times 38 \text{ PSF} / 2000 = 1398$	140 TONS
3	<u>CRUSHED ROCK BED</u> $20(60)(2)/27 = 88.9$	90 cy.
4	<u>BACKFILL</u> $490 - 90 - [12^2(10^3)/27] = 347 \text{ cy}$	350 cy.
5	<u>INTAKE SILT PROTECTION</u> (AROUND CONC INLET BOX) <sup>30+30+12</sup> = 72'	
6	<u>FILTER CLOTH</u> $72^2 - 12^2 = 5040 \text{ SF} + 10\% \text{ LAPS} = \text{SAV}$	5500 SF
7	<u>RIP-RAP</u> $5040 \text{ SF}(1)/27 = 187 \text{ cy}$	190 cy

CONCRETE

11	<u>INLET BOX WALL</u> $44 \times 10 \times 1 = 440$ } $584 / 27 = 21.6 \text{ cy}$	21.6 cy
12	<u>BOTT</u> $12^2 \times 1 = 144$ }	

STEEL COVER  $10.5' \text{ SQ} = 110 \text{ SF}$

1/2" MESH SCREEN



6" Ø PRESTRESSED PIPE (JACKED IN PLACE) 370 LF

6" ID x 5/8" WALL 1623 PLF (AMERON)  $1623 \text{ PLF}(370')/2000 = 300 \text{ T}$

NOTE EXCAVATION ASSUMED PER EXCAVATION (SURRY)  
DETAIL (SH #1) PUMP INTO POND @ INTAKE END  
OR PUMP TO SHORE

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



**TRI-STATE SYNFUELS COMPANY**  
Indirect Coal Liquefaction Plant  
Western Kentucky

**FLUOR ENGINEERS AND CONSTRUCTORS, INC.**  
Contract 836604

**APPENDIX C**

**River Stage Data and Corps of  
Engineers Ohio River Profiles**

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE INSTRUCTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

# Morley and Associates, INC.

CONSULTING ENGINEERS/LAND SURVEYORS

75 S.E. SEVENTH STREET/EVANSVILLE, INDIANA 47713/(812) 484-9585

Fluor Engineers and Constructors, Inc.

P.O. Box CL1944

Santa Ana, CA 92711

RECEIVED

FEB 25 1982

LETTER OF TRANSMITTAL

ATD CONTRACTS DEPT

DATE	JOB NO
February 20, 1982	82-584-1
ATTENTION	
Mr. Jack Buckamier	
RE	
Tri-State Synfuels, Henderson County, KY	

GENTLEMEN:

WE ARE SENDING YOU  Attached  Under separate cover via \_\_\_\_\_ the following items:

- Shop drawings     Prints     Plans     Samples     Specifications  
 Copy of letter     Change order     \_\_\_\_\_

COPIES	DATE	NO	DESCRIPTION
1	9/22/76	1	Corps of Engineers, Louisville District - Daily Ohio River Bulletin
1	1972	2	Ohio River Profile - Mile 780 to Mile 810
1	1972	3	Ohio River Profile - Mile 810 to Mile 840
1	1981	4	USGS Topographic Map (partial)
1	1981	5	USGS Topographic Map (partial)

*Received*  
 FEB 25 1981  
*John G. St...*

THESE ARE TRANSMITTED as checked below:

- For approval     Approved as submitted     Resubmit \_\_\_\_\_ copies for approval  
 For your use     Approved as noted     Submit \_\_\_\_\_ copies for distribution  
 As requested     Returned for corrections     Return \_\_\_\_\_ corrected prints  
 For review and comment     \_\_\_\_\_

REMARKS

This is the data which I was telling you about in our telephone conversation yesterday. The river stage given on our weekly work schedule is based on Evansville gage. To obtain water elevation, add river stage to 329.18 (zero gage) and then subtract 0.48 feet to convert from Ohio River Datum to USGS datum. All river gages and river stages are based on Ohio River Datum (ORD) and most topographic maps are based on United States Geological Survey Datum (USGS). To determine inundation on the topo maps, it is necessary to convert over to USGS. This will allow you to determine when your observation wells will be accessible or inundated.

EXAMPLE: Zero Gage = 329.18 ORD  
 River Stage = +31.2 ORD  
                   360.38 ORD  
 ORD to USGS = - .48  
                   359.90 USGS

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT


If we can be of further assistance, feel free to contact us.

COPY TO File

SIGNED:


*Lee A. McClellan*  
 Lee A. McClellan, PE LAM/tw

If enclosures are not as noted, kindly notify us at once.



USE OR DECLARATION OF CARRY OVER IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

1981  
 USE OR DECLARATION OF CARRY OVER IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT




EVANSVILLE

MIL 792.1/2

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ENGINEER NOTICE PAGES AT THE FRONT OF THIS REPORT

White City


HENDERSON CO




CORPS OF ENGINEERS, U.S. ARMY  
 OHIO RIVER DIVISION  
 CINCINNATI, OHIO

320  
 310  
**PROFILES**  
**OHIO RIVER**  
**MILE 810 TO MILE 840**  
 820


USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT



USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTION ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT



USE OR DISCLOSURE OF REPORT DATA  
 IS SUBJECT TO THE RESTRICTIONS ON THE  
 NOTICE PAGE AT THE FRONT OF THIS REPORT



CORPS OF ENGINEERS, U.S. ARMY  
OHIO RIVER DIVISION  
CINCINNATI, OHIO

**PROFILES**

**OHIO RIVER**


**MILE 780 TO MILE 810**

USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTIONS ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

1972



USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT



USE OR DISCLOSURE OF REPORT DATA  
IS SUBJECT TO THE RESTRICTION ON THE  
NOTICE PAGE AT THE FRONT OF THIS REPORT

