


<b>30-V-1</b> BLOWDOWN FLASH DRUM 36" ID x 6'-0" T/H DESIGN: 1.5 PSIG, 350°F CARBON STEEL	<b>51-T-1B</b> I.P. POWER TURBINE 53.324 BHP (SHAFT)	<b>51-T-2</b> M.P. POWER TURBINE 126.056 BHP (SHAFT)	<b>51-T-3</b> H.P. BFW PUMP TURBINE 4.080 BHP (SHAFT)	<b>30-TK-3</b> CONDENSATE SURGE TANK CAPACITY: 2000 GALS	<b>30-ME-2</b> CONDENSATE POLISHING UNIT DESIGN CAPACITY: 2100 GPM	<b>30-TK-2</b> DEMINERALIZED WATER STORAGE TANK CAPACITY: 2000 GALS EPOXY LINED	<b>30-ME-1</b> WATER DEMINERALIZATION UNIT DESIGN CAPACITY: 50 GPM
----------------------------------------------------------------------------------------------------------	---------------------------------------------------------------	---------------------------------------------------------------	-------------------------------------------------------------------	----------------------------------------------------------------------	--------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------



- NOTES:**
1. FLOWS AND HORSEPOWERS ARE TOTAL FOR ALL TRAINS AT DESIGN CAPACITY.
  2. ZERO BLOWDOWN IS ASSUMED IN THE CALCULATION OF THE HEAT BALANCE.



<b>PROCESS FLOW DIAGRAM</b> <b>STEAM, BFW, &amp; CONDENSATE SYSTEM</b> <b>TEXACO PROCESS-OXYGEN BLOWN</b> <b>SUPERHEATED STEAM BASE CASE</b>		448334-EXT-SH-30-1 05
NONE	448334-EXT-SH-30-1	

448334-101

## COOLING WATER SYSTEMS

This unit provides cooling water for process heat rejection, condensation of exhaust steam from the steam turbines, and cooling of mechanical equipment. Two cooling water systems are provided. The first system, consisting of mechanical draft towers and three low-head pumps, serves only the surface condenser for the steam turbogenerator and high-pressure boiler feedwater pump steam turbine driver. The second system involves one tower and two higher-head pumps. This separation of systems allows the use of the low-head surface condenser water supply pumps by keeping the runs of cooling water lines to a minimum. A further significant advantage is the confinement of contaminants to one cooling tower in the event of a process fluid leak to cooling water.

Makeup water for the surface condenser cooling water system is raw water. The blowdown from this system is treated for calcium hardness in a softener by cold lime-soda addition and is used subsequently as makeup for the process cooling water system. Other makeup flows for the process cooling water system include boiler blowdown and treated effluent from the oily water system. Blowdown from the process cooling tower is an effluent for disposal.

Sulfuric acid is injected into the cooling water system for pH control. A proprietary organic phosphate (nonchromate) solution is injected for corrosion inhibition, scale control, and sludge dispersion. Biocide agents compatible with ammonium ions are injected to maintain clean heat transfer surfaces.

## POWER GENERATION

Process Flow Diagrams EXT-SS-50/51-1 and EXT-SH-50/51-1 describe the steam and power generation systems for the saturated and superheated steam base cases respectively.

The power generation system includes two parallel trains of fuel gas expanders (50-1-EX-1) with generators (50-1-G-1) one high-pressure/intermediate-pressure/medium-pressure steam turbine (51-T-1A&B and 51-T-2) with generator 51-G-1 and one fired heater (51-FH-1) in the saturated steam case only. A power block performance summary for all cases is part of Appendix D, which also includes detailed performance information on the power block components, i.e., fuel gas expanders, fired heaters and steam turbines.

EXT-SS. Reheated fuel gas from 20-1-E-3 at 600°F is expanded to 50 psia in two fuel gas expanders 50-1-EX-1, producing 62 MW total net power in two generators 50-1-G-1, while a portion of the expanded gas ( $3.37 \times 10^6$  SCFH) is used in fired heater 50-FH-1, and remainder constitutes product gas for export.

In the fired heater high-pressure saturated steam from gasifier waste heat boilers is superheated to 900°F before flowing to the high-pressure end of back-pressure turbine 51-T-1A. Exhaust steam from 51-T-1A is combined with saturated intermediate-pressure steam from the sulfur plant, and is then reheated to 900°F in the fired heater. This reheated steam is then used in intermediate-pressure power turbine 51-T-1B, a back-pressure machine. There exists a net demand for medium-pressure steam in the process area. Part of exhaust from 51-T-1B is desuperheated and diverted to the process area. The remainder of 51-T-1B exhaust steam is used to drive the medium-pressure power turbine 51-T-2 and the high-pressure boiler feedwater pump driver turbine 51-T-3. These two turbines exhaust at 2-1/2 inches Hg absolute. Total steam turbine generator 51-G-1 output is 259 MW.

The turbine surface condenser 51-E-1, a single-shell single-pass unit with divided water boxes, handles flow from both condensing turbines. The tubes are 90/10 copper/nickel, 7/8 inch OD, 22 BWG wall thickness. The noncondensable gas removal and priming equipment include two positive displacement rotary vacuum pumps and a recirculating ball-type condenser tube cleaning system. Four motor-driven condensate pumps 51-P-3A-D (two spare) transport the condensate to condensate storage tank 30-TK-3, which is sized for 30-minute capacity at design flow rate.

Deaerating steam is provided to deaerator 51-DA-1 by "letting down" medium-pressure steam from header. Medium-pressure feedwater to the process is supplied by pump 51-P-1A&B. The other boiler feedwater users are supplied by high-pressure boiler feedwater pump 51-P-2A&B. High-pressure boiler feedwater is heated in gas cooling boiler feedwater heaters 21-1-E-1 and fired heater 51-FH-1. At which point it is split and one set of streams is fed to the sulfur plant wasteheat boilers and the other is further heated in raw gas cooling boiler feedwater heaters 20-1-E-4, to high-pressure steam saturation temperature. It is then forwarded to gasifier waste heat boilers 20-1-E-1B.

EXT-SH. Reheated fuel gas at 600°F is similarly expanded as in the saturated steam base case generating also 62 MW net power. However, the entire fuel gas exhausting the expander constitutes product gas for export.


High-pressure superheated steam generated in gasifier waste heat boilers at 1000°F flows to the high-pressure end of back-pressure turbine 51-T-1A. Exhaust steam from 51-T-1A is combined with saturated intermediate-pressure steam from the sulfur plant. It is then reheated to 1000°F in the gasifier waste heat boilers. This reheated steam is then used in a similar fashion as in the SS base case in the power turbine and in the high-pressure boiler feedwater pump driver turbine, and some is desuperheated to provide process steam. The steam turbine generator 51-G-1 output is 167 MW.

The turbine surface condenser 51-E-1 is similar to the saturated steam base case. The condensate is transported and stored in storage tank 30-TK-3 as in the saturated steam base case.


Deaerating steam is provided to deaerator 51-DA-1 by "letting down" medium-pressure steam from header. Medium-pressure feedwater users are supplied by high-pressure boiler feedwater pump 51-P-1A&B. The other boiler feedwater users are supplied by medium-pressure boiler feedwater pump 51-P-2A&B. High-pressure boiler feedwater is heated in a series of exchangers involving gas cooling boiler feedwater heaters 21-1-E-4, at which point it is split and one set of streams fed to the sulfur plant waste heat boilers and the other further heated in raw gas cooling boiler feedwater heaters 20-1-E-4, to high-pressure steam saturation temperature. It is then forwarded to gasifier waste heat boiler 20-1-E-1.

#### Equipment Notes


With the exception of the high temperature gas coolers, all the equipment is commercially available.




SI-1 HEATER 0.42 MM 61U/HR	SI-T-1A HP POWER TURBINE 16,893 SHP	SI-T-1B IP POWER TURBINE 62,483 SHP	SI-T-2 MP POWER TURBINE 135,814 SHP	SI-G-1 STEAM TURBINE GENERATOR 258.97 MW	SI-T-3 HP BFW PUMP TURBINE 5,460 BHP (SHAFT)	SI-DS-1 DESUPERHEATER	SI-DA-1 DEAERATOR OPERATING @ 28 PSIA & 246°F	SI-E-1 SURFACE CONDENSER 1832 MM DI 161-721 SQ. FT TUBES: 90-18 CU SHELL: C.S.
----------------------------------	-------------------------------------------	-------------------------------------------	-------------------------------------------	------------------------------------------------	----------------------------------------------------	--------------------------	--------------------------------------------------------	-----------------------------------------------------------------------------------------------



S. GARCIA DON VAN HUYEN R. G. ELIOTT A. R. DODD J. C. BAKER EPRI		<b>PROCESS FLOW DIAGRAM</b> <b>POWER GENERATION</b> <b>TEXACO PROCESS-OXYGEN BASE</b> <b>SATURATED STEAM BASE</b>	
NONE		448334-EXT-SS-50/	



D. GARCIA DON VAN HOUTEN K. L. HUBBARD A. RAO S. E. WILSON EPRI		<b>PROCESS FLOW DIAGRAM</b> <b>POWER GENERATION</b> <b>TEXACO PROCESS-OXYGEN BLOWN</b> <b>SATURATED STEAM BASE CASE</b>	
NONE	448334-EXT-SS-50/51-1A	04	448334123





**SI-T-1B**  
IP POWER TURBINE  
13.374 BHP

**SI-T-2**  
MP POWER TURBINE  
126.066 BHP


**SI-T-3**  
MP BFW PUMP TURBINE  
4.080 BHP

**SI-G-1**  
STEAM TURBINE GENERATOR  
164.85 KW

**SI-DS-1**  
DESUPERHEATER

**SI-E-1**  
SURFACE CONDENSER  
1834 MM BUDJWR  
103.285 SQ. FT.  
TUBES: 10/10 CUMI  
SHELL: C.S.

**SI-DA-1**  
DEAERATOR  
OPERATING: 38 PSIA  
248°F



D. A. COTTRELL		PROCESS FLOW DIAGRAM	
POWER GENERATION		TEXACO PROCESS - OXYGEN BLOWN	
SUPERHEATED STEAM BASE CASE		NONE	
448334-EXT-SH-50/51-1	05		

335K1212

## GENERAL FACILITIES

The various support systems and services required to produce an operable grass-roots facility are divided into the following units.

- Plant and instrument air
- Potable and utility water
- Fuel system
- Nitrogen system
- Effluent water treating
- Flare system
- Fire water system
- Buildings
- Railroad loading
- Electrical system

### Plant and Instrument Air

One motor-driven compressor, rated for 3150 SCFM, is in normal operation supplying plant air and air to instrument air dryer packages. Another motor-driven compressor supplies air on demand, with a third steam turbine-driven compressor on standby for emergency. Two dryer packages are provided; each is designed to supply 1500 SCFM instrument air. Each dryer package is a dual-tower molecular-sieve adsorbent system with air prefilters, air after-filters, and an adsorbent regeneration system.

### Potable and Utility Water

The potable water system includes two motor-driven 100 gpm pumps, with in-line chlorination. Water is pumped from raw water storage tank 30-TK-1 to an air-pressurized supply drum. Plant water is supplied by two motor-driven pumps, each rated for 200 gpm, operating on demand.

### Fuel System

Fuel oil is used as startup fuel for the fired heater in the saturated steam case only. The fuel system has two 33,000 bbl tanks, two motor-driven pumps and suction heaters (for viscosity reduction). This fuel oil capacity is sufficient to

Support full operation of the fired heater for two weeks. The multiple tank system allows the use of more than one type of fuel oil.

#### Nitrogen System

Nitrogen gas is required for blanketing fuel oil storage tanks and for purging process equipment prior to maintenance. Liquid nitrogen obtained from the air separation plant is stored in a double-walled 7200 bbl cryogenic vessel, from which nitrogen gas is supplied upon demand by vaporization of the liquid in air-fin heaters.

#### Effluent Water Treating

The water streams treated are:

- Storm water
- Utility wastewater
- Cooling tower blowdown

A process condensate blowdown rate of 170 gpm from the gasification and ash handling section was selected as the sizing basis for the process condensate treating unit. This sizing basis was derived from the overall water balance for the enriched air cases. Process condensate composition data are not adequate to finalize the flow which must be treated in a full-scale commercial GCC plant. Therefore, the size of the process condensate treating unit is assumed to be constant for all plants designed and costed in this study. The process itself is designed to remove formates, sulfides, ultrafine ash particles, and ammonia from the water using the following steps:

- Chemical addition with precipitation
- Settling
- Filtration
- Ammonia stripping with steam
- Biotreatment

The effluent water from the process condensate treating unit is suitable for disposal in a navigable body of water. By-products are a precipitate cake and a biotreater sludge both of which may be combined with the ash cake for disposal.

The ammonia stripped from the water is routed to the sulfur plant (Unit 23) furnace. The quantity of ammonia has been judged insufficient to consider its recovery for sale.

Storm water and utility waste waters are directed in underground sewers to the forebay of the storm water pond. Contaminated water from this pond is treated for oil removal in a CPI separator, processed in a deep-bed filtration unit, and then used as makeup water for the process cooling tower.

The cooling water system includes one process and two utility mechanical draft cooling towers for the saturated steam case. The superheated steam case cooling water system includes one process and one utility cooling tower. Blowdown from the utility cooling towers is softened by cold lime-soda treating before being added to the process cooling water system. Blowdown from the process cooling tower is combined with the treated process condensate prior to disposal.

Sanitary sewage streams are sent to the city sewer outside plant boundary limits.

#### Flare System

In conformance with accepted practice, a relief system is provided to protect the process equipment from overpressure. In the event of pressure release, relief lines will carry away the vented gases from the affected processing areas to two elevated flare stacks where ignition will occur. A continuous flare system pilot flame is maintained by a package LPG system comprised of an LPG tank, pumps, and a vaporizer. Separator drums are provided at the base of each flare stack to capture condensate which may be carried in the vented process gases. Sealing systems are provided in each flare stack to prevent air intrusion back into the relief system.

#### Fire Water System

A fire water loop encompassing the entire plant is provided. A motor-driven jockey pump keeps the system under pressure. All equipment and storage tanks are within range of hydrants and monitors in accordance with accepted practice. A total capacity of 5000 gpm is provided by two fire water pumps, one of which is motor-driven while the other is powered by a diesel engine. These pumps take suction either from a 30,000 bbl fire water storage tank or directly from the municipal water supply. The pumps are designed to start automatically when fire water loop pressure drops appreciably. The pumps are also designed to deliver water, at the design flow rate, to the hydrants at a pressure of 125 psig.

Buildings

The following is a list of the buildings included in the capital estimate:

Substations  
Control Houses  
Operators Shelters  
Administration  
Laboratory  
Cafateria  
Change House and Guard House  
Fire House  
First Aid  
Maintenance  
Warehouse

### Section 3

#### PROCESS DISCUSSION

The two base cases, involving the generation of high-pressure saturated steam (EXT-SS) and the generation of high-pressure superheated steam (EXT-SH) in high temperature gas cooling, are discussed here.

#### OVERALL SYSTEM PERFORMANCE

Table 3-1 summarizes the overall system performance for the base case designs. The table is organized into gasification, power system, and overall plant categories.

Both cases produce a gasifier effluent having a higher heating value of 275.8 Btu/SCF (dry). After the gas is cleaned to remove particulates and sulfur compounds, the higher heating value of gas available for export corresponds to 282.3 Btu/SCF (dry). The gas is available for export from the plant boundary limits at a pressure of 50 psia. If the gas is to be transported over longer distances, fuel gas reheat as well as gas expansion would be eliminated, and gas would be available at the plant boundary limits at a pressure of 536 psia. The high pressure steam generation rate would be increased due to the elimination of fuel gas reheater. However, the net effect, as expected, would be a reduction in the overall plant efficiency.

For the saturated steam case,  $6664 \times 10^6$  Btu/hr of fuel gas and 142.4 MW of electrical power are available for export. For the superheated steam case, more fuel gas,  $7637 \times 10^6$  Btu/hr, and less electrical power, 53.3 MW, are available for export. The energy recovery efficiency for the saturated and superheated steam cases is 77.11 percent and 78.77 percent respectively.

Table 3-1

**SUMMARY OF SYSTEM PERFORMANCE TEGACO GASIFICATION  
FUEL GAS PLANTS - BASE CASES <sup>(1)</sup>**

Steam Cycle, psig/°F/°F	1450/900/900	1450/1000/1000
Steam Generated in Gas Coolers	Saturated	Superheated
Gas Temperature Entering Heat Recovery, °F	2400	2400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Nominal Capacity of Gasifiers ST/day	1375	1375
<b>CASE DESIGNATION</b>	<b>EXT-55</b>	<b>EXT-58</b>
<b>GASIFICATION</b>		
Coal Feed Rate, lb/hr (dry)	806,666	806,666
Oxygen*/Coal Ratio, lb/lb m.f.	0.8921	0.8921
Oxidant Temperature, °F	300	300
Slurry Feed Solids Content, weight %	66.5	66.5
Gasification Section Average Pressure, psig	600	600
Raw Gasifier Effluent Temperature, °F	2,400	2,400
Raw Gasifier Effluent HHV (dry basis), Btu/SCF**	275.5	275.8
Cold Gas Efficiency (raw gas HHV/coal feed HHV x 100),	74.64	74.64
<b>POWER SYSTEM</b>		
Temperature of Fuel Gas to Gas Expander, °F	600	600
Gas Expander Exit Temperature, °F	195	195
Condenser Pressure, Inches Hg abs	2.5	2.5
Fired Heater Stack Temperature, °F	400	400
Gas Expander Power#, MW	61.75	61.75
Steam Turbine Power#, MW	258.97	166.85
Oxygen Plant Power##, MW	1.81	1.81
Power Consumed, MW	180.14	177.11
Net System Power, MW	142.40	53.30
<b>OVERALL SYSTEM</b>		
General Facilities Water Consumption, GPM	150	150
Land, acres	190	175
Ash Disposal Rate, Dry ST/D	1023	1023
Sulfur By-Product, ST/D	354	354
Process and Generator Makeup Water, GPM	467	450
Cooling Tower Makeup Water, GPM	4,370	3,212
Cooling Water Circulation Rate§§, 10 <sup>3</sup> GPM	227	167
Cooling Tower Heat Rejection§§, % of coal HHV	22.11	16.26
Air Cooler Heat Rejections, % of coal HHV	2.10	3.04
Clean Fuel Gas Efficiency (exported clean gas HHV x 100/coal feed HHV), %	64.67	74.11
Energy Recovery Efficiency¶ (exported power + exported clean gas HHV)/coal feed HHV x 100, %	77.11	78.77
Clean Fuel Gas HHV (dry basis), Btu/SCF	282.3	282.3
Net Clean Fuel Gas Product, 10 <sup>6</sup> SCFP	566.53	649.25
10 <sup>3</sup> SCF/ton DAF coal	65.03	74.52
10 <sup>6</sup> Btu/hr	6664	7637

<sup>(1)</sup> This table is identical to Table S-1, page S-3

- \* Dry basis, 100 percent oxygen
- \*\* Excluding the HHV of H<sub>2</sub>S, CO<sub>2</sub> and NH<sub>3</sub>
- # At generator terminals
- ## From power recovery expander 11-ME-1
- §§ Includes process and power plant portions
- ¶ Export power credited at 9,000 Btu/kwh.

#### GASIFIER MATERIAL BALANCE

A gasifier material balance for full capacity operation is given in Table 3-2.

The coal quantity and composition, the oxidant composition, the slurry concentration and reaction temperature were taken from EPRI report AP-1624. Fluor has estimated both the quantity of oxidant required and the effluent gas composition. The coal feed is 11,000 tons/day of Illinois No. 6, introduced to the gasifier in a 66.5 weight percent slurry. Texaco has indicated that for this particular coal, slurry concentrations in the range of 60 to possibly 70 percent solids could be achieved. It is important to bear in mind that slurring characteristics of coals vary greatly and that it is not valid to extrapolate performance estimates presented in this report to other coals possessing different slurring characteristics. Per-pass carbon conversion in the gasifier is assumed to be 95 percent.

Some nitrogen from the coal is converted to ammonia, but the extent of conversion cannot be predicted with precision at this time. This study has assumed that 25 percent of the coal's nitrogen forms ammonia. Downstream of the gasifier, ammonia has been assumed to be rapidly complexed as ammonium salts in the process condensate streams. These ammonia-bearing waters, with the exception of a blowdown stream, are eventually recycled to the gasifiers by way of the coal slurry. At gasification temperatures, the gasifiers are assumed capable of destroying recycled ammonia. The presence of ammonia in the process condensate has the beneficial effect of neutralizing dissolved carbon dioxide.

#### HIGH TEMPERATURE GAS COOLING/STEAM GENERATION

In both base cases the high temperature heat recovery equipment consists of a radiant boiler followed by convective heat recovery equipment. The temperature assumed for the gas exiting the radiant boiler is 1500°F. This temperature was chosen based on the assumption that the entrained ash in the gas will be sufficiently cool at 1500°F that it will minimize fouling in the convective exchangers.

The quantity of electric power generated by the steam raised in the hot gas cooling section of the plant depends on the type of service assumed for the high temperature gas coolers. For Case EXT-SS in which only saturated steam is raised in these coolers, all of the sensible heat in the fuel gas down to 640°F is used for steam raising. For Case EXT-SH, where superheating/reheating is assumed, the



Table 3-2  
GASIFIER MATERIAL BALANCE

	FEEDS		T(°F)	lb/hr	lb mol/hr	Gasifier Gaseous/Vapor Effluent	T(°F)	lb/hr	lb mol/hr	mol % (wet)
Coal	140					2,300-2,600				
Moisture	110,000	6,105.9				CH <sub>4</sub>		3,533	220.2	0.24
Ash	80,667					H <sub>2</sub>		53,102	26,340.1	28.35
HAF Coal						CO		993,074	35,453.0	38.17
Carbon	560,909	46,699.8				CO <sub>2</sub>		465,615	10,579.5	11.39
Hydrogen	42,979	21,330.8				H <sub>2</sub> S		30,927	907.4	0.98
Oxygen	80,876	2,525.3				COS		3,835	63.8	0.07
Nitrogen	10,091	360.2				N <sub>2</sub>		17,213	614.4	0.66
Sulfur	31,145	972.3				Ar		4,584	114.7	0.12
TOTAL COAL	916,667					H <sub>2</sub> O		331,899	18,422.5	19.83
						NH <sub>3</sub>		3,067	180.1	0.19
Oxidant	300					TOTAL GASIFIER GASEOUS/VAPOR EFFLUENT		1,906,849	92,895.9	100.00
Oxygen	719,709	22,490.9				Gasifier Solid Effluent	2,300-2,600			
Argon	4,589	114.7				Carbon		29,279	2,437.7	
Nitrogen	9,638	344.2				Ash		146,814		
TOTAL OXIDANT	733,936	22,949.8				TOTAL GASIFIER SOLID EFFLUENT		176,093		
Recycle	140									
Carbon	24,680	2,054.8								
Ash	66,147									
Water	341,512	18,990.5								
	432,339									
TOTAL FEEDS	2,082,942					TOTAL EFFLUENTS		2,082,942		

total quantity of steam raised is less than that in Case EXT-SS due to the additional duty required in the superheater/reheater. Therefore the total quantity of electric power generated in the saturated steam case (EXT-SS) is greater than that for the case where superheating/reheating capability is assumed (EXT-SH). This greater power production capability for Case EXT-SS is offset by a smaller net fuel gas make due to the consumption of approximately 13 percent of the clean fuel gas in the fired superheater/reheater.

#### POWER CONSUMPTION SUMMARY

Table 3-3 summarizes auxiliary power consumptions for the major plant sections under conditions of normal operation at 100 percent capacity factor.

Unit 10, requires 9176 kW of power at full design capacity. The coal grinding equipment (10-ME-4) consumes the greatest proportion of this power to the coal handling equipment. Since the power for grinding is very sensitive to both the type of equipment used and the coal properties, this estimate of power required for coal handling is preliminary, pending grinding tests.

Unit 11 power requirements represent by far the most substantial power consumption in the designs and are due solely to the air and oxygen compressor drivers (11-C-1-M and 11-C-2-M) which are synchronous, Type II induction motors. All intercoolers are water-cooled and the cooling tower pump power is included elsewhere.

Miscellaneous pumps use most of the power for Units 20 and 21.

In Unit 22, the Selexol® fluorocarbon refrigeration units (22-ME-1) and lean solvent pumps (22-P-1) consume most of the power. It should be noted that the hydraulic turbines (22-HT-1) recover approximately 40 percent of the power required by the lean solvent pumps.

In the sulfur recovery unit, the Claus plant air blowers (23-BL-1), the Stretford plant air blowers (24-BL-1), and the Stretford solution circulation pumps are the large power consumers.

The major power consumer in Unit 30 is the condensate transfer pump (30-P-4).

Table 3-3

POWER CONSUMPTION SUMMARY (kW at Full Design Capacity)  
 TEXACO GASIFICATION FUEL GAS PLANTS - BASE CASES

Steam Cycle, psig/°F/°F	1450/900/900	1450/1000/1000
Steam Generated in Gas Coolers	Saturated	Superheated
Gas Temperature Entering Heat Recovery, °F	2,400	2,400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Nominal Capacity of Gasifiers, ST/day	1375	1375
Case Designation	EXT-SS	EXT-SH
Process Unit Number & Description	Power Consumption, kW	Power Consumption, kW
10 Coal Handling*	9,176	9,176
11 Oxidant Feed	143,439	143,439
20 Gasification	1,710	1,710
21 Gas Cooling	941	941
22 Acid Gas Removal	5,963	5,963
23 Sulfur Recovery	584	584
24 Tail Gas Treating	2,610	2,610
30 Raw Water Treating	323	222
32-45 General Facilities**	14,860	12,377
50 Fuel Gas Expander	0	0
51 Steam System	513	70
51 Surface Condenser#	16	10
<b>TOTAL PLANT POWER, kW</b>	<b>180,135</b>	<b>177,111</b>
Power Produced, kW	322,530	230,410
Net Power Output, kW	142,400	53,300

\*This power requirement is largely derived from the coal pulverizing system and is, therefore, preliminary pending grinding tests on Illinois No. 6 coal.

\*\*About 70 percent of this power demand is attributable to the cooling water system pumps and fans.

#For mechanical vacuum pump.

In the general facilities section, the cooling water circulation pumps and the cooling tower fans require the most power. The entire cooling water system is responsible for 60 to 70 percent of the total power demand of the general facilities (Units 32 through 45).

Pumps consume the bulk of the power supplied to Units 50 and 51.

#### PROCESS ENERGY BALANCES

Tables 3-4 and 3-5 represent the overall process energy balances at 100 percent capacity operation for the two base cases. The entire plant, exclusive of the cooling tower but including the power demand of the pumps and fans, is encompassed by the boundary for each balance. Energy contents of streams crossing the boundary are expressed as the sum of the stream's higher heating value (HHV), sensible heat above 60°F, and the latent heat of water at 60°F. Electric power is converted to equivalent heat energy at 3413 Btu/kWh. The energy balances close within three-tenths of a percent. Discrepancies result from approximations applied in calculating enthalpies for some process streams.

Energy balances as a percent of coal HHV, depicted in Table 3-6, are derived from the previous tables. Coal charged at 11,000 short tons/day is equivalent to  $10,304 \times 10^6$  Btu/hr HHV. The significant differences among the cases lie in the "Net Power," "Net Fuel Gas," and "Steam Turbine Condensers" categories. As noted previously, differences in the gas cooling process and the steam system have a substantial impact on the net power generation and fuel gas available for export.

Table 3-4

ENERGY BALANCE - BASE CASE EXT-SS

Oxidant: 98 mole percent oxygen

Gas Temperature Entering Heat Recovery: 2400°F

Sulfur Removal: 94.6 percent

Gasifier: Texaco  
 Steam: 1450 psig, 900°F/900°F superheat/reheat

Oxidant Plant Compressor Drivers: Motors

Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HRV	Sensible	Latent	10 <sup>6</sup> Btu/hr Radiation	Power	Total
<b>IN</b>						
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	2
Air to Fired Heater	-	4	1	-	-	5
Deminerlized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	615	615
<b>TOTAL</b>	<b>10,304</b>	<b>33</b>	<b>57</b>	<b>-</b>	<b>615</b>	<b>11,009</b>
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	227	-	-	-	227
Gasifier and W/B Heat Losses	-	-	-	123	-	123
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Trim Cooler	-	19	5	-	-	24
Selenol Refrigeration Cooler	-	59	-	-	-	59
Selenol Overhead Condenser	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses*	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	884	884
Air Separation Plant Power	-	-	-	-	6	6
Fired Heater Flue Gas	-	74	76	-	-	150
Fired Heater Radiation Losses	-	-	-	18	-	18
Steam Turbine Condensate	-	1,632	-	-	-	1,632
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	22	22
Motor and Mechanical Losses**	-	-	-	-	116	116
Net Fuel Gas Export	5,564	60	-	-	-	5,724
<b>TOTAL</b>	<b>6,847</b>	<b>2,628</b>	<b>141</b>	<b>141</b>	<b>1,239</b>	<b>10,996</b>

$\frac{In-Out}{In} \times 100\% = 0.12\%$

\*Includes tracing, miscellaneous process users, sulfur melting steam and generator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 3-5

ENERGY BALANCE - BASE CASE EXT-SH

Gasifier: Tetaco

Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 2400°F

Steam: 1450 psig, 1000°F/1000°F superheat/reheat

Sulfur Removal: 94.6 percent

Oxidant Plant Compressor Drivers: Motors

Basis: 60°F, water as liquid, 3,413 Btu/kWh

	IN	Sensible	Latent	Radiation	Power	Total
	MBtu	10 <sup>6</sup> Btu/hr				
Coal	10,304	3	55	-	-	10,307
Air to Oxidant Feed System	-	23	-	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	2
Desimularized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	604	604
TOTAL	10,304	29	56	-	604	10,993
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	227	-	-	-	227
Gasifier and WHB Heat Losses	-	-	-	113	-	113
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	47	50	-	-	97
Raw Gas Trim Cooler	-	19	5	-	-	24
Selekol Refrigeration Cooler	-	59	-	-	-	59
Selekol Overhead Condenser	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses*	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	570	570
Air Separation Plant Power	-	-	-	-	6	6
Steam Turbine Condensers	-	1,034	-	-	-	1,034
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	16	16
Motor and Mechanical Losses**	-	-	-	-	105	105
Net Fuel Gas Export	7,637	69	-	-	-	7,706
TOTAL	7,820	2,013	115	113	908	10,968

In-Out x 100% = 0.23%

\*Includes tracing, miscellaneous process users, sulfur setting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 3-6  
**ENERGY BALANCE AS PERCENT OF COAL HHV**  
**TEXACO GASIFICATION FUEL GAS PLANT - BASE CASES**

Steam Cycle, psig/°F/°F	1450/900/900	1450/900/900
Steam Generated in Gas Coolers	Saturated	Superheated
Gas Temperature Entering Heat Recovery, °F	2,400	2,400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Nominal Capacity of Gasifiers, ST/day	1375	1375

CASE DESIGNATION	EXT-SS		EXT-SH	
	10 <sup>6</sup> Btu/hr	%	10 <sup>6</sup> Btu/hr	%
<b>IN</b>				
Coal HHV	10,304	100.00	10,304	100.00
<b>OUT</b>				
Oxidant Compressors Inter/After Cooling	468	4.54	468	4.54
Air Separation Plant Vent Gas, Sensible and Latent	42	0.41	42	0.41
Gasifier and WHB Heat Losses	123	1.19	113	1.10
Ash Cake	71	0.69	71	0.69
Selexol® and Tail Gas Treating Cooling	112	1.08	112	1.08
Sulfur By-product	117	1.13	117	1.13
Sulfur Plant Vent Gas, HHV, Sensible and Latent	8	0.07	8	0.07
Net Power	486	4.72	182	1.77
Fired Heater Flue Gases, Sensible and Latent	150	1.46	0	0
Fired Heater Radiation Losses	18	0.18	0	0
Steam Turbine Condensers	1,632	15.84	1,034	10.04
Power Block Losses	22	0.21	16	0.16
Motor Losses	116	1.13	105	1.02
Other (net) Sensible Losses	234	2.27	284	2.76
Other (net) Latent Losses	<32>	<0.31>	19	0.18
Net Fuel Gas Export, HHV and Sensible	<u>6,724</u>	<u>65.26</u>	<u>7,008</u>	<u>74.80</u>
<b>TOTAL</b>	<b>10,291</b>	<b>99.87</b>	<b>10,279</b>	<b>99.76</b>

\*Values indicated within < > are negative numbers

## Section 4

### CAPITAL AND OPERATING COST ESTIMATES

#### PLANT FACILITIES INVESTMENT

A breakdown of the plant facilities investment for the major units of the base case designs, including initial catalysts and chemicals, is given in Tables 4-1 and 4-2. The estimates in these tables contain allowances for both project and process contingencies. The project contingency allowance is intended to cover additional or improved equipment that would result from a more detailed design of a definitive project at an actual site. An allowance of 15 percent of the sum of Process Plant Investment and the General Facilities Cost has been used for both base cases. The process contingency allowance, applied separately to each major plant section, is an attempt to account for unproven technology in an effort to quantify the uncertainty in the design, performance and cost of the commercial scale equipment. The different process contingency allowances used for each major subsection of the plant designs are shown in Table 4-3. These allowances were supplied by EPRI.

The absolute accuracy of the plant investment estimates is judged to be  $\pm 25$  percent. Comparisons between cases should be much more accurate, perhaps  $\pm 5$  percent, since the same inaccuracies are likely to occur in each case.

As anticipated, the cost of the gas cooling section varies widely for the two cases due to the different waste heat boiler options. Also showing significant variation are the sections associated with power generation such as the turbo-generator and the fired heater.

EPRI incremented by 27 percent the mid-1978 plant facilities investments for the two cases in order to escalate the investment estimate to mid-1980 dollars as shown in Table 4-4.



Table 4-1

PLANT FACILITIES INVESTMENT - BASE CASE EXT-SS  
Mid-1978 Dollars

Plant Section	Cost Breakdown Without Contingencies						Per-cent	Contingencies		Total Plant Investment \$/MH BTU/HR
	Direct Field Labor#	Direct Field Labor#	Eng. & Support Costs\$	Sales Tax	Total Cost \$1000*	Total Cost \$/10 <sup>6</sup> Btu/hr**		Process \$1000*	Project \$1000*	
Coal Handling	20,566	8,356	14,413	1,026	44,361	6,657	0	6,654	51,015	7,657
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	23,417	29.0	23,407	179,453	26,930
Gasification and Ash Handling	24,062	9,810	16,702	1,171	51,745	7,765	9.7	5,133	64,640	9,700
Raw Gas Cooling	71,124	16,455	34,929	3,590	126,098	18,923	23.4	22,625	167,836	25,186
Acid Gas Removal	6,918	2,493	4,513	353	14,277	2,142	2.7	0	16,419	2,464
Sulfur Recovery	2,590	1,217	2,049	134	5,990	.899	1.1	0	6,889	1,034
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1,552	2.0	1,551	13,441	2,017
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	2,010	2.5	0	15,402	2,311
Steam, Condensate and BFW	7,044	351	426	19	1,766	.265	.3	0	2,031	.305
Steam Superheat/Reheat	20,858	6,189	12,049	1,074	40,170	6,028	7.5	0	46,196	6,932
General Facilities	28,485	11,526	16,801	963	57,775	8,670	10.7	0	66,441	9,970
Initial Chemicals and Catalysts					2,358	0.354	0.4		2,358	0.354
TOTAL	279,337	93,220	151,854	11,112	537,885	80,718	100.0	29,509	647,723	97,200

TOTAL PLANT INVESTMENT SUMMARY

	\$1000*	\$/MH BTU/HR**
Process Plant Investment and General Facilities	537,885	80.718
Process Contingency	29,509	4.428
Project Contingency	80,329	12.054
Total Plant Investment	647,723	97.200

\*Mid-1978 dollars

\*\*Based on 100 percent plant design power output of 6663.8 MH Btu/hr Fuel Gas

‡All materials and equipment that become a part of the plant facility

‡Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

‡Includes:

- Indirect field costs including all labor, supervision, and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 4-2

PLANT FACILITIES INVESTMENT - BASE CASE EXT-SH  
Mid-1978 Dollars

Plant Section	Cost Breakdown Without Contingencies				Total Cost \$/10 <sup>6</sup>	Per- cent	Contingencies		Total Plant Investment \$/MM BTU/HR
	Direct Field Mat'l's	Eng. & Support Costs\$	Sales Tax	Total Cost \$/1000*			Process \$/1000*	Project \$/1000*	
Coal Handling	20,566	14,413	1,026	44,361	5,809	8.5	0	6,681	
Oxidant Feed	85,214	38,425	1,839	156,046	20,433	29.9	0	23,499	
Gasification and Ash Handling	24,062	15,702	1,171	51,745	6,776	9.9	5,133	8,464	
Raw Gas Cooling	82,035	40,318	4,147	145,493	19,051	27.9	32,010	26,100	
Acid Gas Removal	6,918	2,493	353	14,277	1,870	2.7	0	2,180	
Sulfur Recovery	2,590	1,217	2,049	5,990	784	1.1	0	902	
Tail Gas Treating	4,552	2,102	3,463	10,339	1,354	2.0	1,551	1,760	
Fuel Gas Expansion	6,954	2,063	4,018	13,393	1,754	2.6	0	2,017	
Steam, Condensate and BFW	754	271	13	1,357	178	3	0	204	
General Facilities	13,543	4,018	7,823	25,081	3,415	5.0	0	3,927	
Initial Chemicals and Catalysts	25,738	10,206	15,091	51,930	6,800	9.9	0	7,820	
TOTAL	272,946	147,134	10,855	522,289	68,391	100.0	38,694	83,691	

TOTAL PLANT INVESTMENT SUMMARY

	\$1000*	\$/MM BTU/HR**
Process Plant Investment and General Facilities	522,289	68.391
Process Contingency	38,694	5.066
Project Contingency	78,152	10.234
Total Plant Investment	639,135	83.691

\*Mid-1978 dollars

\*\*Based on 100 percent plant design power output of 7,636.8 MM Btu/hr Fuel Gas

#All materials and equipment that become a part of the plant facility

#Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

\$Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 4-3

PROCESS CONTINGENCIES  
TEXACO-BASED GASIFICATION FUEL GAS PLANT  
BASE CASES

Steam Cycle, psig/°F/°F	1450/900/900	1450/1000/1000
Steam Generated in Gas Coolers	Saturated	Superheated
Gas Temperature Entering Heat Recovery, °F	2,400	2,400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Nominal Capacity of Gasifiers, ST/day	1,375	1,375

<u>CASE DESIGNATION</u>	<u>EXT-SS</u>	<u>EXT-SH</u>
<u>PROCESS UNIT</u>		
Coal Handling	0	0
Oxidant Feed	0	0
Gasification	15	15
Ash Handling	5	5
Gas Cooling		
Radiant WHB	20	20
Convective WHB	25	N/A
Convective Superheater or Reheater	N/A	40
Acid Gas Removal	0	0
Sulfur Recovery (Claus)	0	0
Tail Gas Treating	15	15
Process Condensate Treating	0	0
Steam, Condensate, and BFW	0	0
Fuel Gas Expansion	0	0
Steam Superheater/Reheater	0	N/A
Steam Turbine-Generator	0	0
General Facilities	0	0

Table 4-4

PLANT FACILITIES INVESTMENT - TEXACO BASED FUEL GAS  
BASE CASES

Mid-1980 Dollars

	1450/900/900	1450/1000/1000
Steam Cycle, psig/°F/°F		
Steam Generated in Gas Coolers	Saturated	Superheated
Gas Temperature Entering Heat Recovery, °F	2,400	2,400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Size of Gasifiers, ST/d	1,375	1,375
Fuel Gas Production, 10 <sup>6</sup> Btu/hr*	6,664	7,637
Net By-Product Power, MW*	142.40	53.30
<u>CASE DESIGNATION</u>	<u>EXT-SS</u>	<u>EXT-SH</u>
Plant Facilities Investment Mid-1978 (\$1,000)	647,723	639,135
Plant Facilities Investment Mid-1980 (\$1,000)	822,608	811,701

\*Production at design capacity

### General Facilities

As expected, the cost for the general facilities is higher for the saturated steam base case. Since more power is generated in this case, the cooling water demand increases, and since the cooling tower represents the major cost of the general facilities, the overall cost of this unit is substantially increased relative to the superheated steam base case.

### TOTAL CAPITAL REQUIREMENT

The Total Capital Requirement for each case is defined as the sum of plant facilities investment, prepaid royalties, organization and startup costs, working capital, allowance for funds during construction and land costs. The plant facilities investment estimates (in mid-1978 dollars) for both cases studied have already been detailed in Table 4-1 and 4-2. The basis for estimating allowances for all of the other capital charges specified above is outlined in Table 4-5.

The mid-1980 Total Capital Requirements as defined above are shown in Table 4-6. The actual cost estimates were prepared in mid-1978 dollars. Mid-1980 dollar plant cost estimates were determined by increasing the mid-1978 dollar estimates by 27 percent. (The 27 percent represents experience with the escalation of installed costs for similar types of equipment in the two year period, from mid-1978 to mid-1980).

The constant dollar mid-1980 allowances for funds during construction (AFDC) were calculated as follows:

- Assuming construction to commence in January 1986 and end in December 1989 (a four year period), and assuming annual construction expenditures to be 15 percent, 25 percent, 35 percent, and 25 percent of the total funds required for the four years respectively, the actual current dollar capital outlays for each of the four years were calculated assuming an annual inflation rate of 10 percent.
- Interest charges on the current dollar capital outlays for each of the four years were calculated to December 1989 based on an interest rate of 12.25 percent per annum.
- The total current dollar investment, which includes escalated amounts for prepaid royalties, organization and startup costs, working capital, land and the AFDC charges, was de-escalated from December 1989 to July 1980 at the general inflation rate of 10 percent/year to generate the constant dollar, mid-1980 Total Capital Requirement shown in Table 4-6.

Table 4-5

**BASIS FOR ESTIMATING CAPITAL CHARGES**

<u>Item</u>	<u>Basis</u>
Prepaid Royalties	0.5 percent of the Plant Facilities Investment.
Organization and Startup Costs	<p>The organization and startup costs are intended to cover operator training, equipment check-out, major changes in plant equipment, extra maintenance, and inefficient use of coal and other materials during plant startup.</p> <p>An allowance of 3 percent of the plant facilities investment should be made to cover organization and startup costs.</p>
Working Capital	<p>Working capital is the sum of the following:</p> <ul style="list-style-type: none"><li>● Cost of a one month supply of coal at full capacity operation.</li><li>● Three months of labor costs.</li><li>● One month of all other operating costs (excluding coal) at full capacity operation.</li><li>● A contingency of 25 percent of the total of the above three items.</li></ul>
Allowance for Funds During Construction (AFDC)	<p>For a regulated utility company, the interest rate on debt (assumed to be 12.25 percent/annum for this study) is used to compute AFDC. For nonregulated companies, return on equity (assumed to be 20.00 percent/annum for this study) is used to calculate AFDC.</p>
Land	<p>Land costs have been estimated at \$5,000/acre in mid-1980 dollars.</p>

Table 4-6

**TOTAL CAPITAL REQUIREMENT  
FOR INVESTOR OWNED UTILITY PRODUCTION OF  
TEXACO-BASED FUEL GAS  
MID-1980 (\$1000)**

Steam Cycle, psig/°F/°F	1450/900/900	1450/1000/1000
Steam Generated in Gas Coolers	Saturated	Superheated
Gas Temperature Entering Heat Recovery, °F	2,400	2,400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Size of Gasifiers, ST/day	1,375	1,375
Fuel Gas Production, 10 <sup>6</sup> Btu/hr*	6,664	7,637
Net By-Products Power, MW*	142.40	53.30
<u>CASE DESIGNATION</u>	<u>EXT-SS</u>	<u>EXT-SH</u>
Plant Facilities Investment	822,608	811,701
Prepaid Royalties	4,113	4,059
Organization and Startup Costs	24,678	24,351
Working Capital	19,577	19,523
Land	950	875
AFDC**	<u>31,044</u>	<u>30,623</u>
Total Capital Requirement (\$1,000)	902,970	891,132
Total Capital Requirement (\$1,000/FOEB/D)#	27.70	26.76

\* Production at design capacity.

\*\* The mid-1980 AFDC was determined by the method described in the text, page 4-6 and 4-7.

# This value was derived by dividing Total Capital Requirement (in \$1,000) by the Fuel Oil Equivalent Barrel plant output per day, using a conversion factor of  $5.85 \times 10^8$  Btu/FOEB, for fuel gas. Similarly, electricity production was converted to a FOEB/day equivalent assuming an energy value of 9,000 Btu/kWh.

Note: There will be some differences in Working Capital and AFDC for nonregulated company ownership.

- The mid-1980 AFDC allowance was then determined by subtracting the estimated constant dollar mid-1980 estimates for all other capital requirements from the Total Capital Requirement.

It is interesting to note that this procedure provides a rather low estimate for the constant dollar AFDC allowance, i.e., 3.8 percent of the plant facilities investment. If the current dollar AFDC charges are examined, it can be seen that they represent approximately 17.6 percent of the escalated plant facilities investment.

The reason for this apparent discrepancy is the following: As construction costs are paid, they are no longer subject to inflation. However, all construction costs are de-escalated from December 1989 to mid-1980, thereby creating the illusion that inflation is tending to reduce the constant mid-1980 plant facilities investment, i.e., Table 4-6 shows that for Case EXT-SS, the constant dollar mid-1980 plant facilities investment is  $\$822.608 \times 10^6$ .

However, if the escalated December 1989 investment of  $\$1,721.440 \times 10^6$  is de-escalated at 10 percent/year for 9-1/2 years, an apparent mid-1980 investment of  $\$696.084 \times 10^6$  results. This would appear to indicate that inflation is helping to reduce the constant dollar plant facilities investment. Lenders understand this problem and therefore index interest rates to inflation to handle this problem and offset the constant dollar principal loss. Therefore, the bulk of the current dollar AFDC charges is being employed to offset principal loss due to inflation. The AFDC allowance shown in Table 4-6, therefore, represents the "real" or "inflation free" interest required by the loan institution which, for this study, has been set at 2.045 percent/year.

#### OPERATING AND MAINTENANCE (O&M) COSTS

Operating and maintenance costs have been divided into two categories: Fixed Operating Costs (including operating labor, maintenance labor and materials, and administrative and support labor) and Variable Operating Costs (including raw water, catalyst and chemicals and ash disposal). The basis for calculating both fixed and variable O&M charges is delineated in Tables 4-7. Table 4-8 enumerates the factors applied to each plant section in order to assess the total plant maintenance cost. A summary of mid-1980 operating costs for both cases is shown in Table 4-9.



Table 4-7

BASIS FOR CALCULATING OPERATING AND MAINTENANCE COSTS

<u>Item</u>	<u>Basis</u>
Fixed Operating Costs	<p>The fixed costs are essentially independent of the plant capacity factor and are composed of the following charges:</p> <ul style="list-style-type: none"><li>• Operating Labor</li><li>• Maintenance costs</li><li>• Overhead charges</li></ul> <p>These items are discussed below:</p>
Operating Labor	<p>The operating labor charge is computed using an average labor rate of \$20.00/person hour (mid-1980\$). This labor rate includes a 35 percent payroll burden.</p>
Maintenance Costs	<p>Annual maintenance costs are estimated as a percentage of the plant facilities investment (PFI), estimated on a section by section basis. The percentage of PFI to be used for each plant section is shown in Table 4-8.</p> <p>The maintenance costs are divided into maintenance labor and maintenance materials. A maintenance labor/materials ratio of 40/60 is used.</p>
Overhead Charges	<p>The only overhead charge to be included in the fixed costs for regulated utility producers is a charge for administrative and support (A &amp; S) labor. This overhead charge is 30 percent of the sum of the operating and maintenance labor.</p> <p>For nonregulated company producers, an additional charge of 0.7 percent of the plant facilities investment should be included in the overhead. This additional cost is associated with general and administrative expenses.</p>
Variable Operating Costs	<p>The variable operating costs are dependent upon the plant capacity factor (CF) and are composed of the following charges:</p> <ul style="list-style-type: none"><li>• Raw water</li><li>• Catalysts and chemicals and other consumables</li><li>• Ash and other waste disposal</li></ul> <p>These items are discussed on the following page.</p>

Table 4-7

BASIS FOR CALCULATING OPERATING AND MAINTENANCE COSTS  
(Continued)

<u>Item</u>	<u>Basis</u>
Raw Water	The first year raw water acquisition cost is 50¢/1,000 gallons (mid-1980\$). Treating costs and pumping costs are included in the operating and maintenance charges.
Catalysts and Chemicals and Other Consumables	The first year catalysts, chemicals and other consumable costs are to be determined by the contractor.
Ash and Other Waste Disposal	Solids disposal costs are to be estimated at \$5.00/dry ton (mid-1980\$). This charge is to be applied to nonhazardous wastes only.

Table 4-8

MAINTENANCE FACTORS

<u>Process Unit</u>	<u>Maintenance</u> <u>% of Installed</u> <u>Plant Section Cost/Yr</u>
Coal Handling	3.0
Oxidant Feed	2.0
Gasification and Ash Handling	4.5
Raw Gas Cooling	3.0
COS Hydrolysis	2.0
Acid Gas Removal	2.0
Sulfur Recovery and Tail Gas Treating	2.0
ZnO Treating	3.0
Fuel Gas Expansion	3.0
Steam, Condensate, and BFW	1.5
Steam Superheat/Reheat	2.0
Steam Turbine-Generator	1.5
General Facilities	1.5

Table 4-9

ANNUAL OPERATING AND MAINTENANCE COSTS - TEXACO-BASED FUEL GAS  
INVESTOR OWNED UTILITY - MID-1980 (\$1,000)

	1450/900/900	1450/1000/1000
	Saturated	Superheated
Steam Cycle, psig/°F/°F		
Steam Generated in Gas Coolers		
Gas Temperature Entering		
Heat Recovery, °F	2,400	2,400
Sulfur Removal, %	94.6	94.6
Oxidant Plant Compressor Drivers	Motors	Motors
Size of Gasifiers, ST/day	1,375	1,375
Fuel Gas Production, 10 <sup>6</sup> Btu/hr*	6,664	7,637
Net By-Products Power, MW*	142.40	53.30
<u>CASE DESIGNATION</u>	<u>EXT-SS</u>	<u>EXT-SH</u>
<u>FIXED OPERATING COSTS</u>		
Operating Labor	5,431	5,256
Maintenance Labor	8,277	8,420
Maintenance Materials	12,415	12,630
Administrative and Support Labor	<u>4,112</u>	<u>4,103</u>
Total Fixed Costs	30,235	30,408
<u>VARIABLE OPERATING COSTS (100% Capacity Factor)</u>		
Raw Water	1,311	1,002
Catalysts and Chemicals	1,464	1,164
Ash Disposal	<u>1,867</u>	<u>1,867</u>
Total Variable Costs	4,642	4,033

\*Production at design capacity.

Operating labor requirements are a function of the number of trains. Requirements for the two plants under consideration are shown below on a per shift basis.

	Saturated Steam Base Case EXT-SS	Superheated Steam Base Case EXT-SH
Control Room Operators	5	5
Field Operators	20	19
Foremen	2	2
Lab and Instrument Technicians	<u>4</u>	<u>4</u>
	31	30

In determining labor requirements, modern computer assistance (cathode ray tube consoles) is assumed to be available.

The initial and annual catalyst and chemicals are presented in Table 4-10. The initial costs for the saturated steam base case (EXT-SS) are about 80 percent higher than those for the superheated steam base case. This is primarily due to the fuel oil requirement for the saturated steam case, a requirement which also increases the annual catalyst and chemicals costs by about 17 percent. In the saturated steam case fuel oil is required for startup of the fired steam superheater/reheater, an average of four times yearly. For each startup, eight hours is the allocated time of fuel oil firing. Other major costs for the two cases are associated with the corrosion inhibitor and the surfactant used exclusively in plant cooling water, and the chemicals required in the Texaco waste water treatment.

TABLE 4-10

CATALYST AND CHEMICAL SUMMARY - BASE CASES

ITEM	UNIT COST	TOTAL REQUIREMENTS			TOTAL COST* (\$1000)		
		EXT-SS INITIAL	ANNUAL	EXT-S INITIAL	ANNUAL**	INITIAL	ANNUAL**
<b>BFV DEHYDRALIZER</b>							
H <sub>2</sub> SO <sub>4</sub> (93%)	\$ 49.76/TON	53.3 TON	33.2 TON		2.7	1.6	
NaOH (50%)	142.80/TON	5.5 TON	3.5 TON		0.8	0.5	
<b>BFV TREATING</b>							
Na <sub>2</sub> SO <sub>4</sub>	\$0.22/LB	7,111 LB	4,466 LB		1.6	1.0	
Hydrazine (35% soln)	\$1.00/LB	90,628 LB	56,917 LB		90.6	56.9	
Morpholine	\$0.86/LB	31,712 LB	19,920 LB		27.3	17.1	
<b>POLISHING</b>							
H <sub>2</sub> SO <sub>4</sub> (93%)	\$ 49.76/TON	35.4 TON	20.7 TON		1.8	1.0	
NaOH (50%)	142.80/TON	70.8 TON	41.5 TON		10.1	5.9	
<b>C.W. TREATING</b>							
Line	\$42.50/TON	507.7 TON	301.2 TON		21.6	12.8	
Soda Ash	\$78.00/TON	604.1 TON	532.2 TON		47.1	41.5	
H <sub>2</sub> SO <sub>4</sub> (93%)	\$49.76/TON	795.6 TON	636.3 TON	0.4 TON	39.6	31.7	0.02
Corrosion Inhibitor	\$ 0.80/LB	563 LB	196,600 LB	412 LB	158.9	156.9	0.33
Surfactant	\$ 0.60/LB	560 LB	196,100 LB	410 LB	119.2	117.7	0.25
Chlorine	\$135.00/TON	20.3 TON	14.8 TON		2.7	2.0	
Biocide	\$ 0.80/LB	22,510 LB	16,493 LB		18.0	13.2	
<b>SELEXYOL6 UNIT</b>							
Solvent	\$ 1.00/LB	908,660 LB	119,225 LB	908,660 LB	119.2	908.7	119.2
<b>CLAUS SULFUR PLANT</b>							
Catalyst	\$320.00/TON	153.8 TON	34.2 TON	153.8 TON	49.2	49.2	10.9
<b>STRETFORD PLANT</b>							
Chemicals	\$3504/TPD SULFUR				101.6	101.6	22.6
	\$2.13/TON SULFUR						
<b>BEAVON UNIT</b>							
Catalyst	\$154/ft <sup>3</sup>	1407 ft <sup>3</sup>	187.6 ft <sup>3</sup>	1407 ft <sup>3</sup>	216.7	216.7	28.9
<b>MISCELLANEOUS OFFSITES</b>							
Plant & Instrument Air Dryers		3,200 LB	3,200 LB		5.2	5.2	
Flare	\$12.22/BBL	4,500 BBL	4,500 BBL		55.0	55.0	
Texaco Waste Water Treating	\$16.50/BBL	65,500 BBL	9,357 BBL		214.9	214.9	
Fuel Oil System					154.3	N/A	N/A
					1,080.7	N/A	N/A
<b>TOTALS, MID-1978 DOLLARS</b>					2357.7	1276.8	916.5
<b>TOTALS, MID-1980 DOLLARS#</b>					2994.3	1621.5	1164.0

\* Mid-1978 Basis, except where noted

\*\* At 100 percent capacity

# These estimates were derived by escalating the mid-1978 costs at 27 percent.

## Section 5

### FINANCIAL ANALYSIS

Using the capital and operating expenses developed in the previous section, the cost of fuel gas from the two base case plant designs was determined. Cost estimating was performed by Fluor. The cost estimates thus derived were escalated by 27 percent in order to reach their equivalent value in mid-1980 dollars. This factor of 27 percent was chosen based on Fluor's experience with the escalation of similar equipment during the two year period between mid-1978 and mid-1980. All cost estimates are intended to represent those for mature technology plant designs. Because certain financial and technical parameters such as inflation rate, investment tax credits and overall plant efficiency are difficult to predict, a further objective of this section will be to analyze the sensitivity of the cost of fuel gas to changes in these parameters.

All evaluations in this section will be for the two base case plant designs, EXT-SS and EXT-SH. These designs have been described in previous sections. Briefly, the fundamental difference between these two designs is located in the high temperature gas cooling section in which saturated steam is generated in Case EXT-SS whereas superheated steam is generated in Case EXT-SH.

#### COST OF FUEL GAS

Calculations of the cost of fuel gas are based on the financial criteria given in Table 5-1. Costs are developed for two types of plant ownership, that of an investor owned utility and that of a nonregulated company. Those financial parameters which differ in these two cases of ownership are noted in Table 5-1. The high capacity factor used for the fuel gas plant designs reflects the high anticipated availability of the plants and the expectation that the fuel gas produced would be used to the limits that availability would allow.

The cost of fuel gas from the two base case plants is presented in Table 5-2. Costs are listed in both current dollars and mid-1980 dollars. The current

Table 5-1  
**FINANCIAL CRITERIA**  
**FOR REVENUE REQUIREMENT CALCULATIONS <sup>(1)</sup>**

Plant Location	• Southern Illinois
Post-1980 General Inflation Rate	• 10%/Year
Year of Plant Startup	• 1990
Design and Construction Period	• 4 Years
Project Book Life	• 30 Years for an Investor Owned Utility
	• 20 Years for a Nonregulated Company
Project Tax Life	• 13 years for Synfuels Plants
Tax Depreciation Method	• Sum-of-the-Year-Digits
Net Plant Salvage Value	• 10% of PFI
Delivered Coal Cost (Mid-1980s)	• \$1.30 /10 <sup>0</sup> Btu
Real Coal Price Escalation (Above General Inflation)	• 1%/Year
Property Tax Rate	• 2%/Year of Escalated PFI
Insurance Rate	• 1%/Year of Escalated PFI
Federal Income Tax Rate	• 46%
State Income Tax Rate	• 6%
Investment Tax Credit	• 10% of Escalated PFI. Normalized Over Period of Commercial Operation for Utility Ownership. Credited during construction period for non-regulated company ownership.
<b>Project Financing</b>	
<b>Investor Owned Utility</b>	
Common Equity	• 35% at 16%/Year After-Tax Return
Preferred Stock	• 15% at 12.75%/Year Dividend
Debt	• 50% at 12.25%/Year Interest
<b>Nonregulated Company</b>	
Common Equity	• 100% at 20%/Year After-Tax Return
Preferred Stock	• 0%
Debt	• 0%
Capacity Factor	• 90%
By-Product Electricity Credit	• 50 mills /KWh in Mid-1980s
	The Cost of Electricity is Allowed to Escalate at the General Inflation Rate

<sup>(1)</sup> This table is identical to Table 5-2/ page S-5.



dollar amounts represent the cost of fuel gas in the given year dollars, while the mid-1980 dollar amounts reflect the cost of fuel gas in the current year de-escalated at the general inflation rate of 10 percent to mid-1980. The fuel gas costs listed for nonregulated company ownership are based on a fixed requirement of 20 percent after tax return on equity.

Detailed calculations of the cost of fuel gas can be found in Appendices B and C. The eight tables in each appendix include a Capital Outlay Schedule, an Annual Capital Recovery Schedule, an Annual Revenue Requirements Schedule and an Annual Cash Flow Schedule for both investor owned utility ownership and nonregulated company ownership of the fuel gas plant designs EXT-SS and EXT-SH. For easy reference, a summary of the results from Table 5-2 follows:

	<u>Investor Owned Utility</u>		<u>Nonregulated Company</u>	
	<u>Mid-1980 Dollars</u>	<u>Current Dollars</u>	<u>Mid-1980 Dollars</u>	<u>Current Dollars</u>
<u>Case EXT-SS</u>				
Levelized				
Cost of Fuel Gas, \$/10 <sup>6</sup> Btu	3.27	19.11	5.32	24.51
<u>Case EXT-SH</u>				
Levelized				
Cost of Fuel Gas, \$/10 <sup>6</sup> Btu	3.39	19.81	5.15	23.74

Three important conclusions can be drawn from these results:

- Texaco-based fuel gas produced by a regulated utility company has the potential to be considerably lower in cost than the selling price of No. 2 fuel oil.
- Utility produced fuel gas will be significantly less expensive than non-regulated company production.
- There appears to be no incentive for the development of high temperature heat recovery equipment capable of generating superheated steam for Texaco-based fuel gas plants.

A major utility application for fuel gas would be as a replacement for No. 2 fuel oil. Based on information from the Department of Energy publication, "Cost and Quality of Fuel for Electric Utility Plants," the mid-1980 cost of No. 2 fuel oil was \$6.77/10<sup>6</sup> Btu. Although there has been some softening in crude oil and

Table 5-2  
**FUEL GAS PRODUCTION COST AND SELLING PRICE ESTIMATES (1)**

Case Designation	Investor Owned Utility Fuel Gas Plant			Nonregulated Company Fuel Gas Plant		
	EXT-SS	EXT-SH	EXT-SH	EXT-SS	EXT-SH	EXT-SH
Steam Generated in Gas Coolers Net Fuel Gas Production, 10 <sup>6</sup> Btu/Hr	Saturated 6664	Superheated 7637	Superheated 7637	Saturated 6664	Superheated 7637	Superheated 7637
Net By-Product Power, MW*	142.40	53.30	53.30	142.40	53.30	53.30
Total Capital Requirement For Startup in 1990, \$/FOEB**/Day	Current Dollars	Mid-1980 Dollars	Current Dollars	Current Dollars	Mid-1980 Dollars	Current Dollars
Cost of Fuel Gas #, \$/10 <sup>6</sup> Btu	68,503	27,700	66,178	26,760	68,404	27,660
First Year (1990)	11.63	4.27	11.56	4.25	14.48	5.32
Fifth Year (1994)	14.77	3.71	14.99	3.76	21.20	5.32
Tenth Year (1999)	20.67	3.22	21.47	3.35	34.14	5.32
Fifteenth Year (2004)	29.79	2.88	31.58	3.06	54.98	5.32
Twentieth Year (2009)	43.50	2.61	47.03	2.83	88.54	5.32
Levelized##	19.11	3.27	19.81	3.39	24.51	5.32

(1) This table is similar to Table S-3, page S-6.

\* Production at 100 percent of design capacity.

\*\* Barrels of distillate fuel oil (5.85 x 10<sup>6</sup> Btu/BBL) with higher heating value equivalent to fuel gas produced. Electricity credited at 9000 Btu/kWh.

# End of year cost.

## A levelized price is one which, if held constant, will yield the same return on common equity as the varying year-by-year values.

derived product prices from their mid-1980 values, the financial estimates presented in Table 5-2 indicate substantial potential for fuel cost savings based on utility ownership of mature technology Texaco-based fuel gas plants. It is critical to remember, however, that before such savings can be realized, Texaco's coal gasification technology must be demonstrated at the scale assumed as the basis for this study. It is also important to realize that the first few commercial scale Texaco-based fuel gas plants can be anticipated to cost appreciably more than the estimates presented for mature plants in this report. Therefore, it is not unreasonable to anticipate that the differential price between utility generated fuel gas and No. 2 fuel oil estimated in this study is substantially greater than that to be expected from the first few commercial fuel gas plants to be built.

The results of Table 5-2 clearly indicate that a substantial savings will be realized if a utility is producing its own fuel gas rather than buying the gas from nonregulated company producer. Because nonregulated companies require a higher return on equity and because a greater proportion of the nonregulated company capital, relative to that of an investor owned utility, is in the form of equity capital, it follows that the fuel gas cost is higher when produced by a nonregulated company.

However, unlike utilities which are limited to a certain maximum return on equity, nonregulated companies can and do maximize their returns by selling at the market price. For this reason the expected selling price of fuel gas from a nonregulated company would be the selling price, for No. 2 fuel oil (\$6.77 in mid-1980 dollars). When sold at this market price, the discounted cash flow rate of return for the nonregulated producer is found to be the following:


<u>Case</u>	<u>Discounted Cash Flow Rate of Return on Common Equity</u>
EKT-SS	30.41%
EKT-SH	32.55%

In order to understand why there is no economic incentive for superheating in the high temperature gas coolers, one must first know the method employed for crediting the by-product power generated by these fuel gas plants. The total

revenue required is based on capital and operating costs. Revenue from the by-product electricity is then subtracted from the total revenue required to obtain a net revenue requirement. This net revenue must be recovered through the sale of the principal product, in this case, fuel gas. The by-product electricity revenue used to derive the net revenue is determined by multiplying the power generated by the electricity credit. For the results of Table 5-2 the electricity credit was assumed to be 50 mills/kWh (in mid-1980). However, when the sensitivity of the cost of fuel gas to the electricity credit is measured, an interesting phenomenon results. Figure 5-1 shows the derived cost of fuel gas when the by-product electricity is credited at rates between 20 mills/kWh and 80 mills/kWh. Since the saturated steam case (EXT-SS) generates almost three times as much electricity as does the superheated steam case (EXT-SH), its consequent cost of fuel gas is more sensitive to electricity crediting than is the fuel gas cost for the superheated case. As a result the slopes of the lines in Figure 5-1 for Case EXT-SS, both regulated and nonregulated ownership, are more negative than the slopes of the lines for Case EXT-SH. Ultimately, as the electricity credit increases for a given type of plant ownership, the lines for EXT-SS and EXT-SH intersect. The electricity credit at the point of intersection of these lines will be henceforth referred to as the "limiting by-product credit."

Figure 5-1 reveals that, for an investor owned utility, when electricity is credited at a rate greater than or equal to 42 mills/kWh (the limiting by-product credit), fuel gas produced by design EXT-SS is less expensive than that by design EXT-SH. However, for a nonregulated company with a rate of return fixed at 20 percent, electricity credits must be greater than or equal to 63 mills/kWh before fuel gas from design EXT-SS is less costly than that from design EXT-SH. Because utilities would be expected to credit the by-product electricity at a marginal rate above 41 mills/kWh in 1980, the EXT-SS design produces less costly fuel gas than the superheating case. Similarly, since a nonregulated company would probably be able to sell its by-product electricity at an avoided cost greater than 63 mills/kWh, again the saturated steam design would produce less expensive fuel gas than the superheated steam case. In conclusion, whether fuel gas is produced by an investor owned utility or a nonregulated company (allowing only a 20 percent return on equity), there appears to be no incentive for developing the high temperature heat recovery equipment capable of generating superheated steam.

**FIGURE 5-1**  
**LEVELIZED COST OF FUEL GAS AT VARYING**  
**RATES OF ELECTRICITY CREDIT**




- \* EXT-SS FOR INVESTOR OWNED UTILITY OWNERSHIP
- EXT-SH FOR INVESTOR OWNED UTILITY OWNERSHIP
- EXT-SS FOR NONREGULATED COMPANY OWNERSHIP
- △ EXT-SH FOR NONREGULATED COMPANY OWNERSHIP

Because a nonregulated company would be expected to strive for the highest discounted cash flow (DCF) rate of return, it will be informative to consider the relative DCF returns at the various rates of by-product electricity crediting. Since the expected market price of fuel gas is higher than the cost of fuel gas derived for the case where the rate of return is fixed at 20 percent, the relative value of fuel gas to electric power increases when the nonregulated company sells fuel gas at the market. Accordingly, when this gas is sold at the market price, the electricity credit rate, above which plant design EXT-SS is more economical than EXT-SH, would be higher. This occurs because the saturated steam case generates more electricity and less fuel gas than does the superheated steam case. Figure 5-1 indicates that, at or above the electricity credit of 63 mills/kWh, saturated steam production is the best design alternative for a nonregulated company with a fixed 20 percent return on equity. However, Figure 5-2 shows that, at the same coal real escalation rate of 1 percent above inflation, an electricity credit of 98 mills/kWh is the by-product credit rate above which the saturated steam design yields the highest DCF return for a nonregulated producer selling fuel gas at the market price. Thus the results confirm the expectation that selling fuel gas at the market price increases the limiting by-product credit. Above this limiting by-product credit the most economic design choice is that of saturated steam generation in the high temperature gas coolers.

Figure 5-2 also shows the impact of different real escalation rates for fuel, both coal and fuel gas. In this analysis, electricity escalation is fixed at the general inflation rate and coal and fuel gas escalate at rates equal to or greater than the inflation rate. This diagram makes evident the conclusion that the limiting by-product credit varies in the same direction as the rate of fuel escalation. Higher rates of escalation result in higher limiting by-product credits. At the high escalation rate of 3 percent real, or 13.3 percent including inflation, the limiting by-product credit for nonregulated company ownership is 128 mills/kWh. Although it is possible that the nonregulated producer could obtain as much as 128 mills/kWh for its net by-product power, even if this were not to be the case, the small expected gain in DCF return for choosing design EXT-SH over EXT-SS at electricity credit rates below the limiting by-product credit may not offset the technical risks and costs associated with the highly developmental high temperature gas coolers which can superheat steam.

**FIGURE 5-2**  
**DISCOUNTED CASH FLOW RATE OF RETURN AS A FUNCTION**  
**OF THE ELECTRICITY CREDIT RATE GIVEN FIXED REAL**  
**RATES OF FUEL ESCALATION**



In summary, there appears to be no economic advantage to superheating steam in the gas coolers in the case of investor owned utility production of fuel gas. At best, under certain economic conditions there might be a marginal advantage to superheating in the case of nonregulated company ownership.

Finally, results from these Texaco fuel gas cost estimates are compared in Table 5-3 with updated cost estimates for oxygen-blown, Lurgi-based fuel gas production from Illinois No. 6 coal. The Lurgi cost estimates were first detailed in EPRI report AF-244. These costs were updated to mid-1978 dollars in report AP-1725. With these estimates the current financial analysis of a Lurgi-based fuel gas plant was performed in the same manner as the estimates for the present Texaco-based designs. Mid-1978 dollars were updated to mid-1980 dollars using a 27 percent escalation factor and the remainder of the analysis is based on the financial factors given in Table 5-1. The ammonia by-product credit assumed is \$120.00/short ton and the liquid hydrocarbons are credited both at \$3.00 /10<sup>6</sup> Btu and at \$0/10<sup>6</sup> Btu. It is important to realize that the original Lurgi fuel gas plant cost estimates were prepared over four years ago. It is therefore likely that these Lurgi estimates are not strictly consistent with the Texaco estimates as they do not incorporate any advances in Lurgi gasification technology that have probably resulted from the extensive experience gained at SASOL within recent years. These older Lurgi estimates have been included simply to provide a frame of reference for the newer Texaco projections. From Table 5-3 it appears that even when all three by-products of the Lurgi process (electricity, ammonia, and liquid hydrocarbons) are credited, fuel gas from a Lurgi-based plant utilizing Illinois No. 6 coal will be more costly than that from a Texaco-based plant.

#### ECONOMIC SENSITIVITY ANALYSIS

Because certain financial and technical parameters are difficult to project for a 1990 plant startup date, knowledge of the sensitivity of fuel gas cost to changes in certain key parameters is critical. Tables 5-4 and 5-5 illustrate the sensitivity to design and financial factors of first year and levelized fuel gas costs, respectively.

Considering the first year fuel gas cost sensitivities of Table 5-4, several interesting observations can be made:

- A reduction in the operating capacity factor from 90 to 70 percent causes an 18 to 21 percent increase in the first year cost of fuel gas.



Table 5-3

SUMMARY OF LURGI- AND TEXACO-BASED FUEL GAS

Type of Ownership Gasifier By-Products Credited	Investor Owned Utility		
	Texaco, 1375 SF/day Electricity	Lurgi, Oxygen-Blown Electricity	Oxygen-Blown Ammonia
Case Designation	EXT-SS	EXT-EH	MX
Total Capital Requirements* (Mid-1980, \$1000)	902,970	891,132	887,527
Total Capital Requirement (Mid-1980, \$1000/FOEB/day)**	27.70	26.76	30.99
Cost of Fuel Gas* (\$/10 <sup>6</sup> Btu)	4.27	4.25	5.28
1st Year in Mid-1980 Dollars	11.63	11.56	14.36
Levelized in Mid-1980 Dollars	3.27	3.39	4.08
Levelized in Current Dollars	19.11	19.81	23.85

Type of Ownership Gasifier By-Products Credited	Nonregulated Ownership		
	Texaco, 1375 SF/day Electricity	Lurgi, Oxygen-Blown Electricity	Oxygen-Blown Ammonia
Case Designation	EXT-SS	EXT-EH	MX
Total Capital Requirement* (Mid-1980, \$1000)	901,491	889,653	886,097
Total Capital Requirement (Mid-1980, \$1000/FOEB/day)**	27.66	26.72	30.94
Cost of Fuel Gas* (\$/10 <sup>6</sup> Btu)	5.32	5.15	6.48
1st Year in Mid-1980 Dollars	14.48	14.01	17.63
Levelized in Mid-1980 Dollars	5.32	5.15	6.48
Levelized in Current Dollars	24.51	23.74	29.87

\*Plant startup at beginning of 1990.

\*\*This value was derived by dividing total capital requirement in \$1000, by the Fuel Oil Equivalent plant output per day, using conversion factor of 5.85 x 10<sup>6</sup> Btu/FOEB for fuel gas. Similarly, electricity production was converted to a FOEB/Day equivalent assuming an energy value of 9,000 Btu/kWh. Hydrocarbons were credited in a like manner where noted.

- A real coal price escalation of 3 percent causes a 9 to 17 percent increase in the first year cost of fuel gas relative to that when the real coal escalation rate is taken to be 1 percent. The more substantial cost increases are associated with nonregulated company ownership.
- A 35 percent increase in the plant facilities investment causes a 17 to 21 percent increase in the cost of fuel gas.
- A lower (5%) annual inflation rate significantly reduces the first year cost of fuel gas produced by an investor owned utility, but it has little impact on the cost of nonregulated company produced gas. It is important to note that the impact of inflation on the constant dollar levelized gas cost for an investor owned utility is negligibly small.
- A 10 percent decrease in clean fuel gas efficiency results in more expensive fuel gas by up to 14 percent while a 10 percent increase in this efficiency can yield a savings of up to 11 percent.
- Governmental assistance in the form of a 25 percent Investment Tax Credit achieves approximately an 11 percent savings in the cost of fuel gas. Assistance in the form of a 75 percent loan guarantee yields a savings of between 28 and 31 percent.
- When the electricity credit is fixed at 50 mills/kWh and when a 30 percent return on common equity is required for a nonregulated owner, the most dramatic impact on fuel gas cost is attained.
- With the exception of this last change which has been analyzed in greater detail in previous discussions, all the changes in financial and technical parameters listed in Table 5-4 result in first year fuel gas costs which remain competitive with the costs of No. 2 fuel oil.

Table 5-4

FIRST YEAR (1990) FUEL GAS COST SENSITIVITY TO DESIGN AND FINANCIAL FACTORS

CONSTANT MID-1980 DOLLARS

	Investor Owned Utility Ownership of Case EXT-SS		Investor Owned Utility Ownership of Case EKY-SH		Nonregulated Company Ownership of Case EXT-SS		Nonregulated Company Ownership of Case EKY-SH	
	Cost Of Fuel Gas		Cost Of Fuel Gas		Cost Of Fuel Gas		Cost Of Fuel Gas	
	First Year \$/10 <sup>6</sup> Btu	% Change From Base	First Year \$/10 <sup>6</sup> Btu	% Change From Base	First Year \$/10 <sup>6</sup> Btu	% Change From Base	First Year \$/10 <sup>6</sup> Btu	% Change From Base
Base Case Results <sup>a</sup>	4.27	Base	4.25	Base	5.32	Base	5.15	Base
70% Capacity Factor Operation	5.16	+ 20.8	5.02	+ 18.1	6.46	+ 21.4	6.14	+ 19.2
3% Escalation in Real Coal Price <sup>b</sup>	4.73	+ 10.8	4.65	+ 9.4	6.24	+ 17.3	5.95	+ 15.5
35% Increase in Plant Facilities Investment	5.12	+ 19.9	4.98	+ 17.2	6.44	+ 21.1	6.12	+ 18.8
5% Annual Inflation Rate <sup>c</sup>	3.20	- 25.1	3.34	- 21.4	5.25	- 1.3	5.11	- 0.8
Clean Fuel Gas Efficiency Decrease by 10% <sup>d</sup>	4.86	+ 13.8	4.76	+ 12.0	6.03	+ 13.3	5.76	+ 11.8
Clean Fuel Gas Efficiency Increase by 10% <sup>e</sup>	3.79	- 11.2	3.83	- 9.9	4.75	- 10.7	4.66	- 9.5
25% Investment Tax Credit	--	--	--	--	4.73	- 11.1	4.65	- 9.7
Loan Guarantee (75% Debt at 12.25%/Year)	--	--	--	--	3.65	- 31.4	3.71	- 28.0
30% Return on Common Equity	--	--	--	--	8.80	+ 65.4	8.15	+ 58.3

see Table 5-6 for explanatory notes.

Table 5-5  
 LEVELIZED FUEL GAS COST SENSITIVITY TO DESIGN AND FINANCIAL FACTORS

CONSTANT MID-1980 DOLLARS

	Investor Owned Utility Ownership Of Case EXT-SS			Investor Owned Utility Ownership Of Case EXT-SH			Nonregulated Company Ownership Of Case EXT-SS			Nonregulated Company Ownership Of Case EXT-SH		
	Cost Of Fuel Gas		% Change From Base	Cost Of Fuel Gas		% Change From Base	Cost Of Fuel Gas		% Change From Base	Cost Of Fuel Gas		% Change From Base
	First Year \$/10 <sup>6</sup> Btu	Base		First Year \$/10 <sup>6</sup> Btu	Base		First Year \$/10 <sup>6</sup> Btu	Base		First Year \$/10 <sup>6</sup> Btu	Base	
Base Case Results*	3.27	Base		3.39	Base		5.32	Base		5.15	Base	
70% Capacity Factor Operation	3.80	+ 16.2		3.84	+ 13.3		6.46	+ 21.4		6.14	+ 19.2	
3% Escalation in Real Coal Price <sup>δ</sup>	4.55	+ 39.1		4.50	+ 32.7		6.24	+ 17.3		5.95	+ 15.5	
35% Increase in Plant Facilities Investment	3.70	+ 13.1		3.76	+ 10.9		6.44	+ 21.1		6.12	+ 18.8	
5% Annual Inflation Rate#	3.28	+ 0.3		3.41	+ 0.6		5.25	- 1.3		5.11	- 0.8	
Clean Fuel Gas Efficiency Decrease by 10%	3.74	+ 14.4		3.80	+ 12.1		6.03	+ 13.3		5.76	+ 11.8	
Clean Fuel Gas Efficiency Increase by 10%	2.88	- 11.9		3.05	- 10.0		4.75	- 10.7		4.66	- 9.5	
25% Investment Tax Credit	--			--			4.73	- 11.1		4.65	- 9.7	
Loan Guarantee (75% Debt at 12.25%/Year)	--			--			3.65	- 31.4		3.71	- 28.0	
30% Return on Common Equity	--			--			8.80	+ 65.4		8.15	+ 58.3	

See Table 5-6 for explanatory notes.

Table 5-6

NOTES FOR TABLES 5-4 AND 5-5

\*The Base Case financial parameters used are given in Table 5-1.

<sup>δ</sup> A 3 percent inflation free coal price escalation rate is equivalent to a 13.3 percent actual escalation rate when the general inflation rate is 10 percent/year.

#For this 5 percent annual inflation rate case, the following financial parameters were used:

	<u>Investor Owned Utility</u>	<u>Nonregulated Company</u>
Annual Return on Common Equity	10.73%	14.55%
Annual Preferred Stock Dividends	7.63%	--
Annual Interest on Debt	7.15%	--
Annual Coal Price Escalation	6.05%	6.05%

#The clean fuel gas efficiencies used were the following:

	<u>Case EXT-SS</u>	<u>Case EXT-SH</u>
Clean Fuel Gas Efficiency When Increased by 10%	71.14%	81.53%
Clean Fuel Gas Efficiency When Decreased by 10%	58.20%	66.71%

(Clean Fuel Gas Efficiency is the exported clean gas HHV x 100/coal feed HHV)

## Section 6

### DESIGN SENSITIVITY STUDIES

#### GENERAL

The primary objective of this study has been both to assess the cost of intermediate-Btu fuel gas produced by a Texaco-based coal gasification plant and to determine whether a savings in the cost of fuel gas could be realized by a design which provides for superheating of steam in the raw gas cooling section. However, four secondary objectives have been addressed in this study, and some interesting conclusions can be drawn from the results.

Each sensitivity study is composed of the evaluation of plant designs which process the same quantity of coal, but which differ from the base case designs in one or more ways. Each was performed with the same degree of accuracy as were the base cases. Results from these analyses are tabulated at the end of this section. The tables include summaries of operating results, summaries of power consumptions, energy balances, and lists of plant facilities investments. Also, included at the end of this section are summaries of total capital requirements, annual operating and maintenance costs, catalyst and chemical costs, and overall block flow diagrams. Two base cases and twelve substudy cases, or fourteen cases in total, were evaluated with the objective of assessing the impact of the four design changes on major performance parameters and on the cost of fuel gas.

The design sensitivities analyzed are:

- The use of a gas recycle to quench the hot gasifier effluent instead of the use of a radiant gas cooler
- Variations in the degree of sulfur removal
- The use of larger capacity gasifiers
- Variations in steam cycle temperature and pressure

The rationale behind each of these design changes, except that regarding the extent of sulfur removal, is that because of their association with expensive equipment items, their optimization has potential for reducing the cost of fuel gas produced by the resulting modified plant designs. The studies evaluating variations in the depth of sulfur removal allow for an understanding of the costs associated with meeting different levels of environmental control requirements.

Tables 6-1 and 6-2 summarize the results of these substudy cases for both investor owned utility and nonregulated company ownership of the fuel gas plants. The base cases which have been discussed throughout this report have been included for comparison purposes. The table headings for each of the fourteen designs indicate the major design changes associated with each plant study. The reader may find these tables a convenient reference for distinguishing the major characteristics of each design.

#### GAS RECYCLE DESIGN OPTION

The raw gas leaves the gasifier at a temperature in the neighborhood of 2400°F. It is difficult to recover heat from such high temperature, ash laden gas in convective type heat transfer equipment due to the "stickiness" and fouling characteristics of the ash at these temperatures. In the base case designs considered for this study, the hot gas is first cooled in radiant type heat exchangers to a temperature of approximately 1500°F, at which point it is possible to continue cooling the gas in convective type equipment. This radiant/convective heat transfer design represents the system that is currently being tested at the 150 ton/day scale in the Ruhrchemie plant as well as the design that has been chosen for the 1000 ton/day Cool Water plant. The radiant boiler used in these designs is an extremely large and costly vessel. It is therefore possible that if the radiant boiler could be eliminated, the plant capital cost could be reduced which would in turn lead to a reduction in the cost of fuel gas. One way to eliminate the radiant unit would be to recycle cold fuel gas from the particulate scrubber to quench the high temperature gasifier effluent gas to 1500°F. The mixed gases could then be further cooled in convective type heat transfer equipment.

The saturated steam base case (EXT-SS) and the saturated steam case with gas recycle (EXT-SS1), shown schematically in the overall block flow diagrams EXT-SS and EXT-SS1, represent the two alternative approaches to gas cooling. Both

Table 6-1

PRODUCTION COSTS AND SELLING PRICE ESTIMATES  
FOR TEMACO-BASED FUEL GAS (\*)  
(INVESTOR OWNED UTILITY, MID-1980 DOLLARS)

	1450/900/900	1450/900/900	1450/900/900	736/900	1450/1000/1000	1450/900/900
Steam Cycle, psig/°F/°F	1375	2200	2200	1375	1375	1375
Steam Generated in Gas Coolers	6664	6664	6664	7163	6558	6626
Gas Temperature Entering Heat Recovery, °F	142.40	142.40	105.96	88.92	125.32	136.61
Sulfur Removal, %	EXT-SS	EXT-SS*	EXT-SS1	EXT-SS2	EXT-SS4	EXT-SS5
Oxidant Plant Compressor Drivers	902,970	835,959	860,481	830,730	880,614	923,423
Nominal Capacity of Gasifiers, \$T/day	27.70	25.65	27.04	26.34	27.57	28.65
Fuel Gas Production, 10 <sup>6</sup> Btu/hr	4.27	4.04	4.32	4.33	4.33	4.43
Net By-Product Power, MW	2.61	2.53	2.75	2.94	2.83	2.71
Case Designation	2009	2009	2009	2009	2009	2009
Total Capital Requirement for 1990 (\$1000)	2400	2400	1500	2400	2400	2400
Total Capital Requirement (\$1000/FOEB/day)	99.6	99.6	99.6	99.6	99.6	99.91
Fuel Gas Price when Electricity is Credited at 50 Mills/kWh	4.04	4.04	4.32	4.33	4.33	4.43
First Year (1990) \$/10 <sup>6</sup> Btu	2.53	2.53	2.75	2.94	2.83	2.71
Twentieth Year (2009) \$/10 <sup>6</sup> Btu	3.12	3.12	3.39	3.49	3.41	3.39
Levelized \$/10 <sup>6</sup> Btu						

	1450/1000/1000	1450/1000/1000	1450/900/900	736/900	1450/1000/1000	1450/1000/1000
Steam Cycle, psig/°F/°F	1375	2200	1375	1375	1375	1375
Steam Generated in Gas Coolers	7637	7637	7402	7637	7668	7621
Gas Temperature Entering Heat Recovery, °F	53.30	53.30	46.82	36.57	54.73	47.20
Sulfur Removal, %	EXT-SH	EXT-SH*	EXT-SH1	EXT-SH2	EXT-SH4	EXT-SH5
Oxidant Plant Compressor Drivers	851,132	819,814	800,543	811,730	832,277	902,610
Nominal Capacity of Gasifiers, \$T/day	26.76	24.62	24.94	25.43	26.34	27.34
Fuel Gas Production, 10 <sup>6</sup> Btu/hr	4.25	4.03	4.17	4.26	4.19	4.35
Net By-Product Power, MW	2.63	2.75	2.89	3.00	2.88	2.90
Case Designation	2009	2009	2009	2009	2009	2009
Total Capital Requirement for 1990 (\$1000)	2400	2400	1500	2400	2400	2400
Total Capital Requirement (\$1000/FOEB/day)	99.6	99.6	99.6	99.6	99.6	99.91
Fuel Gas Price when Electricity is Credited at 50 Mills/kWh	4.03	4.03	4.17	4.26	4.20	4.35
First Year (1990) \$/10 <sup>6</sup> Btu	2.63	2.75	2.89	3.00	2.80	2.90
Twentieth Year (2009) \$/10 <sup>6</sup> Btu	3.39	3.25	3.39	3.49	3.35	3.47
Levelized \$/10 <sup>6</sup> Btu						

(\*) This table is identical to Table S-6, page S-12.  
 A Case EXT-SS or EXT-SH with 2200 ton/day gasifiers.  
 # One ppm total sulfur in the product gas on a mole basis.  
 ## Production at design capacity.  
 # This value was derived by dividing Total Capital Requirement (in \$1000) by the Fuel Oil Equivalent Barrel output per day. Using a conversion factor of 5.85 x 10<sup>6</sup> Btu/FOEB for fuel gas. Similarly, electricity production was converted to a FOEB/day equivalent assuming an energy value of 9,000 Btu/kWh.  
 6 Electricity is credited at 50 Mills/kWh in Mid-1980 Dollars and is allowed to escalate at the general inflation rate.



Table 6-2

PRODUCTION COSTS AND SELLING PRICE ESTIMATES  
FOR TENACO-BASED FUEL GAS  
(NONREGULATED COMPANY, MID-1980 DOLLARS)

	1450/900/900	1450/900/900	1450/900/900	736/900	1450/800/800	1450/1000/1000	1450/900/900
Steam Cycle, psig/°F/°F	1450/900/900	1450/900/900	1450/900/900	736/900	1450/800/800	1450/1000/1000	1450/900/900
Steam Generated in Gas Coolers	←	←	←	Saturated	←	←	←
Gas Temperature Entering Heat Recovery, °F	←	←	←	1500	←	←	←
Sulfur Removal, %	←	←	←	94.6	←	←	←
Oxidant Plant Compressor Drivers	←	←	←	Motors	←	←	←
Nominal Capacity of Gasifiers, ST/day	1375	2200	6558	1375	6942	6558	6526
Fuel Gas Production, 10 <sup>6</sup> Btu/hr	6664	6664	7163	58.28	88.92	125.32	136.61
Net By-Product Power, MW	142.40	142.40	105.96	EXT-SS2	EXT-SS3	EXT-SS4	EXT-SS5
Case Designation	EXT-SS	EXT-SSA	EXT-SS1	879,398	847,685	879,179	921,904
Total Capital Requirement for 1990	901,491	834,613	859,089				
Startup (\$1000)				26.30	26.69	27.52	28.61
Total Capital Requirement (\$1000/FOB/day)	27.66	25.60	27.00				
Fuel Gas Price When Electricity is Credited at 50 Mills/MWh				5.24	5.26	5.36	5.50
First Year (1990) 5/10 <sup>6</sup> Btu	5.32	5.02	5.30				

	1450/1000/1000	1450/1000/1000	1450/900/900	736/900	1450/1000/1000	1450/1000/1000	1450/1000/1000
Steam Cycle, psig/°F/°F	1450/1000/1000	1450/1000/1000	1450/900/900	736/900	1450/1000/1000	1450/1000/1000	1450/1000/1000
Steam Generated in Gas Coolers	←	←	←	Superheated	←	←	←
Gas Temperature Entering Heat Recovery, °F	←	←	←	1500	←	←	←
Sulfur Removal, %	←	←	←	94.6	←	←	←
Oxidant Plant Compressor Drivers	←	←	←	Motors	←	←	←
Nominal Capacity of Gasifiers, ST/day	1375	2200	7402	7637	7637	7668	7621
Fuel Gas Production, 10 <sup>6</sup> Btu/hr	7637	7637	46.82	15.84	36.57	54.73	47.20
Net By-Product Power, MW	53.30	53.30	EXT-SH1	EXT-SH2	EXT-SH3	EXT-SH4	EXT-SH5
Case Designation	EXT-SH	EXT-SHA	EXT-SH1	810,411	830,317	880,330	901,108
Total Capital Requirement for 1990	889,653	818,476	799,263				
Startup (\$1000)				25.39	25.42	26.29	27.30
Total Capital Requirement (\$1000/FOB/day)	26.72	24.58	24.90				
Fuel Gas Price When Electricity is Credited at 50 Mills/MWh				5.10	5.04	5.09	5.26
First Year (1990) 5/10 <sup>6</sup> Btu	5.15	4.87	5.02				

\*Case EXT-SS or EXT-SH with 2200 ton/day gasifiers.

†One ppm total sulfur in the product gas on a mole basis.

#Production at design capacity.

##This value was derived by dividing Total Capital Requirement (in \$1000) by the Fuel Oil Equivalent Barrel output per day. Using a conversion factor of 5.85 x 10<sup>6</sup> Btu/FOB for fuel gas. Similarly, electricity production was converted to a FOB/day equivalent assuming an energy value of 9,000 Btu/kWh.

§Electricity is credited at 50 mills/kWh in Mid-1980 Dollars and is allowed to escalate at the general inflation rate.

cases process 11,000 tons/day of Illinois No. 6 coal. They have identical steam cycles, and the degree of sulfur removal is 94.6 percent in each case.

The option of using a gas recycle to quench the gasifier effluent reduces not only the quality but also the quantity of thermal energy recovered. With no quench gas recycle, Case EXT-SS has thermal energy available for recovery at a higher temperatures (the gas enters the heat recovery section at 2400°F) and produces 24 MW more power than the corresponding recycle Case EXT-SS1, in which gas enters the heat recovery section at the lower temperature of 1500°F. In the recycle case, steam generation is reduced to avoid the lower fuel gas reheater approach temperatures that would be required in order to transfer the same quantity of heat as is transferred in the nonrecycle design. Thus less heat is recovered, and the rejection of more heat to an air-cooled exchanger is a necessary consequence. Table 6-1 indicates that the fuel gas production in the EXT-SS case is  $6664 \times 10^6$  Btu/hr and is slightly lower than the  $6802 \times 10^6$  Btu/hr for the EXT-SS1 case. This result follows from the fact that EXT-SS produces more high-pressure steam and, therefore, more fuel gas is required in the fired heater for superheating and reheating. The energy recovery efficiency for the EXT-SS and EXT-SS1 cases is 77.11 and 75.27 percent respectively. As shown in Table 6-4, the power consumption summary, the major difference in power requirements is in the gas cooling section. For the EXT-SS case it is 941 kW, whereas for the EXT-SS1 case it is 6592 kW. This is due to the power requirements of the recycle gas compressors.

Tables 6-1 and 6-2 give a summary of the economic results for the gas recycle design option. By eliminating the radiant heat recovery unit, mid-1980 capital cost savings of 43 million dollars would be realized by an investor owned utility. However, the reduction in capital cost and the slight increase in net fuel gas output together do not offset the cost associated with both the reduction in efficiency and the increased power consumption of the quench gas recycle design. Consequently, the net impact on the mid-1980 levelized cost of fuel gas from an investor owned utility is a  $\$0.12/10^6$  Btu increase when the recycle option is employed. This increase is less than 4 percent of the fuel gas cost, and given the accuracy of the study, this differential is very small. This is a most encouraging result as it indicates the existence of an alternate approach to high temperature gas cooling to the radiant/convective configuration currently being considered. If scale-up of this approach is not successful, the alternate recycle configuration would be applied at essentially no cost penalty.

#### SULFUR REMOVAL DESIGN OPTIONS

In a Texaco-based GCC system, the cost of the acid gas removal, sulfur recovery and tail gas treating units is a relatively small fraction (approximately four percent) of the total plant investment. These same units constitute a much larger fraction (six to nine percent) of the total plant investment for a clean fuel gas plant. The impact of increased sulfur removal standards on fuel gas plant economics could be significant in terms of final product cost. Hence, sub-studies evaluating the impact of the depth of sulfur removal were performed.

The block flow diagrams EXT-SS and EXT-SS5 depict schematically the high-pressure saturated steam cases with 94.6 percent and +99.9 percent\* sulfur removal respectively. The block flow diagrams EXT-SH, EXT-SH4, and EXT-SH5 represent the schematic block flow diagrams for the high-pressure superheated steam cases, with 94.6 percent, 83.6 percent, and +99.9 percent\* sulfur removal respectively. The deep sulfur removal cases corresponding to 1 ppm total sulfur on a volume basis in the fuel gas require a COS hydrolysis step and zinc oxide treatment.

COS Hydrolysis. The substudy cases EXT-SS5 and EXT-SH5 are the only cases that include a COS hydrolysis step. The following overall reaction occurs in the presence of Haldor Topsoe, Inc. catalyst Type CKA:



Shifting the reaction equilibria to the right is favored by low temperatures and a high ratio of steam to dry gas. The operating temperature is maintained 50°F above the dew point of the gas to avoid pore condensation. This is accomplished by reheating the saturated gas leaving the particulate scrubber from 320°F to 370°F. COS concentration is reduced to 6.5 ppmv in the gas leaving the catalyst bed.

Acid Gas Removal. All cases utilize the Selexol® process for acid gas removal. In Cases EXT-SS5 and EXT-SH5 where sulfur is removed to the extent that only 5 ppmv sulfur on a mole basis remain in the gas leaving the acid gas removal unit, use of the Selexol® unit without the COS hydrolysis step would only be

---

\*Corresponding to 1 ppm total sulfur in the product fuel gas

possible through the use of uneconomical high solvent circulation and steam rates. In these cases, one ppm (mole basis) specification on the clean gas is made possible by passing reheated gas at 600°F through ZnO beds.

In general, acid gas removal processes tend to absorb both the hydrogen sulfide (H<sub>2</sub>S) and the carbon dioxide (CO<sub>2</sub>) present in the feed gas. Absorption of all of the CO<sub>2</sub> would increase the required solvent circulation rates, equipment sizes and energy demands. The design and size of the downstream sulfur recovery units are affected adversely due to the decrease in H<sub>2</sub>S concentration in the acid gas. However, the Selexol® process removes H<sub>2</sub>S in preference to CO<sub>2</sub>. The process has been selected for use in these cases because it accomplishes selective H<sub>2</sub>S removal and its economics compare favorably with other similar processes. In the Selexol® process applied here, the H<sub>2</sub>S concentration is over 20 percent in the acid gas feed to the sulfur recovery unit. At H<sub>2</sub>S concentrations in this range, a "split-flow" sulfur plant design is employed to avoid the use of fuel gas in the sulfur furnace. In the "split-flow" design, the flame in the sulfur furnace can be sustained by burning only acid gas.

Zinc Oxide Treatment. The Deep Sulfur Removal Cases (EXT-SS5 and EXT-SH5) with one ppm sulfur in the fuel gas are the only cases that include a ZnO treating unit. This involves passing the reheated fuel gas at 600°F from which most of the sulfur is removed through beds of ZnO (Type HTZ-3 by Haldor Topsoe, Inc.). Both COS and H<sub>2</sub>S are removed forming ZnS. Sizing of the units provides a one-year bed life, after which the spent bed is replaced with fresh ZnO.

The increased CO<sub>2</sub> absorption with greater depths of sulfur removal results in slightly reduced gas flow to the gas expander. Table 6-3, Summary of Operating Results, shows that less power production in the expander is a consequence. The COS hydrolysis process and the ZnO unit together produce additional pressure drops which further contribute to the reduced power generation by way of decreasing the inlet working pressure at the gas expander. Greater depths of sulfur removal are also associated with increased steam demands in the Selexol® unit, and as a result, less power is generated in the turbogenerator. Net system powers for the EXT-SS and EXT-SS5 cases are 142 and 137 MW respectively and for the EXT-SH, EXT-SH4 and EXT-SH5 cases are 53, 55 and 47 MW respectively.

The fuel gas production rates for the EXT-SS and EXT-SS5 cases are 6664 x 10<sup>6</sup> Btu/hr and 6626 x 10<sup>6</sup> Btu/hr respectively with the energy recovery efficiencies

at 77.11 and 76.24 percent for the two respective cases. For the EXT-SH, EXT-SH4, and EXT-SH5 cases, the fuel gas production rates are  $7637 \times 10^6$  Btu/hr,  $7668 \times 10^6$  Btu/hr and  $7621 \times 10^6$  Btu/hr respectively with energy efficiencies of 77, 79.20, and 78.08 percent for the three respective cases. As the depth of sulfur removal is increased, the fuel gas available for export is decreased slightly due to increased gas absorption in the Selexol® unit.

The initial and annual catalyst and chemicals for Cases EXT-SS5, EXT-SH4, and EXT-SH5 are presented in Table 6-34. Comparing these to the costs presented in Table 4-10 for the base cases, it may be seen that the costs associated with the Selexol® unit, Claus Sulfur Plant, and Stretford Plant increase as the level of sulfur removal is increased.


The mid-1980 capital cost associated with increasing sulfur removal from 94.6 percent to greater than 99.9 percent is 20.5 million dollars in cases where saturated steam is generated in the raw gas coolers. A smaller cost of 11.5 million is associated with the same change in extent of sulfur removal in the cases where superheated steam is generated in the gas coolers. The net impact of increased capital costs and decreased product and by-product output is an increase in investor owned utility constant dollar levelized cost of fuel gas from  $\$3.27/10^6$  Btu (EXT-SS) to  $\$3.39/10^6$  Btu (EXT-SS5). Table 6-1 reveals that a similar increase in depth of sulfur removal results in an increased constant dollar levelized cost of fuel gas as produced from a superheat design by  $\$.08/10^6$  Btu. Figure 6-1 displays, in graphical form, the levelized cost of fuel gas as a function of the depth of sulfur removal. Discontinuities are shown in the plot since the COS hydrolysis step is included at the +99.9 percent level and not at the 94.6 percent level.

As a percent of gas cost, almost complete sulfur removal costs only 3.7 percent more than does 94.6 percent sulfur removal.

#### GASIFIER CAPACITY DESIGN OPTION

The most expensive sections in a fuel gas plant apart from the oxidant feed system are the gasification/gas cooling systems. Decreases in capital requirement and cost of fuel gas may be realized through design changes in these two units. One of the options available is to increase the individual capacities of trains (reducing the number of trains) and to thus realize economies of scale.

**FIGURE 6-1**  
**SENSITIVITY OF FUEL GAS COSTS TO PERCENTAGE OF**  
**SULFUR REMOVAL**



**INVESTOR OWNED UTILITY PRODUCTION**

- \* SATURATED STEAM FUEL GAS PLANT DESIGN WITH A 1450 PSIG/900°F/900°F STEAM CYCLE, NO GAS RECYCLE AND 1375 TON/DAY CAPACITY GASIFIERS.
- O SUPERHEATED STEAM FUEL GAS PLANT DESIGN WITH A 1450 PSIG/1000°F/1000°F STEAM CYCLE, NO GAS RECYCLE AND 1375 TON/DAY CAPACITY GASIFIERS.

Two gasifier sizes were studied, one having a nominal coal processing capacity of 1375 tons/day and the other with a nominal capacity of 2200 tons/day. The smaller capacity gasifier used for the base case designs and cost estimates presented in this report is representative of the first generation commercial-scale Texaco gasifiers to be employed in the Cool Water demonstration plant. The larger, 2200 ton/day gasifiers represent a potential future extension of the Texaco technology after the smaller first generation systems have been successfully demonstrated. The objective of this substudy was to estimate the economic incentives to be associated with development of larger capacity Texaco gasifiers.

With the larger gasifiers, the number of gasification and gas cooling trains were reduced from eight operating and two spare to five operating and one spare, or from 25 to 20 percent spare capacity. Table 6-3 shows that the system performance remains essentially the same when larger gasifiers are used. However, the overall system availability would be somewhat reduced due to the reduction in spare capacity.

The total capital requirement for the four cases (EXT-SS, EXT-SS\*, EXT-SH, and EXT-SH\*) are presented in Table 6-1. As expected, the gasification and gas cooling unit mid-1980 costs are lower for the 2200 ton/day capacity gasifier cases. The effect of the larger gasifiers on the Total Plant Facilities Investment is a decrease of 7 to 8 percent. Detailed Capital Requirements and Operating and Maintenance Costs are shown in Tables 6-32 and 6-33. The 30-year levelized costs of fuel gas in mid-1980 dollars are  $\$3.27/10^6$  Btu and  $\$3.39/10^6$  Btu for the base cases EXT-SS and EXT-SH. These costs for the corresponding cases with the larger gasifiers are  $\$3.12/10^6$  Btu and  $\$3.25/10^6$  Btu respectively. Therefore, a small but significant savings could be realized through the development of these larger scale gasifiers.

#### STEAM CYCLE DESIGN OPTIONS

The oxygen-blown Texaco coal gasification process has significant steam raising capability in the raw gas cooling section. This allows for the development of Texaco-based clean fuel gas plant designs which can export as much as 150 MW of by-product electric power. Choices of steam cycle operating conditions can significantly impact the quantity of this by-product power generation which, together with an associated change in fuel gas output, has the potential for reducing the cost of gas produced.

Steam Pressure. The two steam cycle pressure options studied here include the base case design pressure of 1450 psig and an alternate design of a pressure of 736 psig. The low-pressure designs produce less by-product power and more fuel gas. As there is no reheat in the low-pressure case, power production will be reduced, relative to the high-pressure reheat design. Furthermore, the absence of a reheat results in less internal consumption of the product fuel gas. Material costs are also reduced when equipment operates at lower pressure. Therefore, three major changes result from reducing the steam cycle pressure from the base case condition (1450 psig) to 736 psig. By-product power generation is reduced; fuel gas production is increased; and material costs are lowered.

Results from two sets of designs allow us to evaluate the net impact of these changes on the costs of fuel gas. (Flow diagrams for these designs can be found under the appropriate names at the end of this section.) Table 6-1 shows that designs EXT-SS1 and EXT-SS2 are identical in all operating parameters except steam cycle conditions. While Case EXT-SS1 has a cycle which operates at 1450 psig and superheats and reheats the steam to 900°F, Case EXT-SS2 operates a steam cycle at 736 psig and superheats to 900°F but does not reheat. As anticipated, the low-pressure, non-reheat case generates less power by 47.68 MW, and more fuel gas, by  $361 \times 10^6$  Btu/hr. The low-pressure design requires a total capital outlay that is almost 30 million (mid-1980) dollars less than that for the high-pressure case.

Cases EXT-SH1 and EXT-SH2 allow for the evaluation of a low-pressure steam cycle in designs which superheat in the raw gas cooling section. Again, Table 6-1 shows that all operating parameters, except steam cycle pressure, are identical. Just as in the previous comparison, the low-pressure design, EXT-SH2, results in reduced by-product power, increased fuel gas production and a decreased total capital requirement.

Once again assessment of the economic incentives to design Texaco-based fuel gas plants with high-pressure, reheat steam cycles is complicated by the assignment of a value to the by-product electric power. All financial results shown in Table 6-1 for fuel gas costs generated by regulated utilities have been calculated on the basis of an electricity value of 50 mills/kWh in mid-1980 dollars. The following table summarizes pertinent fuel gas costs from Table 6-1 and presents equivalent fuel gas costs assuming electricity were to be credited at 100 mills/kWh in mid-1980 dollars.



Fuel Gas Production Costs For An  
Investor Owned Utility, Constant Mid-1980 Dollars

Case Designation	<u>EXT-SS1</u>	<u>EXT-SS2</u>	<u>EXT-SH1</u>	<u>EXT-SH2</u>
Steam Generated in Gas Coolers	Saturated	Saturated	Superheated	Superheated
Steam Cycle, psig/°F/°F	1450/900/900	736/900	1450/900/900	736/900
Fuel Gas Production, 10 <sup>6</sup> Btu/hr	6802	7163	7402	7637
Net By-product Power, MW	105.96	58.28	46.82	15.84
<u>Levelized Fuel Gas Cost, \$10<sup>6</sup> BTU</u>				
Electricity Credited at 50 mills/kWh	3.39	3.49	3.39	3.49
Electricity Credited at 100 mills/kWh	2.64	3.10	3.09	3.39

It is evident from the above results that at an electricity credit of 50 mills/kWh, the choice of steam cycle conditions has minor impact (~ 3%) on the cost of fuel gas. However, if the electricity credit is increased to 100 mills/kWh, going to the high-pressure, reheat steam cycle will have major impact (10 to 17%) on the cost of fuel gas produced.

Steam Superheat/Reheat Temperature. Three superheat and reheat temperatures with 1450 psig steam cycle designs are evaluated here. Higher steam temperatures increase the thermodynamic efficiency of the cycle. They also necessitate increased fuel gas consumption in the fired heater where superheating and reheating of steam occurs in designs with saturated steam production in the raw gas coolers. In summary, increasing steam cycle temperature yields increased power production and decreased net fuel gas output. Increasing temperature also increases demands on materials, and therefore total capital requirement changes in the same direction as the temperature.

The three temperatures evaluated in this study are 800°F, 900°F, and 1000°F. Designs EXT-SS3, EXT-SS1 and EXT-SS4 allow for the comparison of these different steam cycle temperatures since, in all other respects, their operating conditions are the same. That is, they all generate only saturated steam in the gas coolers; they all employ a quench gas recycle; and their depth of sulfur removal is 94.6 percent. As with all these sensitivity studies, the performance parameters, process flow diagrams, and detailed cost estimates are tabulated at the end of this section. Table 6-1 provides a summary of this information.

As in the previous case of steam cycle pressure, the impact of steam superheat/reheat temperatures on the cost of fuel gas is critically impacted by the value assigned to the by-product electric power. The financial results presented in Table 6-1 for fuel gas generated by a regulated utility have been calculated on the basis of an electricity value of 50 mills/kWh in mid-1980 dollars. The following table summarizes pertinent fuel gas costs from Table 6-1 and presents equivalent fuel gas costs assuming an electricity credit of 100 mills/kWh in mid-1980 dollars.

Fuel Gas Production Costs For An  
Investor Owned Utility, Constant Mid-1980 Dollars

Case Designation	<u>EXT-SS3</u>	<u>EXT-SS1</u>	<u>EXT-SS4</u>
Steam Generated in Gas Coolers	Saturated	Saturated	Saturated
Steam Cycle, psig/°F/°F	1450/800/800	1450/900/900	1450/1000/1000
Fuel Gas Production, 10 <sup>6</sup> Btu/hr	6942	6802	6658
Net By-product Power, MW	88.92	105.96	125.32
<u>Levelized Fuel Gas Cost, \$/10<sup>6</sup> BTU</u>			
Electricity Credited at 50 mills/kWh	3.41	3.39	3.36
Electricity Credited at 100 mills/kWh	2.80	2.64	2.46

As with the previous case, it can be seen that at an electricity credit of 50 mills/kWh, the impact of steam superheat/reheat temperatures on the cost of fuel gas is negligible (1%). However, at an electricity value of 100 mills/kWh, increasing superheat/reheat temperatures from 800°F to 1000°F will reduce the cost of fuel gas by 12 percent.

Table 6-3

SUMMARY OF OPERATING RESULTS - TEXACO GASIFICATION FUEL GAS PLANTS - ALL CASES

	Base Case	1450/900/900	1450/900/900	1450/800/800	1450/1000/1000	1450/900/900
Steam Cycle, psig/°F/°F	1375	2400	2400			2400
Gas Temperature Entering Heat Recovery, °F						94.6
Sulfur Removal, %						+99.9%
Nominal Capacity of Gasifier, ST/day	1375	2200	2200			
Case Designation	EXT-SS	EXT-SS*	EXT-SS1	EXT-SS3	EXT-SS4	EXT-SS5
<b>GASIFICATION</b>						
Coal Feed Rate, lb/hr m.f.						806.666
Oxygen/Coal Ratio, lb/lb m.f.						0.8921
Oxidant Temperature, °F						300
Slurry Water/Solids Feed Ratio, lb/lb m.f.						0.50308
Gasification Section Average Pressure, psig						600
Raw Gasifier Effluent Temperature, °F						2,400
Raw Gasifier Effluent HHV (dry basis), Btu/SCF**						275.8
Cold Gas Efficiency (raw gas HHV/coal feed HHV x 100), %						74.64
<b>POWER SYSTEM</b>						
Temperature of Fuel Gas to Gas Expander, °F						600
Gas Expander Exit Temperature, °F						195
Condenser Pressure, Inches Hg abs						2.5
Fired Heater Stack Temperature, °F						400
Gas Expander Power#, MW		258.97	227.98			61.75
Steam Turbine Power#, MW						179.43
Oxygen Plant Power#, MW						1.81
Power Consumed, MW		180.14	185.58			184.71
Net System Power, MW		142.40	105.96			58.28
<b>OVERALL SYSTEM</b>						
General Facilities Water Consumption, GPM						150
Land, Acres	190	188				190
Ash Disposal Rate, Dry, ST/day						1023
Sulfur By-Product, ST/day						354
Process & Deaerator Makeup Water, gal/ton DAF coal		77.19	76.53			77.02
Cooling Tower Makeup Water, gal/ton DAF coal		722.31	668.93			618.35
Cooling Water Circulation Rate, gal/ton DAF coal		37.48	34.71			32.50
Cooling Tower Heat Rejection, % of coal HHV		22.11	20.48			18.98
Air Cooler Heat Rejection, % of coal HHV		2.10	3.78			3.90
Clean Fuel Gas Efficiency (exported clean gas HHV x 100/coal feed HHV), %		64.67	66.01			69.51
Energy Recovery Efficiency (exported power + exported clean gas HHV)/coal feed HHV x 100, %		77.11	75.27			74.61
Clean Fuel Gas HHV (dry basis), Btu/SCF		566.63	578.25			282.3
Net Clean Fuel Gas Product, 10 <sup>3</sup> SCFD		65.03	66.37			608.95
Net Clean Fuel Gas Product, 10 <sup>3</sup> SCF/ton DAF coal		6664	6802			69.90
						64.32
						6626

\*One ppm total sulfur in product gas on a mole basis  
 #AT generator terminals  
 ##From power recovery expander 11-MS-1  
 \$\$\$Includes process and power plant portions

\*Case EXT-SS with 2200 ST/day gasifiers  
 on dry basis, 100 percent oxygen  
 \*\*Excluding the HHV of H<sub>2</sub>S, COS, and NH<sub>3</sub>

Table 6-3 (Continued)

SUMMARY OF OPERATING RESULTS - TERACO GASIFICATION FUEL GAS PLANTS - ALL CASES

Base Case	1450/1000/1000	1450/900/900	736/900	1450/1000/1000	1450/1000/1000	1450/1000/1000
Steam Cycle, psig/°F/°F						
Gas Temperature Entering Heat Recovery, °F						
Sulfur Removal, %						
Oxidant Plant Compressor Drivers						
Nominal Capacity of Gasifier, ST/day						
Case Designation						
<b>GASIFICATION</b>						
Coal Feed Rate, lb/hr m.f.						
Oxygen/Coal Ratio, lb/lb m.f.						
Oxidant Temperature, °F						
Slurry Water/Solids Feed Ratio, lb/lb m.f.						
Gasification Section Average Pressure, psig						
Raw Gasifier Effluent Temperature, °F						
Raw Gasifier Effluent HHV (dry basis), Btu/SCF**						
Cold Gas Efficiency (raw gas HHV/coal feed HHV x 100), %						
<b>POWER SYSTEM</b>						
Temperature of Fuel Gas to Gas Expander, °F						
Gas Expander Exit Temperature, °F						
Condenser Pressure, Inches Hg abs						
Fired Heater Stack Temperature, °F						
Gas Expander Power <sup>†</sup> , KW						
Steam Turbine Power <sup>†</sup> , KW						
Oxygen Plant Power <sup>†</sup> , KW						
Power Consumed, KW						
Net System Power, MW						
<b>OVERALL SYSTEM</b>						
General Facilities Water Consumption, GPM						
Land, Acres						
Ash Disposal Rate, Dry, ST/day						
Sulfur By-Product, ST/day						
Process and Deserator Makeup Water, gal/ton DAF coal						
Cooling Tower Makeup Water, gal/ton DAF coal						
Cooling Water Circulation Rate <sup>‡</sup> , mgal/ton DAF coal						
Cooling Tower Heat Rejection <sup>§</sup> , % of coal HHV						
Air Cooler Heat Rejection, % of coal HHV						
Clean Fuel Gas Efficiency (exported clean gas HHV x 100/coal feed HHV), %						
Energy Recovery Efficiency (exported power <sup>††</sup> + exported clean gas HHV)/coal feed HHV x 100, %						
Clean Fuel Gas HHV (dry basis), Btu/SCF						
Net Clean Fuel Gas Product, 10 <sup>6</sup> SCFD						
10 <sup>6</sup> SCF/ton DAF coal						
10 <sup>6</sup> Btu/hr						

\*Case EXT-SH with 2200 ST/day gasifiers  
 †Dry basis, 100 percent oxygen  
 \*\*Excluding the HHV of H<sub>2</sub>, CO<sub>2</sub>, and NH<sub>3</sub>  
 ††Generator terminals  
 ‡From power recovery expander 11-HE-1  
 §Includes process and power plant portions  
 ¶One ppm total sulfur in product gas on a mole basis  
 †††Power credited at 9000 Btu/KWh

Table 6-4

POWER CONSUMPTION SUMMARY (kW at Full Design Capacity)  
TEXACO GASIFICATION FUEL GAS PLANTS

Base Case	1450/900/900		1450/900/900		736/900		1450/800/800		1450/1000/1000		1450/900/900	
	←	→	←	→	←	→	←	→	←	→	←	→
Steam Cycle, psig/°F/°F	2400	1500	SATURATED		2400	199.9						
Steam Generated in Gas Coolers					91.6							
Gas Temperature Entering Heat Recovery, °F					MOTORS							
Sulfur Removal, %												
Oxidant Plant Compressor Drivers	1375	2200	1375									
Nominal Capacity of Gasifiers												
Case Designation	EXT-SS	EXT-SS*	EXT-SS1	EXT-SS2	EXT-SS3	EXT-SS4	EXT-SS5					
Plant Power, kW												
Unit	Unit Operation											
10	9,176	9,176	9,176	9,176	9,176	9,176	9,176	9,176	9,176	9,176	9,176	9,176
11	143,439	143,439	143,439	143,439	143,439	143,439	143,439	143,439	143,439	143,439	143,439	143,439
20	1,710	1,710	1,710	2,294	2,294	2,294	2,294	2,294	2,294	2,294	2,294	2,294
21	941	941	941	6,533	6,533	6,533	6,533	6,533	6,533	6,533	6,533	6,533
22	5,963	5,963	5,963	5,963	5,963	5,963	5,963	5,963	5,963	5,963	5,963	5,963
23	584	584	584	584	584	584	584	584	584	584	584	584
24	2,610	2,610	2,610	2,610	2,610	2,610	2,610	2,610	2,610	2,610	2,610	2,610
30	323	323	323	291	273	282	282	282	282	282	282	282
32-45	14,860	14,860	14,155	13,528	10,213	14,377	14,768	14,768	14,768	14,768	14,768	14,768
50	0	0	0	0	0	0	0	0	0	0	0	0
51	513	513	464	298	395	516	513	513	516	516	513	513
51	16	16	14	13	14	15	16	16	15	15	16	16
TOTAL PLANT POWER, kW	180,135	180,135	185,583	184,711	181,551	185,846	181,941	185,846	185,846	181,941	185,846	181,941
Power Produced, kW	322,530	322,530	291,540	242,990	270,470	311,170	318,550	311,170	311,170	311,170	318,550	318,550
New Power Output, kW	142,400	142,400	105,960	58,280	88,920	125,320	136,610	125,320	125,320	125,320	136,610	136,610

\* Case EXT-SS with 2200 SF/day gasifiers.  
 \*\* About 70 percent of this power demand is attributable to the cooling water system pumps and fans.  
 # This power requirement is largely derived from the coal pulverizing system and is, therefore, preliminary pending grinding tests on Illinois No. 6 coal.  
 ## For mechanical vacuum pump.

Table 6-4 (Continued)

POWER CONSUMPTION SUMMARY (KW at Full Design Capacity)  
TEBACO GASIFICATION FUEL GAS PLANTS

Case Designation Plant Power, KW Unit Operation	Base Case		SATURATED		EXT-SS2	EXT-SS3	EXT-SS4	EXT-SS5
	1450/1000/1000	1450/1000/1000	1450/900/900	736/900				
Steam Cycle, psig/°F	2400	2400	1500	2400				
Steam Generated in Gas Coolers	94.6	94.6						83.6
Gas Temperature Entering Heat Recovery, °F	1375	1375						499.9
Sulfur Removal, %								
Oxidant Plant Compressor Drivers								
Nominal Capacity of Gasifiers		2200	1375					
	EXT-SS	EXT-SS*	EXT-SS1	EXT-SS2	EXT-SS3	EXT-SS4	EXT-SS5	
10 Coal Handling#	9,176	9,176	9,176	9,176	9,176	9,176	9,176	9,176
11 Oxidant Feed	143,439	143,439	143,439	143,439	143,439	143,439	143,439	143,439
20 Gasification	1,710	1,710	2,294	1,710	1,710	1,710	1,710	1,710
21 Gas Cooling	941	941	6,546	6,508	924	947	952	952
22 Acid Gas Removal	5,953	5,953	5,953	5,953	5,492	5,492	7,487	7,487
23 Sulfur Recovery	584	584	584	584	486	486	627	627
24 Tail Gas Treating	2,610	2,610	2,610	2,610	2,181	2,181	2,947	2,947
30 Raw Water Treating	222	222	218	209	220	220	217	217
32-45 General Facilities**	12,377	12,377	12,649	13,694	12,328	12,328	12,293	12,293
50 Fuel Gas Expander	0	0	0	0	0	0	0	0
51 Steam System	70	70	182	80	79	68	69	69
Surface Condenser**	10	10	11	10	12	10	10	10
TOTAL PLANT POWER, KW	177,111	177,111	183,672	183,133	176,057	176,057	176,927	176,927
Power Produced, KW	230,410	230,410	230,490	198,950	71,610	230,790	226,130	226,130
New Power Output, KW	53,300	53,300	46,820	15,840	36,570	54,730	47,200	47,200

# About 70 percent of this power demand is attributable to the cooling water system pumps and fans

\* Case EXT-SH with 2200 ST/day gasifiers.

# This power requirement is largely derived from the coal pulverizing system and is, therefore, preliminary pending grinding tests on

Illinois No. 6 coal

\*\* For mechanical vacuum pump

Table 6-5

ENERGY BALANCE - BASE CASE EXT-SS  
AND CASE EXT-SS\*

Oxidant: 98 mole percent oxygen  
Gas Temperature Entering Heat Recovery: 2400°F  
Sulfur Removal: 94.6 percent

Gasifier: Texaco  
Steam: 1450 psig, 900°F/900°F superheat/reheat  
Oxidant Plant Compressor Drivers: Motors  
Basis: 60°F, water as liquid, 3.413 Btu/kWh

	HHV	10 <sup>6</sup> Btu/hr			Total
		Sensible	Latent	Radiation	
<b>IN</b>					
Coal	10,304	3	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	78
Air to Sulfur Recovery	-	1	1	-	2
Air to Fired Heater	-	4	1	-	5
Demineralized and Raw Water	-	2	-	-	2
Auxiliary Power Inputs	-	-	-	-	615
<b>TOTAL</b>	<b>10,304</b>	<b>33</b>	<b>57</b>	<b>-</b>	<b>11,009</b>
<b>OUT</b>					
Oxidant Compressors Inter/After Cooling	-	468	-	-	468
Condensate from Oxidant Plant	-	1	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	42
Process Water Cooling	-	227	-	-	227
Gasifier and WHB Heat Losses	-	-	-	123	123
Ash Cake	65	6	-	-	71
Process Wastewater	-	18	-	-	18
Raw Gas Trim Cooler	-	19	5	-	24
Selenol Refrigeration Cooler	-	59	-	-	59
Selenol Overhead Condenser	-	19	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	8
Steam Heat Losses	-	2	20	-	22
Fuel Gas Expander Power	-	-	-	-	211
Steam Turbine Power	-	-	-	-	884
Air Separation Plant Power	-	-	-	-	6
Fired Heater Flue Gas	-	74	76	-	150
Fired Heater Radiation Losses	-	-	-	18	18
Steam Turbine Condensers	-	1,632	-	-	1,632
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	22
Motor and Mechanical Losses**	-	-	-	-	116
Net Fuel Gas Export	6,664	60	-	-	6,724
<b>TOTAL</b>	<b>6,897</b>	<b>2,626</b>	<b>141</b>	<b>141</b>	<b>10,996</b>

In-Out x 100% = 0.12%

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent  
\*\*Case EXT-SS with 2200 ST/day gasifiers

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-6

ENERGY BALANCE - CASE EXT-SSI

Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 1500°F  
 Sulfur Removal: 94.6 percent

Gasifier: Texaco  
 Steam: 1450 psig, 900°F/900°F superheat/reheat  
 Oxidant Plant Compressor Drivers: Motors  
 Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HRV	Sensible	Latent	Radiation	Power	Total
<b>IN</b>	10,304	3	55	-	-	10,307
Coal	-	23	1	-	-	78
Air to Oxidant Feed System	-	1	4	-	-	2
Air to Sulfur Recovery	-	4	2	-	-	5
Air to Fired Heater	-	2	-	-	-	2
Demineralized and Raw Water	-	-	-	-	633	633
Auxiliary Power Inputs	-	-	-	-	633	633
<b>TOTAL</b>	<b>10,304</b>	<b>33</b>	<b>57</b>	<b>-</b>	<b>-</b>	<b>11,027</b>
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	468	-	-	-	-	468
Condensate from Oxidant Plant	1	-	-	-	-	1
Air Separation Plant Vent Gas	19	23	-	-	-	42
Process Water Cooling	202	-	-	-	-	202
Gasifier and WHB Heat Losses	-	-	-	115	-	115
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	81	117	-	-	198
Raw Gas Trim Cooler	-	19	5	-	-	24
Selecol Refrigeration Cooler	-	59	-	-	-	59
Selecol Overhead Condenser	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses*	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	778	778
Air Separation Plant Power	-	-	-	-	6	6
Fired Heater Plus Gas	-	64	65	-	-	129
Fired Heater Radiation Losses	-	-	-	15	-	15
Steam Turbine Condensers	-	1,466	-	-	-	1,466
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	20	20
Motor and Mechanical Losses**	-	-	-	-	115	115
Net Fuel Gas Export	6,802	63	-	-	-	6,865
<b>TOTAL</b>	<b>6,985</b>	<b>2,511</b>	<b>247</b>	<b>130</b>	<b>1,130</b>	<b>11,003</b>

In-Out x 100% = 0.22%  
 in

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent  
 \*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites



Table 6-7

ENERGY BALANCE - CASE EXT-552

Gasifier: Texaco  
 Steam: 736 psig, 900°F superheat  
 Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 1500°F  
 Oxidant Plant Compressor Drivers: Motors  
 Sulfur Removal: 94.6%

Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HHV	Sensible	Latent	10 <sup>6</sup> Btu/hr	Radiation	Power	Total
<b>IN</b>							
Coal	10,304	3	-	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	-	2
Air to Fired Heater	-	3	-	-	-	-	3
Demineralized and Raw Water	-	2	-	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	-	630	630
<b>TOTAL</b>	<b>10,304</b>	<b>32</b>	<b>56</b>	<b>-</b>	<b>-</b>	<b>630</b>	<b>11,022</b>
<b>OUT</b>							
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	-	42
Process Water Cooling	-	202	-	-	-	-	202
Gasifier & WHB Heat Losses	-	-	-	117	-	-	117
Ash Cake	65	6	-	-	-	-	71
Process Wastewater	-	18	-	-	-	-	18
Raw Gas Air Cooler	-	85	124	-	-	-	209
Raw Gas Trlm Cooler	-	19	5	-	-	-	24
Selenol Refrigeration Cooler	-	59	-	-	-	-	59
Selenol Overhead Condenser	-	19	-	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	-	8
Steam Heat Losses*	-	2	20	-	-	-	22
Fuel Gas Expander Power	-	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	-	612	612
Air Separation Plant Power	-	-	-	-	-	6	6
Fired Heater Flue Gas	-	36	37	-	-	-	73
Fired Heater Radiation Losses	-	-	-	9	-	-	9
Steam Turbine Condensers	-	1,314	-	-	-	-	1,314
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	-	17	17
Motor and Mechanical Losses**	-	-	-	-	-	112	112
Net Fuel Gas Export	7,163	64	-	-	-	-	7,227
<b>TOTAL</b>	<b>7,346</b>	<b>2,336</b>	<b>216</b>	<b>126</b>	<b>-</b>	<b>958</b>	<b>10,992</b>

$\frac{\text{In-Out}}{\text{In}} \times 100\% = 0.27\%$

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-8

ENERGY BALANCE - CASE EXT-SS3

Gasifier: Texaco  
 Oxidant: 98 mole percent oxygen  
 Steam: 1450 psig, 800°F/800°F superheat/reheat  
 Gas Temperature Entering Heat Recovery: 1500°F  
 Oxidant Plant Compressor Drivers: Motors  
 Sulfur Removal: 94.6 percent  
 Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HRV	Sensible	Latent	Radiation	Power	Total
<b>IN</b>						
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	2
Air to Fired Heater	-	4	1	-	-	5
Deminerallized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	620	620
<b>TOTAL</b>	<b>10,304</b>	<b>33</b>	<b>57</b>	<b>-</b>	<b>620</b>	<b>11,014</b>
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	202	-	-	-	202
Gasifier and WHB Heat Losses	-	-	-	115	-	115
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	81	117	-	-	198
Raw Gas Trim Cooler	-	19	5	-	-	24
Selexol Refrigeration Cooler	-	59	-	-	-	59
Selexol Overhead Condenser	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses*	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	706	706
Air Separation Plant Power	-	-	-	-	6	6
Fired Heater Plus Gas	-	53	54	-	-	107
Fired Heater Radiation Losses	-	-	-	13	-	13
Steam Turbine Condensers	-	1,407	-	-	-	1,407
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	19	19
Motor and Mechanical Losses**	-	-	-	-	101	101
Net Fuel Gas Export	6,942	62	-	-	-	7,004
<b>TOTAL</b>	<b>7,125</b>	<b>2,440</b>	<b>236</b>	<b>128</b>	<b>1,043</b>	<b>10,972</b>

In-Out x 100% = 0.38%

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-9  
ENERGY BALANCE - CASE EXT-554

Oxidant: 98 mole percent oxygen  
Gas Temperature Entering Heat Recovery: 1500°F  
Sulfur Removal: 94.6 percent

Gasifier: Texaco  
Steam: 1450 psig, 1000°F/1000°F superheat/reheat  
Oxidant Plant Compressor Drivers: Motors  
Basis: 60°F, water as liquid, 3,413 Btu/MWh

	HRV	Sensible	Latent	Radiation	Power	Total
<b>IN</b>						
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	2
Air to Fired Heater	-	4	1	-	-	5
Demineralized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	634	634
<b>TOTAL</b>	<b>10,304</b>	<b>33</b>	<b>57</b>	<b>-</b>	<b>634</b>	<b>11,028</b>
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	202	-	-	-	202
Gasifier and WHB Heat Losses	-	-	-	115	-	116
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	79	116	-	-	195
Raw Gas Trim Cooler	-	19	5	-	-	24
Selenol Refrigeration Cooler	-	59	-	-	-	59
Vertical Overhead Condenser	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses*	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	845	845
Air Separation Plant Power	-	-	-	-	6	6
Fired Heater Flue Gas	-	74	76	-	-	150
Fired Heater Radiation Losses	-	-	-	18	-	18
Steam Turbine Condensers	-	1,518	-	-	-	1,518
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	22	22
Motor and Mechanical Losses**	-	-	-	-	116	116
Net Fuel Gas Export	6,658	60	-	-	-	6,718
<b>TOTAL</b>	<b>6,841</b>	<b>2,568</b>	<b>257</b>	<b>134</b>	<b>1,200</b>	<b>11,000</b>

$$\frac{\text{In-Out}}{\text{In}} \times 100\% = 0.25\%$$

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-10

ENERGY BALANCE - CASE EXT-555

Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 2400°F  
 Sulfur Removal: +99.9 percent

Gasifier: Texaco  
 Steam: 1450 psig, 900°F/900°F superheat/reheat  
 Oxidant Plant Compressor Drivers: Motors  
 Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HHV	10 <sup>6</sup> Btu/hr			Total
		Sensible	Latent	Radiation	
<b>IN</b>					
Coal	10,304	3	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	78
Air to Sulfur Recovery	-	1	1	-	2
Air to Fired Heater	-	4	1	-	5
Deminerallized and Raw Water	-	2	2	-	4
Auxiliary Power Inputs	-	-	-	-	621
<b>TOTAL</b>	<b>10,304</b>	<b>33</b>	<b>57</b>	<b>-</b>	<b>11,015</b>
<b>OUT</b>					
Oxidant Compressors Inter/After Cooling	-	468	-	-	468
Condensate from Oxidant Plant	-	1	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	42
Process Water Cooling	-	227	-	-	227
Gasifier and WHB Heat Losses	-	-	-	118	118
Ash Cake	65	6	-	-	71
Process Wastewater	-	18	-	-	18
Raw Gas Trim Cooler	-	19	5	-	24
Solexol Refrigeration Cooler	-	72	-	-	72
Solexol Overhead Condenser	-	60	-	-	60
Tail Gas Treating Unit Cooling	-	23	12	-	35
Sulfur By-product (31,117 lbs/hr)	121	2	-	-	123
Tail Gas Unit Vent Gas	4	1	9	-	14
Steam Heat Losses*	-	3	20	-	23
Fuel Gas Expander Power	-	-	-	-	208
Steam Turbine Power	-	-	-	-	873
Air Separation Plant Power	-	-	-	-	6
Fired Heater Flue Gas	-	74	76	-	150
Fired Heater Radiation Losses	-	-	-	18	18
Steam Turbine Condensers	-	1,598	-	-	1,598
Steam Turbine and Fuel Gas Expander Losses	-	-	-	22	22
Motor and Mechanical Losses**	-	-	-	-	116
Net Fuel Gas Export	6,626	60	-	-	6,686
<b>TOTAL</b>	<b>6,816</b>	<b>2,651</b>	<b>145</b>	<b>136</b>	<b>10,973</b>

$\frac{In-Out}{In} \times 100\% = 0.38\%$

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-11

ENERGY BALANCE - BASE CASE EXT-SH  
AND CASE EXT-SH\*

Gasifier: Texaco

Steam: 1450 psig, 1000°F/1000°F superheat/reheat

Oxidant: 98 mole percent oxygen

Oxidant Plant Compressor Drivers: Motors

Gas Temperature Entering Heat Recovery: 2400°F

Basis: 60°F, water as liquid, 3,413 Btu/kWh

Sulfur Removal: 94.6 percent

	HRV	Sensible	Latent	Radiation	Power	Total
		10 <sup>6</sup> Btu/hr				
<b>IN</b>						
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	2
Deminerlized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	604	604
<b>TOTAL</b>	<b>10,304</b>	<b>29</b>	<b>56</b>	<b>-</b>	<b>604</b>	<b>10,993</b>
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	227	-	-	-	227
Gasifier and WHB Heat Losses	-	-	-	113	-	113
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	47	50	-	-	97
Raw Gas Trim Cooler	-	19	5	-	-	24
Selekol Refrigeration Cooler	-	59	-	-	-	59
Selekol Overhead Condenser	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,480 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	570	570
Air Separation Plant Power	-	-	-	-	6	6
Steam Turbine Condensers	-	1,034	-	-	-	1,034
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	16	16
Motor and Mechanical Losses**	-	-	-	-	105	105
Net Fuel Gas Export	7,637	69	-	-	-	7,708
<b>TOTAL</b>	<b>7,820</b>	<b>2,012</b>	<b>115</b>	<b>113</b>	<b>908</b>	<b>10,968</b>

In-Out  
in x 100% = 0.23%

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-12

ENERGY BALANCE - CASE EXT-SHI

Gasifier: Texaco

Oxidant: 98 mole percent oxygen

Steam: 1450 psig, 900°F/900°F superheat/reheat

Gas Temperature Entering Heat Recovery: 1500°F

Oxidant Plant Compressor Drivers: Motors

Sulfur Removal: 94.6 percent

Basis: 60°F, water as liquid, 3,413 Btu/KWh

	IN	HRV	Sensible	Latent	Radiation	Power	Total
Coal		10,304	3	-	-	-	10,307
Air to Oxidant Feed System		-	23	55	-	-	78
Air to Sulfur Recovery		-	1	1	-	-	2
Air to Fired Heater		-	1	-	-	-	1
Demineralized and Raw Water		-	2	-	-	-	2
Auxiliary Power Inputs		-	-	-	-	627	627
TOTAL		10,304	30	56	-	627	11,017
<b>OUT</b>							
Oxidant Compressors Inter/After Cooling		-	468	-	-	-	468
Condensate from Oxidant Plant		-	1	-	-	-	1
Air Separation Plant Vent Gas		-	19	23	-	-	42
Process Water Cooling		-	202	-	-	-	202
Gasifier and WHB Heat Losses		-	-	-	116	-	116
Ash Cake		65	6	-	-	-	71
Process Wastewater		-	18	-	-	-	18
Raw Gas Air Cooler		-	109	157	-	-	266
Raw Gas Trim Cooler		-	19	5	-	-	24
Selxol Refrigeration Cooler		-	59	-	-	-	59
Selxol Overhead Condenser		-	19	-	-	-	19
Tail Gas Treating Unit Cooling		-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)		115	2	-	-	-	117
Tail Gas Unit Vent Gas		3	1	4	-	-	8
Steam Heat Losses*		-	2	20	-	-	22
Fuel Gas Expander Power		-	-	-	-	211	211
Steam Turbine Power		-	-	-	-	570	570
Air Separation Plant Power		-	-	-	-	6	6
Fired Heater Flue Gas		-	18	20	-	-	38
Fired Heater Radiation Loss		-	-	-	4	-	4
Steam Turbine Condensers		-	1,098	-	-	-	1,098
Steam Turbine and Fuel Gas Expander Losses		-	-	-	-	16	16
Motor and Mechanical Losses**		-	-	-	-	108	108
Net Fuel Gas Export		7,402	57	-	-	-	7,459
TOTAL		7,585	2,129	242	120	911	10,987

In-Out x 100% = 0.27%

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-13

ENERGY BALANCE - CASE EXT-SH2

Gasifier: Texaco  
 Steam: 736 psig, 900°F superheat  
 Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 1500°F  
 Oxidant Plant Compressor Drivers: Motors  
 Sulfur Removal: 94.6 percent  
 Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HHV	10 <sup>6</sup> Btu/hr			Total
		Sensible	Latent	Radiation	
<b>IN</b>					
Coal	10,304	3	55	-	10,307
Air to Oxidant Feed System	-	23	-	-	78
Air to Sulfur Recovery	-	1	1	-	2
Demineralized and Raw Water	-	2	-	-	2
Auxiliary Power Inputs	-	-	-	-	625
<b>TOTAL</b>	<b>10,304</b>	<b>29</b>	<b>56</b>	<b>-</b>	<b>11,014</b>
<b>OUT</b>					
Oxidant Compressors Inter/After Cooling	-	468	-	-	468
Condensate from Oxidant Plant	-	1	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	42
Process Water Cooling	-	202	-	-	202
Gasifier and WHB Heat Losses	-	-	-	118	118
Ash Cake	65	6	-	-	71
Process Wastewater	-	18	-	-	18
Raw Gas Air Cooler	-	111	159	-	270
Raw Gas Trim Cooler	-	19	5	-	24
Selenol Refrigeration Cooler	-	59	-	-	59
Selenol Overhead Condenser	-	19	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	8
Steam Heat Losses*	-	2	20	-	22
Fuel Gas Expander Power	-	-	-	-	211
Steam Turbine Power	-	-	-	-	462
Air Separation Plant Power	-	-	-	-	6
Steam Turbine Condensers	-	1,001	-	-	1,001
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	14
Motor and Mechanical Losses**	-	-	-	-	107
Net Fuel Gas Export	7,637	69	-	-	7,706
<b>TOTAL</b>	<b>7,820</b>	<b>2,018</b>	<b>224</b>	<b>118</b>	<b>10,986</b>

In-Out x 100% = 0.31%

\*Includes tracing, miscellaneous process users, sulfur melting steam and deserator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-14

ENERGY BALANCE - CASE EXT-SH3  
 Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 2400°F  
 Sulfur Removal: 94.6 percent

Gasifier: Texaco  
 Steam: 736 psig, 500°F superheat  
 Oxidant Plant Compressor Drivers: Steam Turbines  
 Basis: 50°F, water as liquid, 3,413 Btu/kWh

IN	HRV	Sensible	Latent	Radiation	Power	Total
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	1	1	-	-	2
Deminerallized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	120	120
TOTAL	10,304	29	56	-	120	10,509
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	227	-	-	-	227
Gasifier and WHB Heat Losses	-	-	-	120	-	120
Ash Cake	60	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	32	34	-	-	66
Raw Gas Trim Cooler	-	19	5	-	-	24
Selezol Refrigeration Cooler	-	59	-	-	-	59
Selezol Overhead Condensate	-	19	-	-	-	19
Tail Gas Treating Unit Cooling	-	21	13	-	-	34
Sulfur By-product (29,490 lbs/hr)	115	2	-	-	-	117
Tail Gas Unit Vent Gas	3	1	4	-	-	8
Steam Heat Losses*	-	2	20	-	-	22
Fuel Gas Expander Power	-	-	-	-	211	211
Steam Turbine Power	-	-	-	-	28	28
Air Separation Plant Power	-	-	-	-	6	6
Steam Turbine Condensers	-	1,138	-	-	-	1,138
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	5	5
Motor and Mechanical Losses**	-	-	-	-	97	97
Net Fuel Gas Export	7,637	69	-	-	-	7,706
TOTAL	7,820	2,101	99	120	347	10,487

$\frac{\text{In-OUT}}{\text{In}} \times 100\% = 0.21\%$

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites



Table 6-15

ENERGY BALANCE - CASE EXT-SH4

Gasifier: Texaco

Oxidant: 98 mole percent oxygen

Steam: 1450 psig, 1000°/1000°F superheat/reheat

Gas Temperature Entering Heat Recovery: 2400°F

Oxidant Plant Compressor Drivers: Motors

Sulfur Removal: 83.6 percent

Basis: 60°F, water as liquid, 3,413 Btu/kWh

	10 <sup>6</sup> Btu/hr					Total
	HHV	Sensible	Latent	Radiation	Power	
<b>IN</b>						
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	-	1	-	-	1
Deminerlized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	601	601
TOTAL	10,304	28	56	-	601	10,989
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	227	-	-	-	227
Gasifier and WHB Heat Losses	-	-	-	121	-	121
Ash Cake	65	6	-	-	-	71
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	46	50	-	-	96
Raw Gas Trim Cooler	-	19	5	-	-	24
Selexol Refrigeration Cooler	-	57	-	-	-	57
Selexol Overhead Condenser	-	10	-	-	-	10
Tail Gas Treating Unit Cooling	-	16	15	-	-	31
Sulfur By-product (26,020 lbs/hr)	101	2	6	-	-	103
Tail Gas Unit Vent Gas	10	1	20	-	-	17
Steam Heat Losses*	-	1	-	-	-	1
Fuel Gas Expander Power	-	-	-	-	212	212
Steam Turbine Power	-	-	-	-	569	569
Air Separation Plant Power	-	-	-	-	6	6
Steam Turbine Condensers	-	1,024	-	-	-	1,024
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	16	16
Motor and Mechanical Losses**	-	-	-	-	104	104
Net Fuel Gas Export	7,668	69	-	-	-	7,737
TOTAL	7,844	1,984	119	121	907	10,975

$\frac{\text{In-Out}}{\text{In}} \times 100\% = 0.13\%$

\*Includes tracing, miscellaneous process users, sulfur melting steam and desaturator vent

\*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-16

ENERGY BALANCE - CASE EXT-SHS

Gasifier: Texaco  
 Oxidant: 98 mole percent oxygen  
 Gas Temperature Entering Heat Recovery: 2400°F  
 Sulfur Removal: +99.9 percent

Steam: 1450 psig, 1000°F/1000°F superheat/reheat  
 Oxidant Plant Compressor Drivers: Motors

Basis: 60°F, water as liquid, 3,413 Btu/kWh

	HFV	Sensible	Latent	Radiation	Power	Total
<b>IN</b>						
Coal	10,304	3	-	-	-	10,307
Air to Oxidant Feed System	-	23	55	-	-	78
Air to Sulfur Recovery	-	1	-	-	-	2
Deminerlized and Raw Water	-	2	-	-	-	2
Auxiliary Power Inputs	-	-	-	-	611	611
<b>TOTAL</b>	<b>10,304</b>	<b>29</b>	<b>56</b>	<b>-</b>	<b>611</b>	<b>11,000</b>
<b>OUT</b>						
Oxidant Compressors Inter/After Cooling	-	468	-	-	-	468
Condensate from Oxidant Plant	-	1	-	-	-	1
Air Separation Plant Vent Gas	-	19	23	-	-	42
Process Water Cooling	-	227	-	-	-	227
Gasifier and WHB Heat Losses	65	-	-	121	-	186
Ash Cake	-	6	-	-	-	6
Process Wastewater	-	18	-	-	-	18
Raw Gas Air Cooler	-	49	51	-	-	100
Raw Gas Trim Cooler	-	19	5	-	-	24
Selextol Refrigeration Cooler	-	72	-	-	-	72
Selextol Overhead Condenser	-	60	-	-	-	60
Tail Gas Treating Unit Cooling	-	23	12	-	-	35
Sulfur By-product (31,117 lb <sub>s</sub> /hr)	121	2	-	-	-	123
Tail Gas Unit Vent Gas	4	1	9	-	-	14
Steam Heat Losses*	-	3	20	-	-	23
Fuel Gas Expander Power	-	-	-	-	208	208
Steam Turbine Power	-	-	-	-	558	558
Air Separation Plant Power	-	-	-	-	6	6
Steam Turbine Condensers	-	988	-	-	-	988
Steam Turbine and Fuel Gas Expander Losses	-	-	-	-	16	16
Motor and Mechanical Losses**	-	-	-	-	106	106
Net Fuel Gas Export	7,621	69	-	-	-	7,690
<b>TOTAL</b>	<b>7,911</b>	<b>2,025</b>	<b>120</b>	<b>121</b>	<b>894</b>	<b>10,971</b>

In-Out in 100% = 0.26%

\*Includes tracing, miscellaneous process users, sulfur melting steam and deaerator vent  
 \*\*Includes all pump and turbine mechanical losses, power to waste water treatment, Unit 32 and other offsites

Table 6-17

PLANT FACILITIES INVESTMENT - BASE CASE EXT-SS  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/900°/900°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 6,664 x 10<sup>6</sup> Btu/hr\*\*  
Gas Temperature Entering Gas Cooling: 2400°F      Sulfur Removal: 94.6 percent      By-Product Power: 142.40 MW

Plant Section	Direct Field		Eng. & Support		Total Cost		Total Plant Investment	
	Mat. #	Labor #	Costs \$	Sales Tax	\$/10 <sup>6</sup> Btu/hr**	Per cent	\$1000*	\$/MM BTU/HR
Coal Handling	20,566	8,356	14,413	1,026	44,361	6.657	6,654	51,015
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	23.417	23,407	179,453
Gasification and Ash Handling	24,062	9,810	16,702	1,171	51,745	7.765	7,762	64,640
Raw Gas Cooling	71,124	16,455	34,929	3,590	126,098	18.923	22,825	167,836
Acid Gas Removal	6,918	2,493	4,513	353	14,277	2.142	2,142	16,419
Sulfur Recovery	2,590	1,217	2,049	134	5,990	.899	0	6,889
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1.552	1,551	13,441
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	2.010	2,009	15,402
Steam, Condensate and BFW	7,970	351	426	19	1,766	.265	0	2,031
Steam Superheat/Reheat	7,044	2,090	4,070	363	13,567	2.036	2,035	15,602
Steam Turbine Generator	20,858	6,189	12,049	1,074	40,170	6.028	6,026	46,196
General Facilities	28,485	11,526	16,801	963	57,775	8.670	8,666	66,441
Initial Chemicals and Catalysts					2,358	0.354	-	2,358
TOTAL	279,337	93,220	151,854	11,112	537,885	80.718	29,509	647,723

TOTAL PLANT INVESTMENT SUMMARY

	\$1000*	\$/MM BTU/HR**
Process Plant Investment and General Facilities	537,885	80.718
Process Contingency	29,509	4.428
Project Contingency	80,329	12.054
Total Plant Investment	647,723	97.200

\*\*Mid-1978 dollars

\*\*Based on 100 percent plant design power output of 6663.8 MM Btu/hr Fuel Gas

#All materials and equipment that become a part of the plant facility

##Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

§Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-1B

PLANT FACILITIES INVESTMENT - BASE CASE EXT-SS WITH 2200 ST/D GASIFIER  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/900°/900°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 6,664 x 10<sup>6</sup> Btu/hr\*\*  
Gas Temperature Entering Gas Cooling: 2400°F      Sulfur Removal: 94.6 percent      By-Product Power: 142.40 MW

Plant Section	Direct Field		Eng. & Support		Sales Tax		Total Cost		Contingencies		Total Plant Investment	
	Mat'l#	Labor#	Cost\$	Cost\$	Cost\$	Cost\$	\$/10 <sup>6</sup>	\$/1000*	\$/1000*	Project	\$/1000*	\$/MM BTU/HR
Coal Handling	19,807	8,051	13,907	991	42,756	6,416	8.5	0	6,413	0	49,169	7,380
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	23,417	31.2	0	23,407	0	179,453	26,930
Gasification and Ash Handling	20,344	8,185	14,008	993	43,530	6,532	8.7	4,105	6,530	4,105	54,165	8,128
Raw Gas Cooling	55,866	12,925	27,434	2,820	99,045	14,864	19.8	18,028	14,855	18,028	131,928	19,797
Acid Gas Removal	6,918	2,493	4,513	353	14,277	2,142	2.8	0	2,142	0	16,419	2,464
Sulfur Recovery	2,590	1,217	2,049	134	5,990	.899	1.2	0	.899	0	6,889	1,034
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1,552	2.1	1,551	1,551	1,551	13,441	2,017
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	2,010	2.7	0	2,009	0	15,402	2,311
Steam, Condensate and BFW	970	351	426	19	1,766	.265	.4	0	.265	0	2,031	305
Steam Superheat/Reheat	7,044	2,090	4,070	363	13,567	2,036	2.7	0	2,035	0	15,602	2,340
Steam Turbine Generator	20,858	6,189	12,049	1,074	40,170	6,028	8.0	0	6,026	0	46,196	6,932
General Facilities	28,210	11,434	16,724	963	57,331	8,603	11.4	0	8,600	0	65,931	9,894
Initial Chemicals and Catalysts	-	-	-	-	2,358	0.354	0.5	-	-	-	2,358	0.354
<b>TOTAL</b>	<b>254,327</b>	<b>87,668</b>	<b>141,086</b>	<b>10,129</b>	<b>500,568</b>	<b>75,118</b>	<b>100.0</b>	<b>23,684</b>	<b>74,732</b>	<b>23,684</b>	<b>598,984</b>	<b>89,886</b>

TOTAL PLANT INVESTMENT SUMMARY

	\$/1000*	\$/MM BTU/HR**
Process Plant Investment and General Facilities	500,568	75.118
Process Contingency	23,684	3.554
Project Contingency	74,732	11.214
<b>Total Plant Investment</b>	<b>598,984</b>	<b>89.886</b>

MID-1978 dollars

\*\*Based on 100 percent plant design power output of 6661.8 MM Btu/hr Fuel Gas

##All materials and equipment that become a part of the plant facility

##Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

###Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-19

TOTAL PLANT INVESTMENT - CASE EXT-SSI  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/900°/900°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 6,802 x 10<sup>6</sup> Btu/hr\*\*  
Gas Temperature Entering Gas Cooling: 1500°F      Sulfur Removal: 94.6 percent      By-Product Power: 105.96 MW

Plant Section	Cost Breakdown Without Contingencies				Total Cost \$/10 <sup>6</sup> Btu/hr**	Per-cent	Contingencies		Total Plant Investment \$/10 <sup>6</sup> Btu/hr**
	Direct Field Mat'l	Direct Field Labor#	Eng. & Support Costs\$	Sales Tax			Process \$1000*	Project \$1000*	
Coal Handling	20,565	8,356	14,413	1,026	44,361	6.522	0	6,654	51,015
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	22.942	0	23,407	179,453
Gasification & Ash Handling	36,915	13,511	23,907	1,820	76,154	11.196	8,613	11,423	96,190
Raw Gas Cooling	50,022	11,567	24,580	2,528	88,697	13.044	10,303	13,304	112,304
Acid Gas Removal	6,918	2,493	4,513	353	14,277	2.099	0	2,142	16,419
Sulfur Recovery	2,590	1,217	2,049	134	5,990	.881	0	899	6,889
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1.520	1,551	1,551	13,441
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	1.969	0	2,009	15,402
Steam Condensate & BFW	920	332	402	18	1,672	.246	0	251	1,923
Steam Superheat/Reheat	6,426	1,907	3,712	331	12,376	1.819	0	1,856	14,232
Steam Turbine Generator	18,776	5,571	10,848	967	36,162	5.317	0	5,424	41,586
General Facilities	28,149	11,315	16,580	962	57,006	8.361	0	8,551	65,557
Initial Catalysts and Chemicals	-	-	-	-	2,204	0.324	-	-	2,204
TOTAL	268,003	91,002	146,910	10,558	518,677	76.257	20,467	77,471	616,615

TOTAL PLANT INVESTMENT SUMMARY

	\$1000*	\$/10 <sup>6</sup> Btu/hr**
Process Plant Investment and General Facilities	518,677	76.257
Process Contingency	20,467	3.009
Project Contingency	77,471	11.390
Total Plant Investment	616,615	90.656

\*\*Mid-1978 dollars

\*Based on HRV of net fuel gas product at 100 percent capacity factor

#All materials and equipment that become a part of the plant facility

#Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

\$Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-20

TOTAL PLANT INVESTMENT - CASE EXT-SSZ  
MID-1978 DOLLARS

Steam Cycle: 736 psig/900°F  
Gas Temperature Entering Gas Cooling: 1500°F  
Oxidant Plant Compressor Drivers: Motors  
Sulfur Removal: 94.6 percent  
Product Fuel Gas: 7,163 x 10<sup>6</sup> Btu/hr\*\*  
By-Product Power: 58.28 MW

Plant Section	Direct Field Labor#		Direct Field Labor\$		Eng. & Support Costs\$		Total Cost \$/10 <sup>6</sup> Btu/hr**		Per-cent	Contingencies		Total Plant Investment \$/10 <sup>6</sup> Btu/hr**
	Mat'l\$	1500°F	Cost\$	Cost\$	Total \$/10 <sup>6</sup> Btu/hr**	Process \$/1000*	Project \$/1000*					
Coal Handling	20,566	8,356	14,413	1,026	44,361	6,193	8.9	0	6,654	51,015	7,122	
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	21,786	31.2	0	23,407	179,453	25,053	
Gasification & Ash Handling	36,916	13,511	23,907	1,820	76,154	10,632	15.2	8,613	11,423	96,190	13,429	
Raw Gas Cooling	48,405	11,193	23,785	2,447	85,830	11,983	17.2	10,408	12,873	109,111	15,233	
Acid Gas Removal	6,918	2,493	4,513	353	14,277	1,993	2.9	0	2,142	16,419	2,292	
Sulfur Recovery	2,590	1,217	2,049	134	5,990	.836	1.2	0	.999	6,889	.962	
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1,443	2.1	1,551	1,551	13,441	1,877	
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	1,870	2.7	0	2,809	15,402	2,150	
Steam Condensate & BFW	872	315	383	17	1,587	.222	0.3	0	238	1,825	.255	
Steam Superheat/Reheat	2,266	673	1,310	117	4,366	.610	0.9	0	655	5,021	.701	
Steam Turbine Generator	15,601	4,629	9,015	803	30,048	4,195	6.0	0	4,507	34,555	4,824	
General Facilities	27,390	10,957	16,127	944	55,418	7,737	11.0	0	8,313	63,731	8,898	
Initial Catalysts and Chemicals	258,244	88,077	141,408	10,080	499,612	69,752	100.0	20,572	74,671	594,855	83,048	

TOTAL PLANT INVESTMENT SUMMARY

	\$/1000*	\$/10 <sup>6</sup> Btu/hr**
Process Plant Investment and General Facilities	499,612	69,752
Process Contingency	20,572	2,872
Project Contingency	74,671	10,424
Total Plant Investment	594,855	83,048

\*\*MID-1978 dollars

\*\*Based on HHV of net fuel gas product at 100 percent capacity factor

##All materials and equipment that become a part of the plant facility

##Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

§Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 5-21

TOTAL PLANT INVESTMENT - CASE EXT-583  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/800°/800°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 6,942 x 10<sup>6</sup> Btu/hr<sup>AA</sup>  
Gas Temperature Entering Gas Cooling: 1500°F      Sulfur Removal: 94.6 percent      By-Product Power: 88.92 MW

Plant Section	Direct Field			Eng. & Support			Cost Breakdown Without Contingencies			Total Cost			Per-		Continuities		Total Plant Investment	
	Man	Hour	\$	Cost	Cost	\$	Man	Hour	\$	Man	Hour	\$	cent	Man	Hour	\$	Man	Hour
Coal Handling	20,566	8,356	14,413	1,026	44,361	6,390	8.7	0	6,654	51,015	7,349			0	6,654	51,015	7,349	
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	22,479	30.5	0	23,407	179,453	25,851			0	23,407	179,453	25,851	
Gasification & Ash Handling	36,916	13,511	23,907	1,820	76,154	10,971	14.9	8,613	11,423	96,190	13,857			8,613	11,423	96,190	13,857	
Raw Gas Cooling	48,891	11,304	24,022	2,471	86,688	12,488	16.9	9,883	13,003	109,574	15,785			9,883	13,003	109,574	15,785	
Acid Gas Removal	6,918	2,493	4,513	353	14,277	2,057	2.8	0	2,142	16,419	2,365			0	2,142	16,419	2,365	
Sulfur Recovery	2,590	1,217	2,049	134	5,990	863	1.2	0	899	6,889	992			0	899	6,889	992	
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1,489	2.0	1,551	1,551	13,441	1,936			1,551	13,441	1,936		
Fuel Gas Expansion	6,954	2,063	4,018	358	13,593	1,929	2.6	0	2,009	15,402	2,219			0	2,009	15,402	2,219	
Steam Condensate & BFV	895	324	392	17	1,628	235	0.3	0	244	1,872	270			0	244	1,872	270	
Steam Superheat/Reheat	4,738	1,406	2,739	244	9,128	1,315	1.7	0	1,369	10,497	1,512			0	1,369	10,497	1,512	
Steam Turbine Generator	18,509	5,491	10,692	953	35,645	5,134	7.0	0	5,347	40,992	5,905			0	5,347	40,992	5,905	
General Facilities	27,664	11,137	16,327	947	56,075	8,078	11.0	0	8,411	64,486	9,289			0	8,411	64,486	9,289	
Initial Catalysts and Chemicals	-	-	-	-	2,049	0,295	.4	-	-	2,049	295			-	-	2,049	295	
TOTAL	264,408	89,972	144,960	10,384	511,773	73,723	100.0	20,047	75,459	608,279	87,625			20,047	75,459	608,279	87,625	

TOTAL PLANT INVESTMENT SUMMARY

	\$1000 <sup>A</sup>	\$/10 <sup>6</sup> Btu/hr <sup>AA</sup>
Process Plant Investment and General Facilities	511,773	73.723
Process Contingency	20,047	2.888
Project Contingency	76,459	11.014
Total Plant Investment	608,279	87.625

<sup>AA</sup>Based on HHV of net fuel gas product at 100 percent capacity factor

<sup>AA</sup>All materials and equipment that became a part of the plant facility

<sup>AA</sup>Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-22

TOTAL PLANT INVESTMENT - CASE EXT-SSA  
 MID-1978-DOLLARS

Plant Section	Direct Field Labor <sup>1</sup>		Cost Breakdown Without Contingencies		Total Cost \$/10 <sup>6</sup> Btu/hr**	Per-cent	Contingencies		Total Plant Investment \$/10 <sup>6</sup> Btu/hr**
	Hat.1#	Labor#	Eng. & Support Costs\$	Sales Tax			Process \$/1000*	Project \$/1000*	
Coal Handling	20,556	8,356	14,413	1,026	6,663	8.4	0	6,654	51,015
Oxidant Feed	85,214	30,568	38,425	1,839	23,438	29.3	0	23,407	179,453
Gasification & Ash Handling	36,916	13,511	23,907	1,820	11,438	14.4	8,613	11,423	96,190
Raw Gas Cooling	50,574	11,694	24,849	2,556	13,468	16.9	10,510	13,449	113,632
Acid Gas Removal	6,918	2,893	4,513	353	2,144	2.7	0	2,142	16,419
Sulfur Recovery	2,590	1,217	2,049	134	.900	1.1	0	899	6,889
Tail Gas Treating	4,552	2,102	3,463	222	1,553	2.0	1,551	1,551	13,441
Fuel Gas Expansion	6,954	2,063	4,018	358	2,012	2.5	0	2,009	15,402
Steam Condensate & BW	927	334	406	18	.253	.3	0	253	1,938
Steam Superheat/Reheat	9,320	2,765	5,384	480	2,696	3.4	0	2,693	20,643
Steam Turbine Generator	21,608	6,411	12,483	1,112	6,250	7.8	0	6,242	47,856
General Facilities	28,369	11,425	16,717	967	8,633	10.8	0	8,622	66,100
Initial Catalysts and Chemicals					0,355	0.4			2,364
<b>TOTAL</b>	<b>274,508</b>	<b>92,940</b>	<b>150,627</b>	<b>10,885</b>	<b>79,803</b>	<b>100.0</b>	<b>20,674</b>	<b>79,344</b>	<b>631,342</b>

Product Fuel Gas: 6,658 x 10<sup>6</sup> Btu/hr\*\*  
 By-Product Power: 125.32 MW

Oxidant Plant Compressor Drivers: Motors  
 Sulfur Removal: 94.6 percent

Steam Cycle: 1450 psig/1000°/1000°F  
 Gas Temperature Entering Gas Cooling: 1500°F

TOTAL PLANT INVESTMENT SUMMARY

	\$/1000*	\$/10 <sup>6</sup> Btu/hr**
Process Plant Investment and General Facilities	531,324	79,803
Process Contingency	20,674	3,105
Project Contingency	79,344	11,917
<b>Total Plant Investment</b>	<b>631,342</b>	<b>94,825</b>

MID-1978 dollars

\*Based on HW of net fuel gas product at 100 percent capacity factor

\*\*All materials and equipment that become a part of the plant facility

##Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

\$Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee



Table 6-23

TOTAL PLANT INVESTMENT - CASE EXT-555  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/900°/900°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 6,626 x 10<sup>6</sup> Btu/hr<sup>14</sup>  
 Inlet Temperature Entering Gas Cooling: 2400°F      Sulfur Removal: 199.9 percent      By-Product Power: 136.61 MW

Plant Section	Direct Field Labor <sup>15</sup>			Eng. & Support Costs <sup>16</sup>			Sales Tax			Total Cost			Contingencies		Total Plant Investment		
	Mat <sup>17</sup>	Field	Lab <sup>18</sup>	Costs <sup>19</sup>	Post <sup>20</sup>	Field	Support	Field	Support	Field	Support	Field	Support	Process	Project	\$1000 <sup>21</sup>	\$/MH Btu/hr <sup>22</sup>
Coal Handling	20,566	8,356	8,356	14,413	1,026	44,361	6,695	8.1	0	0	6,654	51,015	0	0	6,654	179,453	7,699
Oxidant Feed	85,214	30,568	30,568	38,425	1,839	156,046	23,550	28.4	0	0	23,407	179,453	0	0	23,407	64,640	9,755
Gasification & Ash Handling	24,052	9,810	9,810	16,702	1,171	51,745	7,810	9.4	0	0	7,762	172,582	5,133	0	7,762	1,283	26,046
Raw Gas Cooling	72,376	16,744	16,744	35,542	3,653	128,315	19,364	23.4	0	0	19,246	1,283	25,021	0	19,246	1,283	194
COS Hydrolysis	447	246	246	400	23	1,116	168	2	0	0	167	1,283	0	0	167	18,561	7,801
Acid Gas Removal	7,821	2,818	2,818	5,102	399	16,140	2,436	3.0	0	0	2,421	18,561	0	0	2,421	7,321	1,105
Sulfur Recovery	2,753	1,293	1,293	2,177	143	6,366	961	1.2	0	0	955	7,321	0	0	955	14,309	2,160
Tail Gas Treating	4,899	2,240	2,240	3,638	230	11,007	1,661	2.0	0	0	1,651	14,309	1,651	0	1,651	3,455	521
ZNO Bed	1,812	326	326	775	91	3,004	453	0.5	0	0	451	3,455	0	0	451	15,280	2,306
Fuel Gas Expansion	6,900	2,047	2,047	3,985	355	13,287	2,005	2.4	0	0	1,993	15,280	0	0	1,993	2,010	303
Steam Condensate & BFW	962	347	347	421	18	1,748	264	0.3	0	0	262	2,010	0	0	262	15,815	2,357
Steam Superheat/Reheat	7,051	2,092	2,092	4,072	363	13,578	2,049	2.5	0	0	2,037	15,815	0	0	2,037	45,721	6,900
Steam Turbine Generator	20,642	6,125	6,125	11,927	1,063	39,757	6,000	7.2	0	0	5,964	45,721	0	0	5,964	64,505	10,037
General Facilities	28,521	11,526	11,526	16,817	966	57,830	8,728	10.5	0	0	8,675	66,505	0	0	8,675	4,813	0,726
Initial Chemicals and Catalyst	-	-	-	-	-	4,813	0,726	0.9	-	-	-	4,813	-	-	-	662,563	99,992
TOTAL	289,026	94,538	94,538	154,396	11,340	509,113	82,870	100.0	0	0	31,805	662,563	31,805	0	31,805	662,563	99,992

TOTAL PLANT INVESTMENT SUMMARY

	\$1000 <sup>21</sup>	\$/MH Btu/hr <sup>22</sup>
Process Plant Investment and General Facilities	549,113	82,870
Process Contingency	31,805	4,800
Project Contingency	81,645	12,322
Total Plant Investment	662,563	99,992

<sup>14</sup>MID-1978 dollars

<sup>15</sup>Based on 100 percent plant design power output of 6626.1 MH Btu/hr fuel gas

<sup>16</sup>Materials and equipment that become a part of the plant facility

<sup>17</sup>Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

<sup>18</sup>Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-24

PLANT FACILITIES INVESTMENT - BASE CASE EXT-SH  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/1000°/1000°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 7,637 x 10<sup>6</sup> Btu/hr\*\*  
Gas Temperature Entering Gas Cooling: 2400°F      Sulfur Removal: 94.6 percent      By-Product Power: 53.30 MW

Plant Section	Cost Breakdown Without Contingencies				Total Cost \$/10 <sup>6</sup>	Per- cent	Contingencies		Total Plant Investment \$/MM BTU/HR
	Direct Field Labor	Eng. & Support Costs\$	Sales Tax	Total Cost \$1000*			Process \$1000*	Project \$1000*	
Coal Handling	20,566	14,413	1,076	44,362	5,809	8.5	0	6,654	51,015
Oxidant Feed	85,214	30,568	1,839	156,046	20,433	29.9	0	23,407	179,453
Gasification and Ash Handling	24,062	9,810	1,171	51,745	6,776	9.9	5,133	7,762	64,640
Raw Gas Cooling	82,055	18,973	4,147	145,493	19,051	27.9	32,010	21,822	199,325
Acid Gas Removal	6,918	2,493	353	14,277	1,870	2.7	0	2,142	16,419
Sulfur Recovery	2,590	1,217	134	5,990	784	1.1	0	859	6,889
Tail Gas Treating	4,552	2,102	222	10,339	1,354	2.0	1,551	1,551	13,441
Fuel Gas Expansion	6,954	2,063	358	13,393	1,754	2.6	0	2,009	15,402
Steam, Condensate and LEW	754	271	13	1,357	178	.3	0	204	1,561
Steam Turbine Generator	13,843	4,012	697	26,081	3,415	5.0	0	3,912	29,993
General Facilities	25,738	10,206	895	51,930	6,800	9.9	0	7,790	59,720
Initial Chemicals and Catalysts	-	-	-	1,277	0.167	0.2	-	-	1,277
TOTAL	272,946	147,134	10,855	522,289	68,391	100.0	38,694	78,152	639,135

TOTAL PLANT INVESTMENT SUMMARY

	\$1000*	\$/MM BTU/HR**
Process Plant Investment and General Facilities	522,289	68.391
Process Contingency	38,694	5.066
Project Contingency	78,152	10.234
Total Plant Investment	639,135	83.691

\*\*MID-1978 dollars

\*\*Based on 100 percent plant design power output of 7,636.8 MM Btu/hr Fuel Gas

#All materials and equipment that become a part of the plant facility

##Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

\$Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- I/CR office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-25

PLANT FACILITIES INVESTMENT - BASE CASE EXT-SH WITH 2200 ST/D GASIFIERS  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/1000°/1000°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 7,637 x 10<sup>6</sup> Btu/hr\*\*  
Gas Temperature Entering Gas Cooling: 2400°F      Sulfur Removal: 94.6 percent      By-Product Power: 53.30 MW

Plant Section	Direct Field Labor#				Eng. & Support Costs\$				Sales Tax				Total Cost				Total Contingencies				Total Plant Investment	
	Direct Field Labor#	Eng. & Support Costs\$	Sales Tax	Total Cost	Eng. & Support Costs\$	Sales Tax	Total Cost	Per-cent	Process \$1000*	Project \$1000*	Total \$1000*	Process \$1000*	Project \$1000*	Total \$1000*	\$/MH Btu/hr	\$/MH Btu/hr						
Coal Handling	19,807	8,051	13,907	991	42,756	5,599	8.8	0	6,413	49,169	6,439	0	6,413	49,169	6.439	6.439						
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	20,433	32.3	0	23,407	179,453	23,499	0	23,407	179,453	23.499	23.499						
Gasification and Ash Handling	20,344	8,185	14,008	993	43,530	5,700	9.0	4,106	6,529	54,165	7,093	4,106	6,529	54,165	7.093	7.093						
Raw Gas Cooling	65,879	15,234	32,372	3,330	116,815	15,296	24.2	25,933	17,522	160,270	20,986	25,933	17,522	160,270	20.986	20.986						
Acid Gas Removal	6,918	2,493	4,513	353	14,277	1,870	3.0	0	2,142	16,419	2,150	0	2,142	16,419	2.150	2.150						
Sulfur Recovery	2,590	1,217	2,049	134	5,990	1,84	1.2	0	899	6,889	902	0	899	6,889	902	902						
Tail Gas Treating	4,552	2,102	3,463	222	10,539	1,354	2.1	1,551	1,551	1	1,760	1,551	1,551	1	1,760	1.760						
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	1,754	2.8	0	2,009	15,402	2,017	0	2,009	15,402	2.017	2.017						
Steam, Condensate and BFW	754	271	319	13	1,357	178	3	0	204	1,561	204	0	204	1,561	204	204						
Steam Turbine-Generator	13,543	4,018	7,823	697	26,081	3,415	5.4	0	3,912	29,993	3,927	0	3,912	29,993	3.927	3.927						
General Facilities	25,463	10,114	15,015	894	51,466	6,742	10.6	0	7,723	59,209	7,753	0	7,723	59,209	7.753	7.753						
Initial Chemicals and Catalysts																						
TOTAL	252,018	84,316	135,912	9,824	483,347	63,292	100.0	31,590	72,311	555,371	76,897	31,590	72,311	555,371	76.897	76.897						

TOTAL PLANT INVESTMENT SUMMARY

	\$1000*	\$/MH Btu/hr**
Process Plant Investment and General Facilities	483,347	63.292
Process Contingency	31,590	4.136
Project Contingency	72,311	9.469
Total Plant Investment	587,248	76.897

\*\*Mid-1978 dollars

\*\*Based on 100 percent 7,636.8 MH Btu/hr fuel gas

†All materials and equipment that become a part of the plant facility

‡Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

§Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-26

TOTAL PLANT INVESTMENT - CASE EXT-SHI  
MID-1978 DOLLARS

Steam Cycle: 1450 psig/900°/900°F      Oxidant Plant Compressor Drivers: Motors      Product Fuel Gas: 7,402 x 10<sup>6</sup> Btu/hr\*\*  
Gas Temperature Entering Gas Cooling: 1500°F      Sulfur Removal: 94.6 percent      By-Product Power: 46.82 MW

Plant Section	Direct Field		Eng. & Support Costs		Sales Tax		Total Cost		Per-cent	Contingencies		Total Plant Investment	
	Mat'l	Labor	Costs	Costs	Costs	Costs	\$/10 <sup>6</sup>	\$/1000*		\$/1000*	\$/10 <sup>6</sup> Btu/hr**		
Coal Handling	20,566	8,356	14,413	1,026	44,361	5,993	5.2	0	6,654	51,015	6,892	51,015	
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	21,082	32.4	0	23,407	179,453	24,244	179,453	
Gasification and Ash Handling	36,916	13,511	23,907	1,820	76,154	10,288	15.8	8,613	11,423	96,190	12,995	96,190	
Raw Gas Cooling	42,983	9,939	21,121	2,173	76,216	10,297	15.9	8,947	11,432	96,595	13,050	96,595	
Acid Gas Removal	6,918	2,493	4,513	353	14,277	1,929	3.0	0	2,142	16,419	2,218	16,419	
Sulfur Recovery	2,590	1,217	2,049	134	5,990	809	1.2	0	899	6,889	931	6,889	
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1,397	2.1	1,551	1,551	13,441	1,816	13,441	
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	1,809	2.8	0	2,009	15,402	2,081	15,402	
Steam, Condensate and BW	857	307	362	15	1,541	208	.3	0	231	1,772	239	1,772	
Steam Superheat/Reheat	1,219	362	705	63	2,349	317	.5	0	352	2,701	365	2,701	
Steam Turbine-Generator	13,616	4,040	7,865	701	26,222	3,545	5.5	0	3,933	30,155	4,074	30,155	
General Facilities	26,343	10,495	15,541	921	53,300	7,201	11.0	0	7,995	61,295	8,281	61,295	
Initial Catalysts and Chemicals	-	-	-	-	1,538	208	.3	-	-	1,538	208	1,538	
TOTAL	248,726	85,453	136,382	9,625	481,726	65,081	100.0	19,111	72,028	572,865	77,394	572,865	

TOTAL PLANT INVESTMENT SUMMARY

	\$/1000*	\$/10 <sup>6</sup> Btu/hr**
Process Plant Investment and General Facilities	481,726	65,081
Process Contingency	19,111	2,582
Project Contingency	72,028	9,731
Total Plant Investment	572,865	77,394

\*MID-1978 dollars

\*\*Based on HHV of net fuel gas product at 100 percent capacity factor

†All materials and equipment that become a part of the plant facility

‡Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

§Includes:

- Indirect field costs including all labor, supervision and expense required to support field construction
- Home office costs including all salaries and expenses required for engineering design and procurement
- Contractor's fee

Table 6-27

TOTAL PLANT INVESTMENT - CASE EXT-SH2  
MID-1978 DOLLARS

Steam Cycle: 736 psig/500°F  
Gas Temperature Entering Gas Cooling: 1500°F  
Oxidant Plant Compressor Drivers: Motors  
Sulfur Removal: .6 percent  
Product Fuel Gas: 7,637 x 10<sup>6</sup> Btu/hr\*\*  
By-Product Power: 15.84 MW

Plant Section	Direct Field Man'l#	Direct Field Labor#	Cost Breakdown Without Contingencies			Per-cent	Total Plant Investment \$/10 <sup>6</sup> Btu/hr**
			Eng. & Support Costs\$	Sales Tax	Total Cost \$/10 <sup>6</sup> Btu/hr**		
Coal Handling	20,566	8,356	14,413	1,026	44,351	5.809	51,015
Oxidant Feed	85,214	30,568	38,425	1,839	156,046	20.433	179,453
Gasification and Ash Handling	36,916	13,511	23,907	1,820	76,154	9.972	96,190
Raw Gas Cooling	49,705	11,493	24,422	2,512	88,132	11.540	113,638
Acid Gas Recovery	6,918	2,493	4,513	353	14,277	1.870	16,419
Sulfur Recovery	2,590	1,217	2,049	134	5,990	.784	6,889
Tail Gas Treating	4,552	2,102	3,463	222	10,339	1.354	13,441
Fuel Gas Expansion	6,954	2,063	4,018	358	13,393	1.754	15,402
Steam, Condensate and BFW	804	289	338	14	1,445	.189	2.017
Steam Turbine-Generator	11,579	3,435	6,690	596	22,307	2.920	25,645
General Facilities	25,939	10,226	15,163	906	52,234	6.840	60,069
Initial Catalysts and Chemicals					1,277	.167	7,866
TOTAL	251,737	85,753	137,401	9,780	485,948	63.632	581,100

TOTAL PLANT INVESTMENT SUMMARY

	\$/10 <sup>6</sup> *	\$/10 <sup>6</sup> Btu/hr**
Process Plant Investment and General Facilities	485,948	63.632
Process Contingency	22,451	2.940
Project Contingency	72,701	9.520
Total Plant Investment	581,100	76.092

\*Mid-1978 dollars

\*\*Based on HW of net fuel gas product at 100 percent capacity factor

†All materials and equipment that become a part of the plant facility

‡Labor cost for installing direct field materials (exclusive of payroll burdens and craft benefits)

§Inc.udes:

- indirect field costs including all labor, supervision and expense required to support field construction
- home office costs including all salaries and expenses required for engineering design and procurement
- contractor's fee