

## **Environmental Report for the Gasification Product Improvement Facility (GPIF)**

### **Topical Report**

**R.S. Sadowski  
W.H. Skinner  
E.S. Norris  
R.R. Duck  
R.B. Hass  
M.E. Morgan  
J.J. Helble  
S.A. Johnson**

January 1993

Work Performed Under Contract No.: DE-AC21-92MC28202

For  
U.S. Department of Energy  
Office of Fossil Energy  
Morgantown Energy Technology Center  
Morgantown, West Virginia

By  
CRS Serrine Engineers, Inc.  
Greenville, South Carolina

**MASTER**

REPRODUCTION OF THIS DOCUMENT IS UNLIMITED

*ep*

**Environmental Report for the  
Gasification Product Improvement Facility (GPIF)**

**Topical Report**

**R.S. Sadowski  
W.H. Skinner  
E.S. Norris  
R.R. Duck  
R.B. Hass  
M.E. Morgan  
J.J. Helble  
S.A. Johnson**

**Work Performed Under Contract No.: DE-AC21-92MC28202**

**For  
U.S. Department of Energy  
Office of Fossil Energy  
Morgantown Energy Technology Center  
P.O. Box 880  
Morgantown, West Virginia 26507-0880**

**By  
CRS Serrine Engineers, Inc.  
1041 East Butler Road  
Greenville, South Carolina 29606-5456**

**January 1993**

## TASK 1 - NEPA SUPPORT DOCUMENT TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. INTRODUCTION	1
2. PROJECT OBJECTIVES	1
3. SCHEDULE OF MILESTONES	1
4. SUMMARY OF TEST PLANS	2
5. TECHNICAL SUMMARY	2
6. TECHNICAL APPROACH	3
7. EXISTING FACILITY DESCRIPTION	3
8. TEST FACILITY MAJOR EQUIP. CAP. & TIES TO FT MARTIN	3
9. FUNCTIONAL DESCRIPTIONS OF TEST FACILITY - PHASE I	22
10. CONTROL SYSTEM DESCRIPTION	32
11. ELECTRICAL SYSTEM ASSESSMENT	37
12. FUNCTIONAL DESCRIPTIONS OF TEST FACILITY- PHASE II	44
13. PROJECT ENVIRONMENTAL ASPECTS	49
14. EMISSION REDUCTION OF NO <sub>x</sub>	49
15. GREENHOUSE GASES AND AIR TOXICS	49
16. PRODUCTION AND HANDLING OF OTHER EFFLUENTS	50
17. EHSS COMPLIANCE	51
18. PLAN FOR EHSS RISKS AND IMPACTS	52
19. VIABILITY OF THE GASIFICATION CONCEPT	53
20. OVERVIEW OF THE PyGas™ PROCESS	57
21. THE PYROLYZER	58
22. UPPER ZONE OF THE GASIFIER	60
23. UPPER BED GASIFICATION	60
24. LOWER BED GASIFICATION	62
25. MATH MODEL PREDICTIONS	62
26. CONCLUSIONS	64
27. DESCRIPTION OF THE PyGas™ GASIFIER	64
28. UNIQUE FEATURES OF THE PyGas™ GASIFIER	65
28.1 RUN OF MINE COAL	65
28.2 AIR BLOWN	65
28.3 CAKING COALS	65
28.4 TAR CRACKING	66
28.5 VOLATILIZED ALKALI CONTROL	66
28.6 MINIMIZED AMMONIA PRODUCTION	66
29. EMISSIONS CHARACTERISTICS	66

## LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Schedule of Milestones	1
2	GPIF General Arrangement Drawing	4
3	GPIF Project Site Plan	5
4	Photo Showing GPIF Facility Proposed Site Alternates	7
5	The GPIF - PyGas™ Process Flow Sheets	8
6	Proposed Ties Between GPIF and Ft. Martin	21
7	Hydration by Submerged Combustion	24

Missing Pages:

P.2, P.104 and P. 105

## LIST OF TABLES

<u>Figure</u>		<u>Page</u>
1	Fort Martin Tour Route Stop Identification & Locations	6
2	Mass Balance	9 - 20
3	Process Water Consumption	28
4	Test Facility Motor Horsepower Consumption	30
5	Control Room Equipment	33
6	Control Systems and Equipment	34
7	Electrical Equipment	38
8	Effect of Repowering on Effluents	50
9	Trace Elements Present in Coal Ash	52
10	Predicted Gas Compositions	63

**NEPA DOCUMENTATION TABLE OF CONTENTS  
PSIT SUPPORT**

<b><u>Section</u></b>	<b><u>Page</u></b>
1. INTRODUCTION	69
1.1 Trace Elements in Coal	69
1.2 Emission from Fort Martin Plant Under Normal Operation	74
1.3 Trace Element Behavior in GPIF System	85
1.4 Significance of Trace Metal Emission from GPIF	96
2. CRITERIA POLLUTANTS	100
2.1 SO <sub>2</sub> Emissions	100
2.2 NO <sub>x</sub> Emissions	100
2.3 CO Emissions	103
3. NEPA ASSESSMENT OF PSIT FACILITIES	103
3.1 Brief Description of PSIT Laboratory Facilities to be Used in this Project	103
3.2 Anticipated Emission from PSIT Laboratory Facilities	104
3.3 Permits Required	106
3.4 Agency Contacts	106
4. REFERENCES	107

**NEPA DOCUMENTATION TABLE OF CONTENTS  
PSIT SUPPORT  
LIST OF FIGURES**

<b><u>Figure</u></b>		<b><u>Page</u></b>
1	<b>Process flow diagram for Fort Martin</b>	75
2	<b>Boiler mass balance calculation results</b>	77
3	<b>Balance around convective section</b>	81
4	<b>Electrostatic precipitator mass balance</b>	83
5	<b>Overall balance at GPIF facility</b>	86
6	<b>Balance around CaS oxidation unit</b>	93
7	<b>Conversion of ammonia to NO<sub>x</sub> in a turbulent diffusion flame</b>	102
8	<b>PSIT Facility Location Map</b>	105

NEPA DOCUMENTATION TABLE OF CONTENTS  
PSIT SUPPORT  
LIST OF TABLES

<u>Table</u>	<u>Page</u>
1 Fort Martin Coal Analyses (As-Fired Basis)	71
2 Trace Element Concentrations in Pulverized Coals	72
3 Common Forms of Trace Elements in Coals	73
4 Field Measurements of Trace Element Partitioning in Coal-Fired Combustion Boilers	78
5 Balance of Trace Element Concentrations Around the Boilers	80
6 Balance Around Air Heater and Economizer Hoppers	82
7 Trace Metal Balance Around the ESP	84
8 Trace Element Concentration - GPIF Inlet Streams	88
9 Trace Element Partitioning in Gasifier - Ratio of Elemental Concentrations in Fly Ash to Bottom Ash	89
10 Trace Element Partitioning in the Gasifier - Average Partitioning Values Used	91
11 Trace Element Partitioning in the Gasifier - Maximum Partitioning Values Used	92
12 Trace Element Leachability as f(pH)	94
13 Partitioning of GPIF Fly Ash by the ESP	95
14 Effect of GPIF Facility	97
15 Conversion of Coal Nitrogen to Ammonia in a 2-ft Diam Wellman-Galusha Gasifier	101



**Task 1**  
**Gasification Product Improvement Facility (GPIF)**  
**Environmental, Safety, & Health (ES&H) Information**  
**National Environmental Policy Act (NEPA)**

**1. Introduction**

The Department of Energy (DOE) Fossil Energy Program has a mission to develop energy systems that utilize national coal resources in power systems with increased efficiency and environmental compatibility. Coal gasification technology is a versatile candidate that meets this goal.

Optimized air-blown fixed-bed gasification power generation systems at a cost of about \$1000 per kilowatt (KW) are possible if gasifier subsystem process components can be reduced or eliminated.


This two phased project consists primarily of the design, construction and operation of a 5-foot inside diameter (minimum) fixed-bed gasifier called PyGas™ and supporting infrastructure (Phase I), and an additional follow on phase consisting of the design, construction and operation of a hot fuel gas cleanup unit (Phase II).

**2. Project Objectives**

The main goal of the GPIF project is to develop systems and subsystems to resolve technological issues that surround the simplified IGCC concept. Issues expected to be successfully overcome by PyGas™ through its application in this test facility include the processing of high-swelling coals, which causes agglomeration in conventional fixed-bed gasifiers. Such coals comprise 87% of all eastern coals. Other issues expected to be eliminated or significantly reduced include: production of ash clinkers, production of ammonia, the presence of significant tars and fines, and the volatilization of alkalinity in the product fuel gas.

**3. Schedule of Milestones**

**Figure 1**  
**Schedule of Milestones**  
**FY93 Program Schedule**



## **6. Technical Approach**

The gasifier test facility general arrangement drawing (Figure 2) utilizes the CRS Serrine Engineers, Inc. proprietary gasification invention nominally rated (for materials handling purposes) at 6 tons per hour coal throughput. Its capacity is therefore anticipated to be approximately six times the capacity of the existing 42 inch diameter METC test gasifier. The operating pressure is 600 psi, and the gasifier is expected to be 5 feet (minimum) in diameter, and some 34 feet in height. It is designed to operate at a maximum coal firing rate of 150-MBtu/hr. Since it will be located at an existing utility site, it is anticipated that the products of combustion from the coal derived gas will be returned to the existing stack.

## **7. Existing Facility Description**

Fort Martin Generating Station (Figure 3 & Table 1) is a 1000 MWe pulverized coal fired electric utility power plant located in Point Marion, West Virginia, some two miles down the Monongahela River from the Morgantown Energy Technology Center. It is operated by Monongahela Power Co., an Allegheny Power System company. High and low sulfur coals are currently blended to meet current sulfur emission limits. Coal is received by barge, conveyed to an enclosed breaker house, and loaded out to either long term or active open coal piles, and reclaimed in a manner that allows the utility to control feed quantities of the low and high sulfur coal feed stocks. Steam turbine condenser heat of condensation is rejected via conventional cooling towers to the atmosphere. Coal ash is pneumatically conveyed to ash silos and subsequently is trucked to a permitted coal ash landfill area on the premises. Care and due diligence is practiced to avoid excessive dusting using water sprays during ash loading onto the ash trucks, and wind screens are in place as a deterrent to wind blown ash from the landfill. Sulfur is currently the only criteria pollutant requiring controlled emission limits. Figure 4 shows a photograph of the existing site with alternate GPIF locations identified.


## **8. Test Facility Major Equipment Capacities and Ties to Ft. Martin**


Included herewith are the process flow sheet (Figure 5) and typical mass balances (Table 2) for the existing Fort Martin Generating Station along with a mass balance predicted for the Gasification Product Improvement Facility (GPIF) under Phases I & II. The numbered columns match the circled numbers identified in the preliminary process flow diagram. Proposed ties to Ft. Martin are identified in Figure 6.

The concept is to fire coal gas in a closely coupled packaged auxiliary steam generator located within the GPIF. The products of combustion will then be ducted back to the existing flue gas duct of Fort Martin Unit #2 upstream of the existing stack. The heat released within the packaged fired auxiliary steam generator will be returned to the existing Fort Martin Unit #2 in the form of steam. As contemplated, the GPIF represents only approximately 1.5% of the full load rated station firing rate, an aliquot side stream of feedwater will be fed to and returned from the GPIF as auxiliary or high pressure steam for the utility company. The new boiler will have a capacity of approximately 90,000 lbs per hour of steam.

In addition to the light oil ignited coal gas fired heat recovery steam generator (HRSG), either a smaller 10,000 lbs per hour steam light oil fired packaged boiler, or equivalent steam from Ft. Martin, vented to atmosphere is contemplated for space heating and gasification process steam.

The limestone feed capability to the PyGas™ coal gasifier may be sufficient in concert with coal gas combustion and steam generation to reduce Fort Martin sulfur emissions from currently





DATE	ISSUE FOR
NOV 1982	INFORMATION
BY	NO.
BY	NO.

**Richard S. Sedowski**  
 SIGNATURE  
 1/8/92  
 DATE

BY	DATE
W. SKINNER	1/28/92
W. SKINNER	FILE
W. SKINNER	NO.
W. SKINNER	JOB NO. 31604
BY	

**CRSS** Power Division  
 CRSS BIRRIPE Greenville, S.C.

GASIFICATION PRODUCT IMPROVEMENT FACILITY  
 DEPARTMENT OF ENERGY

**FIGURE 2**  
 GENERAL ARRANGEMENT

**31604-001-400**






Table 1

**FORT MARTIN TOUR ROUTE**

- Stop 1 Training Room at the Fort Martin Power Station. Tour groups will be formed and introduced to the utility tour guides.
- Stop 2 Connection point for Filtered Water. Available at quantities up to 200 gpm for steam generation and general use. Anticipated pressure at connection point is 150 psig.
- Stop 3 Connection point for Service Water. Available for fire protection at quantities up to 1200 gpm. Anticipated pressure at the connection point is 85 psig.
- Stop 4 Connection point for Potable Water. Plant storage consists of a 20,000 gal tank. Conveyed (by gravity) to plant through a 3-inch PVC line at 15 gpm. Anticipated pressure at connection point is 120 psig.
- Stop 5 Approximate location of railroad crossing required for access to the GPIF.
- Stop 6 Approximate location of the GPIF, as shown by surveyors stakes. Access during construction and test operations will be via Stop 15 & 5. Approximately four acres.
- Stop 7 Existing storage shed to be relocated area near Stop 8.
- Stop 8 New location of storage shed presently located on the GPIF site.
- Stop 9 Anticipated route of buried GPIF process waste water pipes from the GPIF to the Plant ash settling basins. Plant will provide treatment and discharge.
- Stop 10 Plant ash settling basins.
- Stop 11 Approximate locale for GPIF fuel gas to enter the Plant for combustion in the coal-fired boiler
- Stop 12 Unit #2 coal-fired boiler
- Stop 13 Unit #2 Control Room.
- Stop 14 Coal storage pile for Plant operations. Low-sulfur coal will be made available for GPIF operations.
- Stop 15 Truck weigh station for ash trucks.
- Stop 16 Unimproved roadway leading to the railroad crossing and the GPIF site.
- Stop 17 Paved road leading to the ash disposal pit, contractors' entrance and exit.






Figure 4  
Alternate GPIF Sites  
Ft Martin Generating Station  
Monongahela Power







**REVISION**

NO.	DESCRIPTION	DATE	BY	CHKD
1	ISSUED FOR REVIEW			
2				
3				
4				
5				
6				
7				
8				
9				
10				

**DESIGNER:** W.H. STOKER  
**CHECKED:** W.H. STOKER  
**DATE:** 10/1/84  
**PROJECT NO.:** 31604

**CRSS** Power Division  
 Greenville, S.C.  
 © 1984 CRSS

**GPIF PROJECT**  
**Figure 5**

**DRAWING TITLE**  
 PROCESS FLOW SHEET

**DRAWING NUMBER**  
 31604-40-F-18P-001

2 DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced)

Table 2.2

3 NEPA Support Document, Mass Balance

\*Using FW Data (High Steam - Low Blu) Case

4	5 Stream No.		6	6a	6b
6	Identification		Combustion Air	Combustion Air	Combustion Air
7	From		Total	Exhaust Vents	Ambient
8	To		HRSO Burner	HRSO Burner	HRSO Burner
9	Gas	Mol Wt	lb/hr		
11	CO	28.010	0	0	
12	H2	2.016	0	0	
13	CO2	44.010	49	922	4
14	H2O	18.016	652	426	65
15	CH4	16.042	0	0	
16	C2H6	30.068	0	0	
17	H2S	34.076	0	0	
18	COB	60.070	0	0	
19	N2	28.013	76923	11,458	6546
20	Ar	39.948	1347	201	114
21	HCl	36.461	0	0	
22	HON	27.026	0	0	
23	NH3	17.030	0	0	
24	CS2	76.131	0	0	
25	SO2	64.059	0	3	
26	NO	30.006	0	0	
27	O2	31.999	23559	3,270	2028
28	NaCl	58.497	0	0	
29	KCl	74.596	0	0	
30	CaSO4	136.142	0	0	
31	Ca(OH)2	74.095	0	0	
32	Cl2	35.500	0	0	
33	Total Gas (lb/hr)		102529	16,329	8620
56					
57	C	12.011			
58	H	1.008			
59	O	16.000			
60	N	14.007			
61	S	32.060			
62	CaO	56.079			
63	H2O	18.016			
64	NaCl	58.497			
65	KCl	74.596			
66	CaSO4	136.142			
67	Ca	40.080			
68	CaS	72.140			
69	ASH, Inerts (pph)				
70	Total Solids (pph)				
71	Total Flow (pph)		156499	16329	8620
72					
73	Total Flow (pps)		43	5	
74	Pressure (psia)		15	15	
75	Temperature (F)		90	90	

CONTRACT NO. DE-AC21-92MC28202

6c Air Atmosphere Coal Dryer @ 1.25 lb/lb Coal	6d Heated Drying Air Drying Air Heater Crusher Mill	6e Classifier Air Classifier & Filter Coal Gas Burner @ 0.01% Solids	6f Dust Collector Exhaust Classifier Dust Collector Forced Draft Fan Intake @ 99% Removal Effic.	6g Dust Collector Exhaust Hopper Dust Collector Forced Draft Fan Intake	
0	0	0	0	0	0 11
0	0	0	0	0	0 12
7	922	922	7	7	0 13
96	425	425	96	96	1 14
0	0	0	0	0	0 15
0	0	0	0	0	0 16
0	0	0	0	0	0 17
0	0	0	0	0	0 18
11,336	11,336	11,336	11,336	84	19
198	198	198	198	198	1 20
0	0	0	0	0	0 21
0	0	0	0	0	0 22
0	0	0	0	0	0 23
0	0	0	0	0	0 24
0	3	3	0	0	0 25
0	0	0	0	0	0 26
3,472	3,233	3,233	3,472	26	27
0	0	0	0	0	0 28
0	0	0	0	0	0 29
0	0	0	0	0	0 30
0	0	0	0	0	0 31
0	0	0	0	0	0 32
15,110	16,117	16,217	16,217	112	33
		1.69	0.017	6.43E-04	34
		0.11	0.001		56
		0.28	0.003	1.08E-04	57
		0.03	0.0003	1.16E-05	58
		0.02	0.0002	9.01E-06	59
					60
		0.05	0.0005	1.76E-05	61
					62
					63
					64
					65
					66
		0.07	0.001	2.81E-05	67
					68
		0.37	0.004	1.42E-04	69
		2.63	0.03	1.00E-03	70
15,110	16117	16220	16217	16117	71
					72
4.20	4	5	5	4	73
14.7	14.7	14.7	14.7	14.7	74
80	500	150	367	367	75

02| DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced) Reference Coal - Fort Mart  
 03| Mass & Energy Balance 5 ft Dia Test Size CRSS Predicted Output \*Us

05  Stream No.	06  Identification	07  From	08  To	09  Gas	Mol Wt	8 Coal/Limestone Fines Classifier Dust Collector R Martin Coal Pile lb/hr	9 Compressed Air High Pressure Compressor Total lb/hr	H
11	CO				28.010			0
12	H2				2.016			0
13	CO2				44.010			24
14	H2O				18.015			321
15	CH4				16.042			0
16	C2H6				30.068			0
17	H2S				34.076			0
18	COs				60.070			0
19	N2				28.013			37924
20	Ar				39.948			664
21	HCl				36.461			0
22	HON				27.026			0
23	NH3				17.030			0
24	CS2				76.131			0
25	SO2				64.059			0
26	NO				30.006			0
27	O2				31.999			11615
28	NaCl				58.497			0
29	KCl				74.596			0
30	CaSO4				136.142			0
31	Ca(OH)2				74.095			0
32	CaO				56.079			0
33	Total Gas (lb/hr)							50548
56								
57	C				12.011	1.6741		7
58	H				1.008	0.1072		36
59	O				16.000	0.2799		11918
60	N				14.007	0.0302		37924
61	S				32.060	0.0235		
62	CL2				35.500	0.0000		49884
63	H2O				18.016	0.0457		
64	NaCl				58.497			
65	KCl				74.596			
66	CaSO4				136.142			
67	Ca				40.080			
68	CaO				56.079			
69	ASH, Inerts (pph)					0.3694		
70	Total Solids (pph)					2.5300		0
71	Total Flow (pph)					13		50548
72								
73	Total Flow (pps)					0.004		9
74	Pressure (psia)					15		600
75	Temperature (F)					80		200

Table 2.4

3/10/93 17:19

CONTRACT NO. DE-AC21-92MC28202

9a				9b		9c		
Compressed Air@ High Pressure Compressor Pyrolyzer				Coal/Lm's/n Convey Air High Pressure Compressor Pyrolyzer		Compressed Air High Pressure Compressor Pyrolyzer		
lb/hr	mol wgt	wt %	mol%	lb/hr				
0	0.00	0.00	0.00	0	0	0	0	2
0	0.00	0.00	0.00	0	0	0	0	3
15	0.01	0.06	0.03	3	3	12	12	4
196	0.18	0.84	1.02	37	37	159	159	5
0	0.00	0.00	0.00	0	0	0	0	6
0	0.00	0.00	0.00	0	0	0	0	7
0	0.00	0.00	0.00	0	0	0	0	8
0	0.00	0.00	0.00	0	0	0	0	9
23186	21.65	75.03	77.28	4397	4397	18739	18739	10
406	0.38	1.31	0.95	77	77	329	329	11
0	0.00	0.00	0.00	0	0	0	0	12
0	0.00	0.00	0.00	0	0	0	0	13
0	0.00	0.00	0.00	0	0	0	0	14
0	0.00	0.00	0.00	0	0	0	0	15
0	0.00	0.00	0.00	0	0	0	0	16
0	0.00	0.00	0.00	0	0	0	0	17
0	0.00	0.00	0.00	0	0	0	0	18
7101	6.63	22.98	20.72	1347	1347	5754	5754	19
0	0.00	0.00	0.00	0	0	0	0	20
0	0.00	0.00	0.00	0	0	0	0	21
0	0.00	0.00	0.00	0	0	0	0	22
0	0.00	0.00	0.00	0	0	0	0	23
0	0.00	0.00	0.00	0	0	0	0	24
0	0.00	0.00	0.00	0	0	0	0	25
0	0.00	0.00	0.00	0	0	0	0	26
30904	28.86	100.00	100.00	5860	5860	25043	25043	27
								28
								29
								30
								31
								32
								33
								34
								56
								57
								58
								59
								60
								61
								62
								63
								64
								65
								66
								67
								68
								69
								70
								71
								72
								73
								74
								75

4	
22	
7286	
23186	
30498	Total
0	
30904	29693
8.58	
600	
150	

2 | DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced) Table 2  
 3 | NEPA Support Document, Mass Balance \*Using FW Data (High Steam - Low Blu) Case

Stream No.	Identification	9d			
From	To	Compressed Air@ High Pressure Compressor Gasifier Grate	0.83 A/C	S/A	
Gas	Gas	lb/hr	lb-mol/hr	wt %	mol%
11	CO	0	0.00	0.00	
12	H2	0	0.00	0.00	
13	CO2	5	0.01	0.05	
14	H2O	64	0.18	0.64	
15	CH4	0	0.00	0.00	
16	C2H6	0	0.00	0.00	
17	H2S	0	0.00	0.00	
18	COs	0	0.00	0.00	
19	N2	7527	21.65	75.03	
20	Ar	132	0.38	1.31	
21	HCl	0	0.00	0.00	
22	HCN	0	0.00	0.00	
23	NH3	0	0.00	0.00	
24	CS2	0	0.00	0.00	
25	SO2	0	0.00	0.00	
26	NO	0	0.00	0.00	
27	O2	2305	6.63	22.98	
28	NaCl	0	0.00	0.00	
29	KCl	0	0.00	0.00	
30	CaSO4	0	0.00	0.00	
31	Ca(OH)2	0	0.00	0.00	
32	Cl2	0	0.00	0.00	
33	Total Gas (lb/hr)	10033	28.66	100.00	1
56					
57	C	1			
58	H	7			
59	O	2365			
60	N	7527			
61	S				
62	CaO	9901	Total		
63	H2O				
64	NaCl				
65	KCl				
66	CaSO4				
67	Ca				
68	CaS				
69	ASH, Inerts (pph)				
70	Total Solids (pph)	9728			
71	Total Flow (pph)	9728			
72					
73	Total Flow (pps)	2.70			
74	Pressure (psia)	600			
75	Temperature (F)	225			

9e Compressed Air@ 0.82 A/C High Pressure Compressor Gasifier Top					9i Compressed Air High Pressure Air Compressor Cyclone Fines Conveying	
	lb/hr	lb-mol/hr	wt %	mol%	lb/hr	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.03	5	0.01	0.05	0.03	0	
1.02	61	0.18	0.64	1.02	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
77.28	7211	21.65	75.03	77.28	38	
0.95	126	0.38	1.31	0.95	1	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
20.72	2208	6.63	22.98	20.72	11	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
0.00	0	0.00	0.00	0.00	0	
10.00	9611	28.86	100.00	100.00	50	
1						
7						
2266						
7211						
9485	Total					
+						
9611					0	
9611					50	
2.67					0.01	
600					600	
225					225	



DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced)

NEPA Support Document, Mass Balance

\*Using FW Data (High Steam - Low Blu) Case

Stream No.	Identification	From	To	Gas	10		10a			
					Feed to Pyrolyzer Coal, Air, Steam Pyrolyzer Inlet lb/hr		Products of Pyrolysis - Gases Pyrolyzer Section Upper Area of Gasifier lb/hr	lb-mol/hr	N in coal to NH3 in gas 90.00% Conversion wt %	mol%
11	CO			28.010	0		4859	173.48	13.29	12.52
12	H2			2.016	0		264	130.74	0.72	9.43
13	CO2			44.010	15		5741	130.45	15.70	9.41
14	H2O			18.015	197		1460	81.02	3.99	5.85
15	CH4			16.042	0		256	15.96	0.70	1.15
16	C2H6			30.068	0		0	0.00	0.00	0.00
17	H2S			34.076	0		113	3.33	0.31	0.24
18	COS			60.070	0			0.00	0.00	0.00
19	N2			28.013	23186		23274	830.84	63.66	59.96
20	Ar			39.948	406		442	11.06	1.21	0.80
21	HCl			36.461	0			0.00	0.00	0.00
22	HCN			27.026	0			0.00	0.00	0.00
23	NH3			17.030	0		150	8.81	0.41	0.64
24	CS2			76.131	0			0.00	0.00	0.00
25	SO2			64.059	0			0.00	0.00	0.00
26	NO			30.006	0			0.00	0.00	0.00
27	O2			31.999	7101			0.00	0.00	0.00
28	NaCl			58.497	0			0.00	0.00	0.00
29	KCl			74.596	0			0.00	0.00	0.00
30	CaSO4			136.142	0			0.00	0.00	0.00
31	Ca(OH)2			74.095	0			0.00	0.00	0.00
32	Cl2			56.079	0			0.00	0.00	0.00
33	Total Gas (lb/hr)				30904		36715	1385.68	100.00	100.00
56										
57	C			12.011	7612			3846	3842	-0.10%
58	H			1.008	509			520	525	0.79%
59	O			16.000	8558			8646	8711	0.75%
60	N			14.007	23323			23323	23398	0.32%
61	S			32.060	107			107	107	0.01%
62	CaO			35.500	30498					
63	H2O			18.016	100					
64	NaCl									
65	KCl									
66	CaSO4									
67	Ca				332					
68	CaS									
69	ASH, Inerts (pph)				1679					
70	Total Solids (pph)				11721		36715			
71	Total Flow (pph)				42625		36715			
72										
73	Total Flow (pps)				11.84		10.20			
74	Pressure (psia)				600					
75	Temperature (F)				150					

600 # No Heat Loss, Reduce Air Flow to Control Te  
16521.temp(F), calc. adiab. temp(F)= 3052

Table 2.6

3/10/93 17:19

10b		10c				10d		
Products of Pyrolysis - Solids		Gases - Upper Portion of Gasifier				Solids - Upper portion of Gasifier		4
Pyrolyzer Section		Pyrolyzer Section				Pyrolyzer Section		5
Upper Area of Gasifier		Fixed Bed				Fixed Bed		6
lb/hr	wt %	lb/hr	lb-mol/hr	wt %	mol%	lb/hr	wt %	7
							12.00%	8
		4537	161.98	9.83	9.63			9
		137	68.06	0.30	4.05			10
		6955	158.02	15.06	9.40			11
		3225	179.00	6.98	10.64			12
		0	0.00	0.00	0.00			13
			0.00	0.00	0.00			14
		113	3.33	0.25	0.20			15
			0.00	0.00	0.00			16
		30485	1088.25	66.03	64.71			17
		568	14.22	1.23	0.85			18
			0.00	0.00	0.00			19
			0.00	0.00	0.00			20
		150	8.81	0.32	0.52			21
			0.00	0.00	0.00			22
			0.00	0.00	0.00			23
			0.00	0.00	0.00			24
			0.00	0.00	0.00			25
			0.00	0.00	0.00			26
			0.00	0.00	0.00			27
			0.00	0.00	0.00			28
			0.00	0.00	0.00			29
			0.00	0.00	0.00			30
			0.00	0.00	0.00			31
			0.00	0.00	0.00			32
		46791	1681.66	100.00	100.00			33
								34
3766	63.73		3843	3843		3766	69.17	56
Carbon Remaining	49.50%		531	531				57
			10977	10512				58
			30608	30608				59
			107	107				60
465								61
								62
								63
								64
								65
								66
								67
								68
1679	28.40					1679	30.83	69
5910	92.62	46791				5445	100.00	70
5910		46791				5445		71
								72
1.64		13.00				1.51		73
600		600				600		74
1652		2336		est. temp	2336	2336		75

DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced)

NEPA Support Document, Mass Balance \*Using FW Data (High Steam - Low Btu) Case

4			10e			
5 Stream No.			Gases Evolved through Gasification			
6 Identification			Down Through Fixed Char Bed			
7 From			Slowed Endothermic Reaction Point			
8 To						
9 Gas	Mol Wt		lb/hr	lb-mol/hr	wt %	mol%
10						
11 CO	28.010		9797	349.76	20.53	19
12 H2	2.016		280	138.95	0.59	7
13 CO2	44.010		4382	99.57	9.18	5
14 H2O	18.015		1948	108.11	4.08	5
15 CH4	16.042		0	0.00	0.00	0
16 C2H6	30.068		0	0.00	0.00	0
17 H2S	34.076		113	3.33	0.24	0
18 COS	60.070		0	0.00	0.00	0
19 N2	28.013		30485	1088.25	63.88	60
20 Ar	39.948		568	14.22	1.19	0
21 HCl	36.461		0	0.00	0.00	0
22 HCN	27.026		0	0.00	0.00	0
23 NH3	17.030		150	8.81	0.31	0
24 CS2	76.131		0	0.00	0.00	0
25 SO2	64.059		0	0.00	0.00	0
26 NO	30.006		0	0.00	0.00	0
27 O2	31.999		0	0.00	0.00	0
28 NaCl	58.497		0	0.00	0.00	0
29 KCl	74.596		0	0.00	0.00	0
30 CaSO4	136.142		0	0.00	0.00	0
31 Ca(OH)2	74.095		0	0.00	0.00	0
32 CaO	56.079		0	0.00	0.00	0
33 Total Gas (lb/hr)			47723	1810.99	100.00	100
34						
56						
57 C	12.011			5397	5397	
58 H	1.008			531	531	
59 O	16.000			10512	10512	
60 N	14.007			30608	30608	
61 S	32.060			107	107	
62 CL2	35.500					
63 H2O	18.016					
64 ZnFe2O4						
65 ZnS						
66 FeS						
67 Fe2O3						
68 ZnO						
69 ASH						
70 Total Solids						
71 Total Flow (pph)			48345			
72						
73 Total Flow (pps)			13.43			
74 Pressure (psia)			600			
75 Temperature (F)			1591			

Table 2.7

3/10/93 17:19

10l		Uncomb	10g		Grate S/A 0.56	
Ash & Carbon		% of C	Hol Gas@		Overall A/C 3.92	
Gasifier		29.08%	Lower Bed		Overall S/C 0.46	
Above Grate			Exit		N2 in coal NH3 Conv. 0.0%	
lb/hr	wt %	lb/hr	lb-mol/hr	wt %	mol %	
31		3690	131.76	21.33	17.80	10
67		184	91.31	1.06	12.34	11
60		2284	51.89	13.20	7.01	13
97		3480	193.20	20.12	26.10	14
00		0	0.00	0.00	0.00	15
00		0	0.00	0.00	0.00	16
18		0	0.00	0.00	0.00	17
00		0	0.00	0.00	0.00	18
09		7527	268.71	43.52	36.30	19
79		132	3.30	0.76	0.45	20
30		0	0.00	0.00	0.00	21
30		0	0.00	0.00	0.00	22
19		0	0.00	0.00	0.00	23
30		0	0.00	0.00	0.00	24
30		0	0.00	0.00	0.00	25
30		0	0.00	0.00	0.00	26
30		0	0.00	0.00	0.00	27
30		0	0.00	0.00	0.00	28
30		0	0.00	0.00	0.00	29
0		0	0.00	0.00	0.00	30
0		0	0.00	0.00	0.00	31
0		0	0.00	0.00	0.00	32
0		16988	740.17	100.00	100.00	33
						34
	2213	56.86	2199	2206	-0.30%	56
			574	574	0.00%	58
			6861	6860	0.02%	59
	0	0.00	7527	7527	0.00%	60
	0	0.00	0	0	0.00%	61
						62
		Sub-Totals	17161	17166	-0.03%	63
			Sum of	Sum of Gas	Mass	64
			Streams	Const.	Unbalance	65
				balance check		66
						67
						68
	1679	43.14	0		0.001	69
	3891	100.00				70
	3891		16988			71
						72
	1.08		4.72			73
	600		600			74
	1591		1500			75

2 | DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced)

3 | NEPA Support Document, Mass Balance

\*Using FW Data (High Steam - Low Blu) Case

Stream No.		10h			
Identification		Mixture of Gases from Upper Bed and Lower Bed			86 act/lb of c
From		Gasifier			
To		Combustor			
Gas		lb/hr	lb-mol/hr	wt %	mol
11	CO	28.010	13487	481.52	20.74
12	H2	2.018	464	230.26	0.71
13	CO2	44.010	6666	151.47	10.25
14	H2O	18.016	5428	301.31	8.35
15	CH4	18.042	0	0.00	0.00
16	C2H6	30.068	0	0.00	0.00
17	H2S	34.076	113	3.33	0.17
18	COS	60.070	0	0.00	0.00
19	N2	28.013	38012	1358.96	58.46
20	Ar	39.948	700	17.52	1.08
21	HCl	38.461	0	0.00	0.00
22	HCN	27.026	0	0.00	0.00
23	NH3	17.030	150	8.81	0.23
24	CS2	76.131	0	0.00	0.00
25	SO2	64.059	0	0.00	0.00
26	NO	30.006	0	0.00	0.00
27	O2	31.999	0	0.00	0.00
28	NaCl	58.497	0	0.00	0.00
29	KCl	74.596	0	0.00	0.00
30	CaSO4	136.142	0	0.00	0.00
31	Ca(OH)2	74.095	0	0.00	0.00
32	Cl2	56.079	0	0.00	0.00
33	Total Gas (lb/hr)		65021	2551.16	100.00
56					
57	C	12.011		7602	7602
58	H	1.008		1105	1105
59	O	16.000		17372	17372
60	N	14.007		38136	38136
61	S	32.060		107	107
62	CaO	35.500			
63	H2O	18.016			
64	NaCl				
65	KCl				
66	CaSO4				
67	Ca				
68	CaS				
69	ASH, Inerts (pph)		17		
70	Total Solids (pph)		17		
71	Total Flow (pph)		65333		
72					
73	Total Flow (pps)		18.15		
74	Pressure (psia)		600		
75	Temperature (F)		1568		

Table 2.8

#####

11a	11b	11c	11d	11		
Steam HFSG Gasifier Top lb/hr	H <sub>2</sub> O/coal HFSG Pyrolyzer lb/hr	H <sub>2</sub> O/coal HFSG Grate lb/hr	H <sub>2</sub> O/coal HFSG Ash Lock lb/hr	Total Steam HFSG GPIF lb/hr		
0.00000 S/C	0.00 S/C	0.46 S/C				
18.87					2	
9.03					3	
5.94					4	
11.81	0.00	0	5062	169	5231	5
0.00						6
0.00						7
0.13						8
0.00						9
53.19						10
0.69						11
0.00						12
0.00						13
0.35						14
0.00						15
0.00						16
0.00						17
0.00						18
0.00						19
0.00						20
0.00						21
0.00						22
0.00						23
0.00						24
0.00						25
0.00						26
0.00						27
0.00						28
0.00						29
0.00						30
0.00						31
0.00						32
100.00	0.00	0	5062	169	5231	33
0.00%	0	0	566		566	34
0.00%	0	0	4495		4495	35
0.00%	0	0	5062		5062	36
0.00%	0 Total	0 Total	5062 Total		5062	37
0.00%						38
						39
						40
						41
						42
						43
						44
						45
						46
						47
						48
						49
						50
						51
						52
						53
						54
						55
						56
						57
						58
						59
						60
						61
						62
						63
						64
						65
						66
						67
						68
						69
						70
						71
						72
						73
						74
						75
						76
						77
						78
						79
						80
						81
						82
						83
						84
						85
						86
						87
						88
						89
						90
						91
						92
						93
						94
						95
						96
						97
						98
						99
						100

DOE - GPIF - CRSS Coal Gasification Process

Mass & Energy Balance

\*Using FW Data (High Steam - Low Btu) Case

Stream No.	Identification	Mol Wt	12a		12b		
From	To	Gas	Water Spray Gasifier Outlet Combusitor/HGCU lb/hr	wt %	Steam Injection Gasifier Outlet Combusitor/HGCU lb/hr	wt %	lb/hr
11	CO	28.010					13487
12	H2	2.016					464
13	CO2	44.010					6666
14	H2O	18.016	2,900	100.00	0	100.00	8328
15	CH4	16.042					0
16	C2H6	30.068					0
17	H2S	34.076					113
18	COS	60.070					0
19	N2	28.013					38012
20	Ar	39.948					700
21	HCl	36.461					0
22	HCN	27.026					0
23	NH3	17.030					150
24	CS2	76.131					0
25	SO2	64.059					0
26	NO	30.006					0
27	O2	31.999					0
28	NaCl	58.497					0
29	KCl	74.596					0
30	CaSO4	136.142					0
31	Ca(OH)2	74.095					0
32	CaO	56.079					0
33	Total Gas (lb/hr)		2,900	100.00	0	100.00	67921
56							
57	C	12.011					
58	H	1.008					
59	O	16.000					
60	N	14.007					
61	S	32.060					
62	Cl2	35.500					
63	H2O	18.016					
64	NaCl	58.497					
65	KCl	74.596					
66	CaSO4	136.142					
67	Ca	40.080					
68	CaO	56.079					
69	ASH, Inerts (pph)						
70	Total Solids (pph)						
71	Total Flow (pph)		2,900		0		68233
72							
73	Total Flow (pps)		0.81		0.00		18.95
74	Pressure (psia)		600		600		600
75	Temperature (F)		80		700		1350

Table 2.9

3/10/93 17:19

12 Raw Gas Outlet Gasifier Outlet Combustor (Phase I)/HGU (Phase II)			13 = 13a & 13b Nitrogen Inerting Nitrogen Tanks PyGas™ Gasifier & Locks		14 Ash & Carbon Gasifier Ash Removal		Uncomb % of C 0.20%	14a Ash Lock Hopper Oxidation Reactor	
b-mol/hr	wt %	mol%	lb/hr		lb/hr		wt %	lb/hr	
481.52	19.86	17.75							
230.26	0.68	8.49							
151.47	9.81	5.58							
462.30	12.26	17.05							
0.00	0.00	0.00							
0.00	0.00	0.00							
3.33	0.17	0.12							
0.00	0.00	0.00							
1356.98	55.97	50.03							
17.52	1.03	0.65							
0.00	0.00	0.00							
0.00	0.00	0.00							
8.81	0.22	0.32							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
0.00	0.00	0.00							
2712	100	100							
					15		0.88		15
									58
									59
					0		0.00		60
					0		0.00		61
									62
									63
									64
									65
									66
									67
									68
					1679		99.12		460
					1693		100.00		2064
					1693				2064
									72
					0.47				0.57
					15				14.7
					700				90



DOE - GPIF - CRSS Coal Gasification Process

Mass & Energy Balance

\*Using FW Data (High Steam - Low Blu) Case

Stream No.	Identification	From	To	Gas	Mol Wt	15 Make-up Water Service Water Oxidation Reactor lb/hr	15a Overflow Oxidation Reactor Settling Tank lb/hr	15b Thickened Slurry Settling Tank Drum Filter lb/hr
11	CO				28.01			
12	H2				2.016			
13	CO2				44.01			
14	H2O				18.015			
15	CH4				16.042			
16	C2H6				30.068			
17	H2S				34.076			
18	COs				60.07			
19	N2				28.013			
20	Ar				39.948			
21	HCl				36.461			
22	HCN				27.026			
23	NH3				17.03			
24	CS2				76.131			
25	SO2				64.059			
26	NO				30.006			
27	O2				31.999			
28	NaCl				58.497			
29	KCl				74.596			
30	CaSO4				136.1416			
31	Ca(OH)2				74.09474			
32	Cl2				35.5			
33	Total Gas (lb/hr)							
57	C				12.0105			
58	H				1.008			
59	O				15.9995			
60	N				14.0065			
61	S				32.06			
62	CaO				56.0794			
63	H2O				18.0155	856	12535	
64	NaCl				58.497			
65	KCl				74.596			
66	CaSO4				136.1416		1827	
67	Ca				40.08			
68	CaS				72.14			
69	ASH, Inerts (pph)						690	
70	Total Solids (pph)					856	15353	
71	Total Flow (pph)					856	15353	
73	Total Flow (pps)					0.24	4.26	
74	Pressure (psia)					14.7	14.7	
75	Temperature (F)					80	90	

Table 2.10

3/10/93 17:19

lbs /hr	15c Overflow Settling Tank Oxidation Reactor lb/hr	15d Vent Oxidation Reactor HRSG Bumer lb/hr	16 Air Oxidation Air Blower Oxidation Reactor lb/hr	17 Drum Filter Vent Vacuum Pump Atmosphere lb/hr	18 Gypsum & Ash Drum Filter R Martin Land Fill lb/hr	2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75
		0.43	0.43	0.23		
		446	5.64	9.41		
		688.66	688.66	358.85		
		12.06	12.06	6.28		
		42.18	210.92	109.91		
		1189	918	484.68		
3851	8985				406	
1846	183				1354	
621	69				222	
6117	9236	1189	918	485	460	
6117	9236	1189	918	485	2531	
2	2.57	0.330	0.25	0.135	0.70	
14.7	14.7	14.7	15	14.7	14.7	
90	90	90	90	90	90	

DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced) Table 2.11						
*Using FW Data (High Steam - Low Blu) Case						
Stream No.	Identification	19 Condensate R Martin GPIF lb/hr	19a Steam HRSG R Martin lb/hr	20 Feedwater Water Treatment GPIF lb/hr	20a Feedwater Water Treatment HRSG lb/hr	20b Feedwater Water Treatm Start-up Bol lb/hr
From	To					
Gas	Mol Wt					
11	CO	28.010				
12	H2	2.016				
13	CO2	44.010				
14	H2O	18.015		14507		
15	CH4	16.042				
16	C2H6	30.068				
17	H2S	34.076				
18	COS	60.070				
19	N2	28.013				
20	Ar	39.948				
21	HCl	36.461				
22	HCN	27.026				
23	NH3	17.030				
24	CS2	76.131				
25	SO2	64.059				
26	NO	30.006				
27	O2	31.999				
28	NaCl	58.497				
29	KCl	74.596				
30	CaSO4	136.142				
31	Ca(OH)2	74.095				
32	Cl2	35.500				
33	Total Gas (lb/hr)			14507		
34						
56						
57	C	12.011				
58	H	1.008				
59	O	16.000				
60	N	14.007				
61	S	32.060				
62	CaO	56.079				
63	H2O	18.016	84157		10000	10
64	NaCl	58.497				
65	KCl	74.596				
66	CaSO4	136.142				
67	Ca	40.080				
68	CaS	72.140				
69	ASH, Inerts (pph)					
70	Total Solids (pph)					
71	Total Flow (pph)	84157	14507	10000	10000	10
72						
73	Total Flow (pps)	23	4	3	3	
74	Pressure (psia)	200	600	600	600	
75	Temperature (F)	382	700	80	80	

3/10/93 17:19

NEPA Support Document, Mass Balance

Unit	21 Flue Gas GPIF				Flue Gas GPIF spec vol scfm	29 Emergency Flare Gasifier Atmosphere lb/hr	Criteria Pollutants	Criteria Pollutants	Criteria Pollutants	
	R Martin lb-mol/hr	wt %	mol%	Stack (Normal) lb/hr			Stack (GPIF Operating) lb/hr	Fl. Martin Station Change Due To GPIF %		
	20.10	0.7	0.01	0.01	5	13487	SO2	24,880	24,840	-0.96%
	0.00	0.0	0.00	0.00	0	464	NOx	5,443	5,442	-0.0002%
	31609	718.2	17.49	11.47	4503	6666	Particulates	453	624	37.89%
	14,953	830.0	8.27	13.26	6679	5428		No.2 Oil Fired Startup Boiler		
		0.0	0.00	0.00	0		SO2		0.6	
		0.0	0.00	0.00	0		NOx		3	
		0.0	0.00	0.00	0		Particulates		1	
	1	0.0	0.00	0.00	0	113				
		0.0	0.00	0.00	0					
	120489	4301.2	66.68	68.70	28996	38012		Criteria Pollutants	Criteria Pollutants	Criteria Pollutants
	2144	53.7	1.19	0.86	1369	700		Fl. Martin Station	Fl. Martin Station	Fl. Martin Station
		0.0	0.00	0.00	0			Stack (Normal)	Stack (GPIF Operating)	Change Due To GPIF
		0.0	0.00	0.00	0			lb/hr	lb/hr	%
		0.0	0.00	0.00	0	150				
		0.0	0.00	0.00	0					
	227	3.6	0.13	0.06	22		SO2	24,976	24,735	-0.96%
	23	0.8	0.01	0.01	5		NOx	9,366	9,366	-0.0002%
	11297	353.1	6.25	5.64	2225		Particulates	454	-685	37.89%
		0.0	0.00	0.00	0			No.2 Oil Fired Startup Boiler		
		0.0	0.00	0.00	0		SO2		0.6	
		0.0	0.00	0.00	0		NOx		4	
		0.0	0.00	0.00	0		Particulates		1	
		0.0	0.00	0.00	0					
	180744	6261	100	100	41804	65021				
00	180744					65333				
3	50					18				
00	14.7					600				
80	275					1566				

Q1	Q2	Q3	Q4	Q5
1				
2	2	Mass & Energy Balance	DOE - GPIF - CRSS Co. Gasification	
3	3	Estimated Trace Metals Emissions for NEPA Report	Typical Expected Case	
4	4			18
5	5	Identification	Trace Elements	Trace Elements
6	6	From	Normal R. Martin Ash	Normal R. Martin Flue Gas
7	7	To	R. Martin Ash Landfill	R. Martin Slack
8	8		lb/hr	lb/hr
9	9			
10	10			
11	11			
12	12			
13	13			
14	14			
15	15			
16	16	Antimony	0.7421	0.0042
17	17	Arsenic	14.6723	0.2557
18	18	Barium	105.3615	0.3785
19	19	Beryllium	1.362	0.0064
20	20	Boron	27.2296	3.0518
21	21	Cadmium	0.2905	0.0019
22	22	Chromium	9.2404	0.0896
23	23	Cobalt	3.7805	0.0136
24	24	Copper	9.894	0.0581
25	25	Lead	6.759	0.0830
26	26	Manganese	26.625	0.1210
27	27	Mercury	0.0125	0.1863
28	28	Molybdenum	2.0337	0.0190
29	29	Nickel	8.6515	0.0665
30	30	Selenium	1.5642	0.3472
31	31	Vanadium	13.5963	0.0877
32	32	Uranium	1.3015	0.0047
33	33	Thorium	1.9833	0.0071
34	34	TOTAL TRACE METALS	235.10	4.77
35	35			
36	36	Normal Criteria Particulates	92729	331
37	37	(Ash, Limestone, Carbon Loss)		
38	38			
39	39	TOTALS (Particulates & Trace Metals)	92964	336
40	40			
41	41	Stream No.	Estimated Trace Metals Emissions for NEPA Report	
42	42	Identification	Trace Elements	Trace Elements
43	43	From	Normal R. Martin Ash	Normal R. Martin Flue Gas
44	44	To	R. Martin Ash Landfill	R. Martin Slack
45	45		lb/hr	lb/hr
46	46			
47	47			
48	48			
49	49			
50	50			
51	51			
52	52			
53	53	Antimony	0.7421	0.0042
54	54	Arsenic	14.6723	0.2557
55	55	Barium	105.3615	0.3785
56	56	Beryllium	1.3620	0.0064
57	57	Boron	27.2296	3.0518
58	58	Cadmium	0.2905	0.0019
59	59	Chromium	9.2404	0.0896
60	60	Cobalt	3.7805	0.0136
61	61	Copper	9.8940	0.0581
62	62	Lead	6.7590	0.0830
63	63	Manganese	26.6250	0.1210
64	64	Mercury	0.0125	0.1863
65	65	Molybdenum	2.0337	0.0190
66	66	Nickel	8.6515	0.0665
67	67	Selenium	1.5642	0.3472
68	68	Vanadium	13.5963	0.0877
69	69	Uranium	1.3015	0.0047
70	70	Thorium	1.9833	0.0071
71	71	TOTAL TRACE METALS	235.10	4.77
72	72			
73	73	Normal Criteria Particulates	92729	331
74	74	(Ash, Limestone, Carbon Loss)		
75	75			
76	76	TOTALS (Particulates & Trace Metals)	92964	336

NOTE: THE VALUES ON THIS PAGE HAVE BEEN CARRIED OUT TO SUFFICIENT SIGNIFICANT FIGURES. THEY ARE NOT REFLECTIVE OF EXACTING MEASUREMENTS, BUT DO REPRESENT "TYPICAL".

0.0000000000

	QT	QU	QV	QW	QX	QY	QZ
Process	Table 2.12					3/10/93 16:43	
1s	21						
	Trace Elements	Trace Elements	Trace Elements	Trace Elements	Trace Elements		
	GPIF Flue Gas	Combined Ash	Combined Flue Gas	Change Due To GPIF	Change Due To GPIF		
ndfill	R. Martin Stack	Fl. Martin Ash Landfill	R. Martin Stack	R. Martin Ash Landfill	R. Martin Stack		
	lb/hr	lb/hr	lb/hr	%	%		
-----							
TO ARITHMETICALLY COMPUTE.							
VALUES BASED ON RELEVANT PUBLICATIONS IN THE LITERATURE.							
0260	0.000043	0.75378	0.00416	1.574	-0.905		
0900	0.001220	14.67923	0.25199	0.047	-1.452		
0400	0.000051	105.36880	0.37171	0.007	-1.795		
0270	0.000012	1.36272	0.00629	0.053	-1.742		
0220	0.00815	27.32827	3.00107	0.355	-1.662		
0062	0.0000080	0.29112	0.00187	0.212	-1.508		
0810	0.000204	9.24313	0.08808	0.030	-1.702		
0740	0.000020	3.78158	0.01336	0.028	-1.782		
0930	0.000114	9.90412	0.05709	0.102	-1.733		
0340	0.000237	6.78260	0.08164	0.053	-1.644		
0530	0.000176	26.66433	0.11884	0.148	-1.784		
0011	0.000901	0.01336	0.18361	6.871	-1.446		
0450	0.000037	2.03946	0.01867	0.283	-1.735		
080	0.000128	8.65259	0.05554	0.013	-1.703		
0335	0.000779	1.56882	0.34128	0.296	-1.705		
0730	0.000166	13.60699	0.08617	0.079	-1.740		
0273	0.0000050	1.30369	0.00461	0.168	-1.823		
0390	0.000010	1.98404	0.00697	0.037	-1.788		
073	0.01	235.31	4.69	0.009	-1.795		
526	0.437	92557	325				
531	0.45	92792.48	329.97	0.58	-1.795		
ss							
	Trace Elements	Trace Elements	Trace Elements	Trace Elements	Trace Elements		
	GPIF Flue Gas	Combined Ash	Combined Flue Gas	Change Due To GPIF	Change Due To GPIF		
ndfill	R. Martin Stack	Fl. Martin Ash Landfill	R. Martin Stack	R. Martin Ash Landfill	R. Martin Stack		
	lb/hr	lb/hr	lb/hr	%	%		
-----							
260	0.000043	0.75665	0.00418	1.96	-0.52		
900	0.001220	14.73585	0.25297	0.43	-1.07		
000	0.0000510	105.77534	0.37317	0.39	-1.41		
070	0.000012	1.36798	0.00631	0.44	-1.36		
020	0.008150	27.43134	3.01285	0.74	-1.28		
062	0.0000080	0.29224	0.00188	0.60	-1.12		
010	0.000204	9.27878	0.08842	0.42	-1.32		
040	0.000020	3.79615	0.01341	0.41	-1.40		
030	0.000114	9.93430	0.05732	0.41	-1.35		
040	0.000237	6.78868	0.08196	0.44	-1.26		
030	0.000176	26.76707	0.11931	0.53	-1.40		
011	0.000901	0.01341	0.18433	7.26	-1.06		
050	0.000037	2.04731	0.01874	0.67	-1.35		
080	0.000128	8.68597	0.05576	0.40	-1.32		
035	0.000779	1.57356	0.34262	0.60	-1.32		
030	0.000166	13.65945	0.08651	0.46	-1.35		
073	0.0000050	1.30871	0.00463	0.55	-1.44		
090	0.000010	1.99169	0.00700	0.42	-1.40		
073	0.01	236.20	4.71	1.23	-1.41		
26	0.437	93867	327				
81	0.45	94103.19	331.26	0.95	-1.41		

2 DOE - GPIF - CRSS Coal Gasification Process, Phase II, Hot Gas Cleanup Unit (HGCU)  
 3 NEPA Support Document, Mass Balance \*Using FW Data (High Btu - Low Btu) Case

4	-----				
5	Stream No.		22	23	24
6	Identification		Hot Raw Coal Gas	Hot Raw Coal Gas	Zinc Titanate (ZN4)
7	From		PyGas™	PyGas™	(or Zinc Ferrite) Makeup
8	To		HGCU Absorber	spec vol	HGCU
9	Gas		lb/hr	scfm	lb/hr
10	-----				
11	CO	28.010	13487	3036	
12	H2	2.016	464	1452	
13	CO2	44.010	6666	950	
14	H2O	18.015	8328	3720	
15	CH4	16.042	0	0	
16	C2H6	30.068	0	0	
17	H2S	34.076	113	21	
18	COs	60.070		0	
19	N2	28.013	38012	8517	
20	Ar	39.948	700	447	
21	HCl	36.461		0	
22	HCN	27.026		0	
23	NH3	17.030	150	0	
24	CS2	76.131		0	
25	SO2	64.059		0	
26	NO	30.006		0	
27	O2	31.999		0	
28	NaCl	58.497		0	
29	KCl	74.596		0	
30	CaSO4	136.142		0	
31	Ca(OH)2	74.095		0	
32	Cl2	35.500		0	
33	Total Gas (lb/hr)		67921	18142	
34	-----				
56	-----				
57	C	12.011	7602		
58	H	1.008	1430		
59	O	16.000	19947		
60	N	14.007	38836		
61	S	32.060	107		
62	CaO	56.079			
63	H2O	18.016	67922		
64	Zinc Titanate or Zinc Ferrite				68
65	KCl	74.596			
66	CaSO4	136.142			
67	Ca	40.080			
68	CaS	72.140			
69	ASH, Inerts (pph)		311		
70	Total Solids (pph)		311		68
71	Total Flow (pph)		68233		68
72	-----				
73	Total Flow (pps)		19		0.02
74	Pressure (psia)		600		14.7
75	Temperature (F)		1350		80
76	-----				






2 DOE - GPIF - CRSS Coal Gasification Process (Kinetically Balanced)						Table 2.1		
3 NEPA Support Document, Mass Balance						*Using FW Data (High Steam - Low Blu) Case		
4								
5 Stream No.	1				2		3	Dut Al
6 Identification	Raw Coal		Sorb/Coal		Limestone		Coal & Lm'stne	
7 From	R. Martin Pile		0.068		GPIF Covered Pile		GPIF Rec'g Hopper	
8 To	GPIF Receiving Hopper		wt %		GPIF Receiving Hoppe		Crusher/Dryer	
9 Gas	Mol Wt			2.50 *Ca/S Mole Ratio				
-----								
11	CO	28.010						
12	H2	2.016						
13	CO2	44.010						
14	H2O	18.015						
15	CH4	16.042						
16	C2H6	30.068	Proximate Analysis					
17	H2S	34.076						
18	COs	60.070	Vol Matter	28.92%				
19	N2	28.013	Fixed Carbon	54.86%				
20	Ar	39.948	Moisture	1.81%				
21	HCl	36.461	Ash	14.41%				
22	HCN	27.026						
23	NH3	17.030						
24	CS2	76.131						
25	SO2	64.059						
26	NO	30.006						
27	O2	31.999						
28	NaCl	58.497						
29	KCl	74.596						
30	CaSO4	136.142						
31	Ca(OH)2	74.095						
32	Cl2	35.500						
33	Total Gas (lb/hr)							
-----								
56			Ultimate Analysis					
57	C	12.011	69.03%	8344	88%	111	8455	
58	H	1.008	4.48%	542	Purity		542	
59	O	16.000	8.03%	971		443	1414	
60	N	14.007	1.26%	152			152	
61	S	32.060	0.98%	118			118	
62	CaO	56.079	0.00%	0			0	
63	H2O	18.016	1.81%	219	1%	12	231	
64	NaCl	58.497			Moisture			
65	KCl	74.596						
66	CaSO4	136.142						
67	Ca	40.080				370	370	
68	CaS	72.140						
69	ASH, Inerts (pph)	14.41%		1742		124	1866	
70	Total Solids (pph)			12088		1061	13148	
71	Total Flow (pph)			12088		1061	13149	
-----								
73	Total Flow (pps)			3.36		0.29	3.65	
74	Pressure (psia)			14.7		14.7	14.7	
75	Temperature (F)			80		80	80	

Reference Coal - Fort Martin - Low Sulfur - 11/13/92 - MGAS Kinetics  
 6 & Dia Test Size CRSS Predicted Output

3/10/93 17:19

4		5a		5b	5c	5d	5	
Collector Exhaust	0.01 lb/MBtu	Fuel Oil	Fuel Oil	Fuel Oil	Fuel Oil	Fuel Oil	Fuel Oil	
Bunker	@100acfm	Storage Tank	Storage Tank	Storage Tank	Storage Tank	Storage Tank	Storage Tank	
moeph	@100acfm	Coal Dryer	Burner Support	PyGas™ Preheat	Start-up Boiler	Start-up Boiler	Total Usage @ Startup	
mol%	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	
0.00	0.00							
0.00	0.00							
0.03	0.21							
1.02	2.86							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
77.28	337.61							
0.95	5.91							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
20.72	103.40							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
0.00	0.00							
100.00	450.00							
-----								
0.11	86.65%	250	1,015		1,015	444	2,724	
0.00	12.78%	37	150		150	65	402	
0.44								
0.00	0.05%	0	1		1	0	2	
0.00	0.53%	2	6		6	3	17	
0.00								
0.01								
-----								
0.37								
0.12								
1.06								
1	100.00%	288	1,172		1,172	512	3,144	
-----								
0.0003		0.08	0.33		0.33	0.14	0.87	
14.7		35	35		35	35	35	
80		80	80		80	80	80	

# Proposed Ties Between GPIF and Ft. Martin



CRS Sirmine Engineers, Inc.  
Project 31604.00  
Approved by: R.S. Sadowski  
January 4, 1993

GPIF Air Compressors  
21,000 Lb/Hr

Figure 6

permitted levels. However, the need for the Phase II hot gas cleanup system is potentially of much greater significance to future emission limitations either legislated or required for future fuel cell combined cycle application. To insure that the GPIF does not add to the current sulfur emission levels of the Fort Martin Station, it is proposed that only low sulfur coal will be gasified until such time that the GPIF can be shown to be capable of achieving no net sulfur emissions increase on high sulfur coal. This can only be demonstrated after startup and demonstration on low sulfur coal.

One (1) by approximately 5 ft diameter PyGas™ test sized gasifier is expected to generate sufficient coal gas to test the gasification process while firing the fuel gas (approximately 150-million Btu/hr coal feed rate) in a fired Heat Recovery Steam Generator (HRSG) (Phase 1).

The PyGas™ test gasifier will be designed to utilize approximately 12,000 lb/hr of coal at 600 psi operating pressure.

A zinc ferrite type (or zinc titanate) hot gas cleanup process is contemplated for high efficiency sulfur removal and sorbent regeneration under Phase 2, and a conventional sulfur recovery process may be planned for the production of this valuable by-product of sulfur capture. The initial plan, however, is to return the captured sulfur oxides back to the HRSG as sulfur oxides and hence to the Fort Martin Unit #2 breeching to the electrostatic precipitator. Therefore, secondary firing with coal gas will be carried out in the HRSG, and the resulting products of combustion will be injected directly into the inlet side of the existing Fort Martin Unit #2 electrostatic precipitators. In the event of boiler shutdown or failure during gasifier operation, the coal gas must be directed to an emergency flare.

During normal operations, to the extent practical, all process vents and reliefs shall be directed to the auxiliary steam boiler for combustion. If the auxiliary boiler trips, then vents shall be bypassed to the emergency flare.

## **9. Functional Descriptions of Test Facility - Phase 1**

### **Conceptual Design of the Gasification Product Improvement Facility**

#### **Coal Receiving & Storage**

Coal will be dumptruck delivered from the existing nearby Fort Martin low sulfur coal storage facility to a covered, live day bin. Provisions shall be made to collect all rainwater runoff, and pump it to the existing Fort Martin waste water treatment system. The required front end loader for loading from the utility coal pile as well as coal (also limestone and ash) trucks are expected to be subcontracted to a local trucking company familiar with current ash disposal requirements.

#### **Coal Reclaim**

Live coal pile management is expected to be by front loader. Reclaim is accomplished via a weigh belt feeder capable of 0 to 12,000 lbs /Hr coal feed rate directly onto a continuous conveyor belt. The conveyor belt deposits coal continuously into a crusher/dryer (drying heat to come from a tubular type air heater located downstream of the fired auxiliary steam generator), thence to an inlet coal (and limestone) lock hopper of sufficient capacity for coal and limestone

inventory discharge from the weigh belt feeder to the continuous conveyor belt discharge. Therefore all load change and accurate metering is accomplished by the weigh belt feeder. Provisions shall be made to collect all rainwater runoff, and pump it to the existing Fort Martin waste water treatment system. The feeding and conveying systems shall be properly ventilated, and the vented air shall be filtered before being released to the atmosphere.

### Limestone Receiving & Storage

Limestone is received by dumptruck (by others) from an existing nearby rail unloading or quarry facility and dumped directly into a covered, live day bin. Provisions shall be made to collect all rainwater runoff, and pump it to the existing Fort Martin waste water treatment system. The feeding and conveying systems shall be properly ventilated, and the vented air shall be filtered before being released to the atmosphere.

The current plan is to operate the pyrolyzer tube in the slug-flow region at approximately 3.5 fps because Charlie Lowell (ref: DOE DE-AC21-78MC10484) was successful at that point. This is effectively the same velocity as what Foster Wheeler calls "jetting". Therefore, the same 1/8 inch minus dolomite and 16 x 200 mesh limestone size gradation which Foster Wheeler (ref: DOE DE-AC21-86MC21023) was successful with will initially be utilized at the GPIF.

Since milling is complicated by the differences in grindability or "work index" between limestone and coal (limestone is usually harder), we plan to receive pre-sized limestone or dolomite at 16 x 200 mesh and 1/8 inch minus respectively.

While this will lead to a smaller size fraction entering the gasifier, the tortuous path and co-current flow regime serve to assure calcination without unreacted limestone carryover. In turn, there will be less likelihood of "blinding" calcium sulfide crystals with an outside layer of larger gypsum crystals because of the greater surface to volume ratio of the smaller sized limestone. This is really something which we need to test to verify anyway, so these comments merely reflect our logic for a starting point. These comments have been added to the report.

### Limestone Reclaim

Limestone pile management is expected to be by front loader. Reclaim is accomplished via a weigh belt feeder capable of 0 to 4,000 lbs /Hr limestone feed rate directly onto the coal conveyor belt thereby assuring homogeneity between coal and limestone with a minimum of solids attrition. The conveyor belt deposits the mixture of coal and limestone continuously into a crusher/dryer, thence to an inlet coal (and limestone) lock hopper of sufficient capacity for coal and limestone inventory discharge from the weigh belt feeder to the continuous conveyor belt discharge. Therefore all load change and accurate metering is accomplished by the weigh belt feeder.

### Ash Handling & Storage

Ash sources include mainly the gasifier bottom ash along with a minor source from the gasifier outlet cyclone. Gasifier bottom ash will be pneumatically

conveyed into a 100 ton ash silo. Gasifier outlet cyclone solids will also be pneumatically conveyed into the same ash silo. Since the PyGas™ process provides an oxidation zone immediately above the rotating grate, it is expected that retained sulfur in the ash will be predominantly in the fully sulfated form.

In the event the ash contains unsulfated forms of sulfur, it will be first fed to a submerged combustion reactor to complete the sulfation reaction prior to disposal in the permitted Fort Martin existing coal ash landfill. While the quantity of GPIF ash to be added to the existing ash landfill is extremely small relative to current fill rates, it is likely to contain some unreacted alkali which should serve to provide some neutralization benefit in the ash pile.

### Ash Conditioning & Disposal

The ash is removed from the ash silo conical bottom via a water cooled ash conditioning screw into an ash disposal truck. During periods of limestone utilization, care must be exercised to minimize the use of any water spray for dust control to avoid heat increase by chemical reaction with unreacted but calcined lime. An ash removal truck fitted with bag filter vents is preferred followed by Water conditioning or the current method used at the permitted Fort Martin solid waste land fill site may be considered to minimize dusting. The PyGas™ coal gasification process is designed to produce sulfated ash product which is expected to be free of sulfides. However, provisions shall be made to oxidize all ash generated in the process in a submerged combustion reactor. The exhaust from this reactor shall be vented to the auxiliary steam boiler for additional combustion. The treated ash is then dewatered through mechanical filtration equipment, temporarily stored in the ash silo, and transported by truck to the existing ash pond area of the Fort Martin power plant. Fort Martin has an air permeable dust screen at their landfill site. While some air can pass through it, it does provide a good buffer on windy days resulting in less particulate becoming air-borne. We anticipate approximately 15% free moisture per Page 92 Figure 6. The anticipated properties are moist but dry handling granular solids, and conventional ash hauling trucks will be able to handle it.

The ash silo is sized for 100 tons. This is about four days of ash at full load and should accommodate weekends and holidays. We do plan to normally have daily ash hauls.

### Air Compressor

A four-stage centrifugal compressor will be used in conjunction with (2) reciprocating compressors to boost ambient air to 650 psia for injection into the gasifier. The centrifugal air compressor will incorporate two intercoolers and one aftercooler to control inlet air temperatures to stages 2 and 3 and the reciprocating compressor, respectively. The total air compressor package will consume 1.66 MWe. Cooling water needed for the intercoolers will be minimized by allowing larger temperature rises in the cooling water, if practical. Although this will increase power consumption and decrease compressor efficiency, it may allow the intercoolers to be used as economizers to preheat the necessary water for the cycle while at the same time decreasing water consumption from the host utility.

In addition to providing compressed air for the gasifier, the air compression system will be designed to allow instrument air bleed after the aftercooler which is placed in between the centrifugal and reciprocating air compressors. The instrument air will be extracted at 205 psia, 100°F and the pressure reduced to the instrument requirements.

### Proprietary CRS Serrine Engineers, Inc. PyGas™ Gasifier

The gasifier will be a shop fabricated water cooled vessel with three flanges, capable of operation at up to 600 psig. It will include a pressure lock upstream of its pneumatic crushed coal conveying pipe, and an ash pressure lock at the bottom of the gasifier vessel. A rotating grate similar to any conventional fixed-bed gasifier will be furnished complete with its motor drive assembly. Metered air, steam, and water spray nozzles will be furnished at three critical points within the gasifier vessel. The pressure locking valves will operate such that a continuous pressure seal is maintained constantly. A suitable purge and vent system and media will be incorporated into the design to avert reverse flow of hot coal gas into the coal feed system. An emergency (only) vent and flare stack will also be incorporated to automatically operate in the event of GPIF overpressure or a rare unrelated Ft Martin Unit 2 master fuel trip since the GPIF flue gas flow to it should be discontinued during such an upset condition.

### Hot Coal Gas Piping

The test gasifier includes four (4) inch insulated and lagged stainless steel hot gas piping.

The hot low Btu gas produced by the gasifier shall be discharged to the primary gas cyclone via four (4) inch stainless steel piping insulated with calcium silicate insulation of seven (7) inch thickness and lagged.

### Hot Cyclone

The gasifier outlet cyclone is an insulated stainless steel device intended to capture solids which carryover from the gasifier with the coal gas. It is anticipated that since it has performed well previously, the current GE cyclone will be scaled up to the size required for the gas throughput requirement (approximately a 12 to 1 scale up). The cyclone's captured fines stream discharge by gravity and requires a pressure locking chamber to partially depressurize the fines stream for pneumatic conveyance to the ash silo, separate sampling, or for reinjection back to the gasifier. The hot cyclone is approximately 13 ft tall by 2 ft diameter

The gasifier gas outlet cyclone may alternatively be a carbon steel device with 12" thick refractory liner, intended to separate solids carryover from the gasifier in the hot gas by centrifugal force. It is expected that the primary cyclone shall separate up to 600 lbs per hour of solids (char). As the gas stream and the cyclone shall operate at approximately 600 psig and 1120°F, the fines from the cyclone collection chamber shall be discharged via lock hopper and auto valves operated in sequence.

These locks shall initially be pressurized with inert gas up to the cyclone's operating pressure to prevent coal gas escape when the upper valve is opened to

admit solids. Before the fines are discharged via the pneumatic conveying system to ash storage silo, the lock hopper may be depressurized to near atmospheric pressure, or the inert media at pressure may be used to convey fines.

#### Vent Pipe, Rupture Disc, Detonation Arrestor and Emergency Flare

A rupture disc, detonation flame arrester and vent stack with emergency flare are anticipated to be required in the gas line between the gasifier and primary gas cyclone for emergency pressure relief. These devices are specifically designed to relieve and arrest the high velocity and pressure flame fronts that may accidentally develop in the gas piping from gasifier, and to carry any deflagration front from the gasifier, away from personnel and out the top of the building for combustion prior to release to the atmosphere.

The Protectoseal model F25006, 6" bi-directional detonation flame arrester in 316 SS housing is included.

#### Vortex Type Burner

A single vortex type coal gas burner (Coen or equal) shall be utilized to add sufficient air to the coal gas to completely combust the gaseous fuel product of the gasifier. The coal gas burner nozzle is rated at 154-million Btu/hr coal gas firing rate (including sensible heat in the coal gas). The coal gas firing rate is consistent with an excess air of approximately 10% at MCR which is normal for gas fired burners. While past experience has shown the ability to completely combust hot coal gas without support fuel requirements above 50% gasifier load, provisions shall be made to provide for flame stabilization support using light oil fuel using an NFPA Class I ignitor flame. Therefore, under any operating load, whenever the main flame scanner indicates the need for support flame, the ignitor shall be capable of being automatically placed in flame support service.

It is anticipated that the coal gas will be utilized to produce gasification process steam as well as for auxiliary steam generator duty for return to Fort Martin Station. This will allow the GPIF facility to operate at full capacity while the existing utility boiler operates at anywhere from half to full load. The intent is to render the effect of GPIF operation on the existing utility station to the insignificant level.

#### Water Spray Injection

It is anticipated that water mist and steam will be sprayed into the hot raw gas from the GPIF such that the coal gas pipe temperature to the fired heat recovery steam generator (HRSG), and eventually in Phase II to the hot gas cleanup system does not exceed approximately 1100 -1400 degrees F. In this manner the coal gas piping is protected from excessive temperature at the 600 psig operating pressure. The heat of evaporation minimizes water requirements.

#### Gasifier Water Jacket Steam Generator

The GPIF gasifier test unit includes steam generation heat recovery intended to provide a significant portion of the necessary steam for gasifier steam injection



requirements. In this manner, the test facility may be steam self sufficient after startup. This then may allow the packaged boiler steam supply source to be required only during test startup. It has been determined that sufficient heat is available from the compressor intercooler, gasifier water jacket, and gasifier carbonizer tube cooling to generate the entire gasifier steam demand.

### Water/Steam Loop

A pump forced "once through" water cooled intercool loop is contemplated to control compressor temperatures up to 600 psia air compression. The same water cooling intercooler loop may then be circuited to the gasifier water jacket, possibly the gasifier carbonizer tube, and subsequently back into the gasifier grate air blast. The alternative is a circuit to the existing Ft Martin cooling tower.

### Feed Water Pump

The feed water pump must be sized to provide sufficient water for steam generation for gasifier grate air blast injection. Cooling water for air compressor intercooler will necessitate pump operating pressure significantly greater than the ultimate 600 psia needed for the gasifier. A 750 psia operating pressure is neither inconceivable nor particularly difficult to obtain from a number of suppliers. The cost estimate includes a 50 gpm feedwater pump for cooling and coal gas sprays, plus a 25 gpm feedwater pump booster for steam generation. If acceptable to the host utility, a feedwater bleed from the feedwater heater loop may be utilized in lieu of the above pumps.

An alternative under consideration is to receive feed water from Ft Martin using a booster pump, and make intermediate steam (600 psia/ 700°F) in the HRSG for use in the gasification system with all excess steam going back to the utility's cold reheat system. This alternative provides Ft Martin with more efficient use of steam generated in the GPIF system.

### Water/Steam Considerations

The proprietary PyGas™ test gasifier requires up to 10,080 lb/hr of steam for the gasification of caking coal. There are several heat sinks within the cycle that will be used to generate the needed saturated steam at gasifier pressure. The statement of work indicates that the 650 psia steam is required at 640 F. This is well above the saturation temperature of 495 F associated with the above pressure. It is contemplated that the heat sinks within the process provide enough heat to generate saturated steam at the gasifier pressure. The last heat sink would be the gasifier water jacket and carbonizer tube. Once the saturated steam leaves the gasifier water jacket, the steam is mixed with the compressed air. Since the air leaving the compressor is approximately 700 F, the steam mixed with the air will stay well above the saturation point and remain in a dry state.

To generate 10,080 lb/hr of 650 psia saturated steam, 11.85 million Btu/hr of heat must be absorbed by incoming water at 60 F. The heat sinks within the system are the intercoolers and aftercoolers in the air compression system, the gasifier water-cooled carbonizer tube, and the water/steam jacket on the gasifier. The water/steam jacket absorbs 8.47 million Btu/hr and the gasifier carbonizer tube

absorbs 1.97 million Btu/hr for a total of 10.44 million Btu/hr of the needed 11.85 million Btu/hr. The remaining 1.41 million Btu/hr of heat can be absorbed from the air compressor intercoolers.

The information above indicates that the needed steam can be generated from the heat sinks within the process thus integrating the process as desired.

### Process Water Distribution System

The process water shall be distributed from the main process water line main near Monongahela Power's Unit No. 2 as shown on Exhibit 2 of the site tour of June 18, 1991.

The total process water consumption at the pressure 70 psig is estimated as:

Table 3  
Process Water Consumption

1. GPIF feed water	25 gpm
2. Coal gas cooling	5 gpm
3. Ash conditioning	1 gpm
4. Cooling Water Consumption	<u>500 gpm</u>
Total	531 gpm

A 2 inch main is included to supply this quantity of process water for the facility.

### Cooling Water Distribution

The cooling water distribution to the gasifier jacket, coal gas cooling and carbonizer tube cooling is estimated at 25 gpm. Cooling water from the GPIF will be returned to the existing Fort Martin Unit #2 cooling tower. There will not be a separate GPIF cooling tower.

### Packaged Boiler, Fired Heat Recovery Steam Generator (HRSG), & Induced Draft Fan

A small light oil fired packaged boiler is contemplated for space heating and gasification process steam raising during startup. In addition, a coal gas fired HRSG and tubular type coal dryer air heater followed by an induced draft fan shall provide the heat recovery system for returning the Btu's from the gasification of coal to the host utility. If necessary, the startup and space heating packaged boiler flue gas may be vented into the induced draft fan along with the coal gas fired auxiliary steam generator flue gas for removal back to the existing Fort Martin Unit #2 stack.

## Gasifier Integrated Steam Source

The test gasifier will require up to 0.84 lb of steam per lb of coal gasified. With the test gasifier consuming 12,000 lb of coal per hour, this equates to 10,080 lb/hr of steam. A small packaged boiler will be used for startup. Since, the air discharged from the compressor is at 700°F, saturated steam at gasifier pressure produced in the water/steam jacket can be mixed with the air to insure that the steam will remain dry. This prevents condensation in the pipes. Some 11.8 MMBtu/hr of heat must be absorbed to generate 10,080 lb/hr of saturated steam at 650 psia. Therefore, 8.5 MMBtu/hr is transmitted to the steam jacket of the gasifier. The remaining 3.4 MMBtu/hr of heat needed to make the saturated steam will be absorbed by the water through the heat sinks in the cycle. This heat will be absorbed by the water through the use of carbonizer tube cooling and intercoolers/aftercoolers of the compressor as economizers.

## Boiler Chemical Treatment

All water makeup to the auxiliary boiler and reactor cooling jacket shall be softened and injected with environmentally acceptable oxygen scavengers and corrosion inhibitor chemicals.

## Desulfurization

Provisions have been made for limestone feed to the proprietary PyGas™ coal gasifier. Based upon the results of other pyrolyzer tube testing, approximately 20% to 95% sulfur retention may be possible within the gasifier itself. This retained sulfur will be removed from the gasifier and disposed of in the Fort Martin Generating Station permitted coal ash landfill along with the gasifier bottom ash. It is expected that this solid waste product will contain some unsulfated alkali such that some beneficial neutralization of the currently slightly acidic coal ash contained within the landfill may occur. The expected range of calcium to sulfur mole ratios anticipated for testing is 1.0 to 3.0. Depending on sulfur content in the coal, this results in up to approximately a half ton of limestone per hour.

## Potable Water

A one inch potable water line and reservoir tank is included from the utility interface point to the GPIF for lavatory and shower consumption.

## Test Facility Horsepower Requirements

The following table serves to identify the anticipated motor horsepower requirements of the conceptualized test facility.

**Table 4**  
**Test Facility Motor Horsepower Consumption**

The following is a list of motor and horsepowers associated with the test facility.

<i>Equipment Description</i>	<i>Horsepower</i>	<i>K W</i>
<b>Gasifier</b>		
Rotary Coal Metering Drives (2)	10.0	7.45
Grate Drive	15.0	11.18
<b>Air Compressor</b>		
Centrifugal Compressor	1750.0	1305.0
Reciprocating Compressor (2)	700.0	522.2
<b>Coal Receiving/Storage/Reclaim</b>		
Pile Runoff Collection Sump Pump	1.0	0.74
Gravimetric Feeder Drive	3.0	2.24
Transfer Conveyor Drive	10.0	7.45
Vent Fan Drive(Pit Ventilation)	7.5	5.59
Sample Cutter Drive	1.0	0.74
Coal Crusher/Dryer Drive	20.0	14.90
<b>Limestone Receiving/Storage/Reclaim</b>		
Gravimetric Feeder Drive	3.0	2.24
Sample Cutter Drive	1.0	0.74
<b>Coal Gas Combustion/Heat Recovery</b>		
Forced Draft Fan Motor	125	93
Feedwater Pumps	10.0	7.5
Induced Draft Fan Motor	400	298
<b>Wet Oxidation System</b>		
Vacuum Filter Pump Motor	N/A	N/A
Transfer Pumps (2)	N/A	N/A
Oxidation Air Blower Motor	N/A	N/A
<b>Ash Handling System</b>		
Ash Blower	<u>50.0</u>	<u>37.29</u>
<b>Totals:</b>	<b>2,857</b>	<b>2,131</b>

**Process Building**

The building shell erected shall be : 30'W X 100'L X 50'H

The LRF envelope frame with 0.5:12 slope and BR-II roof panels has a clearspan double slope profile with tapered sidewall columns. It offers almost total flexibility in sizes within the limits of the LRF envelope. The wall panels shall have 2" insulation in each. Two (2) 3' X 7" personnel doors, one (1) 10'

X 10' overhead door, one (1) 25' X 17'-6" removable wall panel, gutters and downspouts over entrance area only, exhaust fan (75,000 CF/hr air exchange), intake louvers are included in the building design.

The building foundation and 6" concrete slab, with 4' X 4' X 6' sump and three (3) 4" floor drains to the storm runoff collection pit.

One sump pump, capacity 30 gpm, 52 HTDH, 2 HP

Steel stairs outside to 12' high elevation, with steel treads, landings and handrails per code.

For the heat protection in the winter to maintain 50°F ambient temperature at 0° exterior temperature, the steam-fired or electric unit heaters are included using existing 600 psi steam or electricity from Ft Martin Station.

Control room inside process building area 12' X 12', with 3' X 7' personnel door with half glass.

On the top of control room, second floor testing room 12' X 12' area, one 3' X 7' personnel door with half glass, entrance from the inter platforms. Heat and air conditioning are included, with 2-1/2" concrete floor over steel form deck.

A lavatory facility, to include separate male & female showers, two toilet stalls (each for handicapped persons), two wash basins (one for handicapped persons), complete with standard fixtures will be provided. A pumping and storage tank for waste disposal by portable tank truck will also be furnished.

A furnished combination meeting and break room complete with dry erase marker board, sink and microwave oven, and with coffeemaking, snack and soda machine provisions will be provided. Furniture will consist of two 4 ft x 8 ft folding type tables and twelve (12) straight back chairs.

All process runoff shall be collected in a sump and pumped to the existing Fort Martin Generating Station waste water treatment system.

#### Ash and Other Process Waste Particulate Handling Storage And Disposal

Ash handling from gasifier bottom and process fines from the outlet of the hot cyclone shall be pneumatically conveyed periodically on a timed basis into a 100 ton ash storage silo, dimensions 14' dia X 28'H.

It is expected that the total solids collection from all above mentioning source shall be in the range of 4007 lbs per hour. The ash shall be discharged periodically from the bottom of gasifier to bottom ash lock hopper by way of airlocks operating in sequence. This cycle proceeds automatically on a timed sequence before accumulated fines shall be discharged to the pneumatic system. The lock hoppers shall be depressurized to an atmospheric pressure. Similar discharge lock hoppers shall be employed after the gas cleaning cyclone.

The ash and other waste solids (spent sorbent) shall be unloaded in the disposal truck by telescopic spout when limestone is fed to the gasifier, or by water cooled ash conditioner. (No limestone utilization). The filter-separator bag

shall be periodically cleaned by pressure air. The sequence shall be set by timer. Care must be exercised with ash conditioning water admixing whenever unreacted lime may be present, as heat of reaction and skin burns have been reported in industrial applications using lime. The ash silo shall be vented to the atmosphere by way of a bag filter or electrostatic precipitator.

## **10. Control and Instrumentation System Description**

### **General**

The test gasifier facility will be equipped with a state-of-the-art control and instrumentation system designed in accordance with the existing engineering practice for this type and size of equipment, with the scope sufficient to ensure a high level of facility's availability and reliability. Taking into account the experimental character of this facility, we have added a certain degree of redundancy, where exact process characteristics were unclear or required special attention to the process.

Process control and monitoring functions will be performed in a central control room (CCR) utilizing a microprocessor-based distributed control system (DCS) along with several dedicated control subsystems.

Conceptual design of the proposed system is illustrated in the system block diagram (Fig.1). From the control point of view, the overall plant equipment will be divided into several functional groups (FG), some of them will be equipped with their own, dedicated (possibly PLC-based) vendor supplied control systems, others will be controlled directly by DCS from CCR. Control systems of individual FG's will provide control interface and necessary inputs to DCS for centralized data acquisition, monitoring and reporting. These dedicated control systems may be based on PLC or DCS technology. Main requirements to their suppliers should be compatibility with the host DCS (i.e. the ability to communicate via a common data highway) and uniformity of their hardware basis (e.g. use of the same make of the PLCs).

The following FG's are expected to be controlled by their dedicated specialized control systems and/or PLC 's via remote I/O racks:

- Coal/Limestone Loading System;
- Steam Generation - Coal Gas Flare, Boiler, Water Treatment;
- Existing Boiler Burner Interlock System;
- Compressed Air and Instrument Air Systems;
- Continuous Emission Monitoring (CEM) System;
- Ash Handling System;
- Balance of Plant Systems;

The following FG's are expected to be controlled directly by the DCS:

- Coal Gasifier with Primary Cyclone;
- Hot Gas Clean-up with Secondary Cyclone and Sulfur Recovery System;

### **Standards**

The C&I system shall conform to the applicable industry standards, such as:

- National Fire Protection Association (NFPA)
- National Electric Code (NEC)
- National Electrical Manufacturers Association (NEMA)
- Instrument Society of America (ISA)
- Institute of Electrical and Electronics Engineers (IEEE)
- American National Standards Institute (ANSI)

### Controls Equipment Scope of Supply

#### Control Room Equipment

We anticipate that the following operator interface equipment will be located in the CCR:

Table 5  
Control Room Equipment

Equipment	Phase I	Phase II	Phase III
Operator Stations (CRT with keyboard)	3	4	5
Printers 2	3	3	
Plant Paging & Telephone System	1	1	1
Fire Protection System 1	1	1	
Main Control Room Panel	1	1	1
Sequence of Event Recorder	1	1	1
Emission Monitoring (CEM) and Reporting System	1	1	1
Logging Station w/printer	1	1	1
Video Copier	1	1	1

The following will be included with the DCS and located next to the CCR:

Engineering Station w/keyboard	1	1	1
Historical Data Storage	1	1	1
Printers	1	1	1

#### Control Systems and Equipment

The following FG control systems will be required and implemented for the two phases of the project outlined as follows:

Table 6  
Control Systems & Equipment

Functional Group		
	Phase I	Phase II
Coal/Limestone Loading	Yes	Yes
Coal Gasifier	Yes	Yes
HGCU/Sulfur Recovery	No	Yes
Steam Generation - Flare/Boiler	Yes	Yes
Existing Boiler Burner Interlock System	Yes	Yes
Cont. Emission Monitoring (CEM)	Yes	Yes
Ash Handling	Yes	Yes
Compressed Air	Yes	Yes
Instrument Air	Yes	Yes

### Control of Individual Functional Groups

#### Coal/Limestone Loading System

Coal and Limestone Loading System which includes coal and pebble limestone bunkers, gravimetric feeders, a common belt conveyor c/w the corresponding drives will be operated and controlled by a PLC-based local control system via remote I/O rack. A configured operator interface screen will be supplied for a window into the operation. The DCS will monitor and act as a data acquisition system via a data interface link between the DCS and PLC data highways.

#### Coal Gasifier System

The overall coal gasifier system, including the gasifier itself, coal feeding, air and steam supplies to the gasifier and coal gas system with the primary cyclone and (possibly) flare, will be controlled from the DCS via a dedicated redundant processor.

In order to monitor and control the position and intensity of the gasification zone in the coal gasifier, we are proposing to install 3 infrared (IR) monitors (scanners) on the sides of the gasifier. Each of these instruments will measure two parameters: intensity and frequency of the IR radiation, which, as we expect, will characterize the intensity and position of the zone of max heat generation. These parameter measurements will allow the operators, during the initial testing and commissioning period, to establish patterns of normal operation and to recognize patterns of abnormal situations. By applying methods of pattern recognition, IR monitors in combination with temperature measurements and gas analyzers will allow development of methods of positioning of the gasification zone and of optimizing the overall gasification process.

The gasifier system will also include a multipoint gas analyzer system to continuously monitor concentration of H<sub>2</sub>S and other gaseous components at



the gasifier, primary cyclone outputs and within the process area. The gas analyzers will be located in the common chemical analysis room.

Our preliminary evaluation of the system control requirements indicates that the processor should be capable to support (approximately) the following number of I/O's:

Analog Inputs (TC's, RTD's, 4-20mA):	100
Analog Outputs:	25
Digital (on/off) Inputs:	75
Digital (relay) Outputs:	50

This system is based on the above I/O count and vendor quotations for control systems of a similar size and configuration.

### Hot Gas Clean-up and Sulphur Recovery Systems

Control requirements for these systems include a substantial number of control functions, mostly sequential logic operations. These systems will be controlled directly by DCS via a dedicated redundant processor.

The HGCU will be served by the multipoint gas analyzer system to continuously monitor concentration of H<sub>2</sub>S and other gaseous components in the hot coal gas upstream and downstream of the absorber and also will monitor oxygen in the regenerator system.

The latest GE RDC report of June 1980 and 50% contingency for the sulphur recovery system, we estimate that the system should be capable to support the following number of I/Os:

Analog Inputs (T/Cs and RTDs)	75
Analog Inputs (4-20 mA)	75
Analog Outputs	40
Digital (on-off) Inputs	120
Digital (relay) Outputs	100

Our estimate is based on this I/O count and a number of vendor quotations for similar size control systems.

This gas analyzer will be common for the gasifier and will be incorporated into one common gas monitoring system.

### Steam Generation System

The Gasifier Steam Generation System will be operated and controlled by a PLC-based local control system via remote I/O rack. The system will execute all necessary water treatment, feedwater, steam temperature and combustion control functions required to meet the load demand and to maintain boiler parameters.

## Coal Gas Combustion

The coal gas burners are expected to be equipped with a vendor supplied (possibly PLC-based ) burner management system (BMS) containing complete package of instruments, valves, flame scanners, etc., to comply with the NFPA recommendations for coal-fired burners. The BMS will be connected to the DCS via hardwired connections and will be controlled from the CRT operator stations. Interlocks and permissives consistent with the safety shutdown philosophy of the existing Fort Martin Station utility boiler's burner management system will be provided. A remote indication of coal gas combustion and steam generation status will be provided and located in the existing Fort Martin Station utility control room.

## Continuous Emission Monitoring System (CEM)

Emission monitoring equipment shall include stack analyzers to continuously monitor the flue gas exhaust for NO<sub>x</sub>, SO<sub>2</sub>, O<sub>2</sub>, CO, H<sub>2</sub>S and Opacity. The analyzers will be housed in a special environmentally controlled analyzer shelter adjacent to the exhaust duct of the auxiliary boiler. The analyzer housing will be shared with the bulk of the analyzer equipment which has to provide thorough monitoring of numerous gas components and solid particulates in the gasifier exhaust, primary and secondary cyclone outlets and HGCU outlet. The equipment will monitor facility compliance for all applicable Federal and State emission requirements. The system will be monitored by the DCS for alarms and critical measurements.

A stand alone personal computer located in the control room and software dedicated to the emission monitoring system will be included with the system. The equipment vendor will provide system certification, start-up assistance, installation supervision, personnel training and maintenance program.

## Ash Handling System

Bottom Ash Removal, Handling and Storage System will be controlled with a PLC-based local control system via remote I/O. System design, scope of supply, functions and interface with the DCS will be similar to the Coal/Limestone Loading System.

## Compressed Air and Instrument Air Systems (From Process Air Compressors)

These systems which include centrifugal and displacement type compressors, filters, dryers, and pressure regulators will be controlled by a PLC-based local control system via remote I/O racks.

## DCS Capabilities and Controls

The DCS will include dynamic controllers, I/O racks, communication devices, and operator stations. The operator interface to the system will be through color

CRT's and operator keyboards which will be preprogrammed for easy access to color graphic displays and specialized operator functions.

The DCS will provide soft A/M stations for remote control of the various field devices and control loops. This control will be accomplished via the operator's CRT console and keyboard. The logic control functions, such as motor control and discrete monitoring, will be accomplished in the DCS using key selection and dynamic displays on the operator console. The configuration of function codes and control strategies will reside in the non-volatile memory and will be maintained in the event of a power failure.

The control schemes will be hardware and software configured with consideration for redundancy as applicable. In the event of any single failure of power supply, processor / controller or highway / communication link / data multiplexers, it will alert the operator while continuing to keep the process under uninterrupted automatic control from the CRT.

If the primary control processor should fail, a secondary processor (operating in the "hot stand-by" mode) will assume control responsibility with bumpless transfer. In the event of a failure of both processors, the system will be configured such that analog and digital outputs will go to pre-determined fail safe positions.

Communication to the individual dedicated PLC-based control systems will be accomplished via one common data interface link between the DCS and PLC data highways. A Performance Assessment package will be configured in the DCS. This software application will gather information for each system and will provide real time displays to the operator.

Power supplies will be redundant, so that in case of a power supply failure, a back-up power supply will assume responsibility. The Operator interface will provide a user friendly environment for control and data acquisition functions. This interface will provide access to plant wide operations allowing the operator to monitor and take corrective action as required. The displays will provide dynamic information by updating information and status displayed to the operator.

An Engineering workstation will allow personnel to configure operator consoles and control hardware. The software package will enable the engineer to design, configure, monitor, trend, tune, modify and document process activities. Graphic symbols and function codes will be used to build the process logic control drawings on the CRT screen. The Engineering workstation will be used during start-up and de-bugging stage of commissioning. It will also be used as a tool to maintain, troubleshoot, operate and re-configure the system if required once the plant is operating.

The DCS will be field maintainable and configurable by the owners personnel after appropriate training.

## **11. Electrical System Assessment**

### **General Requirements**

## Load Profile - New Gasification Plant

4160 V. Load	2.85 MVA.
Total Load	3.4 MVA.

## Project Concept

The Project concept is to supply existing Fort Martin Generating Station with steam from the proposed gasification plant. This plant is to be a stand alone satellite facility to be located in the vicinity of the generating station. All utilities are to be provided to the plant's battery limits. The 13.8 kV utilization voltage will require that the utility company furnish and install the required feeder to the plant's electrical system primary.

## Codes and Standards

Except where noted, all electrical systems shall be designed, fabricated and installed in accordance with the latest edition of the National Electrical Code, and applicable ANSI, ICEA, NEMA, NESC, IEEE Standards as defined in the RFP ( exceptions taken will be defined). Components that are UL listed and labeled shall be provided if required by local authorities.

## Electrical Equipment

Selection and design of all electrical components and systems shall be in accordance with the applicable codes and standards. Reliability of operation shall be the primary consideration in the facility design. The Preliminary single line diagram will serve as a typical basis of supply (CRSS Drawing SK-E-001).

The electrical equipment shall include the following, located in the facility building:

Table 7

MEDIUM VOLTAGE SWITCH GEAR HV-1  
LOW VOLTAGE SWITCHGEAR LVSWG-1  
1750 HP STARTER WYE DELTA  
2 (400HP) COMPRESSOR WYE DELTA  
1200A NON-SEGREGATED BUS  
MCC-001-GPIF  
STATION BATTERY AND CHARGERS  
"UPS" UNINTERRUPTABLE POWER SUPPLY

15 kV Pole Line (by utility company)

A 15 kV ploe line feeder with parallel overhead ACSR conductors will interconnect the GPIF with the existing facility's 13.8 kV switchgear. This feeder line will be used to cold start the GPIF.

## Plant's Primary Transformer

The plant's primary transformer "T1" will be 5 MVA, outdoor, oil filled, 13.8 kV delta to 4.16 kV resistance-grounded wye, standard impedance, equipped with special winding and cooling fans to permit temporary overloading and allow for future growth.

## BUS DUCT.

The bus ducts shall be 5 kV, 1200 A, 3-phase, 3-wire plus ground, non-segregated phase type, rated to accommodate maximum design operating voltage. The rated momentary current will be based on the maximum three-phase fault current to which the bus can be subjected.

## Coal Gasification Electric Power System (parasitic loads)

The electrical power system will perform the following functions:

Provide a reliable source of electrical power for plant auxiliaries during all operating conditions.

Provide rapid isolation of any faulted equipment without unnecessary loss of supply to other equipment.

Provide satisfactory motor starting and bus voltage regulation.

Medium Voltage Distribution Switchgear HVSWG-1  
(4.16 KV, Vacuum Type, 350 MVA).

The circuit breaker and metering portions of the medium voltage switchgear will be a non-drawout, metal-clad, dead front, with each breaker cubicle isolated from the adjacent cubicle by a metal barrier. The interrupting ratings will be selected in accordance with ANSI Standard C37.010 making full allowances for asymmetrical symmetrical current ratios. Incoming breaker and internal bus continuous current ratings will be chosen to be greater than the maximum expected loading.

## Medium Voltage Motor Controllers:

Motor controllers portion of the medium voltage switchgear will be of the draw-out full-voltage across-the-line or reduced vacuum type (as indicated on the single line diagram), rated a minimum of 400 MVA, double-stacked wherever possible.

The controller and the bus will be adequately rated for the voltage class, the continuous current and the available short circuit level.

The protective fuses will be ANSI Class "R" for motor starting duty, and class "E" for transformer feeder duty. Single-phase protection will be provided to open contactors whenever any fuse blows.

Overload, under-voltage, single-phasing and ground fault protection will be provided.

Control voltage will be 120 V AC.

Each controller will have an ammeter and an ammeter switch.

All motors shall have motor circuit protection.

The switchgear lineup will include provisions for future bus extension on one end.

Switchgear rooms will be mechanically cooled and pressurized with filtered air to prevent the entrance of dust and dirt. Switchgear rooms will have at least two exits to assure safe personnel egress.

#### Secondary Unit Substations.

The 480 volt systems will be 4-wire, 3-phase, wye connected, and solidly grounded at the transformer neutral.

Transformer "T2" shall be an indoor dry-type, cast-coil, standard impedance, rated 1000 kVA.

For ease of maintenance, the 480 volt switchgear will be located indoors in pressurized switchgear rooms or other clean areas. Cast-coil, dry type transformers will be used indoors.

Transformer cooling fans will be provided to allow for future load growth and permit temporary overloading. The unit substations will be physically arranged to allow future switchgear additions, and to allow for transformer removal and replacement.

Main circuit breakers will be fully-rated, manually-operated withdrawable, air-break, stored energy spring operated, dead-front type, complete with solid-state overcurrent and ground fault trip devices.

Bus shall be fully rated to supply a continuous load of 1600 A.

Loads supplied directly from unit substations will include motor control centers, and other 480 volt loads larger than 100 amperes.

#### Motor Control Centers and AC Distribution Panels.

MCC's will have NEMA Type 1A enclosures with gaskets on doors and filler plates, or NEMA Type 12 in Water Treatment Area. Locations will be chosen with care to avoid damp, dirty, or hot areas and to allow adequate front and rear access.

Motor control centers will utilize standard modules factory assembled in suitable shipping lengths.

Motor control centers will be rated 65,000 A.S.C. and have NEMA Class I, Type B wiring rated 600 volts for 480 volt service. The upper limit of motor size supplied from MCC starters will be 200 hp where application is continuous duty with infrequent starting. Larger motors may be controlled by MCC starters where the application involves intermittent duty. Dual mounted molded case circuit breaker feeder units will also be provided in MCC's to supply 480 volt unit-related loads that do not require remote control.

Bus shall be fully rated to supply a continuous load as shown on the drawings and specifications.

Each fully rated combination starter unit will be complete with a molded case circuit breaker having adjustable magnetic trips only, magnetic contactor, three bimetallic overloads, auxiliary contacts, control power transformer, and control wiring terminal block. Control power transformers will be adequately sized to power the motor starter as well as the auxiliary control devices. Starter controls will be 120 volt AC with a coil seal-in contact.

The breakers will have 65,000 A interrupting capacity adequate for the available short circuit current.

All motor starters will be of the same manufacturer to ensure interchangeability of parts and to minimize stocking of spare parts. In addition, circuit breaker distribution panels will be provided at selected locations, as required, to serve small loads.

A minimum of 20% fully equipped space shall be provided in the motor control center for future additions.

#### DC Battery Powered Systems (breaker control).

125 VDC battery system with an energy storage capacity of four (4) hour minimum will include a lead-calcium, solid state rectifier-battery chargers, and main DC distribution panels.

The battery capacities will be adequate to supply all associated loads for the required sequence, duration, and combinations that occur when each breaker unit must be operated with no other power sources available.

The battery nominal voltage, float voltage and end of discharge voltage will allow operation over a voltage range acceptable to standard NEMA equipment with only occasional need for recharging.

The battery chargers will be sized to supply those DC loads that exist continuously during normal unit operation while simultaneously recharging a fully discharged battery. The maximum battery recharge period will be 12 hours. Chargers must be capable of operation without the battery.

A circuit breaker DC distribution panel will be provided adjacent to the batteries to minimize the length and maximize the security of the battery feeder cables. The circuit breakers will have thermal-magnetic overload trips, except for circuits feeding emergency auxiliary motors, which will have magnetic trips only.

DC battery powered emergency lighting system shall be furnished similar to the above in all respects.

#### Grounding System.

In general, grounding system will be in accordance with the National Electrical Code and IEEE recommendations.

#### Instrument Grounding System.

A separate insulated grounding system will be provided for the computer and other noise sensitive electronic equipment. This will be a radial system, without loops and will be connected to the plant ground grid at one point only.

Instrument cable shields will be grounded at the load side only, leaving the sensor end ungrounded and insulated with the exception of thermocouples which are to be grounded at the instrument end.

#### Lightning Protection.

The lightning protection system will be designed in accordance with the National Fire Protection Association Lightning Protection Code (NFPA 78) Class I or Class II systems, UL96A, the National Electrical Code, IEEE Standards and the Lightning Protection Institute - Installation Code (LPI-175).

#### Electrical Heat Tracing.

Freeze protection and process heating systems will be provided for outdoor pipes, pumps, vessels and instrument sensing lines requiring process heating or freeze protection. The freeze protection system will automatically operate whenever the ambient falls below 40°F and will provide sufficient heat to prevent water freezing when the ambient temperature falls to 5°F less than the lowest ambient temperature recorded at the site. Control and monitoring systems for freeze protection will be centralized.

#### Lighting Systems.

Plant lighting will consist of normal lighting and self contained DC operated emergency lights.

Normal lighting will provide illumination during normal operating conditions.

Facility indoor lighting distribution will be three-phase, four-wire. A 480/277 volt system will be used. Facility outdoor lighting distribution will be 480 volt, three-phase, three-wire with phase-to-phase connected loads.



Indoor lighting circuits will be distributed through three-phase, four-wire lighting panels, which will be located centered to and near their respective loads to minimize voltage drops.

Distribution will be designed so that failure of any single lighting panel will not totally black out any floor or single large area.

Lighting equipment selection will be based on the requirements of specific areas. Incandescent, fluorescent, and high pressure sodium sources with appropriate luminaries will be used depending on the application and the needs of each location. High pressure sodium lighting will be used for outdoor installations.

Generally, the illumination levels for facility areas will be those recommended by the Illuminating Engineering Society.

Lighting circuits will be switched at their distribution panels. Rooms and small buildings will have light switches at each doorway. Outdoor lighting will be photoelectrically controlled with provisions for manual override.

Loop road lighting will be in accordance with recommendations of the National Illuminating Engineers Society. These fixtures shall be suspended from building structural walls or members.

Emergency AC and lighting system will be provided for purposes of personnel egress and continuation of critical activities during emergency conditions.

Design illumination levels for egress lighting will be those required by applicable Federal, state, or local fire codes.

#### Communication Systems.

Telephones will be provided in the control room, in the offices and electrical switchgear room.

A facility paging and two-party communication system, complete with amplifying equipment, handset stations and speakers will be provided.

#### UPS System.

UPS System shall be 30 KVA with two 200 A, 3 ph., 4W outputs plus isolated ground for process controls and system architecture power supplies, with 15 minute ride-through and lead-acid battery racks as required.

#### Emergency Process Equipment.

The compressed air, auxiliary boiler and gasifier jacket cooling water feed systems shall be capable of automatic switchover to the auxiliary DC power

source in the event of AC power source failure for equipment protection against overheating.

#### Life Safety System (fire alarms).

The zone panel shall be stand alone and report to a central command station located in the Engineer's Office. Total number of zones shall be at least 8 active with four spares.

#### Fire Protection System.

As separate electric source from Fort Martin Generating Station shall be utilized to power a dedicated fire pump serving the GPIF area in the event of fire.

## 12. Functional Descriptions - Phase 2

### Conceptual Design for Coal Gasifier Test Facility

#### Hot Gas Cleanup Unit & Sulfur Recovery

This area will be added under Phase II of the Coal Gasifier Test Facility.

#### Fluid Bed Absorber

The fluid bed absorber follows the ground rules suggested by METC to furnish a two stage bed. Given the reaction kinetics for the sulfidation of zinc ferrite, we feel that a single bed might be adequate to get the desired H<sub>2</sub>S removal. We assume a 2-stage bed is desirable for alternative research studies, and perhaps to produce ultra high sulfur capture, a landable goal.

#### Sorbent Regenerator

We have also used a riser tube sorbent regenerator as suggested by METC. If that arrangement is insufficient, we have allowed some space to install a moderately sized regenerator (fluid bed reactor) to obtain more residence time.

The revised arrangement could require the regenerator to be located above the absorber to permit gravity flow of regenerated sorbent into the absorber bed. That would raise the profile of the HGCU above the building roof thereby adding to the cost.

We have placed an airfin cooler to reduce the recycle gas to about 250-300°F as the recycle blower suction to allow standard materials (CS) in the blower.

Generally we are following the regenerator cooling cycle used by GE on their Schenectady pilot plant. It is believed that the system offers METC a flexible means to test various diluent circulating regimes to optimize the sulfur recovery feed gas.

### Sulfur Recovery Unit

There are a variety of ways to convert the sulfur values in the off-gas to salable products.

The recovery of sulfur as sulfuric acid or liquid SO<sub>2</sub> are available as tested commercial processes so pilot plant study of such processes would be redundant.

The alternative of converting to elemental sulfur is supported by proven commercial processes such as the Allied/Davy Powergas SO<sub>2</sub> Reduction Process.

### Sodium/alumina catalysts (RTI bench scale work)

The tail gas from sulfur recovery should have the capability to be recycled to the process to eliminate final treatment to meet air emission standards.

Disposal of the recovered sulfur may present a problem. Because the sulfur is produced on an intermittent basis according to the pilot plant schedule, it may be difficult to find a user who would accept it. Also, at this point we are not certain of the quality of sulfur produced.

Those factors indicate that disposal to a solid waste dump appears to be a likely method of disposal. Solid sulfur is relatively insoluble, but it is combustible giving off hazardous products of combustion. Therefore, it may not be acceptable in landfills. The disposal of the sulfur will have to be investigated when a specific site is selected during the detailed design phase.

Liquid or solid sulfur produced from the test facility is expected to be either sold or properly disposed of in a disposal facility permitted for this type of material.

As an alternate, regenerated sulfur dioxide may be piped back to the gasifier or auxiliary packaged steam generator for ultimate ducting back into the breeching of Fort Martin Unit #2 upstream of the electrostatic precipitators.

## HGCU Description of Operation

### Coal Gas Cycle:

The purpose of the HGCU is to remove the H<sub>2</sub>S and sulfur compounds to a suitable level (<10 PPMV) from the coal gas stream. This unit also supplies the SO<sub>2</sub> rich feed gas to the direct sulfur recovery unit (DSRU).

The HGCU receives coal gas from the fines cyclone located in the gasifier area. The gas (which includes tars) is fed into the bottom of the HGCU absorber. The feed gas is at 600 psia and 1100°F.

The sorbent reagent is zinc ferrite with a binding agent to make a fluidizable grade catalyst. The zinc ferrite absorbs the sulfur bearing materials in the coal gas by converting the zinc and iron oxide components to zinc and iron sulfide. The sulfidation reaction is exothermic which raises the gas temperature to about 1200°F.

The coal gas passes through the perforated plate in the bottom of the absorber vessel. The gas fluidized sorbent bed allows intimate gas and sorbent contact.

The fluidizing coal gas then passes through a second perforated plate to a second fluidized sorbent bed. The final bed removes the last traces of sulfur bearing materials in the gas to a point less than 10 ppmv.




The cleaned coal gas passes out top of the absorber vessel through the internal cyclone which removes the larger particles from the gas and returns them to the upper bed through the cyclone dip leg.

The gas then passes through the sorbent fines cyclone to remove the sorbent fines from the coal gas before leaving the HGCU for delivery to the flare. The sorbent fines are removed to a tote bin through the cyclone lock hopper. The fines tote bin is either returned to the sorbent manufacturer or its contents are wasted to landfill depending upon sorbent economics.

### Sorbent Cycle

The sorbent treats the coal gas in two fluidizer beds in the HGCU Absorber. In this process, the zinc ferrite is converted to zinc and iron sulfide. This action is known as "sulfidation".




The sulfidation reactions are as follows:



It is necessary to continuously remove the sulfidated sorbent from the fluid beds and reactivate it to zinc and iron oxides. This process is known as "regeneration".

The sorbent is withdrawn from the lower bed by gravity into the spent sorbent receiver through a pipe. The inlet of the pipe is located near the top of the lower bed to catch the overflow of the bed. The rate of flow is controlled by a slide gate or other type of valve.

The sorbent in the spent sorbent receiver is in turn fluidized by the recycle gas stream entering the bottom of the spent sorbent receiver. Air is fed into the fluidized stream to provide oxygen to oxidize the sorbent according to the following reactions:



The zinc sulfate reaction tends to occur at temperatures below 1200°F. Therefore, the regeneration temperature should be between 1250 and 1500°F.

The gas velocity in the riser tube is sufficient to transfer the sorbent up the tube to discharge into the regenerated sorbent cyclone. The cyclone drops out the sorbent into the body of the cyclone. The regeneration gas bearing the SO<sub>2</sub> gas leaves the top of the cyclone.

The regenerated sorbent is then fed by gravity into the upper fluid bed of the HGCU absorber. The flow rate of sorbent is controlled by a slide gate or other type of valve. The flow rate in the sorbent regeneration loop is controlled to prevent the break through of H<sub>2</sub>S in the coal gas discharge. Break through would be any level above 10 ppmv of H<sub>2</sub>S in the clean gas stream.

The sorbent passes from the upper bed to the lower bed through an internal standpipe to complete the sorbent cycle.

As the sorbent circulates, it wears and generates fines which are removed from the sorbent cycle. These losses are made up by feeding fresh sorbent through the fresh sorbent lock hopper. Fresh sorbent is received in tote bins from the sorbent manufacturer. Fresh sorbent batches are transferred through the fresh sorbent feeder and a dense phase pneumatic transfer system to the fresh sorbent lock hopper.

The fresh sorbent and fines lock hoppers must be vented and purged through the plant vent system to remove any coal gas in the vessels. This action is necessary from a safety and pollution control standpoint.

### Regeneration Gas Cycle

The carrier gas for the regeneration reaction in the riser tube is handled in the regeneration gas loop. The purpose of this system is to provide diluent gas for diluting the oxygen fed into the riser tube (regenerator). Dilution and distribution of the oxygen feed is necessary to prevent overheating of the sorbent. The sorbent breaks down when heated over 1500°F.

After the recirculation gas leaves the top of the regenerated sorbent cyclone, it passes through a fines removal cyclone to remove entrained sorbent fines. The fines are removed through a lock hopper to a fines tote bin for disposal.

The gas then passes through a porous metal or ceramic medium filter to remove any fine dust that passes through the fines cyclone. This piece of equipment was added to ensure a clean gas stream to avoid fouling the downstream shell and tube heat exchangers. This may be an optional piece of equipment for the pilot plant depending upon the dusting characteristics of the new fluid bed sorbents being developed.

Because the sorbent regeneration reaction was exothermic, it is necessary to remove the heat of reactions from the system. It is also necessary to cool the recirculating gas to ca. 300°F at the recirculation blower inlet to avoid overheating and the requirement of exotic materials. The recirculating gas heat exchanger accomplishes the cooling by reheating the cool recirculating gas before it is fed to the regenerator. Cold gas feed is likely to thermally shock the hot sorbent.

The SO<sub>2</sub> rich offgas is removed from the recirculating gas stream at either side of the recirc gas heat exchanger. This allows the offgas stream to be taken off at either 400°F or 1100°F as desired. The SO<sub>2</sub> rich offgas is bled off the system through a flow meter and flow control valve to feed the sulfur recovery system or to atmosphere through the dry lime quench system to suit pilot plant operating plans.

The still hot recirc gas then passes through the air preheater to heat up the regeneration system air supply. The regeneration air is supplied from the gasifier compressed air system.

It may also be desirable to dry the regeneration air supply to keep moisture out of the recirc gas system. Moisture in the air could combine with the SO<sub>2</sub> gas in the system to form H<sub>2</sub>SO<sub>4</sub> which, in turn could cause corrosion in the equipment.

The recirc gas then passes through an airfin cooling coil to trim out any residual heat to reduce the gas temperature to 300°F. The cooled recirc gas enters the recirculation blower which increases the gas pressure back to 600 psia to pump it around the system. The blower serves to overcome the system pressure drops such as the riser tube, cyclones, filter, heat exchangers, etc., required by the system.

The blower discharges through the shell side of the recirculating gas heat exchanger into the bottom of the spent sorbent receiver to complete the cycle.

The regeneration air supply is distributed to the air inlets on the regenerator riser tube to burn off the sulfur. The air flow is controlled by a temperature control system to prevent overheating in the riser tube.

A electrically powered start-up heater is provided at the discharge of the blower to heat up the system by circulating hot nitrogen. This would be done for a cold system start-up.