

reactors DSRP-b

Desulf and Regen transport reactor price calculation

DSRP

Regenerator Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	277,458	
Area =	3.854 ft^2	
I.D.	27.137 in	
thickness=	0.494	
shell wt.=	14,298 lbs	
heads wt.=	323 lbs	

air volume	215,340	cfh	HP-O2-N2
ROG volume	299,541	cfh	ROG
regen sorbent flow	1,201,050	lb/hr	ZNS2RGEN
regen sorbent vol.	20,018	cfh	

sorbent vol% 7.21%

Corrosion depth	0.125	in
reactor height	100	ft

total wt. 16,814 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

total wt. 16,814 lbs

size vs. regen size 1

Desulfurization Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	1,687,918	
Area =	23.443 ft^2	
I.D.	66.933 in	
thickness=	1.035	
shell wt.=	73,889 lbs	
heads wt.=	4,121 lbs	

coal gas in volume	1,409,220	cfh	RAW-CG
cg out volume	1,877,650	cfh	CG-CALC
regen sorbent flow	2,669,000	lb/hr	ZNS
regen sorbent vol.	44,483	cfh	

sorbent vol% 2.64%

Corrosion depth	0.125	in
reactor height	100	ft

total wt. 89,711 lbs (includes additional 15% for nozzles, manholes, etc.)

Desulfurization Standpipe

total wt. 89,711 lbs

size vs. desulf size 1

total wt. 213,051 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed	1.415 \$/lb	1990 \$	>100,000 lb calc
	1.512 \$/lb	1996 \$	1.4152335 1.234 <100,000 lb calc

Cost of installation \$644,349

Total reactor cost \$1,771,959 includes cost of installation

DSRP-b reactor

DSRP-b Reactor Cost

DSRP

DSRP Reactor				
v (ft/sec) gas =	3	10800 ft/hr	slipstream	153,708 cfh SLIPSTREAM
V (cfh) =	393,089		ROG volume	237,184 cfh ROG-COOL
space time -gas	33.33 seconds		reactor effluent	361,900 cfh RXNPRD
v (ft/sec) cat =	2.3	8280 ft/hr	DSRP reactor Q	-51,320,000 BTU/hr
Area =	36.868 ft^2		catalyst flow	1,001,581 lb/hr
I.D.	83.936 in		catalyst vol.	16,693 cfh
thickness=	1.266 in			
shell wt.=	113,355 lbs		catalyst vol%	5.47%
heads wt.=	7,929 lbs		Corrosion depth	0.125 in
			reactor height	100 ft

total wt. 139,477 lbs (includes additional 15% for nozzles, manholes, etc.)

DSRP Standpipe

Cyclone (20% of reactor size)	27,895	Area =	36.87 ft^2
standpipe height	40 ft	I.D.	83.94 in
		thickness=	1.27 in
		shell wt.=	45,342 lbs
residence time	11.05 minutes	heads wt.=	7,929 lbs

total wt. 89,157 lbs (includes additional 15% on standpipe weight + Cyclone weight)

Heat Exchanger

Heat Exchanger Area (ft^2)	<u>3556</u>	heat exchanger pipe thickness	<u>0.25</u> in
volume of steel	74		
<u>total weight</u>	<u>36,229 lbs</u>		

total wt. 264,863 lbs weight for DSRP reactor system

COST

C.S. unit price for quantity needed	1.371 \$/lb	1990 \$	>100,000 lb calc
	1.465 \$/lb	1996 \$	1.371208108 1.146 <100,000 lb calc
Cost of installation	\$776,129		

Total reactor cost \$2,134,355 includes cost of installation

reactors DSRP-c

Desulf and Regen transport reactor price calculation

DSRP

Regenerator Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	23,882	
Area =	0.332 ft^2	
I.D.	7.962 in	
thickness=	0.233	
shell wt.=	1,981 lbs	
heads wt.=	13 lbs	

air volume	19,366 cfh	HP-O2-N2
ROG volume	26,009 cfh	ROG
regen sorbent flow	71,663 lb/hr	ZNS2RGEN
regen sorbent vol.	1,194 cft	
sorbent vol%	5.00%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 2,293 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

total wt. 2,293 lbs

size vs. regen size 1

Desulfurization Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	1,164,094	
Area =	16.168 ft^2	
I.D.	55.585 in	
thickness=	0.880	
shell wt.=	52,215 lbs	
heads wt.=	2,419 lbs	

coal gas in volume	1,139,050 cfh	RAW-CG
cg out volume	1,186,750 cfh	CG-CALC
regen sorbent flow	71,663 lb/hr	ZNS
regen sorbent vol.	1,194 cft	
sorbent vol%	0.10%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 62,829 lbs (includes additional 15% for nozzles, manholes, etc.)

Desulfurization Standpipe

total wt. 62,829 lbs

size vs. desulf size 1

total wt. 130,244 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed

1.528 \$/lb	1990 \$
1.632 \$/lb	1996 \$

>100,000 lb calc	
1.5276336	1,459
<100,000 lb calc	

Cost of installation \$425,193

Total reactor cost \$1,169,282 includes cost of installation

DSRP-c reactor

DSRP-c Reactor Cost

DSRP

DSRP Reactor

v (ft/sec) gas =	3	10800 ft/hr	slipstream	9,443 cfh	SLIPSTREAM
V (cfh) =	31,212		ROG volume	20,364 cfh	ROG-COOL
space time -gas	33.33 seconds		reactor effluent	29,995 cfh	RXNPRD
v (ft/sec) cat =	2.3	8280 ft/hr	DSRP reactor Q	-4,029,000 BTU/hr	
Area =	2.93 ft^2		catalyst flow	78,632 lb/hr	
I.D.	23.650 in		catalyst vol%	1,311 cft	
thickness=	0.446 in		catalyst vol%	5.41%	
shell wt.=	11,265 lbs		Corrosion depth	0.125 in	
heads wt.=	222 lbs		reactor height	100 ft	

total wt. 13,210 lbs (includes additional 15% for nozzles, manholes, etc.)

DSRP Standpipe

Cyclone (20% of reactor size)	2,642	Area =	2.93 ft^2
standpipe height	40 ft	I.D.	23.65 in
		thickness=	0.45 in
		shell wt.=	4,506 lbs
residence time	11.17 minutes	heads wt.=	222 lbs

total wt. 8,079 lbs (includes additional 15% on standpipe weight + Cyclone weight)

Heat Exchanger

Heat Exchanger Area (ft^2)	<u>279</u>	heat exchanger pipe thickness	<u>0.25</u> in
volume of steel	6		
<u>total weight</u>	<u>2,844 lbs</u>		

total wt.

24,133 lbs

weight for DSRP reactor system

COST

C.S. unit price for quantity needed	2.588 \$/lb	1990 \$	>100,000 lb calc
	2.766 \$/lb	1996 \$	2.092218539 2.588 <100,000 lb calc
Cost of installation	\$133,482		

Total reactor cost

\$367,075 includes cost of installation

reactors DSRP-100

Desulf and Regen transport reactor price calculation

DSRP

Regenerator Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	36,020	
Area =	0.500 ft^2	
I.D.	9.778 in	
thickness=	0.258	
shell wt.=	2,690 lbs	
heads wt.=	22 lbs	

air volume	28,592 cfh	HP-O2-N2
ROG volume	39,921 cfh	ROG
regen sorbent flow	105,797 lb/hr	ZNS2RGEN
regen sorbent vol.	1,763 cfh	
sorbent vol%	4.90%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 3,119 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

total wt. 3,119 lbs

size vs. regen size 1

Desulfurization Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	545,644	
Area =	7.58 ft^2	
I.D.	38.06 in	
thickness=	0.642	
shell wt.=	26,075 lbs	
heads wt.=	827 lbs	

coal gas in volume	506,745 cfh	RAW-CG
cg out volume	575,144 cfh	CG-CALC
regen sorbent flow	281,971 lb/hr	ZNS
regen sorbent vol.	4,700 cfh	

sorbent vol%	0.86%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 30,938 lbs (includes additional 15% for nozzles, manholes, etc.)

Desulfurization Standpipe

total wt. 30,938 lbs

size vs. desulf size 1

total wt. **68,113 lbs**

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed

1.819 \$/lb	1990 \$
1.943 \$/lb	1996 \$

>100,000 lb calc	
1.7075181	1.819
<100,000 lb calc	

Cost of installation

\$264,748

Total reactor cost

\$728,057 includes cost of installation

DSRP-100 reactor

DSRP-100 Reactor Cost

DSRP

DSRP Reactor

v (ft/sec) gas =	3	10800 ft/hr
V (cfh) =	48,391	
space time -gas	33.33 seconds	
v (ft/sec) cat =	2.3	8280 ft/hr
Area =	4.540 ft ²	
I.D.	29.454 in	
thickness=	0.525 in	
shell wt.=	16,508 lbs	
heads wt.=	405 lbs	

slipstream	15,723 cfh	SLIPSTREAM
ROG volume	31,647 cfh	ROG-COOL
reactor effluent	45,210 cfh	RXNPRD
DSRP reactor Q	-6,459,000 BTU/hr	
catalyst flow	126,056 lb/hr	
catalyst vol.	2,101 cft	
catalyst vol%	5.59%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 19,451 lbs (includes additional 15% for nozzles, manholes, etc.)

DSRP Standpipe

Cyclone (20% of reactor size)	3,890	Area =	4.54 ft ²
standpipe height	40 ft	I.D.	29.45 in
residence time	10.81 minutes	thickness=	0.53 in
		shell wt.=	6,603 lbs
		heads wt.=	405 lbs

total wt. 11,950 lbs (includes additional 15% on standpipe weight + Cyclone weight)

Heat Exchanger

Heat Exchanger Area (ft ²)	448	heat exchanger pipe thickness	0.25 in
volume of steel	9		
<u>total weight</u>	<u>4,560</u> lbs		

total wt. 35,960 lbs weight for DSRP reactor system

COST

C.S. unit price for quantity needed	2.260 \$/lb	1990 \$	>100,000 lb calc
	2.415 \$/lb	1996 \$	1.928109822 2.26
Cost of installation	\$173,677		<100,000 lb calc

Total reactor cost \$477,612 includes cost of installation

reactors DSRP-500

Desulf and Regen transport reactor price calculation

DSRP

Regenerator Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	176,007	
Area =	2,445 ft^2	
I.D.	21.614 in	
thickness=	0.419	
shell wt.=	9,656 lbs	
heads wt.=	174 lbs	

air volume	139,951 cfh	HP-02-N2
ROG volume	194,430 cfh	ROG
regen sorbent flow	528,985 lb/hr	ZNS2RGEN
regen sorbent vol.	8,816 cft	
sorbent vol%	5.01%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 11,305 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

total wt. 11,305 lbs

size vs. regen size 1

Desulfurization Reactor

v (ft/sec) =	20	72000 ft/hr
V (cfh) =	2,722,971	
Area =	37.82 ft^2	
I.D.	85.01 in	
thickness=	1.280348	
shell wt.=	116,135 lbs	
heads wt.=	8,227 lbs	

coal gas in volume	2,531,530 cfh	RAW-CG
cg out volume	2,867,390 cfh	CG-CALC
regen sorbent flow	1,410,630 lb/hr	ZNS
regen sorbent vol.	23,511 cft	

sorbent vol%	0.86%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 143,017 lbs (includes additional 15% for nozzles, manholes, etc.)

Desulfurization Standpipe

total wt. 143,017 lbs

size vs. desulf size 1

total wt. 308,644 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantiy needed

1.342 \$/lb	1990 \$	
1.434 \$/lb	1996 \$	

>100,000 lb calc	
1.3421617	1.088
<100,000 lb calc	

Cost of installation \$885,263

Total reactor cost \$2,434,474 includes cost of installation

DSRP-500 reactor

DSRP-500 Reactor Cost

DSRP

DSRP Reactor

v (ft/sec) gas =	3	10800 ft/hr
V (cfh) =	236,095	
space time -gas	33.33 seconds	
v (ft/sec) cat =	2.3	8280 ft/hr
Area =	22.148 ft^2	
I.D.	65.058 in	
thickness=	1.009 in	
shell wt.=	70,050 lbs	
heads wt.=	3,798 lbs	

slipstream	76,726 cfh	SLIPSTREAM
ROG volume	153,894 cfh	ROG-COOL
reactor effluent	221,163 cfh	RXNPRD
DSRP reactor Q	-31,370,000 BTU/hr	
catalyst flow	612,229 lb/hr	
catalyst vol.	10,204 cft	
catalyst vol%	5.56%	
Corrosion depth	0.125 in	
reactor height	100 ft	

total wt. 84,925 lbs (includes additional 15% for nozzles, manholes, etc.)

DSRP Standpipe

Cyclone (20% of reactor size)	16,985	Area =	22.15 ft^2
standpipe height	40 ft	I.D.	65.06 in
residence time	10.86 minutes	thickness=	1.01 in
		shell wt.=	28,020 lbs
		heads wt.=	3,798 lbs

total wt. 53,575 lbs (includes additional 15% on standpipe weight + Cyclone weight)

Heat Exchanger

Heat Exchanger Area (ft^2)	<u>2174</u>	heat exchanger pipe thickness	<u>0.25</u> in
volume of steel	45		
<u>total weight</u>	<u>22,146</u> lbs		

total wt. 160,646 lbs weight for DSRP reactor system

COST

C.S. unit price for quantity needed	1.477 \$/lb	1990 \$	>100,000 lb calc
	1.579 \$/lb	1996 \$	1.477409568 1.359 <100,000 lb calc
Cost of installation	\$507,200		

Total reactor cost \$1,394,800 includes cost of installation

Appendix I

Sizing Reactors for the AHGP

Copies of the reactor system sizing calculations follow. They include estimates of the reactor system costs. The equations describe in *Appendix G - Calculation of Reactor Size* where used in the spreadsheet.

reactors AHGP

Desulf and Regen transport reactor price calculation

AHGP**N2 lift**

v (ft/sec) =

50

180000 ft/hr

V (cfh) =

64,033

Area =

0.356 ft²

I.D. =

8.245 in

thickness=

0.237

shell wt.=

2,085 lbs

heads wt.=

14 lbs

N2 in volume	42,761	cfh
N2 out volume	79,826	cfh
regen sorbent flow	164,358	lb/hr
regen sorbent vol.	2,739	cfh

N2SOURCE
N2EXIT
FE0-ZNO

sorbent vol% = 4.28%

key
calculated or constant values
inputed variables

Corrosion depth	0.125	in
reactor height	100	ft

total wt. 2,415 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

volume -sorbent

457 ft³

residence time [10] min

Heat Exchanger Area

length of pipe

volume -heat exchanger

necessary standpipe volum

Area = 8 ft²

I.D. = 39 in

thickness= 0.650 in

shell wt. = 16,085 lbs

heads wt. = 863 lbs

heat removal	14,850,494	BTU/hr RGENSTND
heat exchanger pipe thickness	0.25	in
heat exchanger pipe I.D.	1	in

standpipe height [60] ft

Corrosion depth [0.125] in

total wt. 19,491 lbs (includes additional 15% for nozzles, manholes,etc.)

Desulfurization Reactor

v (ft/sec) =

20

V (cfh) =

1,135,506

Area =

15.77 ft²

I.D. =

54.90 in

thickness=

0.871 in

shell wt. =

51,023 lbs

heads wt. =

2,334 lbs

coal gas in volume	1,130,000	cfh
cg out volume	1,130,000	cfh
regen sorbent flow	164,358	lb/hr
regen sorbent vol.	166,009	cfh
sorbent vol%	330,367	lb/hr
Corrosion depth	5,606	cfh
reactor height	0.48%	
	0.125	in
	100	ft

total wt. 61,361 lbs (includes additional 15% for nozzles, manholes,etc.)

Desulfurization Standpipe

volume -sorbent

2,767 ft³

residence time [1] min

Area =

28 ft²

I.D. =

71 in

standpipe height	100	ft
Corrosion depth	0.125	in

thickness=

1,093 in

shell wt. =

83,058 lbs

heads wt. =

4,930 lbs

total wt. 101,186 lbs (includes additional 15% for nozzles, manholes,etc.)

Three Stage Regenerator

I.D. =

13.01 ft

number of reactors	2	
standpipe height	45	ft

I.D. =

156 in

thickness=

2.247 in

shell wt. =

168,516 lbs

heads wt. =

48,735 lbs

Corrosion depth	0.125	in
-----------------	-------	----

total wt. 260,701 lbs (includes additional 20% for cyclones, nozzles, manholes,etc.)

total wt. 383,793 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed

1,303 \$/lb

1,393 \$/lb

>100,000 lb calc

1,30330926 1.01

<100,000 lb calc

Cost of installation

\$1,068,941

Total reactor cost

\$2,939,588 includes cost of installation

SO2 Regenerator Sizing - Commercial Embodiment

Revised

(SO2 Regen)

Case E-2

Givens:

Calculated values:

Hold-up volume, ft³ 2660.41667

Diameter, ft 18.4047564

X-section area, ft² 266.041667

Calculated H/D 0.54333781

RG Vol. flow rate, acf/sec 21.8210028

RG flow rate, lb/hr 86366.3549

Ratio of RG flow/sorbent, lb/lb 0.52024791

Operating conditions/Gas Density Calc'n's:

Pressure, psig 275

Pressure, psia 289.7

MW of gas 64

Bed Temp., C 600

Bed Temp., R 1571.67

R, gas constant, 10.73

Gas density, lb/ft³ 1.099429

Adjusted values:

Assumed Bed Depth, ft 10

SO2 needed ft³/hr 79812.5

Desulf and Regen transport reactor price calculation

AHGP

N2 lift

v (ft/sec) = 50 180000 ft/hr
 V (cfh) = 141,578
 Area = 0.787 ft²
 I.D. = 12.260 in
 thickness= 0.292
 shell wt.= 3,815 lbs
 heads wt.= 39 lbs

N2 in volume 91,631 cfh
 N2 out volume 175,069 cfh
 regen sorbent flow 493,650 lb/hr
 regen sorbent vol. 8,228 cft

key
 calculated or constant values
 inputed variables

sorbent vol% 5.81%
 Corrosion depth 0.125 in
 reactor height 100 ft

total wt. 4,432 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

volume -sorbent 1371 ft³
 Heat Exchanger Area 3,462 ft²
 length of pipe 8,817 ft
 volume -heat exchanger 108 ft³
 necessary standpipe volum 1,479 ft³
 Area = 24.7 ft²
 I.D. = 67.2 in
 thickness= 1,039 in
 shell wt. = 44,713 lbs
 heads wt. = 4,176 lbs

residence time 10 min
 heat removal 49,966,040 BTU/hr RGENSTND
 heat exchanger pipe thickness 0.25 in
 heat exchanger pipe I.D. 1 in

standpipe height 60 ft
 Corrosion depth 0.125 in

total wt. 56,222 lbs (includes additional 15% for nozzles, manholes,etc.)

Desulfurization Reactor

v (ft/sec) = 20 72000 ft/hr
 V (cfh) = 1,176,539
 Area = 16,341 ft²
 I.D. = 55.881 in
 thickness= 0.884 in
 shell wt. = 52,734 lbs
 heads wt. = 2,456 lbs

coal gas in volume 1,160,000 cft
 cg out volume 1,160,000 cft
 493,650 lb/hr
 498,670 lb/hr
 regen sorbent flow 992,320 lb/hr
 regen sorbent vol. 16,539 cft
 sorbent vol% 1.41%
 Corrosion depth 0.125 in
 reactor height 100 ft

total wt. 63,468 lbs (includes additional 15% for nozzles, manholes,etc.)

Desulfurization Standpipe

volume -sorbent 8,311 ft³
 Area = 83 ft²
 I.D. = 123 in
 thickness= 1,803 in
 shell wt. = 237,425 lbs
 heads wt. = 24,424 lbs

residence time 1 min
 standpipe height 100 ft
 Corrosion depth 0.125 in

total wt. 301,127 lbs (includes additional 15% for nozzles, manholes,etc.)

Three Stage Regenerators

I.D. = 12.99 ft
 I.D. = 156 in
 thickness= 2,243 in
 shell wt. = 167,848 lbs
 heads wt. = 48,443 lbs

number of reactors 6
 standpipe height 45 ft
 Corrosion depth 0.125 in

total wt. 1,557,295 lbs (includes additional 20% for cyclones, nozzles, manholes,etc.)

total wt. 1,919,076 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed	1,090 \$/lb	1990 \$	>100,000 lb calc
	1,165 \$/lb	1996 \$	1,09039137 0.585 <100,000 lb calc

Cost of installation \$4,471,817

Total reactor cost \$12,297,497 includes cost of installation

SO2 Regenerator Sizing - Commercial Embodiment

AHGP-b

(SO2 Regen)

Givens: Case E-2
 Sorbent circulation rate, lb/l 496000
 Sorbent bulk density, lb/ft³ 62.4
 Req'd xtr residence time, h 1
 Regen Gas V_{super}, cm/sec 2.5
 Desired H/D 2
 Adjusted values:
 Assumed Bed Depth, ft 10
 SO2 needed ft³/hr 238461.5385

Calculated values:
 Hold-up volume, ft³ 7948.71795
 Diameter, ft 31.8129385
 X-section area, ft² 794.871795
 Calculated H/D 0.31433751
 RG Vol. flow rate, acf/sec 65.1981774
 RG flow rate, lb/hr 258042.961
 Ratio of RG flow/sorbent, lb/lb 0.52024791
 Calculated Bed Depth, ft

Operating conditions/Gas Density Calc'n's:
 Pressure, psig 275
 Pressure, psia 289.7
 MW of gas 64
 Bed Temp., C 600
 Bed Temp., R 1571.67
 R, gas constant, 10.73
 Gas density, lb/ft³ 1.099429

AHGP-c
Desulf and Regen transport reactor price calculation

AHGP			
N2 lift			
V (ft/sec) =	50	180000 ft/hr	
V (cfm) =	13,240		
Area =	0.074 ft^2		
I.D. =	3.749 in		
thickness=	0.176		
shell wt.=	704 lbs		
heads wt. =	2 lbs		
total wt.		812 lbs	(includes additional 15% for nozzles, manholes, etc.)
key		calculated or constant values	
inputed variables			

total wt. 812 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

volume -sorbent	133 ft^3	residence time	10 min
Heat Exchanger Area	3.25 ft^2	heat removal	48,050 BTU/hr RGENSTND
length of pipe	8.27 ft	heat exchanger pipe thickness	0.25 in
volume -heat exchanger	0.10 ft^3	heat exchanger pipe I.D.	1 in
necessary standpipe volume	134 ft^3	standpipe height	60 ft
Area =	2.2 ft^2		
I.D. =	20.2 in		
thickness=	0.400 in	Corrosion depth	0.125 in
shell wt. =	5,168 lbs		
heads wt. =	145 lbs		
total wt.		6,110 lbs	(includes additional 15% for nozzles, manholes,etc.)

Desulfurization Reactor

V (ft/sec) =	20	72000 ft/hr	coal gas in volume	1,120,000 cfm	H2S-CG
V (cfm) =	1,121,611		cg out volume	1,120,000 cfm	CLEAN-CG
Area =	15.58 ft^2		48,050 lb/hr	48,050 lb/hr	COLDSORB
I.D. =	54.56 in		48,626 lb/hr	48,626 lb/hr	STANDPIP
thickness=	0.867 in		96,676 lb/hr	96,676 lb/hr	
shell wt. =	50,444 lbs		1,611 cfm	1,611 cfm	
heads wt. =	2,294 lbs		0.14%	0.14%	
total wt.		60,648 lbs	Corrosion depth	0.125 in	
			reactor height	100 ft	

total wt. 60,648 lbs (includes additional 15% for nozzles, manholes, etc.)

Desulfurization Standpipe

volume -sorbent	810 ft^3	residence time	1 min
Area =	8.10 ft^2		
I.D. =	38.55 in	standpipe height	100 ft
thickness=	0.649 in		
shell wt. =	26,687 lbs	Corrosion depth	0.125 in
heads wt. =	857 lbs		
total wt.		31,676 lbs	(includes additional 15% for nozzles, manholes,etc.)

Three Stage Regenerator

I.D. =	9.90 ft	number of reactors	1
I.D. =	119 in	standpipe height	45 ft
thickness=	1.739 in		
shell wt. =	99,156 lbs	Corrosion depth	0.125 in
heads wt. =	21,807 lbs		
total wt.		145,156 lbs	(includes additional 20% for cyclones, nozzles, manholes,etc.)

total wt. 145,156 lbs (includes additional 20% for cyclones, nozzles, manholes,etc.)

total wt. 183,754 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed	1,447 \$/lb	1990 \$	>100,000 lb calc
	1,546 \$/lb	1996 \$	1,447,067.13 1,298 <100,000 lb calc

Cost of installation \$568,244

Total reactor cost \$1,562,672 includes cost of installation

SO2 Regenerator Sizing - Commercial Embodiment

AHGP-c (SO2 Regen)		Calculated values:		Operating conditions/Gas Density Calc'n's:	
Givens:	Case E-2	Hold-up volume, ft^3	769.23	Pressure, psig	275
Sorbent circulation rate, lb/h	48000	Diameter, ft	9.90	Pressure, psia	289.7
Sorbent bulk density, lb/ft^3	62.4	X-section area, ft^2	76.92	MW of gas	64
Req'd ntr residence time, hr	1	Calculated H/D	1.01	Bed Temp., C	600
Regen Gas V _{upper} , cu/sec	2.5	RG Vol. flow rate, ac/sec	6.31	Bed Temp., R	1571.67
Desired H/D	2	RG flow rate, lb/hr	24971.90	R, gas constant,	10.73
Adjusted values:		Ratio of RG flow/sorbent, lb/lb	0.52	Gas density, lb/ft^3	1.10
Assumed Bed Depth, ft	10	Calculated Bed Depth, ft			
SO2 needed ft^3/hr	23077				

AHGP-100
Desulf and Regen transport reactor price calculation (0.4211 the size of the AHGP case)

AHGP			
N2 lift			
v (ft/sec) =	50	180000 ft/hr	
V (cfm) =	26,964		
Area =	0.150 ft ²		
I.D. =	5.350 in		
thickness=	0.198		
shell wt.=	1,129 lbs		
heads wt.=	5 lbs		
total wt.	<u>1,304</u> lbs	(includes additional 15% for nozzles, manholes, etc.)	
Regenerator Standpipe			
volume -sorbent	192 ft ³	residence time	<u>10</u> min
Heat Exchanger Area	433 ft ²	heat removal	<u>6,253,543</u> BTU/hr RGENSTND
length of pipe	1,103 ft	heat exchanger pipe thickness	<u>0.25</u> in
volume -heat exchanger	14 ft ³	heat exchanger pipe I.D.	<u>1</u> in
necessary standpipe volume	206 ft ³	standpipe height	<u>60</u> ft
Area =	3.43 ft ²		
I.D. =	25.08 in		
thickness=	0.466 in		
shell wt. =	7,478 lbs		
heads wt. =	260 lbs		
total wt.	<u>8,899</u> lbs	(includes additional 15% for nozzles, manholes,etc.)	
Desulfurization Reactor			
v (ft/sec) =	20	72000 ft/hr	
V (cfm) =	478,162		
Area =	6.64 ft ²	coal gas in volume	<u>475,843</u> cfm
I.D. =	35.62 in	cg out volume	<u>475,843</u> cfm
thickness=	0.609 in	regen sorbent flow	<u>69,211</u> lb/hr
shell wt. =	23,154 lbs	regen sorbent vol.	<u>69,905</u> lb/hr
heads wt. =	687 lbs	sorbent vol%	<u>139,118</u> lb/hr
total wt.	<u>27,418</u> lbs	Corrosion depth	<u>2,319</u> cfm
		reactor height	<u>0.48%</u>
			<u>0.125</u> in
			<u>100</u> ft
Desulfurization Standpipe			
volume -sorbent	1,165 ft ³	residence time	<u>1</u> min
Area =	11.7 ft ²	standpipe height	<u>100</u> ft
I.D. =	46.2 in		
thickness=	0.753 in		
shell wt. =	37,140 lbs		
heads wt. =	1,430 lbs		
total wt.	<u>44,356</u> lbs	(includes additional 15% for nozzles, manholes,etc.)	
Three Stage Regenerators			
I.D. =	11.94 ft	number of reactors	<u>1</u>
I.D. =	143 in	standpipe height	<u>45</u> ft
thickness=	2.073 in		
shell wt. =	142,638 lbs		
heads wt. =	37,858 lbs		
total wt.	<u>216,595</u> lbs	(includes additional 20% for cyclones, nozzles, manholes,etc.)	
total wt.	271,154 lbs	weight for desulfurization and regeneration transport reactors	
COST			
C.S. unit price for quantity needed	1.367 \$/lb	1990 \$	>100,000 lb calc 1.36665221 1.137
	1.460 \$/lb	1996 \$	<100,000 lb calc
Cost of installation	\$791,924		
Total reactor cost	\$2,177,791	includes cost of installation	
SO2 Regenerator Sizing - Commercial Embodiment			
AHGP-100 (SO2 Regen)			
Givens:	Case E-2	Calculated values:	Operating conditions/Gas Density Calc'n's:
Sorbent circulation rate, lb/h	69910	Hold-up volume, ft ³	Pressure, psig
Sorbent bulk density, lb/ft ³	62.4	Diameter, ft	Pressure, psia
Req'd xdr residence time, hr	1	X-section area, ft ²	MW of gas
Regen Gas V _{super} , cm/sec	2.5	Calculated H/D	Bed Temp., C
Desired H/D	2	RG Vol. flow rate, acf/sec	Bed Temp., R
Adjusted values:		RG flow rate, lb/hr	R, gas constant,
Assumed Bed Depth, ft	10.00	Ratio of RG flow/sorbent, lb/lb	Gas density, lb/ft ³
SO2 needed ft ³ /hr	33611	Calculated Bed Depth, ft	

AHGP-500
Desulf and Regen transport reactor price calculation (2.1055 the size of the AHGP case)

AHGP

N2 lift

v (ft/sec) = 50 180000 ft/hr
V (cfh) = 134,821
Area = 0.75 ft²
I.D. = 11.96 in
thickness= 0.287592409
shell wt.= 3,671 lbs
heads wt.= 37 lbs

N2 in volume	90,033	cfh	N2SOURCE
N2 out volume	168,074	cfh	N2EXIT
regen sorbent flow	346,056	lb/hr	FE0-ZNO
regen sorbent vol.	5,768	cfh	

key
calculated or constant values
 inputed variables

total wt. 4,264 lbs (includes additional 15% for nozzles, manholes, etc.)

Regenerator Standpipe

volume -sorbent 961 ft³
Heat Exchanger Area 2,167 ft²
length of pipe 5,517 ft
volume -heat exchanger 68 ft³
necessary standpipe volume 1,029 ft³
Area = 17 ft²
I.D. = 56 in
thickness= 0.887 in
shell wt. = 31,844 lbs
heads wt. = 2,480 lbs

residence time 10 min

heat removal	31,267,715	BTU/hr	RGENSTND
heat exchanger pipe thickness	0.25	in	
heat exchanger pipe I.D.	1	in	

standpipe height 60 ft
Corrosion depth 0.125 in

total wt. 39,472 lbs (includes additional 15% for nozzles, manholes,etc.)

Desulfurization Reactor

v (ft/sec) = 20 72000 ft/hr
V (cfh) = 2,390,808
Area = 33.21 ft²
I.D. = 79.66 in
thickness= 1.208 in
shell wt. = 102,638 lbs
heads wt. = 6,813 lbs

coal gas in volume	2,379,215	cfh	H2S-CG
cg out volume	2,379,215	cfh	CLEAN-CG
346,056	lb/hr		COLDSORB
349,532	lb/hr		STNDPIPE

regen sorbent flow 695,588 lb/hr
regen sorbent vol. 11,593 cfh
sorbent vol% 0.48%
Corrosion depth 0.125 in
reactor height 100 ft

total wt. 125,868 lbs (includes additional 15% for nozzles, manholes, etc.)

Desulfurization Standpipe

volume -sorbent 5,826 ft³
Area = 58 ft²
I.D. = 103 in
thickness= 1.530 in
shell wt. = 168,662 lbs
heads wt. = 14,526 lbs

residence time 1 min

standpipe height 100 ft
Corrosion depth 0.125 in

total wt. 210,666 lbs (includes additional 15% for nozzles, manholes,etc.)

Three Stage Regenerators

I.D. = 11.94 ft
I.D. = 143 in
thickness= 2,073 in
shell wt. = 142,618 lbs
heads wt. = 37,850 lbs

number of reactors 5
standpipe height 45 ft
Corrosion depth 0.125 in

total wt. 1,082,809 lbs (includes additional 20% for cyclones, nozzles, manholes,etc.)

total wt. 1,337,211 lbs

weight for desulfurization and regeneration transport reactors

COST

C.S. unit price for quantity needed	1.129 \$/lb	1990 \$	>100,000 lb calc
	1.206 \$/lb	1996 \$	<100,000 lb calc

Cost of installation \$3,225,118

Total reactor cost \$8,869,074 includes cost of installation

SO2 Regenerator Sizing - Commercial Embodiment

AHGP-500
(SO2 Regen)

Givens: Case E-2

Calculated values:

Operating conditions/Gas Density Calc'n's:

Hold-up volume, ft ³	5,600.96	Pressure, psig	275
Diameter, ft	26.70	Pressure, psia	289.7
X-section area, ft ²	560.10	MW of gas	64
Calculated H/D	0.37	Bed Temp., C	600
Req'd xtr residence time, hr	1	Bed Temp., R	1571.67
Regen Gas V _{super} , cm/sec	2.5	R, gas constant,	10.73
Desired H/D	2	Gas density, lb/ft ³	1.099429
	Ratio of RG flow/sorbent, lb/lb		
	Calculated Bed Depth, ft		

Adjusted values:

Assumed Bed Depth, ft	10.00
SO2 needed ft ³ /hr	168,029

Appendix J

Power Generation Achievable from Clean Coal Gas

Two sources were used in determining the power generated by the clean coal gas. The Sierra power generating facility was used as the basis for determining the power generating capacity coal gas.

Sierra Clean Coal Gas Feed		
<u>H₂ (lbmole/hr)</u>	<u>CO (lbmole/hr)</u>	<u>Power Generation (MW)</u>
5760	7570	260

The individual contribution of the H₂ and CO were determined assuming their relative contribution was consistent with their standard heats of combustion.

Standard heat of combustion (Felled & Rousseau):

$$\Delta H_{\text{comb}}^{\circ} (\text{H}_2) = -3.605 \times 10^{-2} \text{ MW hr/lbmole} \quad \Delta H_{\text{comb}}^{\circ} (\text{CO}) = -3.569 \times 10^{-2} \text{ MW hr/lbmole}$$

Power generation can be expressed:

$$E [5760 \Delta H_C (\text{H}_2) + 7570 \Delta H_C (\text{CO})] = 260 \text{ MW}$$

where:

E = Efficiency of power generation

assuming:

$$\Delta H_C (\text{CO}) = 0.99 \Delta H_C (\text{H}_2)$$

and substituting gives:

$$13,254 E \Delta H_C (\text{H}_2) = 260 \text{ MW}$$

$$E \Delta H_C (\text{H}_2) = 0.0196 \text{ MW hr/lbmole}$$

therefore

$$E \Delta H_C (\text{CO}) = 0.0194 \text{ MW hr/lbmole}$$

The values calculated above can be used to write a power generation expression.

$$\text{Power Generation (MW)} = 0.0196 (\text{H}_2 \text{ {lbmoles/hr}}) + 0.0194 (\text{CO} \text{ {lbmoles/hr}})$$

The plant's power generation is determined by inserting the clean coal gas flows for H₂ and CO into the above equation. HGD coal gas consumption is assessed as a debit equivalent to the cost of the lost power generation. The power generation lost is determined by inserting the difference in the dirty coal gas and clean coal gas molar flow rates into the above equation. The cost of the electricity is taken as \$0.04 per kWh. The plant has been assumed to be in operation 90% of the year.

Summary of Power Generation Calculations

simulation	H₂ clean	H₂ in	CO clean	CO in	MW made	MW lost
DSRP	11,444.58	11,765.37	212,200.52	218,162.00	258.25	7.248
DSRP-b	11,450.19	12,468.32	212,276.67	231,196.50	258.35	23.003
DSRP-c	11,443.82	11,535.37	212,195.77	213,897.17	258.24	2.069
DSRP-100	4,819.31	4,954.40	89,357.59	91,868.05	108.75	3.052
DSRP-500	24,110.94	24,772.09	447,055.34	459,341.97	544.06	14.938
AHGP	11,355.75	11,510.68	213,439.25	213,439.25	258.24	1.506
AHGP-b	11,175.21	11,646.28	215,953.67	215,953.67	258.23	4.580
AHGP-c	11,419.66	11,464.48	212,582.61	212,582.61	258.27	0.436
AHGP-100	4,781.91	4,847.15	89,879.27	89,879.27	108.74	0.634
AHGP-500	23,909.53	24,235.73	449,396.34	449,396.34	543.72	3.172

Appendix K

Calculation of Reactor Pressure Drops

Pressure drops for transport reactors have been calculated assuming the pressure drops are related to the energy required to lift the sorbent / catalyst to the top of the reactor.

Energy balance for lifting solid to top of reactor:

$$\Delta E_{PART} = \Delta E_{GAS}$$
$$m_{PART} (g / g_C) h = \Delta P m_{GAS} / \rho_{GAS}$$
$$\Delta P = m_{PART} (g / g_C) h \rho_{GAS} / m_{GAS}$$

$$\Delta P_{REACTOR} = 1.5 \text{ (Energy to lift particle)}$$

DSRP Regeneration Reactor

$$\Delta P = 1.5 m_{PART} (g / g_C) h \rho_{GAS} / m_{GAS}$$

m_{PART} = sorbent mass flow, ZNS2RGEN & ZNO average

$(g / g_C) = 1 \text{ lb}_f/\text{lb}_m$

h = reactor height, defined in Appendix H

ρ_{GAS} = gas density, HP-O2-N2 & ROG average

m_{GAS} = gas mass flow, HP-O2-N2 & ROG average

DSRP Regeneration Reactor (DSRP)

$$\Delta P = 1.5 (250,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.5 \text{ lb}_m/\text{ft}^3) / (40,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 3.32 \text{ psi}$$

DSRP Regeneration Reactor (DSRP-b)

$$\Delta P = 1.5 (1,200,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.5 \text{ lb}_m/\text{ft}^3) / (130,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 4.8 \text{ psi}$$

DSRP Regeneration Reactor (DSRP-c)

$$\Delta P = 1.5 (71,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.5 \text{ lb}_m/\text{ft}^3) / (12,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 3.2 \text{ psi}$$

DSRP Regeneration Reactor (DSRP-100) (DSRP-500)

same as base case $\Delta P = 3.3 \text{ psi}$

DSRP Reactor

$$\Delta P = 1.5 m_{PART} (g / g_c) h \rho_{GAS} / m_{GAS}$$

m_{PART} = catalyst mass flow, Appendix H

$(g / g_c) = 1 \text{ lb}_f/\text{lb}_m$

h = reactor height, defined in Appendix H

ρ_{GAS} = gas density, ROG-COOL & RXNPRD average

m_{GAS} = gas mass flow, RXNPRD

DSRP Reactor (DSRP)

$$\Delta P = 1.5 (300,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.53 \text{ lb}_m/\text{ft}^3) / (55,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 3.0 \text{ psi}$$

DSRP Reactor (DSRP-b)

$$\Delta P = 1.5 (1,000,000 \text{ lb}_m/\text{hr})(1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.53 \text{ lb}_m/\text{ft}^3) / (185,000 \text{ lb}_m/\text{hr})(1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 3.0 \text{ psi}$$

DSRP Reactor (DSRP-c)

$$\Delta P = 1.5 (79,000 \text{ lb}_m/\text{hr})(1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.55 \text{ lb}_m/\text{ft}^3) / (15,000 \text{ lb}_m/\text{hr})(1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 3.0 \text{ psi}$$

DSRP Reactor (DSRP-100) (DSRP-500)

same as base case $\Delta P = 3.0 \text{ psi}$

DSRP Desulfurization Reactor

$$\Delta P = 1.5 m_{PART} (g / g_c) h \rho_{GAS} / m_{GAS}$$

m_{PART} = sorbent mass flow, ZNS

$(g / g_c) = 1 \text{ lb}_f/\text{lb}_m$

h = reactor height, defined in Appendix H

ρ_{GAS} = gas density, RAW-CG & CG-CALC average

m_{GAS} = gas mass flow, CG-CALC

DSRP Desulfurization Reactor (DSRP)

$$\Delta P = 1.5 (670,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.4 \text{ lb}_m/\text{ft}^3) / (510,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 0.6 \text{ psi}$$

DSRP Desulfurization Reactor (DSRP-b)

$$\Delta P = 1.5 (2,700,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.4 \text{ lb}_m/\text{ft}^3) / (660,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 1.6 \text{ psi}$$

DSRP Desulfurization Reactor (DSRP-c)

$$\Delta P = 1.5 (72,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.4 \text{ lb}_m/\text{ft}^3) / (460,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 0.06 \text{ psi}$$

DSRP Desulfurization Reactor (DSRP-100) (DSRP-500)

same as base case $\Delta P = 0.6 \text{ psi}$

AHGP Desulfurization Reactor

$$\Delta P = 1.5 m_{PART} (g / g_C) h \rho_{GAS} / m_{GAS}$$

m_{PART} = sorbent mass flow, STNDPIPE + COLDSORB

$(g / g_C) = 1 \text{ lb}_f/\text{lb}_m$

h = reactor height, defined in Appendix I

ρ_{GAS} = gas density, H2S-CG & CLEAN-CG average

m_{GAS} = gas mass flow, CLEAN-CG

AHGP Desulfurization Reactor (AHGP-100 and AHGP-500 results will be consistent)

$$\Delta P = 1.5 (330,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.4 \text{ lb}_m/\text{ft}^3) / (450,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 0.3 \text{ psi}$$

AHGP-b Desulfurization Reactor

$$\Delta P = 1.5 (990,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.4 \text{ lb}_m/\text{ft}^3) / (460,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 0.9 \text{ psi}$$

AHGP-c Desulfurization Reactor

$$\Delta P = 1.5 (97,000 \text{ lb}_m/\text{hr}) (1 \text{ lb}_f/\text{lb}_m) (100 \text{ ft}) (0.4 \text{ lb}_m/\text{ft}^3) / (440,000 \text{ lb}_m/\text{hr}) (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 0.09 \text{ psi}$$

The pressure drop through the bubble bed regenerator is calculated as the sum of the static head in each stage times 1.3.

AHGP 3-Stage Regenerator Reactor

$$\Delta P = 1.3 \frac{g}{g_C} (\rho h_{\text{top-stage}} + \rho h_{\text{stage2}} + \rho h_{\text{bottom-stage}}) \quad (1/144)$$

m_{PART} = sorbent mass flow, FES-ZNS

$(g / g_C) = 1 \text{ lb}_f/\text{lb}_m$

h = reactor stage height,

ρ_{GAS} = average of density of streams entering and exiting the reactor stage

AHGP 3-Stage Regenerator Reactors

$$\Delta P = 1.3 (1 \text{ lb}_f/\text{lb}_m) [(3.66 \text{ lb}_m/\text{ft}^3) (5.0 \text{ ft}) + (3.20 \text{ lb}_m/\text{ft}^3) (10 \text{ ft}) + (3.40 \text{ lb}_m/\text{ft}^3) (2.5 \text{ ft})] (1 \text{ ft}^3 / 144 \text{ in}^2)$$

$$\Delta P = 0.5 \text{ psi}$$

Appendix L

Summary of the Process Pressure Drops

This appendix contains lists of the calculated pressure drops for the DSRP and AHGP at the various feed conditions.

DSRP pressure drops are used to determine the pressure rise needed from the RECYCOMP (sends tailgas to the Desulfurization reactor) and PRESAIR (pressurizes the air fed to the regenerator) Reactor pressure drops are calculated in Appendix H. Pressure drops in other equipment has been assigned without calculations.

Having streams enter the DSRP Reactor at the same pressure (bold pressures) was the starting point for the calculations.

DSRP (base case) & DSRP-100 & DSRP-500

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
PRESAIR	13.7 psia inlet P	278.9
pipe [P-02-N2]	0	278.9
AIR-HX (shell)	2.0	276.9
pipe [HP-O2-N2]	0	276.9
REGENERATOR	3.3	273.6
pipe [ROG]	0	273.6
AIR-HX (tube)	2.0	271.6
pipe [ROG-COOL]	0	271.6
DSRP	2.0	268.6
pipe [RXNPRD]	0	268.6
PD-COOLR	2.0	266.6
pipe [COOLPRD]	0	266.6
High Press. Cond.	2.0	264.6
pipe [TAILGAS]	0	264.6
VALVE	2.6	262.0
pipe [TAILGAS2]	0	262.0
RECYCOMP		275

Coal Gas Slipstream Pressure

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
Desulfurization Reactor	0.6	274.4
pipe [SLIPSTRM]	0	274.4
VALVE2	2.8	271.6
pipe [SLPSTRM]	0	271.6

DSRP-b

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
PRESAIR	13.7 psia inlet P	279.4
pipe [P-O2-N2]	0	279.4
AIR-HX (shell)	2.0	277.4
pipe [HP-O2-N2]	0	277.4
REGENERATOR	4.8	272.6
pipe [ROG]	0	272.6
AIR-HX (tube)	2.0	270.6
pipe [ROG-COOL]	0	270.6
DSRP	3.0	267.6
pipe [RXNPRD]	0	267.6
PD-COOLR	2.0	265.6
pipe [COOLPRD]	0	265.6
High Press. Cond.	2.0	263.6
pipe [TAILGAS]	0	263.6
VALVE	2.6	261.0
pipe [TAILGAS2]	0	261.0
RECYCOMP		275

Coal Gas Slipstream Pressure

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
Desulfurization Reactor	1.6	273.4
pipe [SLIPSTRM]	0	273.4
VALVE2	2.8	270.6
pipe [SLPSTRM]	0	270.6

DSRP-c

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
PRESAIR	13.7 psia inlet P	279.3
pipe [P-O2-N2]	0	279.3
AIR-HX (shell)	2.0	277.3
pipe [HP-O2-N2]	0	277.3
REGENERATOR	3.2	274.1
pipe [ROG]	0	274.1
AIR-HX (tube)	2.0	272.1
pipe [ROG-COOL]	0	272.1
DSRP	3.0	269.1
pipe [RXNPRD]	0	269.1
PD-COOLR	2.0	267.1
pipe [COOLPRD]	0	267.1
High Press. Cond.	2.0	265.1
pipe [TAILGAS]	0	265.1
VALVE	2.6	262.5
pipe [TAILGAS2]	0	262.5
RECYCOMP		275

DSRP-c

Coal Gas Slipstream Pressure

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
Desulfurization Reactor	0.06	274.9
pipe [SLIPSTRM]	0	274.9
VALVE2	2.8	272.1
pipe [SLPSTRM]	0	272.1

AHGP pressure drop calculations determine the required ΔP for the SO₂-COMP, compressor. The pressure drop balance is done to insure the SO₂ loop with maintain desired pressure. The set pressure (bold) in the SO₂ loop is the pressure at the 3-Stage Regenerator exit. This pressure is set to equal the calculated exit pressure of the AHGP Desulfurization reactor (Appendix K).

AHGP (base case), & AHGP-100 & AHGP-500

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
3-Stage Regenerator	0.5 (Append. K)	274.7
pipe [COOLS2]	0	274.7
HEATX (tube)	2.0	272.7
pipe [S2V+L]	0	272.7
COND-EQ	2.0	270.7
pipe [IN-COND]	0	270.7
DEMISTR	5	265.7
pipe [UNP-RSO2]	0	265.7
SO ₂ -COMP		279.2
pipe [RCYHEATR]	0	279.2
RCYHEATR	2.0	277.2
pipe [WARMRCY]	0	277.2
HEATX (shell)	2.0	275.2
pipe [FEEDRG1]	0	275.2 to 3-Stage Regenerator

AHGP-b

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
3-Stage Regenerator	0.5 (Append. K)	274.1
pipe [COOLS2]	0	274.1
HEATX (tube)	2.0	272.1
pipe [S2V+L]	0	272.1
COND-EQ	2.0	270.1
pipe [IN-COND]	0	270.1
DEMISTR	5	265.1
pipe [UNP-RSO2]	0	265.1
SO ₂ -COMP		278.6
pipe [RCYHEATR]	0	278.6
RCYHEATR	2.0	276.6
pipe [WARMRCY]	0	276.6
HEATX (shell)	2.0	274.6
pipe [FEEDRG1]	0	274.6 to 3-Stage Regenerator

AHGP-c

<u>Equipment</u>	<u>ΔP drop (psi)</u>	<u>P_{EXIT} (psia)</u>
3-Stage Regenerator	0.5 (Append. K)	274.9
pipe [COOLS2]	0	274.9
HEATX (tube)	2.0	272.9
pipe [S2V+L]	0	272.9
COND-EQ	2.0	270.9
pipe [IN-COND]	0	270.9
DEMISTR	5	265.9
pipe [UNP-RSO2]	0	265.9
SO2-COMP		279.4
pipe [RCYHEATR]	0	279.4
RCYHEATR	2.0	277.4
pipe [WARMRCY]	0	277.4
HEATX (shell)	2.0	275.4
pipe [FEEDRG1]	0	275.4 to 3-Stage Regenerator

Appendix M

Summary of Major HGD Equipment

The following tables list equipment required for both HGD processes under various feed conditions. Equipment specifications are also listed in the tables.

DSRP - base Process Equipment Specifications

	DSRP	DSRP-b	DSRP-c	DSRP-100	DSRP-500
REACTORS					
Desulfurization reactor					
height (ft)	100	100	100	100	100
diameter (ft)	4.9	5.6	4.6	3.2	7.1
weight (lbs)	70,000	90,000	63,000	31,000	140,000
Desulf. standpipe					
height (ft)	100	100	100	100	100
diameter (ft)	4.9	5.6	4.6	3.2	7.1
weight (lbs)	70,000	90,000	63,000	31,000	140,000
Regeneration reactor					
height (ft)	100	100	100	100	100
diameter (ft)	1.3	2.3	0.66	0.82	1.8
weight (lbs)	6,000	17,000	2,000	3,000	11,000
Regen. standpipe					
height (ft)	100	100	100	100	100
diameter (ft)	1.3	2.3	0.66	0.82	1.8
weight (lbs)	6,000	17,000	2,000	3,000	11,000
DSRP Reactor					
height (ft)	100	100	100	100	100
diameter (ft)	3.8	7.0	2.0	2.5	5.4
weight (lbs)	43,000	140,000	13,000	19,000	85,000
DSRP standpipe					
height (ft)	40	40	40	40	40
diameter (ft)	3.8	7.0	2.0	2.5	5.4
weight (lbs)	27,000	89,000	8,000	12,000	540,000
COMPRESSORS					
PRESAIR					
acfh	570,000	1,800,000	160,000	240,000	1,200,000
Pin (psia)	13.7	13.7	13.7	13.7	13.7
Pout (psia)	278.9	279.4	279.3	278.9	278.9
power (hp)	3,300	10,000	900	1,400	6,900
stages	6	6	6	6	6
RECOMP					
acfh	49,000	170,000	14,000	21,000	100,000
Pin (psia)	264.4	261	262.5	264.4	264.4
Pout (psia)	275	275	275	275	275
power (hp)	59	227	17	25	124
stages	1	1	1	1	1
HEAT EXCHANGERS					
AIRHX					
Duty (BTU/hr)	4,300,000	14,000,000	1,200,000	1,900,000	9,600,000
Area (ft^2)	700	2,200	200	300	1,400
tube mat.	SS 310	SS 310	SS 310	SS 310	SS 310
shell mat.	SS 304	SS 304	SS 304	SS 304	SS 304
DSRP					
Duty (BTU/hr)	15,000,000	51,000,000	4,000,000	6,500,000	31,000,000
Area (ft^2)	1,000	3,600	280	450	2,200
tube mat.	SS 310	SS 310	SS 310	SS 310	SS 310
PDCOOLR					
Duty (BTU/hr)	5,200,000	17,000,000	1,400,000	2,200,000	11,000,000
Area (ft^2)	1,000	3,200	300	300	2,000
tube mat.	SS 310	SS 310	SS 310	SS 310	SS 310
shell mat.	SS 310	SS 310	SS 310	SS 310	SS 310
MISC.					
High Pressure Condenser					
Duty (BTU/hr)	10,500,000	35,100,000	2,940,000	4,320,000	21,600,000
Material	SS 310	SS 310	SS 310	SS 310	SS 310
VAPORIZR					
Duty (BTU/hr)	550,000	1,900,000	150,000	230,000	1,100,000
Material	SS 310	SS 310	SS 310	SS 310	SS 310
Storage Tank					
vol. (ft^3)	5,600	18,000	1,600	2,400	11,000
Material	SS 310	SS 310	SS 310	SS 310	SS 310

EQPTSPEC.XLS

AHGP Process Equipment Specifications

	AHGP	AHGP - b	AHGP - c	AHGP - 100	AHGP - 500
REACTORS					
Desulfurization reactor					
height (ft)	100	100	100	100	100
diameter (ft)	4.58	4.66	4.55	2.97	6.64
weight (lbs)	61,361	63,000	61,000	27,000	130,000
Desulf. standpipe					
height (ft)	100	100	100	100	100
diameter (ft)	5.92	10.25	3.21	3.85	8.58
weight (lbs)	100,000	300,000	32,000	44,000	210,000
Regeneration reactor					
# of reactors	2	6	1	1	5
height (ft)	45	45	45	45	45
diameter (ft)	13.0	13.0	0.8	11.9	11.9
weight (lbs)	260,000	1,600,000	150,000	270,000	1,000,000
Regen. standpipe & RGENSTAND					
height (ft)	60	60	60	60	60
diameter (ft)	3.25	5.6	1.68	2.1	4.7
weight (lbs)	19,000	56,000	6,100	8,900	39,000
Duty (BTU/hr)	15,000,000	50,000,000	48,000	6,300,000	31,000,000
N2 Lift					
height (ft)	100	100	100	100	100
diameter (ft)	0.69	1.02	0.31	0.45	1.00
weight (lbs)	2,400	4,400	800	1,300	4,300
COMPRESSORS					
CON-COMP					
acfh	1,500	4,400	400	600	3,200
Pin (psia)	15	15	15	15	15
Pout (psia)	279	279	279	279	279
power (hp)	8	26	2	3	17
stages	1	1	1	1	1
LIFTCOMP					
acfh	43,000	92,000	8,600	18,000	91,000
Pin (psia)	272	272	272	272	272
Pout (psia)	275	275	275	275	275
power (hp)	13	28	3	5	27
stages	1	1	1	1	1
SO2-COMP					
acfh	29,000	85,000	8,400	12,000	61,000
Pin (psia)	266	265	266	266	266
Pout (psia)	279	279	279	279	279
power (hp)	38	114	11	16	80
stages	1	1	1	1	1
HEAT EXCHANGERS					
N2-COOLR					
Duty (BTU/hr)	7,020,000	15,800,000	1,480,000	3,130,000	15,700,000
Area (ft^2)	1,100	2,600	210	470	2,300
tube mat.	SS 304	SS 304	SS 304	SS 304	SS 304
shell mat.	SS 304	SS 304	SS 304	SS 304	SS 304
HEATX					
Duty (BTU/hr)	5,100,000	15,000,000	1,500,000	2,100,000	11,000,000
Area (ft^2)	1,600	3,600	500	700	3,500
tube mat.	SS 310	SS 310	SS 310	SS 310	SS 310
shell mat.	SS 310	SS 310	SS 310	SS 310	SS 310
RCYHEATR					
Duty (BTU/hr)	2,530,000	6,070,000	697,000	1,070,000	5,330,000
Area (ft^2)	3,200	7,800	570	1,300	6,700
tube mat.	SS 310	SS 310	SS 310	SS 310	SS 310
shell mat.	SS 310	SS 310	SS 310	SS 310	SS 310
MISC.					
COND-EQ					
Duty (BTU/hr)	5,380,000	16,000,000	1,560,000	2,400,000	12,000,000
Material	SS 310	SS 310	SS 310	SS 310	SS 310
DEMISTR					
Duty (BTU/hr)	0	0	0	0	0
Material	SS 310	SS 310	SS 310	SS 310	SS 310
LP-COND					
vol. (ft^3)	30	100	10	10	70
Material	SS 310	SS 310	SS 310	SS 310	SS 310
Storage Tank					
vol. (ft^3)	5,600	18,000	1,600	2,400	11,000
Material	SS 310	SS 310	SS 310	SS 310	SS 310

EQPTSPEC.XLS

Appendix N

Summary of HGD Costs

The following pages are taken from an Excel spreadsheet containing the culmination of all costs and benefits for all simulated Hot Gas Desulfurization processes.

DSRP costs

Equipment -Sulfur side

Type unit	DSRP Price	DSRP-b Price	DSRP-c Price	DSRP-100 Price	DSRP-500 Price	Mat. of Construction	Purchase date	Purchase price ref.	date of calculation
Heat Exchangers									
AIRHX	\$33,500	\$71,500	\$17,900	\$19,400	\$55,300	SS304 / SS310 tubes	June, 1996	aspen DAIRHX	1/22/98
PDCOOLR	\$63,400	\$126,600	\$25,200	\$42,000	\$90,400	SS310 (calc w SS316)	June, 1996	aspen	1/22/98
Tanks									
7 days Sulfur Storage	\$125,500	\$205,400	\$65,000	\$80,000	\$171,000	SS310 (calc w SS316)	June, 1996	aspen	11/6/97
Condenser									
High Pressure Vaporiser	\$40,400	\$82,200	\$18,500	\$21,900	\$59,600	SS310 (calc w SS316)	June, 1996	aspen	
VAPORIZR	\$16,100	\$17,800	\$15,900	\$15,200	\$16,700	SS310 (calc w SS316)	June, 1996	aspen	
Compressor									
RECOMP	\$52,900	\$52,900	\$52,900	\$52,900	\$52,900	Carbon Steel	June, 1996	aspen	
PRESAIR	\$844,000	\$2,680,000	\$241,000	\$416,000	\$1,740,000		1997 Ingessoll-Rand Centac Pricing		10/20/97
Rеаtоrѕ									
Desulf & Regen	\$1,328,000	\$1,772,000	\$1,169,000	\$728,000	\$2,434,000	SS310 (calc w SS316)	June, 1996 (w install)	P&T calc	10/7/97
DSRP reactor	\$812,129	\$2,134,355	\$367,075	\$477,612	\$1,394,800	SS310 (calc w SS316)	June, 1996 (w install)	P&T calc	10/16/97
Pipes									
pipe lines									
	totals	\$3,315,929	\$7,142,755	\$1,972,475	\$1,853,012	\$6,014,700			

Equipment -Steam side

Type unit	DSRP Price	DSRP-b Price	DSRP-c Price	DSRP-100 Price	DSRP-500 Price	Mat. of Construction	Purchase date	Purchase price ref.
Heat Exchangers								
LCOOLR	\$7,600	\$8,100	\$0	\$6,800	\$7,600		June, 1996	aspen
VCOOLR	\$7,000	\$8,400	\$6,700	\$6,800	\$7,600		June, 1996	aspen
Pumps								
PTOWR	\$4,200	\$8,000	\$2,800	\$3,200	\$5,500		June, 1996	aspen
PHOTH2O	\$1,000	\$3,500	\$0	\$400	\$3,500		price quote from General Pumps	11/26/97
PSTEAM	\$57,400	\$75,100	\$57,400	\$57,400	\$59,300		June, 1996	aspen
	totals	\$77,200	\$103,100	\$66,900	\$74,600	\$83,500		

Expenditures

	DSRP	DSRP-b	DSRP-c	DSRP-100	DSRP-500	cost ref.
Electrical						
Pumps & Compressors						
kW RECYCOMP	59	227	5	7	37 ASPEN generated power requirements	
kW PRESAIR	3282	10414	900	999	4889 ASPEN generated power requirements	
kW Steam pumps	76	193	30	32	160 ASPEN steam simulations	11/26/97
Light & instruments						
kW misc.	683	683	683	683	683 20% base case pump & compressor requirements	
TOTAL kW	4100.4	11517.4	1618.4	1721	5769	
unit cost \$/kWh	0.04	0.04	0.04	0.04	0.04 Self-gen. (Jan. 1990) Peters & Timmeraus	
90 % op Cost \$/yr	\$1,293,988	\$3,634,615	\$510,728	\$543,234	\$1,820,690	
Cooling Water						
lbs/hr	149,000	500,000	25,000	62,744	313,720 ASPEN Complete Steam Generation Scheme simulations	
unit value \$/lb	2.6E-05	2.6E-05	2.6E-05	2.6E-05	2.6E-05 Tower (Jan. 1990) Peters & Timmeraus	
90 % op Cost \$/yr	\$21,854	\$73,336	\$3,667	\$9,203	\$46,014	
Oxygen						
lbs/hr	0	0	0	0	0	
unit value \$/lb						
Cost \$/yr						
Additional Employees						
Engineers	2	2	2	2	2	
unit cost	\$100,000	\$100,000	\$100,000	\$100,000	\$100,000	
Maintenance	2	2	2	2	2	
unit cost	\$70,000	\$70,000	\$70,000	\$70,000	\$70,000	
Cost \$/yr	\$340,000	\$340,000	\$340,000	\$340,000	\$340,000	
Consumed Coal Gas						
MW lost	7	23	2	3	15 Appendix J	
unit cost \$/MWh	40	40	40	40	40 Self-gen. (Jan. 1990) Peters & Timmeraus	
Cost \$/yr	\$2,287,295	\$7,259,195	\$652,927	\$963,138	\$4,714,074	
	totals (yearly)	\$3,943,137	\$11,307,146	\$1,507,322	\$1,855,574	\$6,920,778

Benefits

	DSRP	DSRP-b	DSRP-c	DSRP-100	DSRP-500	Condition	value ref.	date of calc.
Sulfur Recovered								
lbs/hr	5,840	18,590	1,667	2,460	12,300			
90% op tons/year	23,037	73,332	6,576	9,704	48,520			11/4/97
unit value \$/ton	50	50	50	50	50	low purity	Chem. Eng. Progress 1996	
Revenue \$/yr	\$1,151,852	\$3,666,599	\$328,791	\$485,198	\$2,425,991			
Steam Generation								
lbs/hr	23,200	77,700	6,160	9,800	48,800	950 psia, 441 C		11/4/97
unit value \$/lb	0.0039	0.0039	0.0039	0.0039	0.0039	500 psig, (Jan. 1990) Peters and Timmeraus		
90% op Revenue \$/yr.	\$713,833	\$2,390,725	\$189,535	\$301,533	\$1,501,511			
	totals (yearly)	\$1,865,685	\$6,057,324	\$518,326	\$786,731	\$3,927,501		

DSRP	DSRP-b	DSRP-c	DSRP-100	DSRP-500
YEARLY COST	\$2,077,452	\$5,249,823	\$988,996	\$1,068,843
EQUIPMENT COSTS	\$3,393,129	\$7,245,855	\$2,039,375	\$1,927,612
				\$6,098,200

DSRP costs

Equipment -Sulfur side		DSRP				DSRP				DSRP			
Type	Unit	DSRP Price	DSRP-b Price	DSRP-c Price	DSRP-100 Price	DSRP-500 Price	Mat. of Construction	Purchase date	Purchase price ref.	date of calculation			
Heat Exchangers													
AIRHX		\$33,500	\$71,500	\$17,900	\$19,400	\$55,300	SS304 / SS310 tubes	June, 1996	aspen DAIRHX	1/22/98			
PDCOOLR		\$63,400	\$126,600	\$25,200	\$42,000	\$90,400	SS310 (calc w SS316)	June, 1996	aspen	1/22/98			
Tanks													
7 days Sulfur Storage		\$125,500	\$205,400	\$65,000	\$80,000	\$171,000	SS310 (calc w SS316)	June, 1996	aspen	11/6/97			
Condenser													
High Pressure		\$40,400	\$82,200	\$18,500	\$21,900	\$59,600	SS310 (calc w SS316)	June, 1996	aspen				
Vaporiser													
VAPORIZR		\$16,100	\$17,800	\$15,900	\$15,200	\$16,700	SS310 (calc w SS316)	June, 1996	aspen				
Compressor													
RECOMP		\$52,900	\$52,900	\$52,900	\$52,900	\$52,900	Carbon Steel	June, 1996	aspen				
PRESAIR		\$844,000	\$2,6680,000	\$241,000	\$416,000	\$1,740,000			1997 Ingesoll-Rand Centac Pricing				
Reactors													
Desulf & Regen		\$1,328,000	\$1,772,000	\$1,169,000	\$728,000	\$2,434,000	SS310 (calc w SS316)	June, 1996 (w install)	P&T calc	10/7/97			
DSRP reactor		\$812,129	\$2,134,355	\$367,075	\$477,612	\$1,394,800	SS310 (calc w SS316)	June, 1996 (w install)	P&T calc	10/16/97			
Pipes	pipelines												
totals		\$3,315,929	\$7,142,755	\$1,972,475	\$1,853,012	\$6,014,700							

DSRP costs

Equipment -Steam side		DSRP costs					
Type	unit	DSRP Price	DSRP-b Price	DSRP-c Price	DSRP-100 Price	DSRP-500 Price	Purchase price ref.
Heat Exchangers							
LCOOLR		\$7,600	\$8,100	\$0	\$6,800	\$7,600	June, 1996
VCOOLR		\$7,000	\$8,400	\$6,700	\$6,800	\$7,600	June, 1996
Pumps							
PTOWR		\$4,200	\$8,000	\$2,800	\$3,200	\$5,500	June, 1996
PHOTH2O		\$1,000	\$3,500	\$0	\$400	\$3,500	aspen
PSTEAM		\$57,400	\$75,100	\$57,400	\$57,400	\$59,300	price quote from General Pumps
totals		\$77,200	\$103,100	\$66,900	\$74,600	\$83,500	June, 1996
							11/26/97
							11/26/97
							aspen
							aspen
							aspen
							11/26/97
							11/26/97