

Appendix A

Case 1: Texaco gasifier and steam reforming of natural gas (including fugitive emissions study)

CASE 1

The following report gives a brief description of each of the units in the block flow diagram. All capital cost data in this report, except where otherwise specified, has been estimated from similar installations described in the Houston Area Medium-BTU Coal Gasification Project Final Report, published in June 1982 by Union Carbide [1] (All references to material in this report will be referred to as Houston, and all scaling exponents from the Houston report are 0.65). The plant consumes 0.96 million metric tons of coal, 0.82 million metric tons of oxygen, 0.18 billion standard cubic meters of natural gas, and produces 0.50 million metric tons of mixed alcohols per year.

SYNGAS PRODUCTION FROM NATURAL GAS

Compressed natural gas (stream 14) and steam (stream 15) are reacted in the Steam Reformation Block. The cooled output gas (stream 17) goes to the Rectisol Block. The cost for this unit was estimated from data found for a hydrogen production facility, with a scaling exponent of 0.8 [2]. The fuel gas usage for this block is estimated to be 30% of the natural gas feed.

COAL PREPARATION

Coal (stream 10) and water (stream 12), are sent to the Coal Preparation Block. The coal is crushed, mixed with the water, and pumped to the gasifier as a ~60% solids mixture by weight (stream 13). The Coal Preparation Block is composed of four plants from the Houston report. Plant 01 is the Coal Slurry Preparation Plant. The cost of this plant was scaled linearly due to its multiple train format; where each train can handle up to 1,150 tons of coal per day. Plant 61 is the Reclaiming, Transfer, and Crushing Plant. The cost of this plant was scaled exponentially. Plant 22 is the Barge Terminal. This plant was scaled exponentially. Plant 60 is Coal Receiving and Storage and again the cost for this plant was scaled exponentially.

CRYOGENIC OXYGEN PLANT

Compressed air (stream 1) is cooled and sent to the Cryogenic Oxygen Plant Block, and is separated into high purity oxygen (stream 2), nitrogen (stream 3), argon (stream 6), and a water and carbon dioxide waste mixture (stream 28). A small quantity of nitrogen

(stream 19) is sent to the Rectisol Block. The Cryogenic Oxygen Plant Block does not include the inlet air compressors or the outlet oxygen compressors. In the cryogenic system, there are provisions for gaseous and liquid oxygen backups sufficient to maintain downstream plant operation in the event of a shutdown in the cryogenic facility. We also assume that some scale down is possible for this system, so the capital investment has been calculated linearly for the reduction in trains, and exponentially for throughput reduction per train. Each train can produce up to 2,000 tons of oxygen per day. The Houston plants that comprise the Cryoplant Block are 02 and 08.

RECTISOL

The cooled raw gas streams (streams 17 and 18), nitrogen gas (stream 19) for methanol regeneration, and methanol make-up (stream 20) for vapor loss all enter the Rectisol Block. H₂S levels are reduced to the ppb range and CO₂ levels to the ppm range. The clean syngas (stream 22) is sent to the alcohol synthesis loop. A CO₂-N₂ mixture (stream 24) and a CO₂ rich stream (stream 23) are produced as byproducts. Condensed water is also removed (stream 17A). This block is the same as Houston Plant 05. The cost for this plant was estimated by using exponential scaling.

TEXACO GASIFIER

The coal slurry (stream 13) is mixed with compressed oxygen (stream 9) and burned at 1,200-1,400°C and 8,000 kPa in the Texaco Gasifier Block. The hot, raw gas (stream 8) is sent to the Syngas Heat Recovery Block, and the slag (stream 33) is sent to the Slag Handling Block. The equivalent of the Texaco Gasifier Block is Plant 03 in the Houston report, and each train can handle up to 958.3 tons of coal per day.

SLAG HANDLING

Molten slag from the Texaco Gasifier Block (stream 33) is direct quenched with water and sent to slag disposal (stream 37). A small amount of water (stream 36) is purged from the closed loop and is replaced by water make-up (stream 34). This block is the same as Houston Plant 63. The cost for this plant was estimated by exponential scaling.

COS HYDROLYSIS

The sulfide rich stream from the Rectisol Block (stream 25) and steam are sent to the COS Hydrolysis Block where COS is converted to H₂S. The product gas (stream 41) is sent to the Claus Sulfur Recovery Block. The COS Hydrolysis Block cost is assumed to be negligible.

SYNGAS HEAT RECOVERY

The raw gas stream from the Texaco Gasifier Block (stream 8) at 1,300°C and 8,000 kPa enters the Syngas Heat Recovery Block and is cooled against process boiler feed water at 25°C (stream 71). The raw gas stream exits at 300°C (stream 18), and the boiler feed exits as steam at 10,000 kPa and 535°C (stream 68). It is assumed that the raw gas stream is cooled further prior to entering the Rectisol Block. This block is part of Houston Plant 04.

CLAUS PLANT

Hydrogen sulfide rich gas (stream 41) is mixed with air (stream 42) and converted in a two-step reaction to elemental sulfur (stream 46). The unreacted hydrogen sulfide (stream 45) is then sent to the Beavon Plant for further treatment. This block is the same as Houston Plant 06. The cost for this plant was estimated by exponential scaling.

BEAVON PLANT

The Claus tail gas (stream 45) and air (stream 47) go to the Beavon Block. Additional sulfur is made (stream 51), and the gas leaving (stream 50) is sufficiently free from sulfides that it can be vented to the atmosphere. A sour water stream (stream 54) is sent from the plant for treatment. The cost of this block was estimated from data collected from various sources, with a scaling exponent of 0.65 [3].

MoS₂ ALCOHOL SYNTHESIS LOOP

Clean syngas (stream 26) at 140 atmospheres enters the catalytic reactor along with the syngas recycle (stream 56B). The products (stream 26A) are taken to the separations block where the unreacted syngas is removed (stream 59). Part of this stream (stream 27) is sent to power generation while the rest (stream 56) is sent to CO₂ removal. The cost of this block was estimated from the cost of a methanol synthesis loop, with a scaling exponent of 0.565 [4].

CO₂ REMOVAL

This block is very similar to the Rectisol Block. Recycled gas from the alcohol separation block (stream 56) is the only feed. CO₂ free syngas (stream 56A) is then recompressed and sent back to the reactor. CO₂ is taken off as a product (stream 57). The cost of this block is calculated the same way as in the Rectisol block. Its power requirements are included in the Rectisol block.

COMBUSTION GAS TURBINE

The light hydrocarbons extracted from the reactor recycle (stream 27) in the Alcohol Synthesis Loop are sent to a combustion gas turbine with hot gas heat recovery. The power from the combustion gas turbines is assumed to be 35% of the HHV of the fuel in stream 27. This is consistent with recent studies on IGCC plants using medium BTU synthesis gas [9]. The cost for this block was estimated from data taken from an EPRI report, where each train can produce up to 200 MW with a scaling exponent of 0.67 [10].

EXHAUST GAS HEAT RECOVERY

The hot exhaust gas stream from the Gas Turbine Block (stream 70) at 590°C and 101 kPa enters the Exhaust Gas Heat Recovery Block and is cooled against process boiler feed water at 25°C (stream 73). The exhaust gas stream exits at 200°C (stream 75), and the boiler feed exits as steam at 10,000 kPa and 535°C (stream 74). The cost for this block was estimated from data taken from an EPRI report, where each train can generate up to 425 tons of steam per hour with a scaling exponent of 0.67 [10]. This block also supplies the reheat between the high pressure and intermediate pressure steam turbines.

POWER GENERATION

The steam from the Syngas Heat Recovery Block and the Exhaust Gas Heat Recovery Block is let down in the steam turbines for power production. The cost for this block was estimated from data taken from an EPRI report, where each train can produce up to 500 MW with a scaling exponent of 0.67 [10]. This is a 3-stage steam turbine system. The high pressure stage inlet is 535°C, 10,000 kPa steam. The exhaust at 3,000 kPa is reheated to 535°C before entering the intermediate pressure stage. The final stage exhausts to a surface condenser at 7.4 kPa. Each turbine has an assumed efficiency of 75%.

IMPORTANT POINTS OF INFORMATION

Several decisions were made for the creation of this case that should be outlined. Also, there are alternatives that have not been fully considered which will be considered in more detail later. They are listed below along with the reasons behind them.

- Catalytic steam/methane reformation used to adjust the H₂:CO ratio upwards. The ratio from coal gasification is less than 1. Since the optimal ratio for higher alcohol synthesis is approximately 1.1 - 1.2, an additional source of hydrogen was required. The reformer was assumed to operate at equilibrium, as suggested in the literature [8]. Other alternatives to this block are available and will be considered.

- The traditional method for purifying high quantities of pure oxygen is by cryogenics, which is used for this case. However, recent reports suggest that membrane and catalytic processes are becoming economically competitive with cryogenics. Therefore, we will examine these alternatives.
- The Rectisol system was chosen for this case for H₂S and CO₂ removal. The major alternative to Rectisol is Selexol. The literature indicates that Rectisol has a higher installed capital cost, but a lower fixed operating cost than Selexol. Both of these systems are capable of removing H₂S to the ppm level and beyond. However, there is some evidence that quantities of H₂S are beneficial if the reaction involves the MoS₂ catalyst. If this is so, then a system such as the Benfield acid gas removal process might be more suitable. The Benfield system does not remove as much H₂S and has lower capital and operating costs.
- The operating pressure for the Texaco gasifiers has been set at 8,000 kPa. This is the highest pressure indicated in the literature at which a Texaco gasifier has been run. Since the pressure required at the reactor is 14,000 kPa, we would of course like to run the gasifiers at as high a pressure as possible. Another limiting factor is the oxygen feed pressure. According to various sources, the highest pressure available with conventional centrifugal compressors is around 80 atmospheres. It is assumed that, because of the size of this case, a higher cost for the oxygen compressor would be acceptable in return for savings on feed gas compression. In addition, other gasification systems will also be investigated.

TOTAL ESTIMATED CAPITAL INVESTMENT (MM\$)

| | |
|--------------------------------|--------------|
| Synthesis Gas via Natural Gas | 15.9 |
| Coal Preparation | 40.8 |
| Texaco Gasifier | 156.7 |
| Slag Handling | 3.0 |
| Gas Turbines | 45.0 |
| Steam Turbines | 22.1 |
| Exhaust Gas Heat Recovery | 9.9 |
| Synthesis Gas Heat Recovery | 4.6 |
| Cryogenic Oxygen Production | 89.3 |
| Rectisol (Acid Gas Separation) | 34.9 |
| Claus (Sulfur Recovery) | 10.3 |
| Beavon | 2.2 |
| Alcohol Synthesis Loop | 47.2 |
| CO2 Removal | 26.9 |
| Other Compressors | 54.1 |
| TOTAL | 562.8 |

(sum of individual block costs does not exactly equal the total due to round-off)

OVERALL ECONOMIC EVALUATION

The following table gives the totals and breakdowns for the yearly operating costs as well as the total installed cost for the plant.

| | |
|--|-------|
| TOTAL ESTIMATED INSTALLED CAPITAL COST (MM\$) | 562.8 |
| TOTAL ESTIMATED OPERATING COSTS (MM\$/YR) | 149.6 |
| Coal (\$33/metric ton delivered) | 31.8 |
| Natural Gas (\$106/1000 cubic meters) | 18.7 |
| Other Expenses | 99.2 |
| TOTAL ESTIMATED CREDITS (EXCLUDING ALCOHOLS) (MM\$/YR) | 46.6 |
| Power (\$0.05/kWh) | 39.2 |
| Slag (\$5.5/metric ton) (6) | 0.6 |
| Sulfur (\$300/metric ton) (7) | 6.9 |

Credits for nitrogen, argon, and other rare gases have not been included because prices were not available and potential markets have not yet been identified.

STAND ALONE COMPRESSORS AND POWER SUMMARY

There are 5 compressors that are not included in any of the blocks. Their inlet, outlet, pressure change, power rating, and installed capital cost are listed below. Following that is a summary of the total plant power output/input (5). An efficiency of 70% is assumed for all compressors, with a maximum pressure ratio of 5 for a single stage of compression. Multiple compression stages with intercooling are used for services with pressure ratios greater than 5.

| FUNCTION | INLET STREAM | P (kPa) | OUTLET STREAM | P (kPa) | POWER (MW) | COST (MM\$) |
|---|-----------------|------------|------------------|------------|---------------|----------------|
| Air Prep | 1A | 101 | 1 | 500 | -31.1 | 28.3 |
| O2 Prep | 2 | 500 | 9 | 8136 | -10.8 | 10.1 |
| Reform Comp | 17C | 1400 | 17 | 8106 | -6.4 | 5.8 |
| Rxtr Prep | 22 | 8106 | 26 | 14000 | -7.1 | 6.2 |
| Recy Comp | 56A | 12666 | 56B | 14000 | -3.6 | 3.6 |
| Total compressor needs | | | | | -58.9 | |
| Other in plant needs | | | | | -10.1 | |
| Total produced in steam and gas turbines | | | | | 167.0 | |
| Net power output | | | | | 98.0 | |
| Total installed compressor costs (1992 dollars) | | | | | | 54.1 |

REFERENCES

1. *Final Report on the Houston Area Medium-BTU Coal Gasification Project, Volumes 2 and 3*. Prepared by the Linde Division of Union Carbide Corporation, June 1982.
2. Baasel, William D., *Preliminary Chemical Engineering Plant Design, 2nd edition*, Van Nostrand Reinhold, New York, 1990, pp. 268-269.
3. "Beavon Sulfur Removal Process," *Hydrocarbon Processing*, April 1984, p. 78.
4. Frank, Marshall E. "Methanol: Emerging Uses, New Syntheses," *Chemtech*, June 1982, p. 358-362.
5. Baasel, pp. 529-530.
6. T. Torries, personal communication
7. *Chemical Marketing Reporter*, August 31, 1992.
8. Rase, Howard F., *Chemical Reactor Design for Process Plants, Volume 2*, John Wiley & Sons, New York, 1977, pp. 133-138.
9. Report TR-101789, Houston Lighting and Power Company's Evaluation of Coal Gasification Coproduction Energy Facilities, EPRI Project 3226-04, 1992.
10. EPRI Report TR-100319, *Evaluation of a 510-MWe Destec GCC Power Plant Fueled With Illinois No. 6 Coal*, Prepared by Fluor Daniel, Inc., EPRI Project 2733-12, 1992.

Figure A.1 : Block Flow Diagram for Case 1




Table A.1 Case 1 Flow Table

| | 001 | 001A | 002 | 003 | 004 | 006 | 008 | 009 | 010 | 012 |
|--------------|----------|----------|----------|----------|----------|--------|----------|----------|----------|---------|
| Ar | 142.5 | 142.5 | | | | 142.5 | | | 6646.6 | |
| C | | | | | | | | | | |
| CH3OH | | | | | | | | | | |
| C2H5OH | | | | | | | | | | |
| C3H7OH | | | | | | | | | | |
| C4H9OH | | | | | | | | | | |
| C5H11OH | | | | | | | | | | |
| CO | | | | | | 4770.4 | | | | |
| CO2 | 4.9 | 4.9 | | | | 1861.6 | | | | |
| COS | | | | | | 8.9 | | | | |
| CaCO3 | | | | | | | | | | |
| H2 | | | | | | 3649.6 | | | 2716.0 | |
| H2O | 368.3 | 368.3 | | | | 3098.6 | | | 76.5 | 4061.1 |
| H2S | | | | | | 80.4 | | | | |
| N2 | 11933.5 | 11933.5 | | 11933.5 | 11694.5 | | 54.3 | | 58.8 | |
| NH3 | | | | | | | 9.1 | | | |
| O2 | 3208.2 | 3208.2 | 3208.2 | | | | | 3208.2 | 523.5 | |
| S | | | | | | | | | 89.3 | |
| Al2O3 | | | | | | | | | 124.4 | |
| C3H6O2 | | | | | | | | | | |
| C4H8O2 | | | | | | | | | | |
| CH4 | | | | | | | 5.7 | | | |
| C2H6 | | | | | | | | | | |
| kmol/hr | 15657.5 | 15657.5 | 3208.2 | 11933.5 | 11694.5 | 142.5 | 13538.5 | 3208.2 | 10235.2 | 4061.1 |
| kg/hr | 449349.1 | 449349.1 | 102664.0 | 334137.8 | 327447.3 | 5700.1 | 283586.3 | 102664.0 | 120516.7 | 73098.9 |
| Temp. (C) | 25.0 | 25.0 | 25.0 | 25.0 | 25.0 | 25.0 | 1300.0 | 225.0 | 25.0 | 25.0 |
| Press. (KPA) | 500.0 | 101.3 | 500.0 | 500.0 | 500.0 | 500.0 | 8135.8 | 8135.8 | 101.3 | 101.3 |

Table A.1 Case 1 Flow Table (cont'd)

| | 013 | 014 | 015 | 017 | 017A | 017B | 017C | 018 | 019 | 020 | 022 |
|--------------|----------|---------|---------|---------|---------|---------|---------|----------|--------|-------|----------|
| Ar | | | | | | | | | | | |
| C | 6646.6 | | | | | | | | | | |
| CH3OH | | | | | | | | | | 0.9 | |
| C2H5OH | | | | | | | | | | | |
| C3H7OH | | | | | | | | | | | |
| C4H9OH | | | | | | | | | | | |
| C5H11OH | | | | | | | | | | | |
| CO | | | | 611.7 | | | 611.7 | 4770.4 | | | 5382.1 |
| CO2 | | | | 143.1 | | | 143.1 | 1861.6 | | | |
| COS | | | | | | | | 8.9 | | | |
| CaCO3 | | | | | | | | | | | |
| H2 | 2716.0 | | | 2407.5 | | | 2407.5 | 3649.6 | | | 6057.1 |
| H2O | 4137.6 | | 1785.3 | | 3098.6 | 887.3 | | 3098.6 | | | |
| H2S | | | | | | | | 80.4 | | | |
| N2 | 58.8 | | | | | | | 54.3 | 238.9 | | |
| NH3 | | | | | | | | 9.1 | | | |
| O2 | 523.5 | | | | | | | | | | |
| S | 89.3 | | | | | | | | | | |
| Al2O3 | 124.4 | | | | | | | | | | |
| C3H6O2 | | | | | | | | | | | |
| C4H8O2 | | | | | | | | | | | |
| CH4 | | 755.4 | | 0.6 | | | 0.6 | 5.7 | | | 5.7 |
| C2H6 | | | | | | | | | | | |
| kmol/hr | 14296.2 | 755.4 | 1785.3 | 3162.9 | 3098.6 | 887.3 | 3162.9 | 13538.5 | 238.9 | 0.9 | 11444.9 |
| kg/hr | 193615.7 | 12086.3 | 32134.7 | 28248.8 | 55773.9 | 15972.2 | 28248.8 | 283586.3 | 6690.6 | 29.3 | 162904.7 |
| Temp. (C) | 25.0 | 25.0 | 300.0 | 25.0 | 25.0 | 25.0 | 25.0 | 300.0 | 25.0 | 25.0 | 25.0 |
| Press. (KPA) | 8135.8 | 1480.0 | 1480.0 | 8106.0 | 8106.0 | 1400.0 | 1400.0 | 8106.0 | 500.0 | 101.3 | 8106.0 |

Table A.1 Case 1 Flow Table (cont'd)

| | 023 | 024 | 025 | 026 | 026A | 027 | 028 | 033 | 034 | 036 |
|--------------|---------|---------|--------|----------|----------|---------|--------|---------|----------|----------|
| Ar | | | | | | | | | | |
| C | | | | | | | | | | |
| CH3OH | | | | | 628.3 | | | | | |
| C2H5OH | | | 0.9 | | 655.4 | | | | | |
| C3H7OH | | | | | 145.0 | | | | | |
| C4H9OH | | | | | 36.5 | | | | | |
| C5H11OH | | | | | 15.2 | | | | | |
| CO | | | | 5382.1 | 7001.9 | 714.2 | | | | |
| CO2 | 1202.8 | 701.6 | 100.2 | | 1493.7 | 152.4 | 4.9 | | | |
| COS | | | 8.9 | | | | | | | |
| CaCO3 | | | | | | | | | | |
| H2 | | | | 6057.1 | 7880.0 | 803.8 | | | | |
| H2O | | | | | 140.1 | | 368.3 | | 7689.1 | 7689.1 |
| H2S | | | 80.4 | | | | | | | |
| N2 | | 293.2 | | | | | | | | |
| NH3 | | | 9.1 | | | | | | | |
| O2 | | | | | | | | | | |
| S | | | | | | | | | | |
| Al2O3 | | | | | | | | | | |
| C3H6O2 | | | | | 18.0 | | | 124.4 | | |
| C4H8O2 | | | | | 11.9 | | | | | |
| CH4 | | | | 5.7 | 4380.8 | 446.8 | | | | |
| C2H6 | | | | | 171.6 | 17.5 | | | | |
| kmol/hr | 1202.8 | 994.8 | 199.5 | 11444.9 | 22578.5 | 2134.7 | 373.3 | 124.4 | 7689.1 | 7689.1 |
| kg/hr | 52923.7 | 39082.0 | 7861.0 | 162904.7 | 420678.3 | 35983.3 | 6847.1 | 12693.4 | 138404.0 | 138404.0 |
| Temp. (C) | 25.0 | 25.0 | 25.0 | 98.0 | 310.0 | 25.0 | 25.0 | 1300.0 | 25.0 | 25.0 |
| Press. (KPA) | 8106.0 | 8106.0 | 8106.0 | 14000.0 | 12666.0 | 12666.0 | 500.0 | 101.3 | 101.3 | 101.3 |

Table A.1 Case 1 Flow Table (cont'd)

| | 037 | 041 | 042 | 045 | 046 | 047 | 050 | 051 | 054 | 056 | 056A |
|-------------|---------|--------|--------|---------|--------|-------|---------|-------|--------|----------|----------|
| Ar | | | | | | | | | | | |
| C | | | | | | | | | | | |
| CH3OH | | 0.9 | | 0.9 | | | 0.9 | | | | |
| C2H5OH | | | | | | | | | | | |
| C3H7OH | | | | | | | | | | | |
| C4H9OH | | | | | | | | | | | |
| C5H11OH | | | | | | | | | | | |
| CO | | | | | | | | | | 6287.7 | 6287.7 |
| CO2 | | 109.1 | | 109.1 | | | 109.1 | | | 1341.4 | |
| COS | | | | | | | | | | | |
| CaCO3 | | | | | | | | | | | |
| H2 | | | | | | | | | | 7076.3 | 7076.3 |
| H2O | | | | 84.8 | | | | | 89.3 | | |
| H2S | | 89.3 | | 4.5 | | | | | | | |
| N2 | | | 159.6 | 159.6 | | 21.1 | 180.6 | | | | |
| NH3 | | 9.1 | | 9.1 | | | 9.1 | | | | |
| O2 | | | 42.4 | | | 5.6 | 3.4 | | | | |
| S | | | | | 84.8 | | | 4.5 | | | |
| Al2O3 | 124.4 | | | | | | | | | | |
| C3H6O2 | | | | | | | | | | | |
| C4H8O2 | | | | | | | | | | 3933.9 | 3933.9 |
| CH4 | | | | | | | | | | 154.1 | 154.1 |
| C2H6 | | | | | | | | | | | |
| kmol/hr | 124.4 | 208.4 | 202.0 | 368.0 | 84.8 | 26.7 | 303.1 | 4.5 | 89.3 | 18793.3 | 17452.0 |
| kg/hr | 12693.4 | 8020.7 | 5826.1 | 11131.8 | 2715.1 | 768.7 | 10149.9 | 142.9 | 1607.6 | 316794.0 | 257773.6 |
| Temp.(C) | 25.0 | 25.0 | 25.0 | 200.0 | 125.0 | 25.0 | 100.0 | 125.0 | 50.0 | 25.0 | 25.0 |
| Press.(KPA) | 101.3 | 101.3 | 101.3 | 101.3 | 101.3 | 101.3 | 101.3 | 101.3 | 101.3 | 12666.0 | 12666.0 |

Table A.1 Case 1 Flow Table (cont'd)

| | 056B | 057 | 059 | 063 | 064 | 065 | 067 | 068 | 070 | 071 |
|--------------|----------|---------|----------|---------|---------|---------|----------|----------|----------|----------|
| Ar | | | | | | | | | | |
| C | | | | | | | | | | |
| CH3OH | | | | | 628.3 | | | | | |
| C2H5OH | | | | | 655.4 | | | | | |
| C3H7OH | | | | | 145.0 | | | | | |
| C4H9OH | | | | | 36.5 | | | | | |
| C5H11OH | | | | | 15.2 | | | | | |
| CO | 6287.7 | | 7001.9 | | | | | | | |
| CO2 | | 1341.4 | 1493.7 | | | | | | 1348.4 | |
| COS | | | | | | | | | | |
| CaCO3 | | | | | | | | | | |
| H2 | 7076.3 | | 7880.0 | | | | | | | |
| H2O | | | | 140.1 | | 967.2 | | 10615.6 | 2717.1 | 10615.6 |
| H2S | | | | | | | | | | |
| N2 | | | | | | | 20422.1 | | 20422.1 | |
| NH3 | | | | | | | | | | |
| O2 | | | | | | | 5428.7 | | 3714.7 | |
| S | | | | | | | | | | |
| Al2O3 | | | | | | | | | | |
| C3H6O2 | | | | 18.0 | | | | | | |
| C4H8O2 | | | | 11.9 | | | | | | |
| CH4 | 3933.9 | | 4380.8 | | | | | | | |
| C2H6 | 154.1 | | 171.6 | | | | | | | |
| kmol/hr | 17452.0 | 1341.4 | 20928.0 | 170.1 | 1480.4 | 967.2 | 25850.8 | 10615.6 | 28202.4 | 10615.6 |
| kg/hr | 257773.6 | 59020.4 | 352777.2 | 4905.1 | 62996.0 | 17409.0 | 745536.0 | 191080.1 | 798928.2 | 191080.1 |
| Temp. (C) | 45.0 | 25.0 | 25.0 | 25.0 | 25.0 | 25.0 | 25.0 | 535.0 | 590.0 | 25.0 |
| Press. (KPA) | 14000.0 | 12666.0 | 12666.0 | 12666.0 | 12666.0 | 10000.0 | 101.3 | 10000.0 | 101.3 | 10000.0 |

Table A.1 Case 1 Flow Table (cont'd)

| | 073 | 074 | 075 | 076 | 077 | 078 |
|--------------|---------|---------|----------|----------|----------|----------|
| Ar | | | | | | |
| C | | | | | | |
| CH3OH | | | | | | |
| C2H5OH | | | | | | |
| C3H7OH | | | | | | |
| C4H9OH | | | | | | |
| C5H11OH | | | | | | |
| CO | | | | | | |
| CO2 | | | 1348.4 | | | |
| COS | | | | | | |
| CaCO3 | | | | | | |
| H2 | | | | | | |
| H2O | 3600.0 | 3600.0 | 2717.1 | 14215.6 | 14215.6 | 14215.6 |
| H2S | | | | | | |
| N2 | | | 20422.1 | | | |
| NH3 | | | | | | |
| O2 | | | 3714.7 | | | |
| S | | | | | | |
| Al2O3 | | | | | | |
| C3H6O2 | | | | | | |
| C4H8O2 | | | | | | |
| CH4 | | | | | | |
| C2H6 | | | | | | |
| kmol/hr | 3600.0 | 3600.0 | 28202.4 | 14215.6 | 14215.6 | 14215.6 |
| kg/hr | 64800.6 | 64800.6 | 798928.2 | 255880.7 | 255880.7 | 255880.7 |
| Temp. (C) | 25.0 | 535.0 | 200.0 | 40.0 | 380.0 | 535.0 |
| Press. (KPA) | 10000.0 | 10000.0 | 101.3 | 7.4 | 3000.0 | 3000.0 |

Table A.2 Case 1 Energy Analysis

| ELECTRICITY | | |
|------------------------|------------------------------|----------------------------------|
| Plant | Electricity Used (MW) | Electricity Produced (MW) |
| Coal Preparation Plant | 2.0 | 0.0 |
| Cryogenic Oxygen Plant | 4.3 | 0.0 |
| Rectisol Plant | 2.3 | 0.0 |
| Texaco Gasifier | 0.6 | 0.0 |
| Syn. Gas Heat Recovery | 0.9 | 0.0 |
| Claus Plant | 0.1 | 0.0 |
| Gas Turbine | 0.0 | 80.7 |
| Steam Turbine | 0.0 | 86.3 |
| Compressor 1 | 31.1 | 0.0 |
| Compressor 2 | 10.8 | 0.0 |
| Compressor 3 | 6.4 | 0.0 |
| Compressor 4 | 7.1 | 0.0 |
| Compressor 5 | 3.6 | 0.0 |
| Total | 69.1 | 167.0 |

EMISSIONS FROM THE SULFUR REMOVAL PROCESS BASE CASE 1

Base Case 1 is primarily a model of a process that will turn coal into an alcohol based fuel additive. This plant is very large, and will have a production of roughly 0.5 million metric tons of mixed alcohols per year. In order to properly design this Plant, it is important to compare the emissions of this facility with the Threshold Emission levels allowed by the government before Best Available Control Technology (BACT) is required. If BACT is required it will significantly affect the cost of our plant. The emissions were estimated from the Sulfur Removal portion of the plant because all of the sulfur compounds, along with a major part of the plant's CO, ozone producing compounds (VOC's that are precursors to ozone formation), and two Hazardous Air Pollutants (HAP's), methanol and COS, are found in this part of the process. After the estimations were completed, it was found that the H₂S, Total Reduced Sulfur (including H₂S), Reduced Sulfur Compounds (including H₂S and COS), Ozone producing VOC's, and the HAP's were all above the Threshold Values.

If the size of the plant increases, the total emissions will also increase. The stack emissions will go up with any raise in production. However, the fugitive emissions will grow only if the amount of equipment increases, for example, more trains are added.

The estimation of emissions for the sulfur removal process, which includes four blocks from Base Case 1 ; the Rectisol, COS Hydrolysis, Claus, and Beavon blocks (see Figure A.1), includes stack emissions and an estimation of the fugitive emissions for the blocks. The stack emissions were taken from the Base Case 1 flowsheet (see Figure A.1 and Tables A.1), while the fugitive emissions had to be estimated.

The fugitive emissions were estimated by using average emission factors.

$$E_{ij} = m_j F_i N_i$$

i = a type of equipment

j = a component

E_{ij} = Emissions of component j in equip. i (kg/hr)

m_j = mass fraction of component i

F_i = SOCFMI Emission Factor for equipment i (kg/hr/source)

N_i = number of equipment i

The average emission factors (F_i) were taken from the Average Emission Factors for Synthetic Organic Chemical Manufacturing Industry (SOCMI) Fugitive Emissions (see Table A.1), which was taken from the U.S. Environmental Protection Agency, Emission Factors for Equipment Leaks of VOC and HAP, EPA-450/3-86-002, Research Triangle Park, NC, 1986.

Table A.3

| EQUIPMENT | SERVICE | EMISSIONS FACTOR, kg/hr/source |
|------------------------------|--------------|-----------------------------------|
| Valves | Gas | 0.0056 |
| | Light Liquid | 0.0071 |
| | Heavy Liquid | 0.00023 |
| Pumps | Light Liquid | 0.0494 |
| | Heavy Liquid | 0.0214 |
| Compressors | Gas | 0.228 |
| Pressure Relief Valves | Gas | 0.104 |
| Flanges and Other Connectors | All | 0.00083 |
| Open-Ended Lines | All | 0.0017 |
| Sampling Connectors | All | 0.015 |

A "light liquid" is defined by SOCMI as any fluid that is a liquid at the operating conditions and that either:

- (1) Has a vapor pressure greater than 0.3 kPa at 20°C, or
- (2) Contains at least 20% (by weight) of any component that has a vapor pressure greater than 0.3 kPa at 20°C.

A "heavy liquid" is any fluid that is a liquid at the operating conditions and that is not a "light liquid."

The mass fractions for each component in every stream were estimated from actual flowsheets and process specifications. The last estimation made was the quantity of each type of equipment that released fugitive emissions. This estimation involved a classification of each piece of equipment. For example, a reactor would be classified as a vertical vessel (see Table A.4). From these classifications, the total number of valves could be calculated, by using the Valve Estimations provided by the Chemical

Manufacturers Association, Improving Air Quality: Guidance for Estimating Fugitive Emissions from Equipment, p. 25, Washington, DC, January 1989, along with a correlation of the quantity of valves to the number of open-ended lines and flanges.

Table A.4

| VALVE ESTIMATION | |
|-------------------------------------|--------------------------------------|
| Flow Sheet Predicting Item | Estimating Factor Valves per Item |
| Pressure Relief Valves | 3 |
| Flow Transmitter | 6 |
| Storage | 13 |
| Pump | 11 |
| Turbine Meter and Prover Connection | 14 |
| Vertical Vessel (reactor) | 23 |
| Horizontal Vessel (settler) | 21 |
| Heat Exchanger-Heated Side | 8 |
| Heat Exchanger-Cooled Side | 17 |
| Loading or Unloading Point | 4 |

Number of open ended lines = 50% of the number of valves

Number of flanges = 420% of the number of valves

After the estimations and calculations were completed, the total emissions for the sulfur removal process were compared to the West Virginia Administrative Regulations, Air Pollution Control Commission, Chapter 16-20, Series 14, p. 14-5, 1984. If the quantity of a substance released is above its threshold value, then BACT applies. Table A.5 shows the comparison.

Table A.5

SIGNIFICANT EMISSIONS FROM THE SULFUR REMOVAL PROCESS

| CLASSIFICATION | COMPONENTS EMITTED | THRESHOLD VALUES (ton/yr) | TOTAL EMISSIONS (ton/yr) |
|---|-----------------------|---------------------------------|--------------------------------|
| CO | CO | 100 | 42.8 |
| NO _x | n/a | 40 | 0 |
| SO _x | SO ₂ | 40 | 3.52 |
| H ₂ S | H ₂ S | 10 | 20.49 |
| Total Reduced Sulfur Including H ₂ S | H ₂ S | 10 | 20.49 |
| Reduced Sulfur Compounds Including H ₂ S | H ₂ S, COS | 10 | 21.39 |
| Ozone (VOC excluding non-reactives) | CH ₃ OH | 40 | 73.69 |

The total emissions for the sulfur removal process were compared to the 1990 Clean Air Act Amendment, Section 301. Any plant that emits 25 tons per year of any combination of HAP's, or more than 10 tons per year of any HAP compound is classified as a "major source" and is subject to stringent air pollution control. This portion of the plant has two HAP's: methanol and COS. The COS emitted is 0.9 tons per year, which is well below the limit. However, the methanol is well above the limit, 73.69 tons per year, which pushes the plant over the combined 25 tons per year limit by 49.59 tons per year. Thus, the plant is a major source of HAP's.

The conclusion is that for SO_x compounds, we will have no trouble meeting regulations because no other place in our plant has any SO_x. However, H₂S, Total Reduced Sulfur Including H₂S, Reduced Sulfur Compounds Including H₂S, and Ozone (VOC excluding non-reactives) are above the thresholds for BACT. The threshold value is not just for a particular part of the plant, it is a cumulative value that includes the entire plant. Therefore it is a possibility that CO emissions will surpass the threshold, along with an increase in the Ozone (VOC) emissions because all of the alcohols (which are VOC's) are produced in the other portion of the plant. Also the plant is well over the HAP's limit, due to the large amount of methanol going up the stack.

The following tables (A.6-A.8) contain a summary of the emissions from the Stack, the fugitive emissions, and the total emissions for the sulfur removal process.

Table A.6

STACK EMISSIONS FROM THE SULFUR REMOVAL PROCESS

| COMPONENT | STACK EMISSIONS FROM: | | TOTAL STACK EMISSIONS (kmol/hr) | TOTAL STACK EMISSIONS (ton/yr) |
|--------------------|--------------------------|------------------------|---------------------------------|--------------------------------|
| | Rectisol Plant (kmol/hr) | Beavon Plant (kmol/hr) | | |
| CO ₂ | 1535 | 84.2 | 1619 | 560983 |
| N ₂ | 247.5 | 152.8 | 400 | 88255 |
| CH ₃ OH | 0 | 0.19 | 0.19 | 48 |
| NH ₃ | 0 | 8 | 8 | 1111 |

Table A.7

ESTIMATED FUGITIVE EMISSIONS FROM THE SULFUR REMOVAL PROCESS

| COMPONENT | SULFUR REMOVAL EMISSIONS FROM: | | | | TOTAL SULFUR REMOVAL EMISSIONS (ton/yr) |
|--------------------|--------------------------------|------------------------|---------------|----------------|---|
| | Rectisol (kg/hr) | COS Hydrolysis (kg/hr) | Claus (kg/hr) | Beavon (kg/hr) | |
| CH ₃ OH | 3.28 | 0 | 0 | 0 | 25.82 |
| CH ₄ | 0.03 | 0 | 0 | 0 | 0.21 |
| CO | 4.06 | 1.37 | 0 | 0 | 42.80 |
| CO ₂ | 4.54 | 0.77 | 2.65 | 1.76 | 76.50 |
| COS | 0.07 | 0.05 | 0 | 0 | 0.90 |
| H ₂ | 0.33 | 0 | 0 | 0 | 2.58 |
| H ₂ O | 1.28 | 0 | 0.48 | 4.66 | 50.52 |
| H ₂ S | 0.81 | 0.53 | 0.79 | 0.48 | 20.49 |
| N ₂ | 0.65 | 0.08 | 2.31 | 3.31 | 49.99 |
| NH ₃ | 0.01 | 0.03 | 0.1 | 0.06 | 1.63 |
| O ₂ | 0 | 0.02 | 0 | 0.07 | 0.74 |
| SO ₂ | 0 | 0 | 0.45 | 0 | 3.52 |

Table A.8

TOTAL (stack plus fugitive) EMISSIONS FROM THE SULFUR REMOVAL PROCESS

| CLASSIFICATION | COMPONENTS EMITTED | THRESHOLD VALUES (ton/yr) | TOTAL EMISSIONS (ton/yr) |
|---|-----------------------|---------------------------|--------------------------|
| CO | CO | 100 | 42.8 |
| NO _x | n/a | 40 | 0 |
| SO _x | SO ₂ | 40 | 3.52 |
| H ₂ S | H ₂ S | 10 | 20.49 |
| Total Reduced Sulfur Including H ₂ S | H ₂ S | 10 | 20.49 |
| Reduced Sulfur Compounds Including H ₂ S | H ₂ S, COS | 10 | 21.39 |
| Ozone (VOC excluding non-reactives) | CH ₃ OH | 40 | 73.69 |

RECTISOL PLANT

The flowsheet for the Rectisol Plant was taken from the Houston Area Medium-BTU Coal Gasification Project Final Report, published in June 1982 by Union Carbide (Further references to this will be referred to as Houston). The information needed for the flow estimations was taken from Houston as well as the Gas Process Handbook '92, Hydrocarbon Processing, April 1992, p. 125.

Table A.9

RECTISOL PLANT OVERALL FUGITIVE EMISSIONS FOR TWO TRAINS

| COMPONENT | EMISSIONS FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|------------------|------------------------|--|--------------------|------------------------------------|-------------------------------|
| | Vdves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Vdves (kg/hr) | Flanges (kg/hr) | Open- Ended Lines (kg/hr) | |
| CO | 2.02E+ 00 | 0 | 4.22E-01 | 1.76E-01 | 1.16E+ 00 | 2.83E-01 | 4.06 |
| CO2 | 2.45E+ 00 | 0 | 0 | 4.56E-01 | 1.32E+ 00 | 3.21E-02 | 4.54 |
| COs | 4.02E-02 | 2.79E-03 | 0 | 1.34E-03 | 2.01E-02 | 4.90E-03 | 0.07 |
| H2 | 1.63E-01 | 0 | 3.42E-02 | 1.42E-02 | 9.37E-02 | 2.28E-02 | 0.33 |
| H2O | 6.80E-01 | 0 | 0 | 1.48E-01 | 3.65E-01 | 8.89E-02 | 1.28 |
| H2S | 4.67E-01 | 3.24E-02 | 0 | 1.55E-02 | 2.33E-01 | 5.69E-02 | 0.81 |
| N2 | 3.67E-01 | 0 | 0 | 8.17E-03 | 2.25E-01 | 5.48E-02 | 0.65 |
| NH3 | 8.42E-03 | 0 | 0 | 9.02E-04 | 4.36E-03 | 1.06E-03 | 0.01 |
| CH4 | 1.43E-02 | 0 | 0 | 2.78E-03 | 7.73E-03 | 1.88E-03 | 0.03 |
| CH3OH | 1.87E+ 00 | 2.61E-01 | 0 | 9.13E-03 | 9.18E-01 | 2.24E-01 | 3.28 |

The following tables (A.10-A.25) are the actual estimations made for the Rectisol Plant in Base Case 1.

Table A.10

ESTIMATION OF FUGITIVE EMISSIONS FOR THE RECTISOL PLANT

| RECTISOL PLANT | |
|----------------|-------------------------------------|
| QUANTITY | EQUIPMENT TYPE |
| 3 | Pumps |
| 7 | Vertical Vessles |
| 0 | Horizontal Vessles |
| 0 | Storage Tanks |
| 4 | Pressure Relief Valves |
| 3 | Heat - Exchangers (Heating Side) |
| 6 | Heat - Exchangers (Cooling Side) |
| 0 | Loading or Unloading Point |
| 37 | Flow Transmitters |
| 0 | Turbine Meter and Prover Connection |

| QUANTITY | ACTUAL EQUIPMENT |
|----------|-----------------------------|
| 3 | Separators (Knockout Drums) |
| 4 | Towers |
| 4 | Heat Exchangers |
| 3 | Pumps |
| 1 | Compressor |
| 4 | Pressure Relief Valves |
| 37 | Flow Transmitters |

| QUANTITY | ESTIMATED EQUIPMENT |
|----------|---------------------|
| 623 | Valves |
| 312 | Open - Ended Lines |
| 2617 | Flanges |

| QUANTITY | EQUIPMENT WITH FUGITIVES |
|----------|--------------------------|
| 623 | Valves |
| 3 | Pumps |
| 1 | Compressors |
| 4 | Pressure Relief Valves |
| 2617 | Flanges |
| 312 | Open - Ended Lines |

Table A.11

INLET STREAM (gas)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|--------------|---------------|---------------|
| Pumps | 0 | 4673 | 130630 | 4.56E-01 |
| Vertical Vessels | 0 | 1619 | 71245 | 2.48E-01 |
| Horizontal Vessels | 0 | 4 | 210 | 7.31E-04 |
| Storage Tanks | 0 | 5260 | 10520 | 3.66E-02 |
| Pressure Relief Valves | 0 | 3893 | 70074 | 2.44E-01 |
| Heat - Exchangers (Heating Side) | 0 | 72 | 2448 | 8.52E-03 |
| Heat - Exchangers (Cooling Side) | 0 | 46 | 1277 | 4.45E-03 |
| Loading or Unloading Point | 0 | 8 | 141 | 4.91E-04 |
| Flow Transmitters | 2 | 27 | 434 | 1.51E-03 |
| Turbine Meter and Prover Connection | 0 | 1 | 22 | 7.80E-05 |
| TOTAL FLOW | | 15602 | 287201 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 12 | 0 | 0 | 0 | 50 | 6 |

| COMPONENT | EMISSIONS FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-----------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 3.06E-02 | 0 | 0 | 0 | 1.91E-02 | 4.65E-03 | 5.43E-02 |
| CO2 | 1.67E-02 | 0 | 0 | 0 | 1.04E-02 | 2.53E-03 | 2.96E-02 |
| COS | 4.91E-05 | 0 | 0 | 0 | 3.06E-05 | 7.46E-06 | 8.72E-05 |
| H2 | 2.46E-03 | 0 | 0 | 0 | 1.53E-03 | 3.74E-04 | 4.37E-03 |
| H2O | 1.64E-02 | 0 | 0 | 0 | 1.02E-02 | 2.49E-03 | 2.91E-02 |
| H2S | 5.73E-04 | 0 | 0 | 0 | 3.57E-04 | 8.69E-05 | 1.02E-03 |
| N2 | 2.99E-04 | 0 | 0 | 0 | 1.86E-04 | 4.53E-05 | 5.30E-04 |
| NH3 | 3.30E-05 | 0 | 0 | 0 | 2.06E-05 | 5.01E-06 | 5.86E-05 |
| CH4 | 1.01E-04 | 0 | 0 | 0 | 6.32E-05 | 1.54E-05 | 1.80E-04 |
| CH3OH | 5.24E-06 | 0 | 0 | 0 | 3.26E-06 | 7.96E-07 | 9.30E-06 |

Table A.12

FEED HEAT EXCHANGER AND KNOCKOUT VESSEL (Gas)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 1 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 0 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 1 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 2 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|--------|---------------|
| CO | 3071 | 85991 | 5.19E-01 |
| CO2 | 810 | 35622 | 2.15E-01 |
| COS | 2 | 105 | 6.33E-04 |
| H2 | 3425 | 6850 | 4.13E-02 |
| H2O | 1947 | 35037 | 2.11E-01 |
| H2S | 36 | 1224 | 7.38E-03 |
| N2 | 23 | 638 | 3.85E-03 |
| NH3 | 4 | 71 | 4.26E-04 |
| CH4 | 14 | 217 | 1.31E-03 |
| CH3OH | 0 | 11 | 6.76E-05 |
| TOTAL FLOW | 9331 | 165766 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 52 | 0 | 0 | 0 | 218 | 26 |

| COMPONENT | EMISSIONS (kg/hr) FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|--------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 1.51E-01 | 0 | 0 | 0 | 9.40E-02 | 2.29E-02 | 2.68E-01 |
| CO2 | 6.26E-02 | 0 | 0 | 0 | 3.90E-02 | 9.50E-03 | 1.11E-01 |
| COS | 1.84E-04 | 0 | 0 | 0 | 1.15E-04 | 2.80E-05 | 3.27E-04 |
| H2 | 1.20E-02 | 0 | 0 | 0 | 7.49E-03 | 1.83E-03 | 2.14E-02 |
| H2O | 6.15E-02 | 0 | 0 | 0 | 3.83E-02 | 9.34E-03 | 1.09E-01 |
| H2S | 2.15E-03 | 0 | 0 | 0 | 1.34E-03 | 3.26E-04 | 3.82E-03 |
| N2 | 1.12E-03 | 0 | 0 | 0 | 6.98E-04 | 1.70E-04 | 1.99E-03 |
| NH3 | 1.24E-04 | 0 | 0 | 0 | 7.71E-05 | 1.88E-05 | 2.20E-04 |
| CH4 | 3.81E-04 | 0 | 0 | 0 | 2.37E-04 | 5.78E-05 | 6.76E-04 |
| CH3OH | 1.97E-05 | 0 | 0 | 0 | 1.22E-05 | 2.99E-06 | 3.49E-05 |

Table A.13

GAS ABSORBER WASH TOWER (gas)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|--------------|---------------|---------------|
| Pumps | 0 | 4673 | 130830 | 4.56E-01 |
| Vertical Vessels | 1 | 1619 | 71245 | 2.48E-01 |
| Horizontal Vessels | 0 | 4 | 210 | 7.31E-04 |
| Storage Tanks | 0 | 5260 | 10520 | 3.66E-02 |
| Pressure Relief Valves | 0 | 3893 | 70074 | 2.44E-01 |
| Heat - Exchangers (Heating Side) | 0 | 72 | 2448 | 8.52E-03 |
| Heat - Exchangers (Cooling Side) | 0 | 46 | 1277 | 4.45E-03 |
| Loading or Unloading Point | 0 | 8 | 141 | 4.91E-04 |
| Flow Transmitters | 1 | 27 | 434 | 1.51E-03 |
| Turbine Meter and Prover Connection | 0 | 1 | 22 | 7.80E-05 |
| TOTAL FLOW | | 15602 | 287201 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 29 | 0 | 0 | 0 | 122 | 15 |

| COMPONENT | EMISSIONS (kg/hr) FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|--------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 7.40E-02 | 0 | 0 | 0 | 4.61E-02 | 1.12E-02 | 1.31E-01 |
| CO2 | 4.03E-02 | 0 | 0 | 0 | 2.51E-02 | 6.11E-03 | 7.15E-02 |
| COS | 1.19E-04 | 0 | 0 | 0 | 7.39E-05 | 1.80E-05 | 2.11E-04 |
| H2 | 5.95E-03 | 0 | 0 | 0 | 3.70E-03 | 9.03E-04 | 1.06E-02 |
| H2O | 3.96E-02 | 0 | 0 | 0 | 2.47E-02 | 6.01E-03 | 7.03E-02 |
| H2S | 1.38E-03 | 0 | 0 | 0 | 8.62E-04 | 2.10E-04 | 2.46E-03 |
| N2 | 7.22E-04 | 0 | 0 | 0 | 4.49E-04 | 1.10E-04 | 1.28E-03 |
| NH3 | 7.98E-05 | 0 | 0 | 0 | 4.97E-05 | 1.21E-05 | 1.42E-04 |
| CH4 | 2.45E-04 | 0 | 0 | 0 | 1.53E-04 | 3.72E-05 | 4.35E-04 |
| CH3OH | 1.27E-05 | 0 | 0 | 0 | 7.88E-06 | 1.92E-06 | 2.25E-05 |

Table A.14

GAS ABSORBER WASH TOWER (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|-----------|-------------|---------------|
| Pumps | 0 | 0 | 0 | 0 |
| Vertical Vessels | 1 | 0 | 0 | 0 |
| Horizontal Vessels | 0 | 0 | 0 | 0 |
| Storage Tanks | 0 | 0 | 0 | 0 |
| Pressure Relief Valves | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Cooling Side) | 0 | 0 | 0 | 0 |
| Loading or Unloading Point | 0 | 0 | 0 | 0 |
| Flow Transmitters | 1 | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 50 | 1600 | 1 |
| TOTAL FLOW | | 50 | 1600 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 29 | 0 | 0 | 0 | 122 | 15 |

| COMPONENT | EMISSIONS (kg/hr) FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COS | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| N2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0.21 | 0 | 0 | 0 | 0.10 | 0.02 | 3.32E-01 |

Table A.15

H2, CO RECLAIMER #1 (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 1 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 1 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 1 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 3 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO | 350 | 9811 | 4.30E-01 |
| CO2 | 270 | 11876 | 5.21E-01 |
| COS | 0 | 0 | 0.00E+00 |
| H2 | 398 | 795 | 3.49E-02 |
| H2O | 0 | 0 | 0.00E+00 |
| H2S | 0 | 0 | 0.00E+00 |
| N2 | 8 | 213 | 9.34E-03 |
| NH3 | 1 | 23 | 1.03E-03 |
| CH4 | 5 | 72 | 3.17E-03 |
| CH3OH | 0 | 0 | 0.00E+00 |
| TOTAL FLOW | 1031 | 22790 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 61 | 0 | 0 | 1 | 256 | 31 |

| COMPONENT | EMISSIONS (kg/hr) | | | | | TOTAL EMISSIONS (kg/hr) |
|--------------------|-------------------|---------------|---------------------|--------------------------------|-----------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | |
| CO | 1.86E-01 | 0 | 0 | 4.48E-02 | 9.15E-02 | 3.45E-01 |
| CO2 | 2.26E-01 | 0 | 0 | 5.42E-02 | 1.11E-01 | 4.18E-01 |
| COS | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 | 1.51E-02 | 0 | 0 | 3.63E-03 | 7.42E-03 | 2.80E-02 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 0 | 0 | 0 | 0 | 0 | 0 |
| N2 | 4.04E-03 | 0 | 0 | 9.71E-04 | 1.99E-03 | 7.48E-03 |
| NH3 | 4.46E-04 | 0 | 0 | 1.07E-04 | 2.19E-04 | 8.25E-04 |
| CH4 | 1.37E-03 | 0 | 0 | 3.30E-04 | 6.75E-04 | 2.54E-03 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 |
| Open - Ended Lines | | | | | | |
| | | | | | | |

Table A.16

H2, CO RECLAIMER #2 (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|--------------|----------|-------|---------------|
| Pumps | 0 | CO | 350 | 9811 | 4.14E-01 |
| Vertical Vessels | 1 | CO2 | 270 | 11876 | 5.02E-01 |
| Horizontal Vessels | 0 | CO3 | 1 | 70 | 2.96E-03 |
| Storage Tanks | 0 | H2 | 398 | 795 | 3.36E-02 |
| Pressure Relief Valves | 1 | H2O | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | H2S | 24 | 816 | 3.45E-02 |
| Heat - Exchangers (Cooling Side) | 1 | N2 | 8 | 213 | 8.99E-03 |
| Loading or Unloading Point | 0 | NH3 | 1 | 23 | 9.91E-04 |
| Flow Transmitters | 3 | CH4 | 5 | 72 | 3.05E-03 |
| Turbine Meter and Prover Connection | 0 | CH3OH | 0 | 0 | 0 |
| | | TOTAL FLOW | 1056 | 23677 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 61 | 0 | 0 | 1 | 256 | 31 |

| COMPONENT | EMISSIONS (kg/hr) | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 1.79E-01 | 0 | 0 | 4.31E-02 | 8.81E-02 | 2.15E-02 | 3.32E-01 |
| CO2 | 2.17E-01 | 0 | 0 | 5.22E-02 | 1.07E-01 | 2.60E-02 | 4.02E-01 |
| CO3 | 1.28E-03 | 0 | 0 | 3.08E-04 | 6.30E-04 | 1.54E-04 | 2.38E-03 |
| H2 | 1.45E-02 | 0 | 0 | 3.49E-03 | 7.14E-03 | 1.74E-03 | 2.69E-02 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 1.49E-02 | 0 | 0 | 3.58E-03 | 7.33E-03 | 1.79E-03 | 2.76E-02 |
| N2 | 3.89E-03 | 0 | 0 | 9.35E-04 | 1.91E-03 | 4.66E-04 | 7.20E-03 |
| NH3 | 4.29E-04 | 0 | 0 | 1.03E-04 | 2.11E-04 | 5.14E-05 | 7.94E-04 |
| CH4 | 1.32E-03 | 0 | 0 | 3.18E-04 | 6.50E-04 | 1.58E-04 | 2.45E-03 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.17

H₂, CO RECYCLE STREAM (gas)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessies | 0 |
| Horizontal Vessies | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 0 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 1 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 5 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------------|-------------|--------------|---------------|
| CO | 701 | 19622 | 9.25E-01 |
| CO ₂ | 0 | 0 | 0 |
| COS | 0 | 0 | 0 |
| H ₂ | 795 | 1590 | 7.50E-02 |
| H ₂ O | 0 | 0 | 0 |
| H ₂ S | 0 | 0 | 0 |
| N ₂ | 0 | 0 | 0 |
| NH ₃ | 0 | 0 | 0 |
| CH ₄ | 0 | 0 | 0 |
| CH ₃ OH | 0 | 0 | 0 |
| TOTAL FLOW | 1496 | 21212 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0.228 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 47 | 0 | 1 | 0 | 197 | 24 |

| COMPONENT | EMISSIONS (kg/hr) FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|--------------------|--------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 2.43E-01 | 0 | 2.11E-01 | 0 | 1.52E-01 | 3.70E-02 | 6.43E-01 |
| CO ₂ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COS | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H ₂ | 1.97E-02 | 0 | 1.71E-02 | 0 | 1.23E-02 | 2.99E-03 | 5.21E-02 |
| H ₂ O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H ₂ S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| N ₂ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH ₃ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH ₄ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH ₃ OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.18

PURIFIED GAS STREAM
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 0 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 0 |
| Heat - Exchangers (Heating Side) | 2 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 2 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO | 2336 | 65416 | 9.26E-01 |
| CO2 | 0 | 0 | 0 |
| COS | 0 | 0 | 0 |
| H2 | 2630 | 5260 | 7.44E-02 |
| H2O | 0 | 0 | 0 |
| H2S | 0 | 0 | 0 |
| N2 | 0 | 0 | 0 |
| NH3 | 0 | 0 | 0 |
| CH4 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 |
| TOTAL FLOW | 4966 | 70676 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 28 | 0 | 0 | 0 | 118 | 14 |

| COMPONENT | EMISSIONS (kg/hr) FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 1.45E-01 | 0 | 0 | 0 | 9.03E-02 | 2.20E-02 | 2.58E-01 |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COS | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 | 1.17E-02 | 0 | 0 | 0 | 7.26E-03 | 1.77E-03 | 2.07E-02 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| N2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.19

UNSHIFTED GAS METHANOL - WATER SEPARATION TOWER (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 1 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 1 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 3 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO | 0 | 0 | 0 |
| CO2 | 540 | 23747 | 2.41E-01 |
| COS | 1 | 70 | 7.12E-04 |
| H2 | 0 | 0 | 0 |
| H2O | 3900 | 70200 | 7.12E-01 |
| H2S | 24 | 816 | 8.27E-03 |
| N2 | 15 | 426 | 4.31E-03 |
| NH3 | 3 | 47 | 4.77E-04 |
| CH4 | 9 | 144 | 1.46E-03 |
| CH3OH | 100 | 3214 | 3.26E-02 |
| TOTAL FLOW | 4592 | 98665 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 44 | 0 | 0 | 1 | 185 | 22 |

| COMPONENT | EMISSIONS (kg/hr) FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 | 7.52E-02 | 0 | 0 | 2.50E-02 | 3.69E-02 | 9.00E-03 | 1.46E-01 |
| COS | 2.22E-04 | 0 | 0 | 7.40E-05 | 1.09E-04 | 2.66E-05 | 4.32E-04 |
| H2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 2.22E-01 | 0 | 0 | 7.40E-02 | 1.09E-01 | 2.66E-02 | 4.32E-01 |
| H2S | 2.58E-03 | 0 | 0 | 8.60E-04 | 1.27E-03 | 3.09E-04 | 5.02E-03 |
| N2 | 1.35E-03 | 0 | 0 | 4.49E-04 | 6.62E-04 | 1.61E-04 | 2.62E-03 |
| NH3 | 1.49E-04 | 0 | 0 | 4.96E-05 | 7.32E-05 | 1.79E-05 | 2.90E-04 |
| CH4 | 4.57E-04 | 0 | 0 | 1.52E-04 | 2.25E-04 | 5.48E-05 | 8.89E-04 |
| CH3OH | 1.02E-02 | 0 | 0 | 3.39E-03 | 5.00E-03 | 1.22E-03 | 1.98E-02 |

Table A.20

UNSHIFTED GAS STRIPPING COLUMN (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|------------|--------------|---------------|
| Pumps | 0 | 0 | 0 | 0 |
| Vertical Vessels | 1 | 540 | 23756 | 8.84E-01 |
| Horizontal Vessels | 0 | 0 | 70 | 2.61E-03 |
| Storage Tanks | 0 | 0 | 0 | 0.00E+00 |
| Pressure Relief Valves | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | 24 | 816 | 3.04E-02 |
| Heat - Exchangers (Cooling Side) | 0 | 15 | 426 | 1.58E-02 |
| Loading or Unloading Point | 0 | 3 | 47 | 1.75E-03 |
| Flow Transmitters | 2 | 9 | 145 | 5.39E-03 |
| Turbine Meter and Prover Connection | 0 | 50 | 1600 | 5.96E-02 |
| TOTAL FLOW | 0 | 642 | 26859 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 35 | 0 | 0 | 0 | 147 | 18 |

| COMPONENT | EMISSIONS (kg/hr) | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 | 2.20E-01 | 0 | 0 | 0 | 1.08E-01 | 2.63E-02 | 3.54E-01 |
| COS | 6.49E-04 | 0 | 0 | 0 | 3.19E-04 | 7.78E-05 | 1.05E-03 |
| H2 | 0.00E+00 | 0 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 7.55E-03 | 0 | 0 | 0 | 3.71E-03 | 9.04E-04 | 1.22E-02 |
| N2 | 3.94E-03 | 0 | 0 | 0 | 1.93E-03 | 4.71E-04 | 6.34E-03 |
| NH3 | 4.34E-04 | 0 | 0 | 0 | 2.13E-04 | 5.20E-05 | 6.99E-04 |
| CH4 | 1.34E-03 | 0 | 0 | 0 | 6.57E-04 | 1.60E-04 | 2.16E-03 |
| CH3OH | 1.48E-02 | 0 | 0 | 0 | 7.27E-03 | 1.77E-03 | 2.38E-02 |

Table A.21

UNSHIFTED GAS STRIPPING COLUMN (gas)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|------------|-------------|---------------|
| Pumps | 0 | 0 | 0 | 0 |
| Vertical Vessels | 1 | 0 | 0 | 0 |
| Horizontal Vessels | 0 | 0 | 0 | 0 |
| Storage Tanks | 0 | 0 | 0 | 0 |
| Pressure Relief Valves | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Cooling Side) | 0 | 101 | 2828 | 1 |
| Loading or Unloading Point | 0 | 0 | 0 | 0 |
| Flow Transmitters | 1 | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 0 | 0 | 0 |
| TOTAL FLOW | | 101 | 2828 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 29 | 0 | 0 | 0 | 122 | 15 |

| COMPONENT | EMISSIONS (kg/hr) FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COS | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| N2 | 1.62E-01 | 0 | 0 | 0 | 1.01E-01 | 2.47E-02 | 2.88E-01 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.22

UNSHIFTED METHANOL REGENERATION TOWER (gas feed)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|--------------|----------|-------|---------------|
| Pumps | 0 | CO | 0 | 0 | 0 |
| Vertical Vessels | 1 | CO2 | 270 | 11876 | 9.30E-01 |
| Horizontal Vessels | 0 | COS | 1 | 35 | 2.77E-03 |
| Storage Tanks | 0 | H2 | 0 | 0 | 0 |
| Pressure Relief Valves | 1 | H2O | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | H2S | 12 | 408 | 3.19E-02 |
| Heat - Exchangers (Cooling Side) | 1 | N2 | 8 | 213 | 1.67E-02 |
| Loading or Unloading Point | 0 | NH3 | 1 | 23 | 1.84E-03 |
| Flow Transmitters | 3 | CH4 | 5 | 72 | 5.66E-03 |
| Turbine Meter and Prover Connection | 0 | CH3OH | 5 | 145 | 1.13E-02 |
| | | TOTAL FLOW | 301 | 12772 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 61 | 0 | 0 | 1 | 256 | 31 |

| COMPONENT | EMISSIONS (kg/hr) | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------|---------------|---------------------|--------------------------------|----------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 |
| CO2 | 3.18E-01 | 0 | 0 | 9.67E-02 | 4.82E-02 |
| COS | 9.47E-04 | 0 | 0 | 2.88E-04 | 1.44E-04 |
| H2 | 0 | 0 | 0 | 0 | 0 |
| H2O | 0 | 0 | 0 | 0 | 0 |
| H2S | 1.09E-02 | 0 | 0 | 3.32E-03 | 6.79E-03 |
| N2 | 5.69E-03 | 0 | 0 | 1.73E-03 | 3.54E-04 |
| NH3 | 6.27E-04 | 0 | 0 | 1.91E-04 | 3.91E-04 |
| CH4 | 1.93E-03 | 0 | 0 | 5.89E-04 | 1.20E-03 |
| | | | | | Open - Ended Lines (kg/hr) |
| | | | | | 0 |
| | | | | | 6.60E-01 |
| | | | | | 1.97E-03 |
| | | | | | 0 |
| | | | | | 0 |
| | | | | | 2.27E-02 |
| | | | | | 1.18E-02 |
| | | | | | 1.30E-03 |
| | | | | | 4.02E-03 |

Table A.23

UNSHIFTED METHANOL REGENERATION TOWER (liquid feed)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|----------|-------|---------------|
| Pumps | 1 | 0 | 0 | 0 |
| Vertical Vessels | 1 | 0 | 0 | 0 |
| Horizontal Vessels | 0 | 0 | 0 | 0 |
| Storage Tanks | 0 | 1 | 70 | 2.82E-02 |
| Pressure Relief Valves | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | 24 | 816 | 3.28E-01 |
| Heat - Exchangers (Cooling Side) | 1 | 0 | 0 | 0 |
| Loading or Unloading Point | 0 | 0 | 0 | 0 |
| Flow Transmitters | 3 | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 50 | 1600 | 6.44E-01 |
| TOTAL FLOW | | 75 | 2486 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|--------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0.0494 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 69 | 1 | 0 | 0 | 290 | 35 |

| COMPONENT | EMISSIONS (kg/hr) | | | FROM : | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COS | 1.38E-02 | 1.39E-03 | 0 | 0 | 6.79E-03 | 1.66E-03 | 2.37E-02 |
| H2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 1.61E-01 | 1.62E-02 | 0 | 0 | 7.89E-02 | 1.92E-02 | 2.75E-01 |
| N2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 3.15E-01 | 3.18E-02 | 0 | 0 | 1.55E-01 | 3.77E-02 | 5.40E-01 |

Table A.24

METHANOL RECYCLE STREAM (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|----------|-------|---------------|
| Pumps | 2 | 0 | 0 | 0 |
| Vertical Vessies | 0 | 0 | 0 | 0 |
| Horizontal Vessies | 0 | 0 | 0 | 0 |
| Storage Tanks | 0 | 0 | 0 | 0 |
| Pressure Relief Valves | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 1 | 0 | 0 | 0 |
| Heat - Exchangers (Cooling Side) | 0 | 0 | 0 | 0 |
| Loading or Unloading Point | 0 | 0 | 0 | 0 |
| Flow Transmitters | 4 | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 100 | 3200 | 1 |
| TOTAL FLOW | | 100 | 3200 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|--------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0.0494 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 54 | 2 | 0 | 0 | 227 | 27 |

| COMPONENT | EMISSIONS (kg/hr) FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COS | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| N2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 3.83E-01 | 9.88E-02 | 0 | 0 | 1.88E-01 | 4.59E-02 | 7.16E-01 |

Table A.25

H₂S , COS RICH STREAM (gas)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE UNSHIFTED RECTISOL TRAIN

| EQUIPMENT TYPE | QUANTITY | kg/hr | mass fraction |
|-------------------------------------|----------|------------|---------------|
| Pumps | 0 | 0 | 0 |
| Vertical Vessels | 0 | 3555 | 5.59E-01 |
| Horizontal Vessels | 0 | 210 | 3.30E-02 |
| Storage Tanks | 0 | 0 | 0 |
| Pressure Relief Valves | 0 | 0 | 0 |
| Heat - Exchangers (Heating Side) | 0 | 2448 | 3.85E-01 |
| Heat - Exchangers (Cooling Side) | 0 | 0 | 0 |
| Loading or Unloading Point | 0 | 141 | 2.22E-02 |
| Flow Transmitters | 2 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 6 | 9.56E-04 |
| FLOW SUMMARY | | 165 | 6360 |
| CO | | 0 | |
| COS | | 4 | |
| H ₂ | | 0 | |
| H ₂ O | | 0 | |
| H ₂ S | | 72 | |
| N ₂ | | 0 | |
| NH ₃ | | 8 | |
| CH ₄ | | 0 | |
| CH ₃ OH | | 0 | |
| TOTAL FLOW | | 165 | 6360 |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 12 | 0 | 0 | 0 | 50 | 6 |

| COMPONENT | EMISSIONS (kg/hr) FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|--------------------|--------------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO ₂ | 4.76E-02 | 0 | 0 | 0 | 2.34E-02 | 5.70E-03 | 7.67E-02 |
| COS | 2.81E-03 | 0 | 0 | 0 | 1.38E-03 | 3.37E-04 | 4.53E-03 |
| H ₂ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H ₂ O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H ₂ S | 3.28E-02 | 0 | 0 | 0 | 1.61E-02 | 3.93E-03 | 5.28E-02 |
| N ₂ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH ₃ | 1.89E-03 | 0 | 0 | 0 | 9.28E-04 | 2.26E-04 | 3.04E-03 |
| CH ₄ | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH ₃ OH | 8.14E-05 | 0 | 0 | 0 | 4.00E-05 | 9.75E-06 | 1.31E-04 |

COS HYDROLYSIS PLANT

The flowsheet for the COS hydrolysis along with the information needed for the stream estimations were taken from the Gas Process Handbook '84, Hydrocarbon Processing, April 1984, p. 78.

Table A.26

COS HYDROLYSIS PLANT OVERALL FUGITIVE EMISSIONS

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|--------------------|------------------|---------------|---------------------|--------------------------------|-----------------|--------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open-Ended Lines (kg/hr) | |
| CO | 6.65E-01 | 0 | 0 | 1.93E-01 | 4.14E-01 | 1.01E-01 | 1.37 |
| CO ₂ | 3.74E-01 | 0 | 0 | 1.08E-01 | 2.33E-01 | 5.67E-02 | 0.77 |
| COS | 2.21E-02 | 0 | 0 | 6.40E-03 | 1.37E-02 | 3.50E-03 | 0.05 |
| H ₂ | 7.36E-04 | 0 | 0 | 2.13E-04 | 4.58E-04 | 1.12E-04 | 0 |
| H ₂ S | 2.57E-01 | 0 | 0 | 7.47E-02 | 1.60E-01 | 3.91E-02 | 0.53 |
| N ₂ | 3.65E-02 | 0 | 0 | 1.06E-02 | 2.27E-02 | 5.54E-03 | 0.08 |
| NH ₃ | 1.48E-02 | 0 | 0 | 4.30E-03 | 9.23E-03 | 2.25E-03 | 0.03 |
| CH ₃ OH | 6.39E-04 | 0 | 0 | 1.85E-04 | 3.98E-04 | 9.70E-05 | 0 |
| O ₂ | 1.11E-02 | 0 | 0 | 3.22E-03 | 6.91E-03 | 1.68E-03 | 0.02 |

The following tables (A.27-A.29) are the actual estimations made for the COS Hydrolysis Plant in Base Case 1.

Table A.27

ESTIMATION OF FUGITIVE EMISSIONS FOR THE COS HYDROLYSIS PLANT

| COS HYDROLYSIS | |
|----------------|-------------------------------------|
| QUANTITY | EQUIPMENT TYPE |
| 0 | Pumps |
| 1 | Vertical Vessles |
| 0 | Horizontal Vessles |
| 0 | Storage Tanks |
| 1 | Pressure Relief Valves |
| 1 | Heat - Exchangers (Heating Side) |
| 0 | Heat - Exchangers (Cooling Side) |
| 0 | Loading or Unloading Point |
| 5 | Flow Transmitters |
| 0 | Turbine Meter and Prover Connection |

| QUANTITY | ACTUAL EQUIPMENT |
|----------|------------------------|
| 1 | Preheater |
| 1 | Hydrolysis Reactor |
| 1 | Pressure Relief Valves |
| 5 | Flow Transmitters |

| QUANTITY | ESTIMATED EQUIPMENT |
|----------|---------------------|
| 64 | Valves |
| 32 | Open - Ended Lines |
| 269 | Flanges |

| QUANTITY | EQUIPMENT WITH FUGITIVES |
|----------|--------------------------|
| 64 | Valves |
| 0 | Pumps |
| 0 | Compressors |
| 1 | Pressure Relief Valves |
| 269 | Flanges |
| 32 | Open - Ended Lines |

Table A.28

MIXER - PREHEATER
ESTIMATION OF FUGITIVE EMISSIONS FOR COS HYDROLYSIS

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|----------|-------|---------------|
| Pumps | 0 | 3.5 | 98 | 9.28E-01 |
| Vertical Vessels | 0 | 81 | 3555 | 5.21E-01 |
| Horizontal Vessels | 0 | 4 | 210 | 3.08E-02 |
| Storage Tanks | 0 | 4 | 7 | 1.03E-03 |
| Pressure Relief Valves | 0 | 72 | 2448 | 3.59E-01 |
| Heat - Exchangers (Heating Side) | 1 | 12 | 347 | 5.09E-02 |
| Heat - Exchangers (Cooling Side) | 0 | 8 | 141 | 2.07E-02 |
| Loading or Unloading Point | 0 | 0 | 6 | 8.91E-04 |
| Flow Transmitters | 3 | 3 | 106 | 1.55E-02 |
| Turbine Meter and Prover Connection | 0 | 184 | 6820 | |
| TOTAL FLOW | | | | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 26 | 0 | 0 | 0 | 109 | 13 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 1.35E-01 | 0 | 0 | 0 | 8.41E-02 | 2.05E-02 | 2.40E-01 |
| CO2 | 7.59E-02 | 0 | 0 | 0 | 4.72E-02 | 1.15E-02 | 1.35E-01 |
| COS | 4.48E-03 | 0 | 0 | 0 | 2.79E-03 | 6.80E-04 | 7.95E-03 |
| H2 | 1.49E-04 | 0 | 0 | 0 | 9.30E-05 | 2.27E-05 | 2.65E-04 |
| H2S | 5.23E-02 | 0 | 0 | 0 | 3.25E-02 | 7.93E-03 | 9.27E-02 |
| N2 | 7.41E-03 | 0 | 0 | 0 | 4.61E-03 | 1.13E-03 | 1.32E-02 |
| NH3 | 3.01E-03 | 0 | 0 | 0 | 1.88E-03 | 4.57E-04 | 5.34E-03 |
| CH3OH | 1.30E-04 | 0 | 0 | 0 | 8.08E-05 | 1.97E-05 | 2.30E-04 |
| O2 | 2.25E-03 | 0 | 0 | 0 | 1.40E-03 | 3.42E-04 | 4.00E-03 |

Table A.29

HYDROGENATION / HYDROLYSIS REACTOR
ESTIMATION OF FUGITIVE EMISSIONS FOR COS HYDROLYSIS

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|----------|-------|---------------|
| Pumps | 0 | 0 | 0 | 0 |
| Vertical Vessels | 1 | 87 | 3846 | 5.57E-01 |
| Horizontal Vessels | 0 | 0 | 0 | 0 |
| Storage Tanks | 0 | 0 | 0 | 0 |
| Pressure Relief Valves | 1 | 76 | 2567 | 3.72E-01 |
| Heat - Exchangers (Heating Side) | 0 | 12 | 347 | 5.03E-02 |
| Heat - Exchangers (Cooling Side) | 0 | 8 | 141 | 2.04E-02 |
| Loading or Unloading Point | 0 | 0 | 6 | 8.80E-04 |
| Flow Transmitters | 2 | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 184 | 6907 | |
| TOTAL FLOW | | | | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 38 | 0 | 0 | 1 | 160 | 19 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO | 1.97E-01 | 0 | 0 | 9.65E-02 | 1.23E-01 | 3.00E-02 | 4.47E-01 |
| CO2 | 1.11E-01 | 0 | 0 | 5.42E-02 | 6.91E-02 | 1.68E-02 | 2.51E-01 |
| COS | 6.55E-03 | 0 | 0 | 3.20E-03 | 4.08E-03 | 9.95E-04 | 1.48E-02 |
| H2 | 2.18E-04 | 0 | 0 | 1.07E-04 | 1.36E-04 | 3.32E-05 | 4.94E-04 |
| H2S | 7.64E-02 | 0 | 0 | 3.73E-02 | 4.75E-02 | 1.16E-02 | 1.73E-01 |
| N2 | 1.08E-02 | 0 | 0 | 5.29E-03 | 6.74E-03 | 1.64E-03 | 2.45E-02 |
| NH3 | 4.40E-03 | 0 | 0 | 2.15E-03 | 2.74E-03 | 6.68E-04 | 9.96E-03 |
| CH3OH | 1.90E-04 | 0 | 0 | 9.27E-05 | 1.18E-04 | 2.88E-05 | 4.29E-04 |
| O2 | 3.29E-03 | 0 | 0 | 1.61E-03 | 2.05E-03 | 5.00E-04 | 7.46E-03 |

CLAUS PLANT

The flowsheet for the Claus Plant was taken from Houston. The information needed for the flow estimations was taken from Houston as well as the Gas Process Handbook '84, Hydrocarbon Processing, April 1984, p. 74.

Table A.30

CLAUS PLANT OVERALL FUGITIVE EMISSIONS
FOR TWO TRAINS

| COMPONENT | EMISSIONS FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|--------------------|-------------------|------------------|------------------------|---|--------------------|------------------------------------|-------------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open- Ended Lines (kg/hr) | |
| CO ₂ | 1.33E+ 00 | 0 | 0 | 2.93E-01 | 8.25E-01 | 2.01E-01 | 2.65 |
| H ₂ O | 2.33E-01 | 0 | 0 | 6.51E-02 | 1.45E-01 | 3.54E-02 | 0.48 |
| H ₂ S | 4.07E-01 | 0 | 0 | 6.44E-02 | 2.53E-01 | 6.18E-02 | 0.79 |
| N ₂ | 1.12E+ 00 | 0 | 0 | 3.23E-01 | 6.97E-01 | 1.70E-01 | 2.31 |
| CH ₃ OH | 2.10E-03 | 0 | 0 | 4.65E-04 | 1.31E-03 | 3.19E-04 | 0.00 |
| S | 3.39E-03 | 0 | 0 | 2.77E-03 | 2.11E-02 | 5.15E-03 | 0.06 |
| SO ₂ | 2.11E-01 | 0 | 0 | 7.21E-02 | 1.32E-01 | 3.21E-02 | 0.45 |
| O ₂ | 0 | 0 | 0 | 0 | 0 | 0 | 0.00 |
| NH ₃ | 4.87E-02 | 0 | 0 | 1.08E-02 | 3.03E-02 | 7.39E-03 | 0.10 |

The following tables (A.31-A.37) are the actual estimations made for the Claus Plant in Base Case 1.

Table A.31

ESTIMATION OF FUGITIVE EMISSIONS FOR THE CLAUS PLANT

| CLAUS PLANT | |
|-------------|-------------------------------------|
| QUANTITY | EQUIPMENT TYPE |
| 0 | Pumps |
| 6 | Vertical Vessles |
| 6 | Horizontal Vessles |
| 0 | Storage Tanks |
| 8 | Pressure Relief Valves |
| 8 | Heat - Exchangers (Heating Side) |
| 0 | Heat - Exchangers (Cooling Side) |
| 0 | Loading or Unloading Point |
| 28 | Flow Transmitters |
| 0 | Turbine Meter and Prover Connection |

| QUANTITY | ACTUAL EQUIPMENT |
|----------|-------------------------------|
| 2 | Separators (Knockout Drums) |
| 2 | Thermal Incinerators |
| 2 | Boilers |
| 6 | Reheaters |
| 2 | 3 - Staged Catalytic Reactors |
| 2 | Sulfur Condensers |
| 8 | Pressure Relief Valves |
| 28 | Flow Transmitters |

| QUANTITY | ESTIMATED EQUIPMENT |
|----------|---------------------|
| 520 | Valves |
| 260 | Open - Ended Lines |
| 2184 | Flanges |

| QUANTITY | EQUIPMENT WITH FUGITIVES |
|----------|--------------------------|
| 520 | Valves |
| 0 | Pumps |
| 0 | Compressors |
| 8 | Pressure Relief Valves |
| 2184 | Flanges |
| 260 | Open - Ended Lines |

Table A.32

SEPARATOR
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE CLAUSTRATION TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|----------|-------|---------------|
| Pumps | 0 | 87 | 3846 | 5.57E-01 |
| Vertical Vessels | 0 | 0 | 0 | 0 |
| Horizontal Vessels | 1 | 76 | 2567 | 3.72E-01 |
| Storage Tanks | 0 | 12 | 347 | 5.03E-02 |
| Pressure Relief Valves | 0 | 0 | 6 | 8.80E-04 |
| Heat - Exchangers (Heating Side) | 0 | 0 | 0 | 0 |
| Heat - Exchangers (Cooling Side) | 0 | 0 | 0 | 0 |
| Loading or Unloading Point | 0 | 0 | 0 | 0 |
| Flow Transmitters | 5 | 8 | 141 | 2.04E-02 |
| Turbine Meter and Prover Connection | 0 | 184 | 6907 | |
| TOTAL FLOW | | | | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 51 | 0 | 0 | 0 | 214 | 26 |

| COMPONENT | EMISSIONS FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-----------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 1.59E-01 | 0 | 0 | 0 | 9.90E-02 | 2.41E-02 | 2.82E-01 |
| H2O | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 1.06E-01 | 0 | 0 | 0 | 6.61E-02 | 1.61E-02 | 1.88E-01 |
| N2 | 1.44E-02 | 0 | 0 | 0 | 8.94E-03 | 2.18E-03 | 2.55E-02 |
| CH3OH | 2.51E-04 | 0 | 0 | 0 | 1.56E-04 | 3.82E-05 | 4.46E-04 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NH3 | 5.83E-03 | 0 | 0 | 0 | 3.63E-03 | 8.86E-04 | 1.04E-02 |

Table A.33

THERMAL INCINERATOR AND BOILER
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE CLAUS TRAIN

| EQUIPMENT TYPE | QUANTITY | kg/hr | kgmol/hr | mass fraction |
|-------------------------------------|----------|-------|----------|---------------|
| Pumps | 0 | 1282 | 29 | 2.81E-01 |
| Vertical Vessels | 0 | 222 | 12 | 4.86E-02 |
| Horizontal Vessels | 1 | 385 | 11 | 8.43E-02 |
| Storage Tanks | 0 | 1883 | 67 | 4.12E-01 |
| Pressure Relief Valves | 1 | 2 | 0 | 4.49E-04 |
| Heat - Exchangers (Heating Side) | 0 | 61 | 2 | 1.33E-02 |
| Heat - Exchangers (Cooling Side) | 1 | 685 | 11 | 1.50E-01 |
| Loading or Unloading Point | 0 | 0 | 0 | 0.00E+00 |
| Flow Transmitters | 0 | 47 | 3 | 1.03E-02 |
| Turbine Meter and Prover Connection | 0 | 4566 | 135 | |
| TOTAL FLOW | | | | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 41 | 0 | 0 | 1 | 172 | 21 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 6.45E-02 | 0 | 0 | 2.92E-02 | 4.01E-02 | 9.78E-03 | 1.44E-01 |
| H2O | 1.12E-02 | 0 | 0 | 5.06E-03 | 6.95E-03 | 1.69E-03 | 2.49E-02 |
| H2S | 1.94E-02 | 0 | 0 | 8.77E-03 | 1.20E-02 | 2.94E-03 | 4.31E-02 |
| N2 | 9.47E-02 | 0 | 0 | 4.29E-02 | 5.89E-02 | 1.44E-02 | 2.11E-01 |
| CH3OH | 1.03E-04 | 0 | 0 | 4.66E-05 | 6.41E-05 | 1.56E-05 | 2.29E-04 |
| S | 3.06E-03 | 0 | 0 | 1.38E-03 | 1.90E-03 | 4.64E-04 | 6.81E-03 |
| SO2 | 3.44E-02 | 0 | 0 | 1.56E-02 | 2.14E-02 | 5.23E-03 | 7.67E-02 |
| O2 | 0.00E+00 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| NH3 | 2.37E-03 | 0 | 0 | 1.07E-03 | 1.47E-03 | 3.59E-04 | 5.27E-03 |

Table A.34

FIRST REHEATER AND FIRST REACTOR STAGE
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE CLAUS TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 1 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 1 |
| Heat - Exchangers (Heating Side) | 1 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 3 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO2 | 44 | 1923 | 3.40E-01 |
| H2O | 12 | 222 | 3.92E-02 |
| H2S | 24 | 813 | 1.44E-01 |
| N2 | 69 | 1940 | 3.43E-01 |
| CH3OH | 0 | 3 | 5.37E-04 |
| S | 0 | 0 | 0 |
| SO2 | 11 | 685 | 1.21E-01 |
| O2 | 0 | 0 | 0.00E+00 |
| NH3 | 4 | 71 | 1.25E-02 |
| TOTAL FLOW | 164 | 5656 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 52 | 0 | 0 | 1 | 218 | 26 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 9.90E-02 | 0 | 0 | 3.54E-02 | 6.16E-02 | 1.50E-02 | 2.11E-01 |
| H2O | 1.14E-02 | 0 | 0 | 4.08E-03 | 7.11E-03 | 1.73E-03 | 2.44E-02 |
| H2S | 4.18E-02 | 0 | 0 | 1.49E-02 | 2.60E-02 | 6.35E-03 | 8.92E-02 |
| N2 | 9.99E-02 | 0 | 0 | 3.57E-02 | 6.22E-02 | 1.52E-02 | 2.13E-01 |
| CH3OH | 1.57E-04 | 0 | 0 | 5.59E-05 | 9.74E-05 | 2.38E-05 | 3.34E-04 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SO2 | 3.53E-02 | 0 | 0 | 1.26E-02 | 2.19E-02 | 5.35E-03 | 7.51E-02 |
| O2 | 0.00E+00 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| NH3 | 3.63E-03 | 0 | 0 | 1.30E-03 | 2.26E-03 | 5.51E-04 | 7.74E-03 |

Table A.35

SECOND REHEATER AND SECOND REACTOR STAGE
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE CLAUSTRAIN

| EQUIPMENT TYPE | QUANTITY | FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|--------------|----------|-------|---------------|
| Pumps | 0 | CO2 | 44 | 1923 | 3.93E-01 |
| Vertical Vessels | 1 | H2O | 28 | 509 | 1.04E-01 |
| Horizontal Vessels | 0 | H2S | 8 | 271 | 5.55E-02 |
| Storage Tanks | 0 | N2 | 69 | 1940 | 3.97E-01 |
| Pressure Relief Valves | 1 | CH3OH | 0 | 3 | 6.21E-04 |
| Heat - Exchangers (Heating Side) | 1 | S | 0 | 0 | 0 |
| Heat - Exchangers (Cooling Side) | 0 | SO2 | 3 | 175 | 3.58E-02 |
| Loading or Unloading Point | 0 | O2 | 0 | 0 | 0.00E+00 |
| Flow Transmitters | 2 | NH3 | 4 | 71 | 1.44E-02 |
| Turbine Meter and Prover Connection | 0 | TOTAL FLOW | 156 | 4893 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 46 | 0 | 0 | 1 | 193 | 23 |

| COMPONENT | EMISSIONS FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-----------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 1.01E-01 | 0 | 0 | 4.09E-02 | 6.30E-02 | 1.54E-02 | 2.20E-01 |
| H2O | 2.68E-02 | 0 | 0 | 1.08E-02 | 1.67E-02 | 4.07E-03 | 5.84E-02 |
| H2S | 1.43E-02 | 0 | 0 | 5.77E-03 | 8.89E-03 | 2.17E-03 | 3.11E-02 |
| N2 | 1.02E-01 | 0 | 0 | 4.12E-02 | 6.36E-02 | 1.55E-02 | 2.23E-01 |
| CH3OH | 1.60E-04 | 0 | 0 | 6.46E-05 | 9.96E-05 | 2.43E-05 | 3.49E-04 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SO2 | 9.23E-03 | 0 | 0 | 3.73E-03 | 5.75E-03 | 1.40E-03 | 2.01E-02 |
| O2 | 0.00E+00 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| NH3 | 3.71E-03 | 0 | 0 | 1.50E-03 | 2.31E-03 | 5.64E-04 | 8.09E-03 |

Table A.36

THIRD REHEATER AND REACTOR STAGE
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE CLAUSTRATION TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 1 |
| Horizontal Vessels | 1 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 1 |
| Heat - Exchangers (Heating Side) | 1 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 2 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO2 | 44 | 1923 | 3.97E-01 |
| H2O | 33 | 585 | 1.21E-01 |
| H2S | 4 | 128 | 2.63E-02 |
| N2 | 69 | 1940 | 4.01E-01 |
| CH3OH | 0 | 3 | 6.28E-04 |
| S | 0 | 0 | 0 |
| SO2 | 3 | 192 | 3.97E-02 |
| O2 | 0 | 0 | 0.00E+00 |
| NH3 | 4 | 71 | 1.46E-02 |
| TOTAL FLOW | 156 | 4841 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 67 | 0 | 0 | 1 | 281 | 34 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 1.49E-01 | 0 | 0 | 4.13E-02 | 9.28E-02 | 2.26E-02 | 3.06E-01 |
| H2O | 4.53E-02 | 0 | 0 | 1.26E-02 | 2.82E-02 | 6.88E-03 | 9.30E-02 |
| H2S | 9.88E-03 | 0 | 0 | 2.74E-03 | 6.15E-03 | 1.50E-03 | 2.03E-02 |
| N2 | 1.50E-01 | 0 | 0 | 4.17E-02 | 9.36E-02 | 2.28E-02 | 3.09E-01 |
| CH3OH | 2.36E-04 | 0 | 0 | 6.53E-05 | 1.47E-04 | 3.58E-05 | 4.83E-04 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SO2 | 1.49E-02 | 0 | 0 | 4.12E-03 | 9.26E-03 | 2.26E-03 | 3.05E-02 |
| O2 | 0.00E+00 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| NH3 | 5.47E-03 | 0 | 0 | 1.52E-03 | 3.40E-03 | 8.30E-04 | 1.12E-02 |

Table A.37

SULFUR CONDENSER
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE CLAUS TRAIN

| EQUIPMENT TYPE | QUANTITY | kg/hr | kgmol/hr | mass fraction |
|-------------------------------------|----------|-------|----------|---------------|
| Pumps | 0 | 7050 | 160 | 3.58E-01 |
| Vertical Vessels | 0 | 1714 | 95 | 8.71E-02 |
| Horizontal Vessels | 1 | 939 | 28 | 4.77E-02 |
| Storage Tanks | 0 | 7704 | 275 | 3.91E-01 |
| Pressure Relief Valves | 0 | 11 | 0 | 5.67E-04 |
| Heat - Exchangers (Heating Side) | 0 | 1086 | 34 | 5.52E-02 |
| Heat - Exchangers (Cooling Side) | 0 | 924 | 14 | 4.69E-02 |
| Loading or Unloading Point | 0 | 0 | 0 | 0.00E+00 |
| Flow Transmitters | 4 | 259 | 15 | 1.31E-02 |
| Turbine Meter and Prover Connection | 0 | 19687 | 622 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 45 | 0 | 0 | 0 | 189 | 23 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 9.02E-02 | 0 | 0 | 0 | 5.62E-02 | 1.37E-02 | 1.60E-01 |
| H2O | 2.19E-02 | 0 | 0 | 0 | 1.37E-02 | 3.33E-03 | 3.89E-02 |
| H2S | 1.20E-02 | 0 | 0 | 0 | 7.48E-03 | 1.82E-03 | 2.13E-02 |
| N2 | 9.86E-02 | 0 | 0 | 0 | 6.14E-02 | 1.50E-02 | 1.75E-01 |
| CH3OH | 1.43E-04 | 0 | 0 | 0 | 8.90E-05 | 2.17E-05 | 2.54E-04 |
| S | 1.39E-02 | 0 | 0 | 0 | 8.65E-03 | 2.11E-03 | 2.47E-02 |
| SO2 | 1.18E-02 | 0 | 0 | 0 | 7.36E-03 | 1.80E-03 | 2.10E-02 |
| O2 | 0.00E+00 | 0 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| NH3 | 3.31E-03 | 0 | 0 | 0 | 2.06E-03 | 5.03E-04 | 5.88E-03 |

BEAVON PLANT

The flowsheet for the Beavon Plant along with the information needed for the stream estimations were taken from the Gas Process Handbook '84, Hydrocarbon Processing, April 1984, p. 88.

Table A.38

BEAVON PLANT OVERALL FUGITIVE EMISSIONS

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|--------------------|-------------------|------------------|------------------------|---|--------------------|------------------------------------|-------------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open- Ended Lines (kg/hr) | |
| CO ₂ | 9.91E-01 | 8.12E-02 | 0 | 0 | 5.53E-01 | 1.35E-01 | 1.76 |
| O ₂ | 3.77E-02 | 0 | 0 | 1.00E-02 | 1.85E-02 | 4.51E-03 | 0.07 |
| S | 1.46E-01 | 0 | 0 | 2.56E-02 | 7.17E-02 | 1.75E-02 | 0.26 |
| H ₂ O | 2.61E+ 00 | 2.58E-02 | 0 | 4.06E-01 | 1.30E+ 00 | 3.17E-01 | 4.66 |
| H ₂ S | 2.65E-01 | 5.39E-03 | 0 | 4.00E-02 | 1.35E-01 | 3.29E-02 | 0.48 |
| N ₂ | 1.86E+ 00 | 8.20E-02 | 0 | 1.42E-01 | 9.82E-01 | 2.39E-01 | 3.31 |
| NH ₃ | 3.64E-02 | 2.98E-03 | 0 | 0 | 2.03E-02 | 4.95E-03 | 0.06 |
| CH ₃ OH | 1.57E-03 | 1.28E-04 | 0 | 0 | 8.75E-04 | 2.13E-04 | 0.00 |

The following tables (A.39-A.48) are the actual estimations made for the Beavon Plant in Base Case 1.

Table A.39

ESTIMATION OF FUGITIVE EMISSIONS FOR THE BEAVON PLANT

| BEAVON PLANT | |
|--------------|-------------------------------------|
| QUANTITY | EQUIPMENT TYPE |
| 4 | Pumps |
| 16 | Vertical Vessles |
| 6 | Horizontal Vessles |
| 2 | Storage Tanks |
| 6 | Pressure Relief Valves |
| 2 | Heat - Exchangers (Heating Side) |
| 2 | Heat - Exchangers (Cooling Side) |
| 0 | Loading or Unloading Point |
| 42 | Flow Transmitters |
| 0 | Turbine Meter and Prover Connection |

| QUANTITY | ACTUAL EQUIPMENT |
|----------|---------------------------------|
| 2 | Preheater |
| 2 | Hydrolysis Reactor |
| 4 | Boilers |
| 4 | Pumps |
| 2 | Desuperheater Contact Condenser |
| 2 | Venturi Scrubber-Stripper |
| 8 | Pressure Relief Valves |
| 4 | Oxidizer Tanks |
| 2 | Slurry Tank |
| 2 | Balance Tank |
| 2 | Separation Wash and Reslurry |
| 2 | Sulfur Collector Drum |
| 46 | Flow Transmitters |

| QUANTITY | ESTIMATED EQUIPMENT |
|----------|---------------------|
| 442 | Valves |
| 221 | Open - Ended Lines |
| 1856 | Flanges |

| QUANTITY | EQUIPMENT WITH FUGITIVES |
|----------|--------------------------|
| 442 | Valves |
| 4 | Pumps |
| 0 | Compressors |
| 8 | Pressure Relief Valves |
| 1856 | Flanges |
| 221 | Open - Ended Lines |

Table A.40

FEED COOLER
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAYON TRAIN

| EQUIPMENT TYPE | QUANTITY | kg/hr | mass fraction |
|-------------------------------------|----------|-------|---------------|
| Pumps | 0 | 1923 | 4.11E-01 |
| Vertical Vessels | 0 | 0 | 0.00E+00 |
| Horizontal Vessels | 0 | 0 | 0 |
| Storage Tanks | 0 | 0 | 0 |
| Pressure Relief Valves | 0 | 34 | 1.31E-01 |
| Heat - Exchangers (Heating Side) | 0 | 128 | 2.73E-02 |
| Heat - Exchangers (Cooling Side) | 1 | 69 | 4.15E-01 |
| Loading or Unloading Point | 0 | 4 | 1.51E-02 |
| Flow Transmitters | 2 | 3 | 6.50E-04 |
| Turbine Meter and Prover Connection | 0 | 4677 | |
| FLOW SUMMARY | | | |
| CO2 | | 44 | |
| O2 | | 0 | |
| S | | 0 | |
| H2O | | 34 | |
| H2S | | 4 | |
| N2 | | 69 | |
| NH3 | | 4 | |
| CH3OH | | 0 | |
| TOTAL FLOW | | 155 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 29 | 0 | 0 | 0 | 122 | 15 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 6.88E-02 | 0 | 0 | 0 | 4.16E-02 | 1.01E-02 | 1.18E-01 |
| O2 | 0.00E+00 | 0 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 2.12E-02 | 0 | 0 | 0 | 1.32E-02 | 3.22E-03 | 3.77E-02 |
| H2S | 4.43E-03 | 0 | 0 | 0 | 2.76E-03 | 6.72E-04 | 7.66E-03 |
| N2 | 6.74E-02 | 0 | 0 | 0 | 4.20E-02 | 1.02E-02 | 1.20E-01 |
| NH3 | 2.45E-03 | 0 | 0 | 0 | 1.53E-03 | 3.72E-04 | 4.35E-03 |
| CH3OH | 1.08E-04 | 0 | 0 | 0 | 6.57E-05 | 1.60E-05 | 1.87E-04 |

Table A.41

DESUPERHEATER CONTACT CONDENSER (liquid lines)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 2 |
| Vertical Vessels | 1 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 0 |
| Heat - Exchangers (Heating Side) | 1 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 5 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO2 | 44 | 1823 | 4.11E-01 |
| O2 | 0 | 0 | 0.00E+00 |
| S | 0 | 0 | 0 |
| H2O | 34 | 611 | 1.31E-01 |
| H2S | 4 | 128 | 2.73E-02 |
| N2 | 69 | 1942 | 4.15E-01 |
| NH3 | 4 | 71 | 1.51E-02 |
| CH3OH | 0 | 3 | 6.50E-04 |
| TOTAL FLOW | 155 | 4677 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|--------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0.0484 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 83 | 2 | 0 | 0 | 349 | 42 |

| COMPONENT | EMISSIONS FROM: | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|-----------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 2.42E-01 | 4.06E-02 | 0 | 0 | 1.19E-01 | 2.90E-02 | 4.31E-01 |
| O2 | 0.00E+00 | 0.00E+00 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 7.70E-02 | 1.29E-02 | 0 | 0 | 3.78E-02 | 9.22E-03 | 1.37E-01 |
| H2S | 1.61E-02 | 2.89E-03 | 0 | 0 | 7.89E-03 | 1.92E-03 | 2.86E-02 |
| N2 | 2.45E-01 | 4.10E-02 | 0 | 0 | 1.20E-01 | 2.93E-02 | 4.36E-01 |
| NH3 | 8.89E-03 | 1.49E-03 | 0 | 0 | 4.38E-03 | 1.06E-03 | 1.58E-02 |
| CH3OH | 3.83E-04 | 6.42E-05 | 0 | 0 | 1.88E-04 | 4.58E-05 | 6.81E-04 |

Table A.42

DESUPERHEATER CONTACT CONDENSER (vapor lines)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY | kg/hr | mass fraction |
|-------------------------------------|------------|-------|---------------|
| Pumps | 0 | 1923 | 4.11E-01 |
| Vertical Vessels | 1 | 0 | 0.00E+00 |
| Horizontal Vessels | 0 | 0 | 0 |
| Storage Tanks | 0 | 611 | 1.31E-01 |
| Pressure Relief Valves | 0 | 128 | 2.73E-02 |
| Heat - Exchangers (Heating Side) | 0 | 1842 | 4.15E-01 |
| Heat - Exchangers (Cooling Side) | 0 | 71 | 1.51E-02 |
| Loading or Unloading Point | 0 | 3 | 6.50E-04 |
| Flow Transmitters | 2 | 4677 | |
| Turbine Meter and Prover Connection | 0 | | |
| FLOW SUMMARY | | | |
| CO2 | 44 | | |
| O2 | 0 | | |
| S | 0 | | |
| H2O | 34 | | |
| H2S | 4 | | |
| N2 | 69 | | |
| NH3 | 4 | | |
| CH3OH | 0 | | |
| TOTAL FLOW | 155 | | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 36 | 0 | 0 | 0 | 147 | 18 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 8.06E-02 | 0 | 0 | 0 | 5.02E-02 | 1.22E-02 | 1.43E-01 |
| O2 | 0.00E+00 | 0 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 2.56E-02 | 0 | 0 | 0 | 1.58E-02 | 3.89E-03 | 4.54E-02 |
| H2S | 5.34E-03 | 0 | 0 | 0 | 3.33E-03 | 8.11E-04 | 9.48E-03 |
| N2 | 8.14E-02 | 0 | 0 | 0 | 5.07E-02 | 1.24E-02 | 1.44E-01 |
| NH3 | 2.96E-03 | 0 | 0 | 0 | 1.84E-03 | 4.49E-04 | 5.25E-03 |
| CH3OH | 1.27E-04 | 0 | 0 | 0 | 7.93E-05 | 1.93E-05 | 2.28E-04 |

Table A.43

VENTURI SCRUBBER / STRIPPER (vapor line)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|----------|-------|---------------|
| Pumps | 0 | 44 | 1923 | 4.11E-01 |
| Vertical Vessels | 2 | 0 | 0 | 0.00E+00 |
| Horizontal Vessels | 0 | 0 | 0 | 0 |
| Storage Tanks | 0 | 34 | 611 | 1.31E-01 |
| Pressure Relief Valves | 0 | 4 | 128 | 2.73E-02 |
| Heat - Exchangers (Heating Side) | 0 | 69 | 1942 | 4.15E-01 |
| Heat - Exchangers (Cooling Side) | 0 | 4 | 71 | 1.51E-02 |
| Loading or Unloading Point | 0 | 0 | 3 | 6.50E-04 |
| Flow Transmitters | 0 | 155 | 4877 | |
| Turbine Meter and Prover Connection | 0 | | | |
| TOTAL FLOW | | | | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0056 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 46 | 0 | 0 | 0 | 193 | 23 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 1.06E-01 | 0 | 0 | 0 | 6.59E-02 | 1.61E-02 | 1.88E-01 |
| O2 | 0.00E+00 | 0 | 0 | 0 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 3.37E-02 | 0 | 0 | 0 | 2.10E-02 | 5.11E-03 | 6.87E-02 |
| H2S | 7.02E-03 | 0 | 0 | 0 | 4.37E-03 | 1.07E-03 | 1.25E-02 |
| N2 | 1.07E-01 | 0 | 0 | 0 | 6.66E-02 | 1.62E-02 | 1.90E-01 |
| NH3 | 3.89E-03 | 0 | 0 | 0 | 2.42E-03 | 5.90E-04 | 6.89E-03 |
| CH3OH | 1.67E-04 | 0 | 0 | 0 | 1.04E-04 | 2.54E-05 | 2.87E-04 |

Table A.44

VENTURI SCRUBBER / STRIPPER (liquid lines)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 2 |
| Horizontal Vessels | 0 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 0 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 5 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO2 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 |
| S | 0 | 0 | 0 |
| H2O | 20 | 360 | 5.81E-01 |
| H2S | 1 | 34 | 5.49E-02 |
| N2 | 8 | 225 | 3.64E-01 |
| NH3 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 |
| TOTAL FLOW | 29 | 619 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 78 | 0 | 0 | 0 | 319 | 38 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 3.14E-01 | 0 | 0 | 0 | 1.54E-01 | 3.75E-02 | 5.05E-01 |
| H2S | 2.98E-02 | 0 | 0 | 0 | 1.45E-02 | 3.55E-03 | 4.77E-02 |
| N2 | 1.96E-01 | 0 | 0 | 0 | 9.64E-02 | 2.35E-02 | 3.18E-01 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.45

OXIDIZER TANK (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY | kg/hr | mass fraction |
|-------------------------------------|----------|-------------|---------------|
| Pumps | 0 | 0 | 0 |
| Vertical Vessels | 2 | 69 | 4.82E-02 |
| Horizontal Vessels | 0 | 0 | 0 |
| Storage Tanks | 0 | 0 | 0 |
| Pressure Relief Valves | 1 | 54 | 6.81E-01 |
| Heat - Exchangers (Heating Side) | 0 | 5 | 1.13E-01 |
| Heat - Exchangers (Cooling Side) | 0 | 8 | 1.58E-01 |
| Loading or Unloading Point | 0 | 0 | 0 |
| Flow Transmitters | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 1 | 69 | 0 |
| TOTAL FLOW | | 1427 | |

| FLOW SUMMARY | kg/hr | mass fraction |
|-------------------|-----------|---------------|
| CO2 | 0 | 0 |
| O2 | 2 | 4.82E-02 |
| S | 0 | 0 |
| H2O | 54 | 6.81E-01 |
| H2S | 5 | 1.13E-01 |
| N2 | 8 | 1.58E-01 |
| NH3 | 0 | 0 |
| CH3OH | 0 | 0 |
| TOTAL FLOW | 69 | 0 |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0.104 | 0.0083 | 0.0017 |
| QUANTITY | 55 | 0 | 0 | 1 | 231 | 28 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O2 | 1.88E-02 | 0 | 0 | 5.01E-03 | 9.25E-03 | 2.25E-03 | 3.53E-02 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 2.86E-01 | 0 | 0 | 7.08E-02 | 1.30E-01 | 3.18E-02 | 4.99E-01 |
| H2S | 4.42E-02 | 0 | 0 | 1.19E-02 | 2.17E-02 | 5.29E-03 | 6.30E-02 |
| N2 | 6.17E-02 | 0 | 0 | 1.64E-02 | 3.03E-02 | 7.39E-03 | 1.16E-01 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.46

SLURRY TANK AND WASH (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY | kgmol/hr | kg/hr | mass fraction |
|-------------------------------------|----------|-----------|-------------|---------------|
| Pumps | 0 | 0 | 0 | 0 |
| Vertical Vessels | 0 | 0 | 0 | 0 |
| Horizontal Vessels | 1 | 5 | 173 | 1.23E-01 |
| Storage Tanks | 1 | 64 | 971 | 6.92E-01 |
| Pressure Relief Valves | 1 | 1 | 34 | 2.42E-02 |
| Heat - Exchangers (Heating Side) | 0 | 8 | 226 | 1.61E-01 |
| Heat - Exchangers (Cooling Side) | 0 | 0 | 0 | 0 |
| Loading or Unloading Point | 0 | 0 | 0 | 0 |
| Flow Transmitters | 2 | 0 | 0 | 0 |
| Turbine Meter and Prover Connection | 0 | 68 | 1403 | 0 |
| TOTAL FLOW | | 68 | 1403 | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|-------------------|-----------|-------------|---------------|
| CO2 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 |
| S | 5 | 173 | 1.23E-01 |
| H2O | 64 | 971 | 6.92E-01 |
| H2S | 1 | 34 | 2.42E-02 |
| N2 | 8 | 226 | 1.61E-01 |
| NH3 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 |
| TOTAL FLOW | 68 | 1403 | 0 |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 49 | 0 | 0 | 1 | 206 | 26 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| S | 4.28E-02 | 0 | 0 | 1.28E-02 | 2.10E-02 | 5.13E-03 | 8.18E-02 |
| H2O | 2.41E-01 | 0 | 0 | 7.20E-02 | 1.18E-01 | 2.88E-02 | 4.60E-01 |
| H2S | 8.43E-03 | 0 | 0 | 2.52E-03 | 4.14E-03 | 1.01E-03 | 1.61E-02 |
| N2 | 5.59E-02 | 0 | 0 | 1.67E-02 | 2.74E-02 | 6.69E-03 | 1.07E-01 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.47

BALANCE TANK (liquid)
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 0 |
| Horizontal Vessels | 1 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 1 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 1 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO2 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 |
| S | 0 | 0 | 0 |
| H2O | 20 | 360 | 5.81E-01 |
| H2S | 1 | 34 | 5.48E-02 |
| N2 | 8 | 225 | 3.64E-01 |
| NH3 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 |
| TOTAL FLOW | 29 | 619 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0.104 | 0.00083 | 0.0017 |
| QUANTITY | 30 | 0 | 0 | 1 | 128 | 15 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| S | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2O | 1.24E-01 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2S | 1.17E-02 | 0 | 0 | 6.04E-02 | 6.08E-02 | 1.48E-02 | 2.60E-01 |
| N2 | 7.76E-02 | 0 | 0 | 5.71E-03 | 5.74E-03 | 1.40E-03 | 2.45E-02 |
| NH3 | 0 | 0 | 0 | 3.78E-02 | 3.81E-02 | 8.28E-03 | 1.63E-01 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table A.48

WATER - SULFUR SEPARATOR
ESTIMATION OF FUGITIVE EMISSIONS FOR ONE BEAVON TRAIN

| EQUIPMENT TYPE | QUANTITY |
|-------------------------------------|----------|
| Pumps | 0 |
| Vertical Vessels | 0 |
| Horizontal Vessels | 1 |
| Storage Tanks | 0 |
| Pressure Relief Valves | 0 |
| Heat - Exchangers (Heating Side) | 0 |
| Heat - Exchangers (Cooling Side) | 0 |
| Loading or Unloading Point | 0 |
| Flow Transmitters | 3 |
| Turbine Meter and Prover Connection | 0 |

| FLOW SUMMARY | kgmol/hr | kg/hr | mass fraction |
|--------------|----------|-------|---------------|
| CO2 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 |
| S | 5 | 173 | 1.09E-01 |
| H2O | 64 | 1161 | 7.27E-01 |
| H2S | 1 | 34 | 2.16E-02 |
| N2 | 8 | 225 | 1.42E-01 |
| NH3 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 |
| TOTAL FLOW | 78 | 1563 | |

| EQUIPMENT WITH FUGITIVES | Valves | Pumps | Compressors | Pressure Relief Valves | Flanges | Open - Ended Lines |
|--------------------------|--------|-------|-------------|------------------------|---------|--------------------|
| EMISSION FACTOR | 0.0071 | 0 | 0 | 0 | 0.00083 | 0.0017 |
| QUANTITY | 39 | 0 | 0 | 0 | 164 | 20 |

| COMPONENT | EMISSIONS FROM : | | | | | | TOTAL EMISSIONS (kg/hr) |
|-----------|------------------|---------------|---------------------|--------------------------------|-----------------|----------------------------|-------------------------|
| | Valves (kg/hr) | Pumps (kg/hr) | Compressors (kg/hr) | Pressure Relief Valves (kg/hr) | Flanges (kg/hr) | Open - Ended Lines (kg/hr) | |
| CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| S | 3.02E-02 | 0 | 0 | 0 | 1.48E-02 | 3.82E-03 | 4.87E-02 |
| H2O | 2.01E-01 | 0 | 0 | 0 | 9.88E-02 | 2.41E-02 | 3.24E-01 |
| H2S | 5.95E-03 | 0 | 0 | 0 | 2.82E-03 | 7.12E-04 | 9.58E-03 |
| N2 | 3.94E-02 | 0 | 0 | 0 | 1.94E-02 | 4.72E-03 | 6.35E-02 |
| NH3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CH3OH | 0 | 0 | 0 | 0 | 0 | 0 | 0 |