

# Appendix F

## Case 6: Shell gasifier and steam reforming of natural gas

### CASE 6

All capital cost data in this report, except where otherwise specified, has been estimated from similar installations described in the Houston Area Medium-BTU Coal Gasification Project Final Report, published in June 1982 by Union Carbide [1] (All references to material in this report will be referred to as Houston, and all scaling exponents from the Houston report are 0.65). The plant consumes 0.59 million metric tons of coal, 0.48 million metric tons of oxygen, 0.35 billion standard cubic meters of natural gas, and produces 0.50 million metric tons of mixed alcohols per year.

### SYNGAS PRODUCTION FROM NATURAL GAS

Compressed natural gas (stream 14) and steam (stream 15) are reacted in the Steam Reformation Block. The cooled output gas (stream 17) goes to the Rectisol Block. The cost for this unit was estimated from data found for a hydrogen production facility, with a scaling exponent of 0.8 [2]. The fuel gas usage for this block is estimated to be 30% of the natural gas feed.

### COAL PREPARATION

Coal (stream 10) and carbon dioxide (stream 12) are sent to the Coal Preparation Block. The coal is crushed, mixed with the carbon dioxide, and sent to the gasifier (stream 13). The Coal Preparation Block is composed of three plants from the Houston report. Plant 61 is the Reclaiming, Transfer, and Crushing Plant. The cost of this plant was scaled exponentially. Plant 22 is the Barge Terminal. This plant was scaled exponentially. Plant 60 is Coal Receiving and Storage and again the cost for this plant was scaled exponentially.

### CRYOGENIC OXYGEN PLANT

Compressed air (stream 1) is cooled and sent to the Cryogenic Oxygen Plant Block, and is separated into high purity oxygen (stream 2), nitrogen (stream 3), argon (stream 6), and a water and carbon dioxide waste mixture (stream 28). A small quantity of nitrogen (stream 19) is sent to the Rectisol Block. The Cryogenic Oxygen Plant Block does not include the inlet air compressors or the outlet oxygen compressors. In the cryogenic system, there are provisions for gaseous and liquid oxygen backups sufficient to maintain downstream plant operation in the event of a shutdown in the cryogenic facility. We also assume that some scale down is possible for this system, so the capital investment has

been calculated linearly for the reduction in trains, and exponentially for throughput reduction per train. Each train can produce up to 2,000 tons of oxygen per day. The Houston plants that comprise the Cryoplant Block are 02 and 08.

### **RECTISOL**

The cooled raw gas streams (streams 17 and 18), nitrogen gas (stream 19) for methanol regeneration, and methanol make-up (stream 20) for vapor loss all enter the Rectisol Block. H<sub>2</sub>S levels are reduced to the ppb range and CO<sub>2</sub> levels to the ppm range. The clean syngas (stream 22) is sent to the alcohol synthesis loop. A CO<sub>2</sub>-N<sub>2</sub> mixture (stream 24) and a CO<sub>2</sub> rich stream (stream 23) are produced as byproducts. Condensed water is also removed (stream 17A). This block is the same as Houston Plant 05. The cost for this plant was estimated by using exponential scaling.

### **SHELL GASIFIER**

The coal is conveyed by CO<sub>2</sub> to the gasifier, where it mixes with compressed oxygen (stream 9) and is burned at approximately 1,300°C and 2,800 kPa in the Shell Gasifier Block. The hot raw gas (stream 8) is sent to the Syngas Heat Recovery Block, and the slag (stream 33) is sent to the Slag Handling Block. Each train can handle up to 2,541 tons of coal per day, with a scaling exponent of 0.65.

### **SLAG HANDLING**

Molten slag from the Shell Gasifier Block (stream 33) is direct quenched with water and sent to slag disposal (stream 37). A small amount of water (stream 36) is purged from the closed loop and is replaced by water make-up (stream 34). This block is the same as Houston Plant 63. The cost for this plant was estimated by exponential scaling.

### **COS HYDROLYSIS**

The sulfide rich stream from the Rectisol Block (stream 25) and steam are sent to the COS Hydrolysis Block where COS is converted to H<sub>2</sub>S. The product gas (stream 41) is sent to the Claus Sulfur Recovery Block. The COS Hydrolysis Block cost is assumed to be negligible.

### **SYNGAS HEAT RECOVERY**

The raw gas stream from the Shell Gasifier Block (stream 8) at 1,300°C and 2,800 kPa enters the Syngas Heat Recovery Block and is cooled against process boiler feed water at 25°C (stream 71). The raw gas stream exits at 300°C (stream 18), and the boiler feed

exits as steam at 10,000 kPa and 535°C (stream 68). It is assumed that the raw gas stream is cooled further prior to entering the Rectisol Block. This block is part of Houston Plant 04.

### **CLAUS PLANT**

Hydrogen sulfide rich gas (stream 41) is mixed with air (stream 42) and converted in a two-step reaction to elemental sulfur (stream 46). The unreacted hydrogen sulfide (stream 45) is then sent to the Beavon Plant for further treatment. This block is the same as Houston Plant 06. The cost for this plant was estimated by exponential scaling.

### **BEAVON PLANT**

The Claus tail gas (stream 45) and air (stream 47) go to the Beavon Block. Additional sulfur is made (stream 51), and the gas leaving (stream 50) is sufficiently free from sulfides that it can be vented to the atmosphere. A sour water stream (stream 54) is sent from the plant for treatment. The cost of this block was estimated from data collected from various sources, with a scaling exponent of 0.65 [3].

### **MoS<sub>2</sub> ALCOHOL SYNTHESIS LOOP**

Clean syngas (stream 26) at 140 atmospheres enters the catalytic reactor along with the syngas recycle (stream 56B). The products (stream 26A) are taken to the separations block where the unreacted syngas is removed (stream 59). Part of this stream (stream 27) is sent to power generation while the rest (stream 56) is sent to CO<sub>2</sub> removal. The cost of this block was estimated from the cost of a methanol synthesis loop, with a scaling exponent of 0.565 [4].

### **CO<sub>2</sub> REMOVAL**

This block is very similar to the Rectisol Block. Recycled gas from the alcohol separation block (stream 56) is the only feed. CO<sub>2</sub> free syngas (stream 56A) is then recompressed and sent back to the reactor. CO<sub>2</sub> is taken off as a product (stream 57). The cost of this block is calculated the same way as in the Rectisol block. Its power requirement is included in the Rectisol block.

### **COMBUSTION GAS TURBINE**

The light hydrocarbons extracted from the reactor recycle (stream 27) in the Alcohol Synthesis Loop are sent to a combustion gas turbine with hot gas heat recovery. The power from the combustion gas turbines is assumed to be 35% of the HHV of the fuel in

stream 27. This is consistent with recent studies on IGCC plants using medium BTU synthesis gas [9]. The cost for this block was estimated from data taken from an EPRI report, where each train can produce up to 200 MW with a scaling exponent of 0.67 [10].

### **EXHAUST GAS HEAT RECOVERY**

The hot exhaust gas stream from the Gas Turbine Block (stream 70) at 590°C and 101 kPa enters the Exhaust Gas Heat Recovery Block and is cooled against process boiler feed water at 25°C (stream 73). The exhaust gas stream exits at 200°C (stream 75), and the boiler feed exits as steam at 10,000 kPa and 535°C (stream 74). The cost for this block was estimated from data taken from an EPRI report, where each train can generate up to 425 tons of steam per hour with a scaling exponent of 0.67 [10]. This block also supplies the reheat between the high pressure and intermediate pressure steam turbines.

### **POWER GENERATION**

The steam from the Syngas Heat Recovery Block and the Exhaust Gas Heat Recovery Block is let down in the steam turbines for power production. The cost for this block was estimated from data taken from an EPRI report, where each train can produce up to 500 MW with a scaling exponent of 0.67 [10]. This is a 3-stage steam turbine system. The high pressure stage inlet is 535°C, 10,000 kPa steam. The exhaust at 3,000 kPa is reheated to 535°C before entering the intermediate pressure stage. The final stage exhausts to a surface condenser at 7.4 kPa. Each turbine has an assumed efficiency of 75%.

### **IMPORTANT POINTS OF INFORMATION**

Several decisions were made for the creation of this case that should be outlined. Also, there are alternatives that have not been fully considered which will be considered in more detail later. They are listed below along with the reasons behind them.

- Catalytic steam/methane reformation used to adjust the H<sub>2</sub>:CO ratio upwards. The ratio from coal gasification is less than 1. Since the optimal ratio for higher alcohol synthesis is approximately 1.1 - 1.2, an additional source of hydrogen was required. The reformer was assumed to operate at equilibrium, as suggested in the literature [8]. Other alternatives to this block are available and will be considered.
- The traditional method for purifying high quantities of pure oxygen is by cryogenics, which is used for this case. However, recent reports suggest that membrane and catalytic processes are becoming economically competitive with cryogenics. Therefore, we will examine these alternatives.

- The Rectisol system was chosen for H<sub>2</sub>S and CO<sub>2</sub> removal. The major alternative to Rectisol is Selexol. The literature indicates that Rectisol has a higher installed capital cost, but a lower fixed operating cost than Selexol. Both of these systems are capable of removing H<sub>2</sub>S to the ppm level and beyond. However, there is some evidence that quantities of H<sub>2</sub>S are beneficial if the reaction involves the MoS<sub>2</sub> catalyst. If this is so, then a system such as the Benfield acid gas removal process might be more suitable. The Benfield system does not remove as much H<sub>2</sub>S and has lower capital and operating costs.

### TOTAL ESTIMATED CAPITAL INVESTMENT (MM\$)

Synthesis Gas via Natural Gas	27.8
Coal Preparation	19.5
Texaco Gasifier	92.5
Slag Handling	2.2
Gas Turbines	44.9
Steam Turbines	17.9
Exhaust Gas Heat Recovery	11.0
Synthesis Gas Heat Recovery	3.3
Cryogenic Oxygen Production	49.4
Rectisol (Acid Gas Separation)	14.5
Claus (Sulfur Recovery)	7.5
Beavon	1.6
Alcohol Synthesis Loop	47.2
CO2 Removal	26.9
Other Compressors	50.6
<b>TOTAL</b>	<b>416.6</b>

(sum of individual block costs does not exactly equal the total due to round-off)

### OVERALL ECONOMIC EVALUATION

The following table gives the totals and breakdowns for the yearly operating costs as well as the total installed cost for the plant.

TOTAL ESTIMATED INSTALLED CAPITAL COST (MM\$)	416.6
TOTAL ESTIMATED OPERATING COSTS (MM\$/YR)	130.5
Coal (\$33/metric ton delivered)	19.5
Natural Gas (\$106/1000 cubic meters)	37.6
Other Expenses	73.4
TOTAL ESTIMATED CREDITS (EXCLUDING ALCOHOLS) (MM\$/YR)	38.1
Power (\$0.05/kWh)	33.6
Slag (\$5.5/metric ton) (6)	0.3
Sulfur (\$300/metric ton) (7)	4.2

Credits for nitrogen, argon, and other rare gases have not been included because prices were not available and potential markets have not yet been identified.

## STAND ALONE COMPRESSORS AND POWER SUMMARY

There are 5 compressors that are not included in any of the blocks. Their inlet, outlet, pressure change, power rating, and installed capital cost are listed below. Following that is a summary of the total plant power output/input (5). An efficiency of 70% is assumed for all compressors, with a maximum pressure ratio of 5 for a single stage of compression. Multiple compression stages with intercooling are used for services with pressure ratios greater than 5.

FUNCTION	INLET STREAM	P (kPa)	OUTLET STREAM	P (kPa)	POWER (MW)	COST (MM\$)
Air Prep	1A	101	1	500	-18.2	16.6
O2 Prep	2	500	9	2834	-3.6	3.7
Reform Comp	17C	1400	17	2804	-4.9	4.7
Rxtr Prep	22	2804	26	14000	-23.9	21.9
Recy Comp	56A	12666	56B	14000	-3.6	3.6
Total compressor needs					-54.2	
Other in plant needs					-4.9	
Total produced in steam and gas turbines					143.1	
Net power output					84.0	
Total installed compressor costs (1992 dollars)						50.6

## REFERENCES

1. *Final Report on the Houston Area Medium-BTU Coal Gasification Project, Volumes 2 and 3*. Prepared by the Linde Division of Union Carbide Corporation, June 1982.
2. Baasel, William D., *Preliminary Chemical Engineering Plant Design, 2nd edition*, Van Nostrand Reinhold, New York, 1990, pp. 268-269.
3. "Beavon Sulfur Removal Process," *Hydrocarbon Processing*, April 1984, p.78.
4. Frank, Marshall E. "Methanol: Emerging Uses, New Syntheses," *Chemtech*, June 1982, pp. 358-362.
5. Baasel, pp. 529-530.
6. T. Torries, personal communication
7. *Chemical Marketing Reporter*, August 31, 1992.
8. Rase, Howard F., *Chemical Reactor Design for Process Plants, Volume 2*, John Wiley & Sons, New York, 1977, pp. 133-138.
9. Report TR-101789, Houston Lighting and Power Company's Evaluation of Coal Gasification Coproduction Energy Facilities, EPRI Project 3226-04, 1992.
10. EPRI Report TR-100319, *Evaluation of a 510-MWe Destec GCC Power Plant Fueled With Illinois No. 6 Coal*, Prepared by Fluor Daniel, Inc., EPRI Project 2733-12, 1992.



Figure F.1 : Block Flow Diagram for Case 6




Table F.1 Case 6 Flow Table

	001	001A	002	003	004	006	008	009	010	012
Az	80.4	80.4				80.4			4070.3	
C										
CH3OH										
C2H5OH										
C3H7OH										
C4H9OH										
C5H11OH										
CO							4148.7			
CO2	2.7	2.7					228.3			312.7
CO5							5.0			
CaCO3										
H2							1202.6		1663.3	
H2O	215.2	215.2					454.1		46.9	
H2S							49.7			
N2	6975.4	6975.4		6975.4	6948.2		35.4		36.0	
NH3							1.2			
O2	1875.6	1875.6	1875.6					1875.6	320.6	
S									54.7	
Al2O3									76.2	
C3H6O2										
C4H8O2										
CH4										
C2H6							0.9			
HCN										
kmol/hr	9149.3	9149.3	1875.6	6975.4	6948.2	80.4	6126.0	1875.6	6267.9	312.7
kg/hr	262536.9	262536.9	60018.6	198310.7	194548.6	3215.3	139806.5	60018.6	73803.2	13758.0
Temp. (C)	25.0	25.0	25.0	25.0	25.0	25.0	1300.0	141.0	25.0	25.0
Press. (kPa)	500.0	101.3	500.0	500.0	500.0	500.0	2833.7	2833.7	101.3	2833.7

Table F.1 Case 6 Flow Table (cont'd)

	013	014	015	017	017a	017b	017c	018	019	020
AF										
C	4070.3									
CH3OH										
C2H5OH										
C3H7OH										0.1
C4H9OH										
C5H11OH										
CO				1233.4			1233.4	4148.7		
CO2	312.7			288.6			288.6	228.3		
O2								5.0		
C4CO3										
H2	1663.3			4854.6			4854.6	1202.6		
H2O	46.9		3599.8		454.1	1789.3		454.1		
N2								49.7		
NH3	36.0							35.4	27.2	
O2	320.6							1.2		
S	54.7									
A1203	76.2									
C3H6O2										
C4H8O2										
CH4				1.2			1.2	0.9		
C2H6		1523.2								
HCN										
kmol/hr	6580.6	1523.2	3599.8	6377.7	454.1	1789.3	6377.7	6126.0	27.2	0.1
kg/hr	87561.2	24371.0	64797.0	56961.3	8174.7	32206.7	56961.3	139806.5	762.0	3.3
Temp. (C)	25.0	25.0	300.0	25.0	25.0	25.0	25.0	300.0	25.0	25.0
Press. (kPa)	2833.7	1480.0	1480.0	2803.6	2803.9	1400.0	1400.0	2803.9	500.0	101.3

Table F.1 Case 6 Flow Table (cont'd)

	022	023	024	025	026	026A	027	028	033	034
Ar										
C										
CH3OH										
C2H5OH				0.1		628.3				
C3H7OH						655.4				
C4H9OH						145.0				
C5H11OH						36.5				
CO	5382.1					15.2				
CO2			180.9	25.8	5382.1	7001.9	714.2			
GOS				5.0		1493.7	152.4	2.7		
CaCO3										
N2	6057.1				6057.1	7880.0	803.8			
H2O						140.1		215.2		4708.7
H2S				49.7						
N2			62.6							
NH3				1.2						
O2										
S										
Al2O3										
C3H6O2						18.0			76.2	
C4H8O2						11.9				
CH4					2.1	4345.7	443.3			
C2H6	2.1					171.6	17.5			
HCN										
kmol/hr	11441.4		243.5	81.9	11441.4	22543.4	2131.1	217.9	76.2	4708.7
kg/hr	162847.5		9713.2	3151.5	162847.5	420117.3	35926.1	3992.3	7773.3	84757.1
Temp. (C)	25.0		25.0	25.0	275.0	310.0	25.0	25.0	1300.0	25.0
Press. (kPa)	2803.9		2803.9	2803.9	14000.0	12666.0	12666.0	500.0	101.3	101.3

Table F.1 Case 6 Flow Table (cont'd)

	036	037	041	042	045	046	047	050	051	054
Ar										
C			0.1		0.1			0.1		
CH3OH										
C2H5OH										
C3H7OH										
C4H9OH										
C5H11OH										
CO			30.9		30.9			30.9		
CO2										
COS										
CaCO3										
H2					52.0					54.7
H2O	4708.7				2.7					
H2S			54.7		2.7					
N2				97.7	97.7		11.0	108.8		1.2
NH3			1.2		1.2					
O2				26.0			2.9	1.6		
S						52.0			2.7	
Al2O3		76.2								
C3H6O2										
CaH2O2										
CH4										
C2H6										
HCN										
kmol/hr	4708.7	76.2	86.9	123.7	184.6	52.0	14.0	141.3	2.7	55.9
kg/hr	84757.1	7773.3	3241.2	3567.9	5146.9	1662.7	403.2	4457.0	87.5	1005.5
Temp. (C)	25.0	25.0	25.0	25.0	200.0	125.0	25.0	100.0	125.0	50.0
Prebb. (KPA)	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3

Table F.1 Case 6 Flow Table (cont'd)

	056	056A	056B	057	059	063	064	065	067
AF									
C									
CH3OH							628.3		
C2H5OH							655.4		
C3H7OH							145.0		
C4H9OH							36.5		
C5H11OH							15.2		
CO	6287.7	6287.7	6287.7		7001.9				
CO2	1341.4			1341.4	1393.7				
CO3									
C6CO3									
H2									
H2O	7076.3	7076.3	7076.3		7880.0	140.1		964.2	
H2S									20360.4
N2									
NH3									
O2									5412.3
S									
AL2O3									
C3H6O2						18.0			
C4H8O2						11.9			
CH4	3902.4	3902.4	3902.4		4345.7				
C2H6	154.1	154.1	154.1		171.6				
HCl									
kmol/hr	18761.9	17420.5	17420.5	1341.4	20892.9	170.1	1480.4	964.2	25772.6
kg/hr	316290.2	257269.8	257269.8	59020.4	352216.3	4905.1	62996.0	17356.3	743282.7
Temp. (C)	25.0	25.0	45.0	25.0	25.0	25.0	25.0	25.0	25.0
Press. (kPa)	12666.0	12666.0	14000.0	12666.0	12666.0	12666.0	12666.0	10000.0	101.3

Table P.1 Case 6 Flow Table (cont'd)

	068	070	071	073	074	075	076	077	078
Ac									
C									
CH3OH									
C2H5OH									
C3H7OH									
C4H9OH									
C5H11OH									
CO		1344.8				1344.8			
CO2									
CO3									
C6003									
H2									
H2O	6115.7	2707.0	6115.7	4200.7	4200.7	2707.0	10316.4	10316.4	10316.4
H2S									
N2		20360.4				20360.4			
NH3									
O2		3705.5				3705.5			
S									
Al2O3									
C3H6O2									
C4H8O2									
CH4									
C2H6									
HCl									
kmol/hr	6115.7	28117.7	6115.7	4200.7	4200.7	28117.7	10316.4	10316.4	10316.4
kg/hr	110083.5	796565.1	110083.5	75612.0	75612.0	796565.1	185695.5	185695.5	185695.5
Temp. (C)	535.0	590.0	25.0	25.0	535.0	200.0	40.0	380.0	535.0
Press. (kPa)	10000.0	101.3	10000.0	10000.0	10000.0	101.3	7.4	3000.0	3000.0

**Table F.2 Case 6 Energy Analysis**

<b>ELECTRICITY</b>		
<b>Plant</b>	<b>Electricity Used (MW)</b>	<b>Electricity Produced (MW)</b>
Coal Preparation Plant	1.2	0
Cryogenic Oxygen Plant	2.5	0
Rectisol Plant	0.6	0
Syn. Gas Heat Recovery	0.5	0
Claus Plant	0.1	0
Gas Turbine	0	80.4
Steam Turbine	0	62.6
Compressor 1	18.2	0
Compressor 2	3.6	0
Compressor 3	4.9	0
Compressor 4	23.9	0
Compressor 5	3.6	0
<b>Total</b>	<b>59.0</b>	<b>143.1</b>