

Appendices

Appendix A – WKE Case

Appendix B – TXU Case

Appendix C – BB Power Report on Boiler Penetraions

Appendix A – WKE Case

Gasification Based Biomass Cofiring, Phase I
DOE Project DE-FC26-00NT40898




Table A-1 Reid Plant Single KC-18 Material and Energy Balance

Stream ID	1	2	3	4	5	6	7	8	9
Stream Name	GASIFIER FEED	GASIFIER COMB AIR	GASIFIER BOTTOM ASH	GASIFIER SYNGAS	QUENCH WATER	HGF INLET SYNGAS	HOT GAS FILTER EXHAUST	ID FAN EXHAUST	PILOT GAS
Pressure, psig ("w.c.-g)	---	(20.0)	---	(-0.25)	50	(-0.50)	(-10.0)	(8.0)	30
Temperature, °F	77	80	300	1550	77	1400	1382	1382	77
Molecular Weight (lb/lbmole)	---	28.68	67.17	24.95	18.02	24.69	24.66	24.66	16.04
Component	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h
Carbon	4,617		467						
Hydrogen	527								
Nitrogen	463								
Oxygen	3,416								
Sulfur	83								
Chlorine	0								
Fuel Gas									23
Carbon Monoxide				3,819		3,819	3,819	3,819	
Carbon Dioxide				9,207		9,207	9,207	9,207	
Hydrogen				421		421	421	421	
Water (V)		267		5,412		6,576	6,576	6,576	
Nitrogen		20,853		21,316		21,316	21,316	21,316	
Oxygen		6,313							
Sulfur Dioxide				166		166	166	166	
Hydrogen Chloride				0					
Ash	3,494		3,961	70		70			
Lime									
Water (l)	4,200				1,164				
TOTAL	16,800	27,433	4,428	40,410	1,164	41,574	41,505	41,505	23

Table A-1 Reid Plant Single KC-18 Material and Energy Balance (contd.)

Stream ID	1	2	3	4	5	6	7	8	9
Stream	GASIFIER FEED	GASIFIER COMB	GASIFIER BOTTOM	GASIFIER SYNGAS	QUENCH WATER	HGF INLET	HOT GAS FILTER	ID	PILOT GAS
Name		AIR	ASH			SYNGAS	EXHAUST	FAN	GAS
Pressure, psig ("w.c.-g)	----	(20.0)	----	(-0.25)	50	(-0.50)	(-10.0)	(8.0)	30
Temperature, °F	77	80	300	1550	77	1400	1382	1382	77
Molecular Weight (lb/lbmole)	---	28.68	67.17	24.95	18.02	24.69	24.66	24.66	16.04
Component	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h
TOTAL	16,800	27,433	4,428	40,410	1,164	41,574	41,505	41,505	23
AVAILABLE ENERGY VALUE (LHV-Hv), Btu/lb	4,196		14,100.0	953.9		927.1	928.7	928.7	21,502
AVAILABLE ENERGY, MMBtu/h	70.50		6.6	38.5	0.0	38.5	38.5	38.5	0.5
FLOW RATE, scfm (gpm)		6,050		10,243	(2.33)	10,652	10,644	10,644	9
FLOW RATE, acfm		6,283		39,593		38,100	37,701	37,701	9

Table A-1 Reid Plant Single KC-18 Material and Energy Balance (contd.)

Stream ID	10	11	12	13	14	15	16
Stream	OVERFIRE	OVERFIRE	PILOT	REOX	COMB	GASIFIER	GASIFIER
Name	COMB	SYNGAS	GAS	COMB	PROD TO	COOLING	CW
	AIR			AIR	BOILER	WATER	RETURN
Pressure, psig ("w.c.-g)	(13.0)	(7.0)	30	(13.0)	(6.0)	60	10
Temperature, °F	80	2400	scfm	80	2330	110	165
Molecular Weight (lb/lbmole)	28.68	26.96	16.04	28.68	28.02	18.02	18.02
Component	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h
Carbon							
Hydrogen							
Nitrogen							
Oxygen							
Sulfur							
Chlorine							
Fuel Gas			23				
Carbon Monoxide		633					
Carbon Dioxide		14,276			15,335		
Hydrogen		200					
Water (v)	157	8,756		245	10,844		
Nitrogen	12,257	33,574		19,099	52,673		
Oxygen	3,711			5,782	3,737		
Sulfur Dioxide							
Hydrogen Chloride							
Ash							
Lime							
Water (l)						26,738	26,738
TOTAL	16,125	57,440	23	25,125	82,588	26,738	26,738

Table A-1 Reid Plant Single KC-18 Material and Energy Balance (contd.)

Stream ID	10	11	12	13	14	15	16
Stream	OVERFIRE	OVERFIRE	PILOT	REOX	COMB	GASIFIER	GASIFIER
Name	COMB	SYNGAS	GAS	COMB	PROD TO	COOLING	CW
	AIR			AIR	BOILER	WATER	RETURN
Pressure, psig ("w.c.-g)	(13.0)	(7.0)	30	(13.0)	(6.0)	60	10
Temperature, °F	80	2400	scfm	80	2330	110	165
Molecular Weight (lb/lbmole)	28.68	26.96	16.04	28.68	28.02	18.02	18.02
Component	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h	lb/h
TOTAL	16,125	57,440	23	25,125	82,588	26,738	26,738
AVAILABLE ENERGY VALUE (LHV-Hv), Btu/lb		229.0	21,502			0.0	1.0
AVAILABLE ENERGY, MMBtu/h		13.2	0.5			0.0	1.5
FLOW RATE, scfm (gpm)	3,556	13,478	9	5,541	18,642	(53.5)	(53.5)
FLOW RATE, acfm	3,693	74,129	8	5,754	100,031		


Table B-2 Reid Plant Cost Sensitive Analysis

Case		2	3	4	5	6	7	8
	Base Case							
Litter Cost	\$/ton	\$ 12	\$ 10	\$ 12	\$ 6	\$ 8	\$ 10	\$ 12
Ash Credits	\$/Ton	\$ (6)	\$ (8)	\$ (10)	\$ (12)	\$ (12)	\$ (14)	\$ (16)
Capital Cost		\$ 9,500,000	\$ 9,500,000	\$ 9,500,000	\$ 8,900,000	\$ 8,900,000	\$ 8,900,000	\$ 8,900,000
WKE Cost		\$ 4,750,000	\$ 4,750,000	\$ 4,750,000	\$ 4,450,000	\$ 4,450,000	\$ 4,450,000	\$ 4,450,000
Interest	%	7.5%	7.0%	7.0%	7.0%	7.5%	7.0%	7.0%
Period	Years	10.0	15.0	15.0	15.0	10.0	10.0	10.0
Power Cost								
Fuel	c/kwh	1.74	1.35	1.58	0.56	0.87	1.10	1.33
O&M	c/kwh	1.03	1.03	1.03	1.03	1.03	1.03	1.03
Capital	c/kwh	2.39	1.80	1.80	1.69	2.24	2.19	2.19
Total	c/kwh	5.17	4.18	4.41	3.28	4.14	4.32	4.55


Table A-2 Electrical Power Consumption

SYSTEM MOTOR LIST & ELECTRICAL REQUIREMENT					
ITEM	MOTOR				ELEC.
	SIZE Hp	QTY SUPL.	QTY OPRTG	OPR FACTOR	USAGE Kw
Fuel Receiving Hopper	15	1	1	0.40	4.5
Fuel Receiving Hopper Discharge Conveyor	15	1	1	0.40	4.5
Storage Silo Bucket Elevator	20	1	1	0.40	6.0
Separation Screen	5	1	1	0.40	1.5
Hammermill	50	1	1	0.40	14.9
Hammermill Air System	15	1	1	0.40	4.5
Silo Unloader	15	1	1	0.40	4.5
Silo Discharge Conveyor	10	1	1	0.40	3.0
Metering Bin Discharge Screw	5	1	1	0.50	1.9
Bucket Elevator	5	1	1	0.50	1.9
Fuel Feed Rotary Valve	5	1	1	0.50	1.9
Fuel Infeed Auger	5	1	1	0.50	1.9
Agitator	5	1	1	0.50	1.9
Ash Discharge Auger #1	3	1	1	0.50	1.1
Ash Discharge Auger #2	3	1	1	0.50	1.1
Ash Cooling Auger	5	1	1	0.50	1.9
Underfire Air Fan	40	1	1	0.85	25.5
Cooling Water Pump	10	2	1	0.38	2.8
Syngaas Compressor	100	1	1	0.65	48.6
Fly Ash Discharge Valve	1	2	2	0.50	0.7
Final Ash Conveyor	10	1	1	0.50	3.7
ID Fan	250	1	1	0.83	155.3
Overfire Air Fan	10	1	1	0.50	3.8
Reox/Recycle Fan	10	1	1	0.55	4.1
Air Compressor	100	1	1	0.50	37.4
Miscellaneous Electrical Usage	----	----	----	----	2.0
Total	567.0				340.6


Reid Plant Boiler Penetration Schematic



Boiler Penetration Sizing Nomogram



Proposed Gasifier Location at Reid Plant




Reid Plant
Boiler

Proposed
Gasifier
Location

Fuel Receiving and Storage




Reid Plant Boiler Penetrations



- Four Penetrations
- 2 on each side of the boiler
- Just below the lower windbox line
- Pressure at the burner -10"-12" of WC
- Velocity at the burner 150~300 ft/sec
- Flow 70,000~100,000 scfm


Reid Plant Turbine Energy Balance
Turbine Name Plate Data by GE




Ref: GE Design Case @ 65.85 MW Gross Turbine Output

B. Patel/ 3/23/01
Nexant Inc.

Turbine Design Point steam Load v/s Boiler heat Input





REFERENCE	
SK-002	REID PLANT GENERAL ARRANGEMENT GASIFICATION FACILITY PLAN
SK-005	REID PLANT GENERAL ARRANGEMENT GASIFICATION FACILITY FUEL STO. AREA PLAN

NO.	DATE	REVISIONS	BY	CHKD	APP'D
1	11-27	ISSUED FOR INFORMATION			
2	12-07	ISSUED FOR INFORMATION			
3	01-27	REISSUED FOR INFORMATION			

NEXANT INC.


POULTRY LITTER GASIFICATION
HENDERSON, KENTUCKY

REID PLANT SITE PLAN

JOB No. 24,355-018

DRAWING No. SK-001

REV B



Gasification Based Biomass ~~Nextant~~ Nextant, Inc.

POULTRY LITTER GASIFICATION
HENDERSON, KENTUCKY

REID PLANT GENERAL ARRANGEMENT
GASIFICATION FACILITY

PLAN

JOB No.	24355-018	DRAWING No.	SK-002
REV	B		

SCALE 1/8"=1'-0"

GRAPHIC SCALE

8 4 0 8 16 FT

NOTES

- 1. FOR REFERENCE SEE DRAWING SK-001.

NO.	DATE	BY	CHKD	APP'D
1	03-27-01			
2	04-20-01			
3	05-01-01			
4	05-01-01			
5	05-01-01			
6	05-01-01			
7	05-01-01			
8	05-01-01			
9	05-01-01			
10	05-01-01			

