

TABLES

Table 1

**NO_x Specific Emission Norms for Boilers to be Installed at TPS
before 01.01.2001**

Boiler thermal output, MW	Fuel fired	Units of measurement		
		g/MJ	kg/tfe	mg/m ³ of dry gas (= 1.4)
100-299	Gas	0.05	1.46	150
	Fuel oil	0.10	2.93	290
	Brown coal:			
	dry-bottom	0.12	3.50	320
	wet-bottom	0.13	3.81	350
	Bituminous coal:			
	dry-bottom	0.17	4.98	470
	wet-bottom	0.23	6.75	640
>300	Gas	0.05	1.46	150
	Fuel oil	0.103	3.03	300
	Brown coal	0.14	3.95	370
	Bituminous coal:			
	dry-bottom	0.2	5.86	540
	wet-bottom	0.25	7.33	700

**NO_x Specific Emission Norms for Boilers to be Installed at TPS
since 01.01.2001**

Boiler thermal output, MW Fuel fired	Units of measurement			
		g/MJ	kg/tfe	mg/m ³ of dry gas (= 1.4)
100-299	Gas	0.043	1.26	125
	Fuel oil	0.086	2.52	250
	Brown coal	0.11	3.2	300
	Bituminous coal:			
	dry-bottom	0.17	4.98	470
	wet-bottom	0.23	6.75	640
>300	Gas	0.043	1.26	125
	Fuel oil	0.086	2.52	250
	Brown coal	0.11	2.52	250
	Bituminous coal:			
	dry-bottom	0.13	3.81	350
	wet-bottom	0.21	5.97	570

SOx Emission Norms for Boilers to be Installed before 01.01.2001

Boiler thermal output, MW	Unit of measurement	g/MJ		kg/tfe		mg/m ³ (= 1.4)	
	Fuel	Normatired S content, % kg/MJ					
		S _{0.045}	S _{>0.045}	S _{0.045}	S _{>0.045}	S _{0.045}	S _{>0.045}
100-299	All solid and oil fuels	0.875	1.5	25.7	44.0	2000	3400
300		0.875	1.5	25.7	38.0	2000	3000

SOx Emission Norms for Boilers to be Installed since 01.01.2001

Boiler thermal output, MW	Unit of measurement	g/MJ		kg//tfe		mg/m ³ (= 1.4)	
	Fuel	Normatired S content, % kg/MJ					
		Sn 0.054	Sn>0.045	Sn0.045	Sn>0.045	Sn0.045	Sn>0.045
100-199	All solid and oil fuels	0.5	0.6	14.77	17.6	1200	1400
200-249		0.4	0.45	11.7	13.1	950	1050
250-299		0.3	0.3	8.8	8.8	700	700
300		0.3		8.8		700	

Table 3

Particular Matter Specific Emission Norms for Boilers to be Installed before 01.01.2001

Boiler thermal output, MW	Unit of measurement	g/MJ			kg/tfe			mg/m ³ (= 1.4)		
	Fuel	Normatired ash content, % kg/MJ								
		below 0.6	0.6-2.5	above 2.5	below 0.6	0.6-2.5	above 2.5	below 0.6	0.6-2.5	above 2.5
100-299	All solid fuels	0.06	0.06-0.2	0.2	0.176	1.76-5.85	5.86	150	150-500	500
300	All solid fuels	0.04	0.04-0.16	0.16	1.175	1.175-4.7	4.7	100	100-400	400

Particulate Matter Specific Emission Norms for Boilers to be Installed since 01.01.2001

Boiler thermal output, MW	Units of measurement	g/MJ			kg/tfe			mg/m ³ (= 1.4)		
	Fuel	Normatired ash content, % kg/MJ								
		below 0.6	0.6-2.5	above 2.5	below 0.6	0.6-2.5	above 2.5	below 0.6	0.6-2.5	above 2.5
100-299	All solid fuels	0.6	0.06-0.1	0.1	1.76	1.76-2.93	2.93	150	50-250	250
300	All solid fuels	0.02	0.02-0.06	0.06	0.586	0.586-1.76	1.76	50	50-150	150

Table 4

Some Data on Steam Turbine Units of Russia

Quantity	Unit rating, MW					
	150	200	300	500	800	1200
Total number of units	37	89	101	7	14	1
Including coal-fired units	27	47	31	7	2(5)	
Number of monoblock	14	57	50	6	14	1
Number of two-boilers single-turbine units	23	32	51	1		
Number of TKZ boilers	22	58	91		12	1
Number of ZIO boilers	38	56	65	8	2	
Number of BKZ boilers		9				
Number of LMZ turbines	4	89	53		14	1
Number of KhTZ turbines	33		26	7		
Number of TMZ turbines			22			
Number of EAS alternators	37	31	71		14	1
Number of ETM alternators		58	26	5		
Number of SETM alternators			4	2		
Live steam pressure, MPa	14.0	14.0	25.5	25.5	25.5	25.5
Live and reheat steam temperature, C	545	545	545	545	545	545
Steam Flow, t/h	500	640-670	950-1000	1650	2650	3950
kg/s	139	178-186	264-278	458	736	1097
Nom. gas flow, thou.m ³ /h	500	660	1060	1700	2700	4000
kg/s	172	227	364.5	585	929	1376

Table 5

Data on some pulverized coal boilers

Name	Type and Manufacturers of Boilers						
	E-500 BKZ	TPE-214A TKZ	TPE-216 TKZ	TPP-312A TKZ	P-57R ZIO	TPP-804 TKZ	P-67 ZIO
Delivery of first boiler	1981	1988	1984	1976	1986	1982	1983
Grade of Coal	Brown	Bitumin.	Brown	Bitumin.	Bitumin.	Bitumin.	Brown
Coal Field	Berezovo	Kuznetsk	Berezovo Kharanor	Donbas	Ekibastuz	Kuznetsk	Berezovo
Steam capacity, t/h	500	670	670	1000	1650	2650	2650
kg/s	139	186	186	278	458	736	736
Live steam pressure, MPa	14.0	14.0	14.0	25.5	25.5	25.5	25.5
temperature, C	545	545	545	545	545	545	545
Reheat temperature, C	—	545	545	545	542	542	542
Furnace section (depth width), m	10.311.3	12.513.5	13.512.5	8.717.4	9.821.8	15.530.9	23.123.1
Heat release rate:							
volume, MW/m ³	0.1	0.072	0.084	0.135	0.134	0.075	0.061
section, MW/m ²	3.22	3.38	3.39	5.33	6.04	4.29	3.95
Boiler efficiency, %	90.0	92.0	90.5	89.5	90.5	92.4	92.6
Exhaust gas temperature, C	167	131	158	165	157	132	140

Table 6

Basic Parameters of Large Steam Turbines Operating in Russia

Parameters	Turbine type and manufacturer									
	LMZ					KhTZ		TMZ		
	K-1200-240	K-800-240	K-300-240	K-210-130	PT-80/100-130/13	K-500-240	K-160-130	T-250-240	T-185-130	T-100-130
1. Nominal capacity, MW	1200	800	300	210	80	500	160	250	185	100
2. Max.output, MW	1400	870	330	215	100	535	165	300	220	120
3. Live steam pressure, MPa	23.5	23.5	23.5	12.8	12.8	23.5	12.8	23.5	12.8	12.8
4. Live steam temperature, C	540	540	565*	565*	555	540	565	540	555	555
5. Reheat pressure, MPa	3.5	3.24	3.53	2.31		3.65	2.8	3.68		
6. Reheat temperature, C	540	540	565*	565*		540	565	540		
7. HP cylinder max. steam flow: t/h	3950	2650	930	670	470	1650	516	980	760	485
kg/s	1097.2	736.1	258.3	186.1	130.6	458.3	143.3	272.5	225	135
8. Condenser pressure, kPa	3.58	3.43	3.43	3.45		3.5	3.43	5.8	5.0	5.6
9. Cooling water temperature, C	12	12	12	10	20	12	12	20	20	20
10. Cooling water flow, thou.m ³ /h	103	73	33.5	25.0	8.0	53.5	20.8	28.0	24.8	16.0
11. Number of steam extraction for regeneration ⁹	8	8	7	7	9	7	8	7	7	
12. Feedwater temperature, C	274	274	265	240	249	265	229	263	232	232
13. Designed specific heat consumption, kJ/kW.h	7660	7720	7720	8065	9610	7720	8260	8170	8760	9080
14. Same at present, kJ/kW.h	7616	7683	7704			7640		8145		
15. Number of cylinders	5	5	3	3	2	4	2	4	3	3
16. Number of stages, including	21	26	29	27	30	26	21	31	25	25
HP**	8	1R+11	1R+11	1R+11	1R+16	16+9	7	1R+11	1R+12	2R+8
IP**	28	29	12	11	1R+8	11	8	10+26	9	14
LP**	25	25	25	24	1R+3	45	26	23	2(1R+2)	2(1R+1)
17. Number of exhausts	6	6	3	2x1.5	1	4	2	2	2	2
18. Last stage average dia, mm	3000	2480	2480	2100	2000	2550	2125	2390	2280	1915
19. Last stage blade length, mm	1200	960	960	765	665	1030	1030	940	830	550

* - operated at 540 C; ** - 1R, 2R - single and twin control stage.

Table 7

Parameters of heavy-duty GT units

Name	Type, manufacturer and purpose							
	TMZ		NZL	KhTZ	Mashproject	LMZ		
	GTN-16	GTN-25	GTN-25	GTE-45	GTG-110	GTE-150	GTE-150	GTE-200
	mechanical drive			utility				
1. Output, MW	16.8	25.5	30.0	54.0	110.0	131.0	161.0	190.0
2. Efficiency, %	29.5	32.3	29.0	28.0	36.0	31.0	31.5	33.1
3. Number of shafts	2	2	3	1	1	1	1	1
4. Turbine inlet gas temperature, C	920	1060	900	900	1210	950	1100	1250
5. Turbine outlet gas temperature, \bar{N}	430	460	400	475	517	423	530	545
6. Pressure ratio	11.5	13.0	12.5	7.8	14.7	13.0	13.0	15.6
7. Air flow, kg/s	89	103	170	271	357	636	630	630
8. Possible heating load, MJ/s	28.5	37.9	51.1	98.8	157	220	296.5	302
9. Turbine unit weight, t	60	60	97	180	50	320	320	320

Table 8

Parameters of CIS marine and aeroderivative GT units

Name	Manufacturer, type, year of production					
	Mashproject		YuTZ	Tushino	"Saturn"	"Trud"
	GT-15	GT-16	GT-25	RD29-300	AL-31STE	NK-37
	1990	1993	1994	1996	1996	1994
1. GT output, MW	15.8	17.0	25.7	20.0	20.0	25.0
2. GT efficiency, %	30.0	35.5	36.8	30.0	35.5	36.4
3. Pressure ratio	12.8	20.0	21.8	10.7	21.0	23.4
4. Turbine inlet gas temperature, C				957	1252	1147
5. Gas flow, kg/s	98.5	71.0	85.0	98.0	62.0	101.0
6. Turbine outlet gas temperature, C	365	420	497	457	518	425
7. Possible heating load, MW	23.4	22.6	33.3	34.4	25.9	23.1

Table 9

Parameters of Domestic CCPs

Designation	CCP-450T	CCP-325	CCP-80
1. GT type/manufacturer	V94.2, Siemens-LMZ	GTG-110, Mashproject	NK-37, TRUD
2. Number of GTs	2	2	2
3. Heat recovery boiler (HRSG) manufacturer	ZIO	ZIO	BZEM
4. ST manufacturer	LMZ	LMZ	KTZ
5. GT gross output, MW	143.6	110.0	24.2
6. ST gross output, MW _{162.8}	115.0	19.8	
7. CCP gross output, MW	450.0	325.0	68.2
8. Auxiliary consumption, MW	13.5	8.1	3.4
9. CCP net output, MW	436.5	316.9	64.8
10. CCP efficiency, %	50.0	52.5	45.5
11. Gas flow, kg/s	499.4	358.5	104.2
12. Gas turbine outlet temperature, C	545	524	429
13. Exhaust gas temperature, C	110	100	130
HP Circuit			
14. Steam flow, t/h	472	305	71
15. Steam pressure past HRSG/before ST, MPa	8.0/7.6	7.0/6.5	40.8/37.0
16. Steam temperature past HRSG/before ST, C	515/510	495/490	430/427
LP Circuit			
17. Steam flow, t/h	114.0	75.0	18.5
18. Steam pressure past HRSG/before ST, MPa	0.65/0.6	0.65/0.6	0.765/0.6
19. Steam temperature past HRBG/before ST, C	200/195	210/205	205/203

Table 10

Gas Turbine Blade Alloy characteristics

Name	Deformed alloys									
	EI607A	EI893	EI765	TsD-1	TsJ-24	EP783	EP800	EI-929	EP-220	EP-957
1. Ultimate strength, MPa	930	1050	1100	1050	1150	1100	1150	1150	1165	1260
2. Yield point, MPa	485	560	620	630	660	710	750	730	845	940
3. Relative elongation, %	39	30	25	25	20	15	10	15	15	8
4. Impact viscosity, kJ/m ²	1350	500	400	400	350	200	200	200	230	110
5. Stress rupture, MPa: 650C	275	390	390	430	480					650
750C		180	180	190	210	275	280	300		350
850C							95	110	130	135
6. Corrosion loss, mg/cm ²	9	10				11	320	320	660	
Name	Casting alloys									
	EI893L	EP539LMU	TsL-2	TsL-4 (ZMI-4U)	TsL5(7)	ZMI-3	TsNK-7RS	TsNK-7NK	JSBK-RS	JSBK-NK
1. Ultimate strength, MPa	700	750	740	750	700	800	800	750	950	750
	750	850	800	850	850	860	900	1100	1000	1100
2. Yield point, MPa	440	650	600	600	500	700	700	700	850	700
	480	700	700	650	600	750	770	1050	900	1100
3. Relative elongation, %	10-25	2-4	2.2-3.6	2.5-6.0	2.5-5.0	2.5-5.0	2.5-7.0	1.5-2.5	1-3	1-20
4. Stress rupture, MPa: 650C		580				615	645	665		
750C	180	320				335	360	380		
850C		120	120	115	120	125	145	155	170	190
5. Corrosion loss, mg/cm ²	10	8	30		6	13	6	6	650	650

Table 11

Forecast of Electric Energy Generation in Regions of Russia

Parameter	Calendar year	Main regions							
		Center	N-W	Middle Volga	N.Caucasus	Urals, Tumen	Siberia	Far East	Total
Electricity production, bln kWh	1990	305.9	77.0	111.1	58.8	260.4	199.6	44.6	1057.0
	2010	457.8	131.4	162.0	112.0	401.6	344.0	102.1	1711.0
Heat consumption, bln GJ	1990	3.546	0.754	1.242	0.502	2.140	2.001	0.175	10.363
	2010	4.112	0.892	1.708	0.586	2.483	3.538	0.837	14.156
Installed capacity, GW	1990	55.3	14.5	22.5	10.8	41.2	45.2	11.1	200.7
	2010	84.3	24.7	34.5	25.3	71.6	73.2	26.5	340.
including TPS, GW	1990	39.2	6.0	13.2	8.6	38.8	22.0	8.3	136.2
	2010	59.3	14.9	23.9	17.7	69.8	43.3	15.7	244.6
Max.Load, GW	1990	47.8	11.8	16.7	11.3	38.4	31.8	7.9	165.7
	2010	74.0	19.0	22.6	18.6	59.8	47.0	18.6	259.6
Fuel demand, mln. tfe	1990	106.7	17.2	44.2	21.5	103.8	57.8	17.9	351.2
	2010	150.0	35.0	64.5	45.4	174.0	114.0	40.3	582
Including coal, mln. tfe	1990	13.8	1.9	1.0	3.7	21.9	55.0	12.3	97.3
	2010	27.2	6.0	9.8	10.4	67.2	99.0	27.7	219.6

Table 12

NO_x Control Technologies

Data \ Project Technology Developer Sponsor p.p. of CCTDF	The Babcock & Wilcox coal-reburning system Babcock & Wilcox Company 7-40	ABB CE LNCFS with AOFA Southern Co Services, Inc. 7-48	Foster Wheeler's LNB with AOFA Southern Co Servisec, Inc. 7-46	The Babcock & Wilcox Low-NO _x Cell burner system The Babcock & Wilcox Company 7-42	EERC's gas-reburning and Low-NO _x burner system (GR-LNB) Energy & Envir.Res. Corp. 7-44	Fuller's micronized coal reburning technology Tennessee Valley Authority 7-52	SCR Technology for the Control of NO _x Emission Southern Co Serv. Inc. 7-50
1. Power Unit Output, MW	100 – 300	200 – 800	50 – 800	300 – 800	50 – 800	50 – 800	200 – 800
2. Status (development stage): Pilot, demo, commercial.	commercial	commercial	commercial	commercial	commercial	demo	pilot
Date of commercial implementation	1995	1995	1995	1995	1995	1998	1998
3. Reasonable operating time, ths.hrs/yr	> 6	> 4	> 4	> 4	> 4	> 4	> 4
4. Emissions reduction, %	50	40	65	55	70	50 – 60	>80
5. Construction period, years	1.0	0.5	0.2	0.2	1.0	0.5	0.92
6. Availability, %	—	—	—	90.0	—	—	—
7. Kinds of fuel** A, Bit, Lign	Bit, Lign	Bit	Bit	Bit	Bit	Bit	—
8. Reagents: type consumption, g/MJ	—	—	—	—	natural gas < 20%	—	ammonia —
9. Capital investment, doll/kW	40 – 65	30 – 40	30 – 40	5.5 – 8.0	17 – 42	32	80 – 90
10. Maintenance costs, cents/kW.h	0.21 – 0.29	0.067 – 0.17	0.067 – 0.17	0.03 – 0.04	0.2 – 0.7	0.1	0.4 – 0.5
11. Cost of 1 t of NO _x removed, \$	260	420 – 1590	420 – 1590	160 – 450	400 – 2000	—	700 – 5000
12. Reference Unit Capacity, MW	200	500	500	500	300	300	300

* – Clean Coal Technology Demonstration Program; Program Update 1993

** – A (anthracite), Bit (bituminous coals), Lign (Lignites)
Service life is about 20 years

Table 13

SO₂ Control Technologies

Data	Project Technology Developer Sponsor p.p. of CCTDP*	(CT-121) advanced FGD process (wet) South.Co Serv., Inc. 7-62	AFGD-process (wet) Pure Air on the Lake, L.P. 7-60	FLS milio a/s's (GSA) system for FGD (semidry) AirPol, Inc. 7-54	Bechtel Corp.'s (CZD/FGD) process (semidry) Bechtel Corp. 7-56	LIFAC's sorbent injection process (semidry) LIFAC-North America 7-58
1. Power Unit Output, MW		100	200 - 800	50 - 300	50 - 800	50 - 300
2. Status (development stage): pilot, demo, commercial.		demo	commercial	pilot	demo	commercial
Date of commercial implementation		1995	1995	2000	1995	1995
3. Reasonable operating time, ths.hrs/yr		> 6	> 6	> 4	> 4	> 4
4. Emission reduction, %						
- of SO ₂		95	95	90	50	80
- of NO _x		~20	-	-	-	-
- of particulate matter		~50	-	-	-	-
5. Construction period, years		2.0	2.5	0.4	0.3	1.1
6. Availability, %		-	99.9	-	-	-
7. Kinds of fuel**		Bit; S > 2% Lign; S > 1.5%	Bit; S > 2% Lign; S > 1.5%	Bit; 1 < S < 2% Lign; 0.6 < S < 1.5%	Bit; S < 0.4% Lign; S < 0.3%	Bit; S < 1% Lign; S < 0.6%
8. Water requirement, l/MJ		-	0.1	-	-	-
9. Reagents: type		CaCO ₃	CaCO ₃	Ca(OH) ₂ Mg(OH) ₂	Ca(OH) ₂	CaCO ₃
Ca/S ratio		~1	~1	~1.0 - 1.5	~2	~2
consumption, g/MJ		< 5	< 5	< 2.8	0.7	< 2.5
10. Wastewater, ml/MJ		-	5.0***	-	-	-
11. By-Products type		CaSO ₄	CaSO ₄	CaSO ₄ , CaSO ₃ , CaCO ₃	CaSO ₄ , CaSO ₃ , MgSO ₄ , MgSO ₃	CaCO ₃
yield, g/MJ		< 6.5	< 6.5	< 5 + fly ash	< 1 + fly ash	< 3 + fly ash
application		sale	sale	ash disposal	ash disposal	ash disposal
12. Capital investment, doll/kW		180 - 250		(160)	30 - 60	50 - 60
13. Maintenance costs, cents/kW.h		0.5 - 1.3		(0.551)	-	-
14. Cost of sulfur removed, doll/t		470 - 630		420 - 680	500 - 650	650
15. Reference Unit Capacity, MW		100	500	300	200	-

* CCTDP - Clean Coal Technology Demonstration Program; Program Update 1993

** - Bit (bituminous coals), Lign (lignites)

*** - Wastewater Dissolved Solids: pH = 8-9; content of chloride - 4560 ppm; sulphate - < 2500 ppm; fluoride - 19 ppm;
total dissolved solids - 1.41 g/m³
Service life is about 20 years.

Table 14

Combined SO₂/NO_x Control Technologies

Data	Project Technology Developer Sponsor p.p. of CCTDP*	SNOX Flue Gas Cleaning Technology	SNRB Flue Gas Cleaning Technology	NOXSO SO ₂ /NO _x Flue Gas Cleanup System	Integrated Dry NO _x /SO ₂ Emission Control System	Millicen Clean Coal Technology Demonstrat. Project New York State E & G Corp 7-72	Technology		E & E Research Corp.'s Gas Reburning and sorbent injection process Energy & Envir. Research Corp. 7-70	TWR-technology Healy Clean Coal Project Alaska Industr. 7-32
		ABB Environ. System 7-64	The Babcock & Wilcox Co 7-68	NOXSO Corp. 7-74	B&W Technology Public Service Co of Colorado 7-76	Babcock & Wilcox Co 7-66	LIMB B&W	Coolside Consol. Coal Co		
1. Power Unit Output, MW		200 - 800 commercial	50 - 200 pilot	100 - 300 demo	50 - 250 demo	300 demo	50 - 500 commercial	50 - 250 commercial	50 - 500 commercial	50 - 300 pilot
2. Status (development stage): Pilot, demo, commercial Date of commercial implementation		1998	2000	(no results) after 2000	1998	(no results) after 2000	1995	1995	1995	after 2000
3. Reasonable operating time, ths. hrs/yr		> 6	> 6	> 6	> 4	> 6	> 4	> 6	> 5	> 6
4. Emission reduction, %										
- of SO ₂		95	80	97	70	98	20 - 30	70	> 50	> 90
- of NO _x		90	90	70	70	50	40 - 50		> 60	80
- particulate matter		> 99	99.8	-	-	20	-	-	-	99.9
5. Construction period, years		1.0	0.8	1.0	1.3	1.1	2	2	2.3	2.3
6. Kinds of fuel**		Bit; S > 2% Lign; S > 1.5%	Bit; S < 1% Lign; S < 0.6%	Bit; S > 2% Lign; S > 1.5% sorbent	Bit; S < 0.7% Lign; S < 0.4%	Bit; S > 2% Lign; S > 1.5%	Bit; S < 0.3% Lign; S < 0.2%	S < 0.7% S < 0.4%	Bit; S < 0.4 Lign; S < 0.3	Bit; 1 < S < 2% Lign; 0.7 < S < 1.5
7. Reagents, type		NH ₃	Ca(OH) ₂ + NH ₃	natural gas	Na + Na + urea	CaCO ₃	CaCO ₃	Ca(OH) ₂	CaCO ₃ , Ca(OH) ₂	CaCO ₃
		catalysis	NaHCO ₃ + NH ₃			urea				
	Ca/S ratio	-	1.5 - 2.0 (Ca/S) 1.0 - 1.5 (Na ₂ /S)	-	-	~1	2	2***	1.7	-
	NH ₃ /NO _x ratio consumption, g/MJ	0.9 NH ₃ - 0.2	0.9 Ca(OH) ₂ - 1.4 NH ₃ - 0.2	-	-	CaCO ₃ < 5	NaCO ₃ < 5	-	0.65	-
8. Wastewater						neutralized CaSO ₄ , CaCl ₂				
9. By-Products, type		H ₂ SO ₄ , Na ₂ CO ₃ , NaNO ₃ , NaCl	CaSO ₄ , CaSO ₃ , CaCO ₃ , CaCl ₂ , CaO, Na ₂ SO ₄ , Na ₂ SO ₃	sulfur	CaSO ₄ , CaSO ₃ , Na ₂ SO ₄ , Na ₂ SO ₃ , fly ash		CaSO ₄ , CaSO ₃ , CaCO ₃ , Na ₂ SO ₄	CaSO ₄ , CaSO ₃ , CaCO ₃	slag, CaSO ₄ , CaCO ₃ , fly ash	
	yield, g/MJ application	< 4.7 sale	1.4 + fly ash ash disposal	< 1.5 sale	- ash disposal	< 6.5 sale	- ash disposal	1.9 + fly ash ash disposal	0.9 + fly ash ash disposal	- ash disposal
10. Capital investment, doll/kW		-	260	250	-	180	31-102	69 - 160	40	-
11. Maintenance costs, cents/kW.h		-	1.5	0.4	-	-	0.54	-	-	-
12. Cost of sulfur removed, doll/t NO _x removed, doll/t		-	510	210	-	450	370 - 620	-	-	-
13. Reference Unit Capacity, MW		300	200	200	100	300	200	200	300	200

* - CCTDP - Clean Coal Technology Demonstration Program. Program Update 1993

** - Bit (bituminous coals), Lign (Lignites)

*** - With addition NaOH or Na₂CO₃ of Na/Ca = 0.2 ratio
Service life is about 20 years

Table 15

Basic Characteristics of Coal TPS Emission Reduction Technologies

Contaminant	Technology		Coal grade and combustion technology	Maximum cleaning efficiency %	Enlarged specific heat consumption Btu/kW.h (%)***	Specific cost, \$/kW		Enlarged costs for repair and service c/kW.h	Enlarged electricity cost, c/kW.h	
						new plants	modified plants		new plants	modified plants
Sulfur Dioxide	FGD	Wet Limestone/ Forced Oxidation	High Sulfur Coals	95 - 98	120 (1.34)	130 - 300	150 - 250	0.28	0.48 - 0.61	0.53 - 0.66
		Lime Slurry Wet/Dry	Low Sulfur Coals	80 - 90	60 (0.67)	100 - 150	130 - 200	0.16	0.35 - 0.40	0.37 - 0.48
		Simplified Wet/Dry	Low Sulfur Coals	60 - 70	54 (0.6)	30	70	0.15	0.30	0.35
		Dry	Low Sulfur Coals	30 - 50	9 (0.1)	30	40	0.10	0.10	0.10
Nitrogen Oxides	Low-NO _x burners + overfire air supply		reconstruction of dry-bottom boilers	40	20 (0.22)	<10	10 - 20	0.01	<0.03	0.03 - 0.04
	reburning and additional measures (burners. etc.)		FBC, PC and cyclon boilers	50 - 70	22(0.25)			0.10	0.04	0.05
	SCR on hot side at high dust content		rigid standards for PC, FBC and cyclon boilers	60 - 80	75 (0.84)	70 - 90	80 - 100	0.26	0.40 - 0.43	0.41 - 0.45
	SNCR with ammonia or urea injection		rigid standards for PC,CFB,FBC	40 - 80	0	5-10	10 - 20	0.10	0.11 - 0.12	0.12 - 0.13
Fly ash	ESP		High Sulfur Coals	4.3-8.6* 11 - 22**	5 - 20 (0.06 - 0.22)	85	85	0.15	0.25	0.20
	baghouses	reverse air cleaning	All grades of coals	4.3*/11**	<10 (<0.11)	70	90	0.17	0.28	0.31
		pulse jet cleaning	All grades of coals	4.3*/11**	20 (0.22)	50	60	0.20	0.28	0.30

* mg/MJ;

** mg/m³ at SR =1.4;*** at b_s = 8980 BTu/kW.h, which corresponds to =38%

Table 16

Advanced Electric Power Generation Projects

Data	Pressurized Fluidized-bed Combustion (PFBC) Systems				Atmospheric circulating FB Combustion Systems		Integrated Gasification Combined Cycle (IGCC)						
	Tidd PFBC The Ohio Power Co 7-14	The Appal- lachian Power Co PFBC 7-8	DMEC-1 Limited Partnership PYROFLOW PCFB 7-10	Four Rivers Energy Partners PCFB 7-12	ACFB York County Energy Partners 7-18	ACFB Nucla Tri-State Generation & Transmis. 7-16	ABB CE Inc. 7-20	Texaso's technology Tampa Electric Co 7-28	Tampella U-GAS system TAMCO Partn.Co 7-26	Pinon Pine Sierra Pacific Power Co KRW 7-24	Wabash River Coal Gasific Repowering Project JV Destec 7-30	Duke Energy Corp. BGL 7-22	Centerior Energy Corp. COREX 7-96
1. Power Unit Output, MW	80	300 - 500	50 - 200	300-500	100 - 300	50 - 200	200 - 400	200 - 600	200 - 600	200 - 600	200 - 600	200 - 600	200 - 400
2. Status (development stage):	commercial	demo	demo	pilot	demo	commercial	demo	demo	demo	demo	demo	demo	demo
Pilot, demo, commercial Date of commercial implementation	1998	2000	after 2000	after 2000	2000	1995	after 2000	1998	2000	2000	1998	2000	after 2000
3. Reasonable operating time, ths./hrs./yr	>6	>6	>6	>6	>4	>4	>4	>6	>6	>6	>6	>6	>6
4. Emissions reduction, %													
of SO ₂	90	95	90	95	90	70 - 95	99	96	99	98 - 99	98	99	90
of NO _x	80	80	70	70	60(80)	60	90	90	90	94	80	90	97
5. Construction period, yrs	3.0	3.2	2.0	—	1.5	—	—	2.7	—	2.2	—	—	—
6. Kinds of fuel**	Bit1 <S <2.5%	BitS >2%	Bit1 <S <2%	BitS >2%	BitS <2%	BitS <1.5%	BitS <3%	BitS >3%	BitS >3%	BitS >3%	BitS >3%	BitS >3%	Bit1 <S <2%
	Lig0.6 <S <2%	LigS >1.5%	Lig0.6 <S <1.5%	—	LigS <1.5%	LigS <1.0%	LigS >2%	LigS >2%	LigS >2%	—	—	—	Lig0.6 <S <1.5%
7. Water requirement,	no	no	no	no	no	no	no	yes	no	no	yes	yes	yes
8. Reagents type	CaCO ₃	CaCO ₃	CaCO ₃	CaCO ₃	CaCO ₃	CaCO ₃	regenerated	—	CaCO ₃	CaCO ₃	regenerated	regenerated	CaCO ₃
Ca/S ratio	—	—	—	—	—	1.5/4.0	—	—	—	—	—	—	—
9. By-products type	M	M	M	M	M	M	slag	H ₂ SO ₄ slag	M	M	sulfur, slag	sulfur, sl.	M
application	ash disposal	ash dispos	ash disposal	ash dispos.	ash dispos.	ash dispos.	sale	sale	ash disposal	ash disposal	sale	sale	—
10. Reference Unit Capacity, MW	80	340	100	300	250	150	200	250	300	300	300	300	200
11. Reference Unit Efficiency, %	40.0	42.2	40.0	47.0	39.5	—	45.0	42.0	46.2	45.9	40.0	44.6	47.2
12. Emissions Particulate matter, mg/MJ	—	—	—	—	—	—	—	—	—	4.3	—	—	—
SO ₂ , mg/MJ	—	—	—	—	100	—	45	90	25	20	85	45	100
NO _x , mg/MJ	—	—	130	130	—	80	45	115	40	30	45	65	50
mg/m ³	165 - 200	110	330	330	—	200	115	300	100	75	85	105	130
13. Year of Unit Start-up -	2002	1997	—	1997	—	1998	1996	1998	1997	1995	1998	1999	—
14. Cleaning	—	—	—	—	—	—	dry clean.	wet clean.	dry clean.	dry clean.	wet clean.	wet clean.	wet cleaning
15. Oddizer	—	—	—	—	—	—	air	oxygen	air	air	oxygen	oxygen	oxygen

* CCTDP - Clean Coal Technology Demonstration Program, Program Update 1993

** Bit(bituminous coals); Lig(Lignites)

M mixture of utilized (CaSO₄, CaSO₃) and nonutilized (CaCO₃) sorbent with fly ash
Service life is about 20 years

Table 17

IGCC Demo Projects developed in USA in accordance with CCTP

Name	Location						
	Wabash River	Springfield	Pinon Pine	Cleveland	Camden	Tampa	Tom Creek
1. Gasification technology	EF	EF	FB	FB	MB	EF	FB
2. Developer	DCh	CE	KRW	VA	BGL	Texaco	T
3. Gasifier output, t/h	95	23	30	111	435	72	16.5
4. Coal grade	bituminous						
5. CCP output, MW	269	60	100	150	480	260	55
6. Type of GT, MW	M7F	M6B	M6FA	—	M7F	M7F	M6B
7. GT output, MW	191	40	61	—	2192	192	—
8. ST output, MW	111	25	46	—	—	(124)	—
9. CCP efficiency, %	39.0	—	—	—	—	40.6	39.1
10. Blown by	O	A	A	O	O	O	A
11. Ash removal in gasifier	L	S	S	—	L	L	S
12. Clean up of particulates	H	H	H	—	—	H	H
13. Desulfurisation of gas	C	H	H	—	C	H	H
14. New (n)/retrofit (r)	r	r	r	n	n	n	n
15. Start of tests	1995	1996	1997	—	—	1996	1998
16. Completion of tests	1998	2001	2000	—	—	1997	2000
17. Project cost, mln.USD	398	271	270	825	780	241	197
18. DOE share, %	50	48	50	18	25	50	47

EF - entrained-flow; FB - in fluidized bed; MB - in moving (fixed) bed; DCh - Dow Chemical;
 CE - Combustion Engineering; VA - Voest Alpine; BGL - British-Gas-Lurgi; KRW - Kellogg;
 T - Tampella & Gas Research Institute; O - oxygen; A - air; L - liquid; S - solid; H - hot; C - cold.

Table 18

Test Results of Direct Coal Combustion for GT

Name	Company				
	Solar	Allison		Westinghouse	
1. GT capacity, MW	4.0	4.6		104	
2. Fuel supplied	CWS	CWS		dust	CWS
3. Max. particle size, mm	75	15		200	110
4. Mean particle size, mm	11	5		44	40
5. Ash content (dry), %	3.0	0.8		6.5	
6. S (dry), %	0.6	0.7		1.0	
7. Gas outlet temperature, C	1054	1127		1054	1010
8. Combuster pressure, MPa	0.55	1.07		0.59	0.60
9. Air flow, kg/s	1.60	1.86	15.0	3.18	
10. Carbon burnout, %	99.9	99.6	94 - 99	99	
11. Type of slag removal	liquid	dry	liquid		
12. Type of precipitator		inertial + filter		inertial	
13. Ash slag removal, %	98	-	89	90	89
14. Emissions of NO _x , ppm	29	25	25	90	80
15. Capture of SO ₂ , %	55	50	-	40	22
16. Type of sorbent		dolomite		limestone	
17. Ca/S molar ratio	1.2 - 1.6	3.7	-	2 - 4	3

CWS coal-water-slurry

Table 19

Quality of Russian Coals Fired at TPS in 1993

Coal Field/Type	Used at TPS, mln.t	Content as per working mass						Volatiles V, %
		W, %	A, %	LHV, MJ/kg	C, %	S, %	N, %	
Kuznetsk, bit.	22.3	10.7	20.4	21.8	40.5 - 66.0	0.4	1.3 - 1.8	12 - 41
Kansk-Achinsk, br.	27.5	33.1	6.8	15.4	37.4 - 44.3	0.3	0.5	48.0
Eastern Donbas, AC	5.8	8.2	25.1	21.5	62.5	1.7	0.5	5.0
Pechora, bit. (Inta)	2.2	11.6	29.1	17.0	43.9	2.4	1.5	40.0
Neryungrinsk, bit.(Yakutia)	4.2	8.3	15.8	24.85	64.8	0.2	0.7	20.0
Chelyabinsk, br. (Urals)	6.4	15.2	37.2	12.6	33.8	0.8	0.9	44.0
Near-Moscow, br.	6.0	29.6	36.2	7.9	22.2	2.35	0.4	48.0
Azeisk, br. (East)	8.0	23.5	17.4	16.3	43.1	0.5	0.9	48.0
Kharanorsk, br. (East)	8.2	38.6	13.6	11.8	34.3	0.3	0.5	44.0
Bikinsk, br. (Far East)	5.5	38.0	28.8	7.0	22.0	0.3	0.6	53.0
Ekibastuz, subbitum. (Kazakhstan)	25.6	6.1	39.9	16.4	41.9	0.7	0.8	25.0
Gusinoozersk, br. (Buryatia)	2.5	24.7	21.3	13.1	38.3	0.4	0.6	43.0

Bit bituminous; br. brown; AC anthracite culm.

Table 20

Some Characteristics of Kuznetsk Coals and their Ash

Name	Coal Grade						
	LF	G	WS1	WS2	L&A	Wastes	
Moisture content, W , %	11.5 - 13(18)	8.5 - 11(19)	9 - 12(21)	8.5 - 12(19)	710(13)	6 - 25	
Ash content, A^d , %	18(25)	18.5 - 25	20 - 30	18 - 30	20 - 25	13 - 45	
Volatiles, V^{daf} , %	40.5	39.5	31	20	12.5	16 - 41.5	
Sulfur content, S^{daf} , %	0.4	0.5	0.5	0.4	0.5	0.3 - 0.9	
LHV, Q , MJ/kg	21.9(18 - 23)	23.6(16 - 27)	23.4(17 - 25)	25.3(16 - 26)	25.1(27.7)	17.4 - 22.3	
Fixed nitrogen, N^{daf} , %	2.6	2.7	2.1	2.1	2.2	1.7 - 3.1	
SO_2 concentration in combustion gases: mg/MJ	365	425	430	315	400	345 - 810	
	mg/m ^{3*}	935	1080	1090	810	1020	880 - 2060
Ash composition, %:	SiO_2	59.5	55.7	56.0	59.7	55.4	41.4 - 64.2
	Al_2O_3	20.6	21.6	23.6	22.4	25.4	17.4 - 26.8
	Fe_2O_3	6.7	7.8	10.1	8.5	77.2	4.1 - 10.8
	CaO	3.9	6.0	4.0	2.7	4.6	2.4 - 7.6
	MgO	2.7	2.8	1.8	1.6	1.9	1.4 - 3.4
	K_2O	3.0	2.3	2.0	2.6	1.9	0.8 - 3.9
	Na_2O	2.0	2.0	0.7	0.9	0.7	0.4 - 3.7
	TiO_2	0.9	0.8	1.0	0.9	0.8	0.8 - 1.2
	P_2O_5	0.5	0.8	0.5	0.5	1.6	0.2 - 1.6
	MnO	0.2	0.2	0.2	0.3	0.3	0.4
Temperature of normal liquid slag removal, C	1600	1500	1550	1700	-	1430 - 1580	

* Here and hereinbelow, the emissions are related to m³ in standard conditions with excess air of 1.4 or O₂ = 6%. The bracketed values are limiting for open-cast produced coals.

Table 21

Some Characteristics of Bituminous Coals and their Ash

Name	Field/Coal Grade							
	Pechora		East Donbass		S.-Yakutia. Neryungri	Ekibastuz		
	Inta	Vorkuta	L	AC	WS	group 1	group 2	middle
	LF	G						
Moisture content, W, %	11.5	8.0	6.0	9.0	10.0	6.0	5.0	6.0
Ash content, A ^d , %	32.5	32.0	34.0	35.0	22.0	43.0	48.0	45.0
Volatiles, V ^{daf} , %	40.0	33.0	12.0	4.0	20.0	25.0	25.0	25.0
Sulfur content, S ^{daf} , %	3.2	1.1	2.7	1.9	0.2	0.6	0.6	0.6
LHV, Q, MJ/kg	16.9	20.8	20.6	19.1	22.5	16.1	14.6	15.5
Fixed nitrogen, N ^{daf} , %	2.6	2.4	0.8	0.8	0.8	1.7	1.7	1.7
SO ₂ concentration in combustion gases, mg/MJ	3790	1060	2620	1990	180			770
mg/m ³	9680	2700	6700	5080	460			1970
Ash composition, %:								
SiO ₂	54.6	62.6	49.9	54.1	53.6	62.6	59.2	60.6
Al ₂ O ₃	18.6	19.4	22.3	23.9	27.5	28.2	29.6	28.6
Fe ₂ O ₃	14.1	8.6	17.5	11.1	8.0	5.0	6.0	5.4
CaO	6.9	3.0	4.0	2.9	4.9	1.0	1.6	
MgO	2.3	2.3	1.6	1.7	2.4	0.7	0.6	
K ₂ O	1.3	2.1	2.8	3.5	0.7	0.6	0.5	
Na ₂ O	1.4	1.0	1.2	1.5	0.7	0.2	0.2	0.2
TiO ₂	0.8	1.0	0.7	1.3	1.2	1.1	1.3	
P ₂ O ₃					0.8	0.6	0.7	
MnO					0.2	0.1	0.2	
Temperature of normal liquid slag removal, C	1450	1550	1400	1550	1600	1650	1580	1600

Table 22

Brown Coal Ash Chemical Composition and Fusibility

Field	Ash Chemical Composition, %								Ash Fusibility, C			T _{nj} , C
	SiO ₂	TiO ₂	Al ₂ O ₃	Fe ₂ O ₃	CaO	MgO	K ₂ O	Na ₂ O	T _a	T _b	T _c	
1. Kansk-Achinsk coals:												
Irsha-Borodinsk 46.8	0.6	12.9	7.9	25.8	5.0	0.5	0.5	1180	1210	1230	1300	
Nazarovo	30.5	0.6	10.0	19.0	35.0	4.0	0.4	0.4	1200	1220	1240	1300
Berezovo	30.0	—	11.0	9.0	42.0	6.0	1.2	0.8	1270	1290	1310	1400
2. Azeisk	52.8	0.4	28.8	7.2	7.9	2.1	0.6	0.2	1200	1340	1420	1550
3. Gusiniozersk	51.5	1.3	23.6	12.1	5.6	2.8	1.9	1.2	1150	1260	1330	1460
4. Kharanorsk	57.9	0.7	23.3	5.5	7.4	2.8	1.6	0.8	1170	1270	1360	1450
5. Raichikhinsk	55.7	0.8	25.5	7.8	7.0	1.4	1.2	0.6	1150	1240	1340	1400
6. Bikinsk	58.2	0.7	26.8	5.3	3.5	2.3	1.7	1.5	1240	1450	1500	—
7. Near-Moscow	47.5	0.5	38.5	8.5	3.5	0.5	0.7	0.3	1350	1500	1500	1750

T_a, T_b, T_c, C typical temperatures of ash softening;

T_{nj}, C temperature of beginning of normal liquid slag removal.

Table 23

Base-Case Options of Russian Advanced Coal TPS

Parameters	Supercritical Pulverized Coal Units			IGCC Plant		Supercritical Pulverized Coal Units			Supercritical Pulverized Coal Units		CFB Unit	Subcritical Pulverized Coal Units	IGCC Plant		
	existing	De-SO ₂ -De-NO _x systems	Ecologically clean	oxygen blowing	air blowing	existing	with De-SO ₂ -De-NO _x systems LD HD		existing	with De-SO ₂ -De-NO _x clean					
TPS capacity, MW	6400			6000		4000			2400			360	500	640	
Utilization period, h/yr	6500			6500		6190			4000			6000			
Unit capacity, MW	800			650		500			300			180	250	320	
Fuel characteristics:	KANSK-ACHINSK					EKIBASTUZ			DONETSK			KUZNETSK			
Coal field	BROWN COAL					BITUMINOUS			AC			BITUMINOUS			
Coal grade	15.07					14.45			17.25			22.25			
Heat value, MJ/kg	7.00					45.60			36.00			21.60			
Ash content, %	38 (33 - 38)					5.00			10.00			10(12 - 20)			
Moisture content, %	0.3 (0.2 - 0.5)					0.60			1.40			0.4			
Sulfur content, %	0.80					0.50			1.50						
Nitrogen content, % 0.3	37.60			38.70	42.50	43.50	38.15	35.90	37.20	37.60	36.80	37.30	36.30	38.50	41.90
Efficiency in nominal output, %	38.50														
Relative specific investment cost	1.227	1.483	1.193	1.326	1.358	1.000	1.577	1.470	1.043	1.673	1.071	1.375	1.534	1.399	
Specific emissions NO _x , mg/m ³	600	200	200	40*	30*	900	200	200	80-1200	200	200	900	80*	80*	
mg/MJ	220	75	75	30	25	320	70	70	28-420	70	70	320	65	65	
SO ₂ , mg/m ³	600	300	300	3.5	10	2100	200	200	2800	200	200	1000	60*	60*	
mg/MJ	220	110	110	2.5	8	750	70	70	1000	70	70	350	48	48	
Particulate matter, mg/m ³	150	50	50	0.7	0.7	500	100	100	500	50	50	250	2*	2*	
mg/MJ	55	18	18	0.6	0.6	180	35	35	180	18	18	90	1.6	1.6	

* For IGCC Plants the emissions are related to m³ in standard conditions with excess air of 3.0 or O₂ = 15%

Table 24

Technical Characteristics of modular type FRO-12000 fabric filter

Filtering surface area, m ²	1200
Specific gas loading at filtering surface, m ³ /(m ² min)	not more than 47
Number of sections	24
Number of filtering bags per section	54
Total number of filtering bags	1296
Bag length, mm	10000
Bag diameter, mm	300
Temperature of gases to be cleaned, C	not more than 180
Rarefaction in the filter, Pa	not more than 8000
Pressure drop, Pa	not more than 2000
Dimensions, mm: length	40200
width	9810
height	19000
Filter weight, kg	420000

Table 25

Characteristics of catalysts for different De-NO_x locations

Name	De-NO _x location	
	before air heater	past De-SO _x
Flue gases dust content, g/m ³	70 - 100	not more than 0.15
SO ₂ concentration, mg/m ³	2000-2200	200 - 300
Temperature, N	300 - 320	320 - 350
Catalyst:		
channel size, mm	6.1 - 6.3	3.4 - 3.6
surface, m ² /m ³	430 - 470	750
relative activity	1.0	1.0 - 1.2
relative volume	1.0	0.4 - 0.5
service life, thou.h	12 - 15	24
Relative pressure drop	1.0	1.0 - 2.5

Table 26

Some Data of Limestone DeSO_x Plant

Cleaned gas flow, m ³ /h	2110
Gas temperature: before DeSO _x plant, C	100
past absorber, C	50
past DeSO _x plant, C	55
SO ₂ Concentration: before DeSO _x plant, mg/m ³	2100
past DeSO _x plant, mg/m ³	300
SO ₂ discharge after cleaning, g/s	175
Pressure drop, kPa	3.5
Limestone consumption (95% of calcite), kg/h	6860
Amount of gypsum produced, kg/h	10860
Service water consumption, m ³ /h	60
Gas dust content: before DeSO _x plant, mg/m ³	150
past DeSO _x plant, mg/m ³	100

Table 27

Performance of 500 MW Unit with differ De-NO_x Plant Location

Parameter	500 MW Unit		
	Ekibastuz TPS-2	Ecologically clean TPS	
		DeNO _x past DeSO _x	in-build DeNO _x
Additional capacity*, MW	0	4.8	1.1
Heating surface, thou.m ²			
air heater	163	252	252
economizer	124	124	17.3
heat exchangers: air-water	—	3.42	6.12
in-build air-water	—	23.10	7.50
gas-gas	—	230.00	—
Design power of draft machines. MW	10.22	20.48	13.70
ESP power, MW	2.05	3.80	3.80
Power consumed for DeSO _x plant, MW	—	5.53	5.68
Increased auxiliary power, MW	—	17.54	13.15
Total fuel consumption, t/h	327.3	339.0	327.2
Boiler efficiency, %	91.09	94.37	94.07
Exhaust gas temperature, C	159	99	100
Annual specific fuel consumption, g/kW.h	322.4	342.7	330.3
Annual efficiency, %	38.15	35.89	37.20
Relative specific investment cost	1.0	1.58	1.50

* Power, produced by steam which was not used for feedwater preheating

Table 28

Design Characteristics of CFB Boiler for 300 MW Units

FURNACE	
Number per boilers	2
Plan dimensions, mm	108008600
Outer diameter and wall thickness of waterwall tubes, mm	326
Heat absorption surface of furnace waterwalls, m ²	1144
CYCLONES	
Number per boiler	4
Inner diameter, mm	10000
Inlet port size, mm	25005715
Lakedown inner diameter, mm	1500
Total height, mm	25000
EXTERNAL HEAT EXCHANGERS	
Number per boiler	4
Number of main superheater sections	2
Number of reheater sections	1
Outer diameter and wall thickness of tube, mm	386
Heat transfer surface, m ²	1250+480
Exchanger dimensions, mm: length	14200
width	6000
height	6000
CONVECTIVE SECTION	
Superheater: number of banks	1
tube dia, mm	3256
heat transfer surface, m ²	2750
Reheater: number of banks	2
tube dia, mm	424
heat transfer surface, m ²	6230
Economiser: number of banks	2
tube dia., mm	383
heat transfer surface, m ²	8200
Air heater: number of banks	3
number of passes	4
tube dia, mm	401.5
heat transfer surface, m ²	67500
Boiler dimensions, m: width	39.0
depth	43.5
height	52.5

Table 29

Some Data of CFB 300 MW AC-fired Boilers

Boiler capacity, t/h	1000
Flow of reheated steam, t/h	800
Temperature of superheated steam, C	545
Temperature of reheated steam, C	545
Pressure of live steam, MPa	25.0
Pressure of reheated steam, MPa	3.8
Feedwater temperature, C	270
Boiler efficiency, %	86.4
Heat losses, %: exhaust gases	5.5
unburned gases (CO, CH ₄ , etc.)	0
carbon loss	6.0
external	0.2
slag	0.4
limestone decomposition	1.5
Total fuel consumption, t/h	176.6
Limestone consumption, t/h	16.8
Exhaust gas temperature, C	140 (100)
Furnace thermal characteristics:	
outlet temperature, C	900
mean gas velocity, m/s	6.4
volume heat release rate, kW/m ³	169.3
Furnace ash balance:	
flue gas fly ash concentration at furnace outlet, kg/m ³	10.4
fly ash circulation ratio	180
ash fed to furnace, t/h	5300
Air distribution:	
furnace air excess	1.02
same, past air heater	1.28
share of primary air of total air flow, %	50
share of secondary air, %	50
share of recirculation air past air heater, %	9.5
Temperature, N:	
economizer inlet water	270
furnace chamber wall outlet steam	394
convective superheater outlet steam	402
external heat exchanger superheater outlet steam	545
convective reheater inlet steam	287
same, outlet steam	446
external heat exchanger reheater outlet steam	545
cold air	30
air heater inlet	50
air heater outlet	300
Convective section gas velocity, m/s:	
superheater	10.0
reheater	10.0
economizer	6.5
air heater	13.3
Air heater air velocity, m/s	6.9

Table 30
IGCC Plant Performance

Name	Types of gasifiers												Natural gas CCP			
	moving bed				entrained flow				air blast							
	oxygen blast		air blast		oxygen blast		air blast		oxygen blast		air blast					
Ambient temperature, C	-5	+15	-5	+15	-5	+15	-5	+15	-5	+15	-5	+15	-5	+15	-5	+15
HP live steam flow to ST, t/h	472	454	577	532	607	574	585	551	495	480						
LP steam flow past boiler, t/h	228	185	268	209	244	190	232	184	244	195						
Steam consumed for drying, t/h	99	86	129	112	124	106	111	97	0	0						
Superheated steam temperature, C	515	535	520	540	520	540	520	540	505	525						
Reheat temperature, C	460	470	455	465	460	475	465	475	455	460						
LP steam temperature, C	240	232	256	243	248	236	247	234	248	237						
Reheat steam pressure past boiler, MPa	2.25	2.16	2.30	2.16	2.30	2.16	2.30	2.16	2.20	2.16						
GT output, MW	509	418	500	413	510	414	445	372	487	405						
ST output, MW	196	188	240	220	246	233	242	227	222	210						
CCP gross output, MW	705	606	740	633	756	647	687	600	709	615						
Auxiliary power, MW	74	68	38	32	110	94	36	31	13	11						
IGCC net efficiency (on coal basis), %	43.6	43.4	44.9	44.2	43.9	43.8	44.8	44.1	52.1	52.0						
Fuel saving as compared with p.c.																
800 MW unit (39% efficiency), %	10.6	10.1	13.1	11.8	11.2	11.0	12.9	11.6	25.1	25.0						

Table 31

Coal characteristics adopted in CCP design

Parameter	Coal grade			
	Berezovo		Kuznetsk WS2	
	raw	dried	raw	dried
Heat value, Q, MJ/kg	15.66	21.97	20.51	
Ash content, %	4.70	6.60	24.00	
Moisture, %	33.00	6.00	11.50	
Sulfur content, %	0.20	0.28	0.40	
Elementary composition on fired basis, %:				
C	44.63	62.62	56.80	63.20
H	3.06	4.29	3.01	3.35
N	0.61	0.86	1.38	1.53
O	13.8	19.35	3.01	3.35
Volatiles per combustibles, %	48.00		20.00	

Table 32

Composition and properties of coal-derived gas

Parameters	Gasification technology and type of blast			
	moving-bed		entrained-flow	
	air		oxygen (95%)	
	raw	cleaned	raw	cleaned
Gas composition, %				
including: CO	19.52	19.53	54.60	54.70
CO ₂	5.92	5.93	9.70	9.72
H ₂	10.17	10.18	20.40	20.44
H ₂ S	0.06		0.175	
CH ₄	1.39	1.39		
H ₂ O	14.96	14.97	14.10	14.10
N ₂	47.98	48.00	1.00	1.00
Density, kg/m ³	1.120	1.001	1.005	
Low heat value, MJ/m ³	4.07	4.06	9.09	9.07
Consumption per 1 kg of dried coal, kg				
oxydant		2.69	0.74	
steam		0.40		
Combustible gas yield, kg/kg		4.454	1.590	
Raw gas temperature at reaction zone outlet, C	1280		1530	

With entrained-flow oxygen-blown gasification of Kuznetsk coal featuring lower ash melt temperature, the gasifier outlet temperature is adopted at 1300C. The raw syngas contains 65% CO, 2.7% CO₂, 29.7% H₂; its LHV = 11.43 MJ/m³, density 0.925 kg/m³.

Table 33

Characteristics of fluidized bed gasification system

Reaction chamber pressure, MPa	2.0 - 2.1
Fluidized bed area, m ²	8.7
Fluidized bed height, m	3.0
Combustible gas LHV, MJ/kg	4.07
Flows for one gasifier, t/h (kg/s):	
coal	60 (16.7)
steam and air	230 (63.9)
ash from bed	8 (2.2)
Consumption of oxydizers per kg of coal, kg:	
air	3.15
steam	0.67
Gas yield, kg/kg of coal	4.3
Temperature, C:	
in reaction volume	1100
steam-air	450
gas past reactor	950
gas before cleaning	210
gas past cleaning	160
gas before expansion turbine	310
Coal characteristics: LHV, MJ/kg	23.65
Moisture, %	10 - 12
Ash content, %	13 - 21.5
Sulfur content, %	0.35 - 0.40

FIGURES




Fig.1. Russian electric power generation mix, GW




Fig. 2. Russian fuel mix for fossil power plants




Fig.3. Some data on coal condensing power units (TPS)





Fig. 4. Pp-3950-25-545/542 GMN (TGMP-1202) Boiler: a,b) - longitudinal and cross sections respectively






Fig. 5. Pp.-2650-255 (P-67) Boiler
(cross-section)



a)



b)

Fig.6. Boiler P-1650-255 (P-57R):

a - longitudinal section view

b - cross section view




Fig. 7. The 420 t/h bubbling fluidized bed boiler (E-420-140 KS); steam pressure 13,8 MPa, temperature 560°C




Fig. 8. Demo 500 t/h CFB boiler




Fig 9. The Supercharged
 Steam Generator
 Steam output - 655 t/h;
 live steam pressure-14 MPa;
 superheated steam tempera-
 ture - 545/545°C; gas
 pressure - 0,9 MPa




Fig. 10. The typical design of HP cylinder with loop steam flow




Fig. 11. The typical LP cylinder




Fig. 12. Longitudinal section through GTE-150 unit




Fig. 13. Longitudinal section through NK-37 unit




Fig. 14. The first stage buckets with various internal cooling

a - air deflector

b - serpentine

c - vortex




Fig. 15. NO_x emission versus O₂ after superheater before (1991) and after (1992-93) reconstruction. Boiler 420 t/h; brown coal




Fig. 16. NOx emissions when high concentrated pulverized coal mixture is fired

- 1 - coal entrance before burner;
- 2 - coal entrance in burner throat; α - furnace outlet excess air coefficient




Fig. 17. Sulfur fixation by fly ash in
boilers firing K-A coals




Fig. 18. The coal pulverizing system with an installation for high-temperature powder heating (for a P-67 boiler). (1) Raw coal hopper; (2) raw coal feeder; (3) MV 3400 fan-pulverizer; (4) coal-powder concentrator; (5) coal-powder heater; (6) muffle burner; (7) cyclone; (8) furnace; (I) fuel; (II) coal-powder-air mixture (concentrated stream); (III) coal-powder-air mixture (low-powdery stream); (IV) hot air; (V) flue gases




Fig. 19. Two-storey baghouse with PR0-12000 filter




Fig. 20. Cross-section of 800 MW Unit
1-ST; 2-boiler; 3-mills; 4-air heater; 5-baghouse;
6-induced draught fan; 7-stack




Fig. 21. The layout of the furnace:
with in-wall vortex burners




Fig. 22. The furnace with tangential scheme of fuel combustion




Fig. 23. Low Temperature 500 MW Unit's Boiler Path with High Dust DeNOx

1-economiser; 2-hot ESP; 3-DeNOx; 4-air heater; 5-main ESP; 6-main induced draught fan; 7-DeSOx; 8-gas heater; 9-auxiliary induced draught fan; 10-stack; 11-hot water for gas heating; 12-flue gases





Fig. 24. Low Temperature 500 MW Unit's Boiler Path with Low Dust DeNO_x

1-economiser; 2-air heater; 3-main ESP; 4-DeSO_x system; 5-main induced draught fan; 6-convective gas heater-cooler; 7-high temperature gas heater; 8-DeNO_x; 9-auxiliary induced draught fan; 10-stack; 11-superheated steam for gas heating; 12-flue gases


Fig. 25. Wet Desox System

1 - scrubber; 2 - water collected part; 3 - slurry
 recirculating pump; 4 - slurry tanks; 5 - oxidizing
 air blower; 6 - waste slurry and sludge pump;
 7 - hydrocyclone; 8 - centrifuge; 9 - gas heater;
 10 - induced-draught fan; 11 - limestone; 12 - water;
 13 - slurry preparation



1 - boiler's economizer; 2 - tube air heater; 3,4,5 - first, second and third stage; 6 - feedwater heater; 7 - condensate heater; 8 - LP preheaters; 9 - HP preheaters; 10 - ambient air; 11 - to-furnace air; 12 - recirculated air

Fig. 26. Deep flue gas cooling using excessive air method



1 - ST: 2 - boiler: 3 - hot ESP: 4 - Denox system: 5 - air heater:
6 - main ESP: 7 - DeSOx system: 8 - induced draught fan

FIG. 28. Cross-section of p.c.500 MW Unit





FIG. 29. Schematic of a CFB boiler with K-300-240 Turbine



1. raw coal hopper
2. hammer mill
3. separator
4. cyclon
5. day hopper
6. furnace and gas path
7. live steam-ash heat exchanger
8. reheat steam-ash heat exchanger
9. full flow separator
10. starting separator
11. air preheater
12. ESP
13. overflow air
14. HP air-water heater
15. LP air-water heater
16. discharged bed ash cooler
17. for mill air fan
18. steam turbine
19. condenser
20. LP steam-water preheaters
21. feed water turbo pump
22. feed water electrical pump
23. HP steam-water preheaters
24. forced draft fans
25. induced draft fans
26. condensate pumps

FIG. 30. Cross-section of the 1000 t/h GFB boiler




Fig. 31. The layout of the 1000 t/h CRB boiler




FIG. 32. CRB boiler installation: a) cross-section, b) layout
1 - furnace; 2 - hot cyclones; 3 - air heater; 4 - ESP





FIG. 33. Cross-section of 300 MW CRB unit
 1 - ST; 2 - CRB boiler; 3 - ESP; 4 - stack



(a) anthracite culm conversion;
 (b) NOx formation (Ca/S=2.5 - 4.0,
 $t = 860-900^{\circ}\text{C}$, $\alpha = 1.15-1.25$); (c)
 SO_2 fixation, 1 - primary air to fuel
 stoichiometry

FIG. 34. Anthracite culm firing
 efficiency with CFB





FIG. 35. Demo 500t/h CFB boiler with "cold" cyclones.



1 - coal treatment: 2 - gasifier: 3 - waterwall cooling system:
 4 - gas cooler: 5 - gas cleaning: 6 - GT: 7 - HRSG: 8 - ST:
 9 - condenser: 10 - direct contact preheater: 11 - alternator:
 12 - additional compressor: 13 - combustible gas auxiliary
 compressor

a - coal: b - raw combustible gas; c - clean combustible gas;
 d - GT exhausted gases; e - to stack; f - air; g - compressed
 air; h - steam




Fig. 26 - Flow Sheet of Air Blown IGCC-600

Fig. 37. Flow Sheet of Oxygen Blown IGCC-600




FIG. 38. Moving-bed gasifier




FIG. 39. Convective gas cooler for moving-bed gasifier





Fig. 40. Entrained-flow oxygen blown gasifier



- 1 - desulfurization reactors
- 2 - cyclones of coarse cleaning
- 3 - ceramic filters
- 4 - regenerators
- 5 - sorbent hopper
- 6 - feeder
- 7 - lockhopper
- 8 - dathopper
- a - raw combustible gas
- b - cleaned combustible gas
- c - pure gas
- d - SO₂ for sulphuric acid production
- e - cooling water
- f - regenerated sorbent and ash
- g - sorbent addition
- h - sorbent-ash mix
- o - oxidizer




Fig. 41. The cleaning system of raw coal derivative gases.

1 - GT; 2 - HRSC; 3 - ST; 4 - condenser;
 5 - direct contact preheater; 6 -
 additional compressor; 7 - auxiliary
 turbine; 8 - condensate pump; 9 - feed
 pump; 10 - air to gasifier (for air
 blown options); 11 - feedwater to gas
 cooler; 12 - steam for coal drying; 13 -
 steam to gasifier; 14 - steam of
 gasification system; 15 - condensate
 return from dryers





Fig. 42 - Flow Sheet of Power Plant IGCC-600

FIG. 43. Heat-Recovery Boiler



A-A




Fig. 44. Layout of the Main Building for Power Part of IGCC Plant

- 1 - GT; 2 - alternator; 3 - HRSG; 4 - air suction; 5 - ST;
- 6 - ST alternator; 7 - electrical driven feed pump; 8 - stand
- by feed pump; 9 - place for maintenance





Fig. 45. Cross-section of the Main Building for Power Part of ICC Plant

- 1 - CT; 2 - alternator; 3 - HRSG; 4 - air suction; 5 - ST; 6 - ST alternator; 7 - main control room

- 1 - gasifier; 2 - steam drum of gasifier cooling;
- 3 - reactor of desulfurisation system; 4 -
- cyclone of coarse cleaning; 5 - ceramic filters;
- 6 - regenerator; 7 - sorbent hopper; 8 - feeder;
- 9-10 - lockhopper system; 11 - day hopper; 12 -
- slag removing lockhopper; 13 - hopper; 14 -
- cyclone; 15 - bridge crane; 16 - lump coal hopper;
- 17 - fines hopper; 18 - convective gas cooler

Fig. 46. Cross-section of gasification system using air blown moving-bed gasifier






Fig. 47. The layout of TPS with 10 IGCC 600 MW Units

- 1 - main building; 2 - main control room; 3 - gasification systems;
- 4 - fuel treatment; 5 - transformers; 6 - air separation plant (ASP); 7 - ASP compressor's building; 8 - sulphuric acid plant;
- 9 - coal yard; 10 - conveyors galleries; 11 - fuel oil tank;
- 12 - open switchgear; 13 - auxiliary building; 14 - offices;
- 15 - water treatment; 16 - ash disposal place; 17 - sludge pond;
- 18 - auxiliary boilerhouse




Fig. 48. Flow Sheet of IGCC Unit rated 250 MW

- 1 - coal drying; 2 - fluidized-bed gasifier;
- 3 - gas cooler; 4 - drum of SSG; 5 - internal circulating pump SSG; 6 - furnace of SSG;
- 7 - top combustor; 8 - gas-water heater (GMH);
- 9 - scrubber; 10 - auxiliary steam turbine; compressor; 12 - auxiliary steam turbine;
- 13 - turboexpander; 14 - economizer; 15 - HP preheaters; 16 - main steam turbine; 17 - alternators; 18 - GT compressor; 19 - GT turbine;
- 20 - steam condenser; 21 - condensate pump;
- 22 - LP preheaters; 23 - deaerator; 24 - feed pump; 1, 11 - steam to HP and LP sections of ST;
- III - condensate to GMH; IV - feedwater to GMH; V - condensate to deaerator; VI - feedwater to economizer




Fig. 49. Fluidized-bed Gasifier
and Convective Gas
Cooler




Fig. 50. Fuel Treatment for Fluidized-bed Gasifier

- 1 - raw coal hopper; 2 - feeder; 3 - screen
- 4 - crusher; 5 - elevator; 6 - fluidized-bed dryer;
- 7 - combustion gases; 8 - treated fuel feeder;
- 9 - to lockhopper; 10 - dust granulator; 11 - ESP;
- 12 - cyclone




Fig. 51. The Layout of IGCC Plant rated 250 MW

- 1 - GT; 2 - ST; 3 - supercharged boiler; 4 - gas-water heat exchanger; 5 - stack; 6 - gasifier's building; 7 - fuel treatment; 8 - auxiliary compressor-turbodetander; 9 - I&C room; 10 - main control room; 11 - balance of plant equipment; 12 - place for maintenance