

U.S. Department of Energy National Energy Technology Laboratory

Early Entrance Co-Production Plant – Decentralized Gasification Cogeneration Transportation Fuels and Steam From Available Feedstocks

DOE Cooperative Agreement DE-FC26-00NT40693

Quarterly Technical Progress Report July to September 2002

WMPI PTY., LLC January 2003

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the Untied States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

ABSTRACT

Waste Processors Management, Inc. (WMPI), along with its subcontractors Texaco Power & Gasification (now ChevronTexaco), SASOL Technology Ltd., and Nexant Inc. entered into a Cooperative Agreement DE-FC26-00NT40693 with the U. S. Department of Energy (DOE), National Energy Technology Laboratory (NETL) to assess the technoeconomic viability of building an Early Entrance Co-Production Plant (EECP) in the United States to produce ultra clean Fischer-Tropsch (FT) transportation fuels with either power or steam as the major co-product. The EECP design includes recovery and gasification of low-cost coal waste (culm) from physical coal cleaning operations and will assess blends of the culm with coal or petroleum coke.

The project has three phases. Phase I is the concept definition and engineering feasibility study to identify areas of technical, environmental and financial risk. Phase II is an experimental testing program designed to validate the coal waste mixture gasification performance. Phase III updates the original EECP design based on results from Phase II, to prepare a preliminary engineering design package and financial plan for obtaining private funding to build a 5,000 barrel per day (BPD) coal gasification/liquefaction plant next to an existing co-generation plant in Gilberton, Schuylkill County, Pennsylvania.

The current report covers the period performance from July 1, 2002 through September 30, 2002.

Table of Contents

TABLE OF CONTENTS

Sec	tion		Page
1	Intro	duction and Summary	1-1
	1.1	Introduction	1-1
		1.1.1 Phase I - Concept Definition and RD&T Planning	1-1
		1.1.2 Phase II - R&D and Testing	1-1
		1.1.3 Phase III – Preliminary Engineering Design	1-2
	1.2	Summary	1-2
2	Phase	e I Task 1 – Project Plan	2-1
3	Phase	e I Task 2 – Concept Definition, Design Basis & EECP Process Configuration	3-1
4	Phase	e I Task 3 – System Technical Assessment	4-1
5	Phase	e I Task 4 - Feasibility Design Package Development	5-1
	5.1	Preliminary Plant Air Emission Estimates	5-1
6	Phase	e I Task 5 - Market Analysis	6-1
7	Phase	e I Task 6 – Preliminary Site Analysis	7-1
8	Project Management		
	8.1	Biweekly Project Status Report	8-1
	8.2	Project Milestones Plan and Log	8-1
9	Expe	rimental	9-1
	9.1	Executive Summary	9-1
	9.2	Experimental	9-1
	9.3	Results and Discussion	9-1
	9.4	Conclusions	9-1
	9.5	References	9-1

Table of Contents

List of Figures and Tables

List of Figures

Figure 5.1	Overall EECP Process Configuration
Figure 8.1	Project Schedule (Revised 8/15/2002)

List of Tables

Table 1.1	Scope of Work Task Summary
Table 5.1	Fuel Gas to and Corresponding Flue Gas from the GT
Table 5.2	Fuel Gas to and Corresponding Flue Gas from the HC Reactor Fired Heater
Table 5.3	Fuel Gas to and Corresponding Flue Gas from the HC Fractionator Fired Heater
Table 5.4	Estimated Flow and Composition of Thermal Oxidizer Exhaust
Table 5.5	Estimated Flow and Composition of Truck Loading Vent Thermal Incineration Exhaust
Table 5.6	Estimated Flow and Composition of Average Tank Filling Displacement Vent

Section 1 Introduction and Summary

1.1 INTRODUCTION

WMPI, along with its subcontractors Texaco (now ChevronTexaco), Sasol, and Nexant entered into a Cooperative Agreement DE-FC26-00NT40693 with the U. S. Department of Energy (DOE), National Energy Technology Laboratory (NETL), to assess the technical and economic viability of building an Early Entrance Co-Production Plant (EECP) in the U. S. to produce ultra clean Fischer-Tropsch (FT) transportation fuels with either power or steam as the major co-product. The EECP design emphasizes on recovery and gasification of low-cost coal wastes (culm) from coal cleaning operations, and will assess blends of the culm with coal or petroleum coke as feedstocks. The project has three phases.

1.1.1 Phase I – Concept Definition and RD&T Planning

Phase I objectives include concept development, technology assessment, conceptual designs and economic evaluations of a Greenfield commercial co-production plant and of a site specific demonstration EECP to be located adjacent to the existing Gilberton Power Station. There are very few expected design differences between the Greenfield commercial co-production plant versus the EECP plant other than:

- The Greenfield commercial plant will be a stand-alone FT/power co-production plant, potentially with larger capacity than the EECP to take full advantage of economies of scale.
- The EECP plant, on the other hand, will be a nominal 5,000 bpd plant, fully integrated into the Gilberton Power Company's Cogeneration Plant's existing infrastructure to reduce cost and minimize project risks. The Gilberton EECP plant will be designed to use eastern Pennsylvania anthracite coal waste and/or a mixture of culm and other fuels as feedstock.

Phase I includes 11 tasks and the following major deliverables.

- A project management plan.
- A process feasibility design package with sufficient details to determine orderof-magnitude cost estimates for preliminary economic and market analyses.
- A preliminary environmental and site analysis.
- A Research, Development and Testing (RD&T) plan for Phase II tasks.
- A preliminary project financing plan.

1.1.2 Phase II – R&D and Testing

The Phase II objective is to perform research, development and process performance verification testing of any design deficiencies identified in Phase I. Due to the relative maturity of the two key technologies (Texaco's coal gasification and SASOL's FT) proposed for the EECP designs, Phase II activities will focus on feedstock

Section 1 Introduction and Summary

characterization and gasification process performance testing rather than research and development. Specific Phase II goals include:

- Characterization of anthracite culm and its mixture with other fuels as feedstocks for the Texaco gasifier.
- Gasification performance (pilot plant) testing of design anthracite culm feedstocks at an existing Texaco facility to verify its performance.

1.1.3 Phase III – Preliminary Engineering Design

The objective in Phase III is to upgrade the accuracy of the Phase I site-specific Gilberton EECP capital cost from plus or minus 35% to plus or minus 20%. The increased cost estimation accuracy is achieved by updating the Phase I inside battery limits (ISBL) processing plant design packages to incorporate Phase II findings, by refining the outside battery limits (OSBL) utility and offsite support facility design packages to include final and updated ISBL unit demands, by obtaining actual budgetary quotes for all major equipment, and by further engineering to define the actual bulk commodities requirements.

The upgraded Phase III capital cost estimate, together with the updated operating and maintenance cost estimate, are crucial elements to finalize the EECP Project Financing Plan needed to proceed with detailed engineering, procurement and construction of the EECP.

The Phase III goals and deliverables include the development of:

- Preliminary Engineering Design package of the EECP.
- A Project Financing Plan.
- An EECP Test Plan.

The project scope of work consists of sixteen tasks organized into the three phases as shown in Table 1.1. The table also shows the project team members responsible for the leading role for each task. The specific task description details were discussed in the Project Management Plan.

1.2 SUMMARY

Main technical activity performed during the current reporting period centers on completing the Greenfield (Texaco gasifier based) EECP design package, capital and operating cost estimates, and preliminary plant emission estimates needed for Phase I Task 7 activity of Preliminary Environmental Assessment.

Section 1 Introduction and Summary

Table 1-1

Scope of Work Task Summary

Phase/Task	Description	Task Leaders
Phase I	Concept Definition and RD&T Planning	
Task 1	Project Plan	Nexant
Task 2	Concept Definition, Design Basis & EECP Process Configuration Development	Nexant
Task 3	System Technical Assessment (Trade-off Analysis)	Nexant
Task 4	Feasibility Study Design Package Development	Nexant (w/individual Process Design package from Texaco and Sasol)
Task 5	Market Assessment	Texaco
Task 6	Preliminary Site Analysis	WMPI and Consultants
Task 7	Preliminary Environmental Assessment	WMPI and Consultants
Task 8	Economic Assessment	WMPI and Consultants
Task 9	Research Development and Test Plan	Texaco
Task 10	Preliminary Project Financing Plan	WMPI and Consultants
Task 11	Phase I - Concept Report	Nexant
Phase II	R&D and Testing	
Task 1	Feedstock Mix Characterization and Gasification Performance Verification	Texaco (w/ support from Nexant and WMPI)
Task 2	Update RD&T Plan	Техасо
Phase III	EECP Engineering Design	
Task 1	Preliminary Engineering Design Package Development	Nexant – with a) Texaco – Gasification Design Package b) Sasol – FT Design Package c) Nexant – BOP and cost estimate
Task 2	Project Financing Plan	WMPI and Consultants
Task 3	EECP Test Plan	Nexant

Section 2 Phase I Task 1 – Project Plan

TASK COMPLETED.

A Project Management Plan was prepared, issued and approved by DOE. A copy was submitted to the AAD Document Control Office of DOE/NETL on May 15, 2001.

This plan provides a road map for the overall project execution delineating the project:

- Objectives.
- Detailed work breakdown structure and obligated deliverables.
- Technical and management approach.
- Control plan scheduling, budget and reporting.
- Administration details.

Section 3 Phase I Task 2 – Concept Definition, Design Basis & EECP Process Configuration

TASK COMPLETED.

- 3.1 EECP concept and process configuration defined, giving full considerations of:
 - WMPI's feedstock availability and quality (e.g., ash content, composition and anticipated fusion temperature.)
 - Desired mode of operation for Texaco's gasification process in handling the design project feed mix.
 - Design consideration of Sasol's Low-Temperature FT (LTFT) process giving the estimated design syngas feed.
 - System integration and site-related issues (e.g., syngas clean up, utility availability.)
- 3.2 Gilberton EECP Design Basis established, and a Basic Engineering Design Data (BEDD) package was developed to guide the overall process design development regarding:
 - Plant capacity
 - Site data
 - Feedstock properties
 - Product specifications
 - Battery limits and offsite utility specifications
- 3.3 Project Instruction of Equipment Code of Accounts established.

Details of the above were reported in previous Quarterly Technical Progress reports.

Section 4 Phase I Task 3 – System Technical Assessment

TASK COMPLETED.

Under this task 1) technical design issues/systems (e.g., ash fusion characteristics of EECP feed mix and its potential effect on gasification performance) identified in Phase 1 Task 2 were assessed in more detail, and 2) preliminary heat, material and utility balance sensitivity analyses were carried out, based on process performance estimates and utility demands from Texaco and Sasol for the gasification and FT synthesis section respectively, to optimize the overall EECP process plant configuration for detailed process design package development of Phase I Task 4 activity.

Greenfield (Texaco gasifier based) EECP Design Package completed.

Figure 5-1 shows the overall Texaco gasifier based EECP block flow configuration.

Figure 5-1 Overall EECP Process Configuration

Overall ISBL plant consists of two main process sections: Texaco Gasification, and Sasol FT Synthesis and product work up (PWU). It is designed to use anthracite culm of 20% ash as the primary feed. The design has the operation flexibility of feeding in 25% petroleum coke as feed. The plant is supported by nineteen OSBL offsite facilities, descriptions of which were reported in previous quarterly technical reports.

5.1 Preliminary EECP Plant Air Emission Estimates

The following preliminary air pollutants emission information for the EECP are based on the Greenfield design material balances of gasifying 100% anthracite culm feed at 600 psig (Texaco Type C Feasibility Study Package), and for synthesizing FT liquid using SASOL iron-based catalyst (SASOL Feasibility Study Package). Total anthracite culm feed is 3534 short tons (dry)/day with a HHV of 11,119 Btu/LB (dry). Total FT liquid produced includes 3732 BPSD of upgraded diesel plus 1281 BPSD of stabilized naphtha. The plant generates approximately 131 MW of electricity, of which 92 MW is consumed internally and 39 MW is available for export. It is assumed that the two CO2-rich streams from the Rectisol unit will be exported to third party for CO2 production or sequestration.

There are four continuous atmospheric vents for the EECP:

- Combined cycle power plant gas turbine/HRSG flue gas;
- Hydrocracker reactor fired heater flue gas;
- Hydrocracker fractionator fired heater flue gas;
- Sulfur Recovery/Tail Gas Treating Unit thermal oxidizer exhaust.

There are two intermittent but regular vents of displaced vapor from tank truck loading, and from storage tank filling. The estimated daily average tank truck loading and storage tank filling displacement volumes are 20 ACFM each, which is equivalent to the daily average FT diesel and naphtha production rate.

Intermittent emissions from startup and shutdown vents and flares are not included. These intermittent loads and venting durations will vary depending on the final plant startup and shutdown procedures. Also, not included are leaks and tank breathing vents.

Air pollutants include SO2, NOx, CO, VOC, and PM. Following are the preliminary estimated total continuous pollutant emissions for the EECP Greenfield Plant:

	Lbs/Hr	Tons/Year (1)
CO	14.4	54
NOx	18.6	70
SOx	7.8	29
VOC	2.2	8
Particulates	6.2	23

Notes:

(1) Assumed 7500 operating hours per year (85% onstream factor).

Detailed emission rates for the continuous vents are discussion in the following sections.

5.1.1 Combined Cycle Power Plant Gas Turbine Flue Gas Air Pollutants Emission

Excess process offgases are burned in a gas turbine (GT) to generate electricity. The GT is equipped with HRSG to recover waste heat from the GT exhaust by preheating boiler feed water and generating high pressure superheated steam. After meeting the overall plant steam demands, excess steam from the HRSG and other process producers are converted to electricity in a condensing steam turbogenerator (STG).

Table 5.1 is a listing of the flows and compositions of the fuel gas to, and the corresponding flue gas from the GT.

Emissions of VOC and PM are calculated based on fuel gas HHV per EPA AP-42 Section 3.1 (Stationary Gas Turbines for Electricity Generations). The fuel gas fired in the GT has a HHV of 841 MMBtu/Hr, and the emissions based on the published EPA emission factors are:

VOC	0.0021 lbs/MMBtu (HHV)	841 x 0.0021 = 1.8 Lbs/Hr
PM	0.0066 lbs/MMBtu (HHV)	841 x 0.0066 = 5.6 Lbs/Hr

Steam injection is included in the GT combustion to control the NOx level in the GT exhaust to 25 ppmV (98,900 MPH at 15% O2). The HRSG is equipped with SCR to further reduce the NOx and the CO emission rates to 2.5 and 3.0 ppmV (at 15% O2) respectively. The estimated NOx and CO emissions from the CC HRSG stack are:

CO	3.0 ppmV @ 15% O2 $3.0 \times 98900 / 1000000 \times 28 = 8.3 \text{ Lbs}$	s/Hr
NOx	2.5 ppmV @ 15% O2 2.5 x 98900 / 1000000 x 46 = 11.4 Lbs	s/Hr

For SOx emissions, it is assumed that all of the sulfur in the syngas feed to the FT block (which includes both the FT plant and the PSA Hydrogen plant) is included in the FT tailgas. Total syngas feed to the FT block is 21,367 moles/Hr or 195 MMSCFD. With a design sulfur content of 40 ppbV to meet Sasol Iron-based FT process specifications, total sulfur in the syngas feed is $21,367 \times 40 / 1,000,000,000 = 0.00085$ moles/Hr, and the maximum SOx emission from the GT is $0.00085 \times 64 = 0.055$ Lbs/Hr as SO2. And maximum H2S content in 70.8 MMSCFD of fuel gas is thus $40 \times 195 / 70.8 = 110$ ppbV.

Description	GT Fuel	Combustion	NOx	GT Flue
*	Gas	Air	Steam	Gas
Туре	HP Med	Ambient		
	Btu Syngas	Air		
Heating Values:				
MMBtu/Hr (HHV)	841	10	84	165
MMBtu/Hr (LHV)	767	0	0	0
Btu/SCF(LHV)	261	0	0	0
Gas Flow Rates & Properties:				
MMSCFD (1)	70.5	458.4	40.6	546.2
LB/Hr (1)	167.300	1451.900	80.390	1.699.600
Mole Wt	21.6	28.9	18.0	28.3
Gas Composition, Vol%:				
$N_2 + Ar$	6.8	78.3		66.5
O_2		20.7		11.3
$\overline{CO_2}$	20.6			7.5
Water	0.1	1.0	100.0	14.7
H ₂	38.9			
C_1 's	2.5			
C_2 's	0.3			
C_3 's	0.5			
C_4 's	0.3			
C_5 +'s	0.3			
H_2S	110 ppbV (1	1)		
CO	29.7			5 ppmV
NOx				4 ppmV
SOx				14 ppbV (1)
Hydrocarbons				1 ppmW
Particulates				3 ppmW
Estimated Pollutant Emission	. Lbs/Hr:			
CO	64.620			8 (3)
NOx				11 (3)
SOx				0.055 (1)
VOC				1.8 (2)
Particulates				5.6 (2)

Table 5.1 Fuel Gas to and Corresponding Flue Gas from the GT

Notes:

(1) Assume all sulfur in the syngas feed to the FT Block is left in the GT fuel gas.

(2) Based on EPA AP-42 emission factors for uncontrolled natural gas fired GT.

(3) Based on GE's estimate of 3 ppmV for CO and 2.5 ppmV for NOx after SCR.

5.1.2 Hydrocracker Reactor Fired Heater Flue Gas Air Pollutants Emission

FT Hydrocracker reactor feed is preheated in a fired heater before enters the reactor. FT plant low-pressure (LP) offgases mixed with the PSA Hydrogen plant purge gas are burned as fuel in the HC reactor fired heater.

Table 5.2 is a listing of the flows and compositions of the fuel gas to, and the corresponding flue gas from the Hydrocracker (HC) reactor (Rx) fired heater.

Emissions of NOx, CO, VOC and PM are calculated based on fuel gas HHV per EPA AP-42 Section 1.4 (Natural gas fired heater less than 100 MMBtu/Hr). The emission rates will be calculated assuming uncontrolled natural gas fired heaters. The fuel gas fired in the HC Rx heater has a HHV of 20.7 MMBtu/Hr. Emissions based on the published EPA emission factors are:

CO	0.0824 lbs/MMBtu (HHV)	20.7 x 0.0824 =	1.7 Lbs/Hr
NOx	0.098 lbs/MMBtu (HHV)	$20.7 \ge 0.098 =$	2.0 Lbs/Hr
VOC	0.0054 lbs/MMBtu (HHV)	20.7 x 0.0054 =	0.11 Lbs/Hr
PM	0.0075 lbs/MMBtu (HHV)	20.7 x 0.0075 =	0.16 Lbs/Hr

For SOx emissions, it is assumed that all of the sulfur in the Di-Methyl Di-Sulfide (DMDS) injection for sulfiding the HC catalysts will end up in the LP fuel gas. Maximum DMDS injection rate is estimated to be 1.0 liters/hr, which is 2.35 lbs/hr or 0.025 MPH. Total LP fuel gas burned is 2.88 MMSCFD, or 316 MPH. The maximum H2S content in the LP fuel gas is thus $2 \times 0.025 / 316 \times 1000000 = 158$ ppmV.

Maximum SOx emission from burning LP fuel gas is thus $2 \ge 0.025 \ge 64 = 3.2$ lbs/Hr as SO2. This rate is conservative since there are potential sulfur losses due to solubility in the liquids and irreversible reactions with the FT catalysts. Since 34.4% of the total LP fuel gas is burned in the HC Rx fired heater, SOx emission from the HC Rx fired heater is $3.2 \ge 0.344 = 1.1$ lbs/Hr.

Table 5.2

Fuel Gas to and Corresponding Flue Gas from the HC Reactor Fired Heater

Description	HC Rx Fired Htr Fuel Gas	Combustion Air	HC Rx Fired Htr Flue Gas
Туре	LPMed Btu Syngas	Ambient Air	
Heating Values:			
MMBtu/Hr (HHV)	20.7	0.10	1.6
MMBtu/Hr (LHV)	19.2	0	0
Btu(LHV)/SCF	467	0	0
Gas Flow Rates & Properties			
MMSCFD	0 99	4 74	5 41
LB/Hr	2 300	15 000	17 300
Mole Wt	21.2	28.9	29.1
Gas Composition Vol%			
$N_2 + Ar$	3.1	78.3	68.9
O_2		20.7	2.0
$ \frac{C}{CO_2} $	53		14.5
Water	0.6	1.0	14.6
H ₂	38.0		
C_1 's	0.1		
C_2 's	0.2		
C_3 's	2.3		
C_4 's	3.8		
C_5 +'s	1.2		
H ₂ S	158 ppm ^V	V(1)	
CO	45.4		102 ppmV
NOx			73 ppmV
SOx			29 ppmV (1)
Hydrocarbons			6 ppmW
Particulates			9 ppmW
Estimated Pollutant Emission Lbs/Hr			
СО	1380		1.7 (2)
NOx			2.0 (2)
SOx			1.1 (1)
VOC			0.11 (2)
Particulates			0.16 (2)

Notes:

(1) Assume all sulfur in the DMDS injection for HC catalyst sulfiding is left in the LP fuel

gas.

(2) Based on EPA AP-42 emission factors for uncontrolled natural gas fired process furnaces.

5.1.3 Hydrocracker Fractionator Fired Heater Flue Gas Air Pollutants Emission

FT Hydrocracker (HC) fractionator feed is heated in a fired heater before being separated into diesel and naphtha products. FT plant low pressure (LP) offgases mixed with PSA Hydrogen plant purge gas are burned as fuel in the HC fractionator fired heater. In addition to burning LP fuel gas, the HC fractionator also serves to incinerate the small alcohol-contaminated overhead vent from the FT produced water stripper.

Table 5.3 is a listing of the flows and compositions of the LP fuel gas to, and the corresponding flue gas from the Hydrocracker (HC) fractionator (Fract) fired heater.

Emissions of NOx, CO, VOC and PM are calculated based fuel gas HHV per EPA AP-42 Section 1.4 (Natural gas fired heater less than 100 MMBtu/Hr). The emission rates will be calculated assuming uncontrolled natural gas fired heaters. The fuel gas fired in the HC Fract heater has a HHV of 39.5+1.29=40.8.0 MMBtu/Hr. Emissions based on the published EPA emission factors are:

CO	0.0824 lbs/MMBtu (HHV)	40.8 x 0.0824 =	3.4 Lbs/Hr
NOx	0.098 lbs/MMBtu (HHV)	$40.8 \ge 0.098 =$	4.0 Lbs/Hr
VOC	0.0054 lbs/MMBtu (HHV)	40.8 x 0.0054 =	0.22 Lbs/Hr
PM	0.0075 lbs/MMBtu (HHV)	40.8 x 0.0075 =	0.31 Lbs/Hr

As discussed in the previous Hydrocracker reactor fired heater emission, maximum SOx emission from burning LP fuel gas is 3.2 lbs/Hr as SO2. Since 65.6% of the total LP fuel gas is burned in the HC fractionator fired heater, SOx emission from the HC fractionator fired heater is $3.2 \times 0.656 = 2.1$ lbs/Hr. And the maximum H2S content in the LP fuel gas is 158 ppmV.

Description	HC Fract Fired Htr Fuel Gas	FT Prod Water Strip Ovhd Vent	Combustion Air	HC Fract Fired Htr Flue Gas
Туре	Med Btu Syngas	CO2 Rich Gas	Ambient Air	
Heating Values: MMBtu/Hr (HHV) MMBtu/Hr (LHV) Btu(LHV)/SCF	39.5 36.6 467	1.29 1.25 166	0.20 0 0	3.2 0 0
Gas Flow Rates & Prop MMSCFD LB/Hr Mole Wt	erties: 1.88 4,390 21.2	0.18 780 39.1	9.43 29,880 28.9	10.91 35,040 29.3
$\begin{array}{c} \text{Gas Composition, Vol}\% \\ N_2 + Ar \\ O_2 \\ \text{CO}_2 \\ \text{Water} \\ H_2 \\ C_1 \text{'s} \\ C_2 \text{'s} \\ C_3 \text{'s} \\ C_4 \text{'s} \\ C_5 + \text{'s} \\ H_2 S \\ \text{CO} \\ \text{NOx} \\ \text{SOx} \\ \text{Hydrocarbons} \\ \text{Particulates} \end{array}$	6: 3.1 5.3 0.6 38.0 0.1 0.2 2.3 3.8 1.2 158 ppmV 45.4 	 69.9 7.0 1.0 0.5 (1) 1.5 20.1 	78.3 20.7 1.0 	68.1 2.0 15.5 14.4 101 ppmV 72 ppmV 27 ppmV 27 ppmV (1) 6 ppmW 9 ppmW
Estimated Pollutant Em CO NOx SOx VOC Particulates	ission, Lbs/Hr 2630 	: 8.4 	 	$\begin{array}{cccc} 3.4 & (2) \\ 4.0 & (2) \\ 2.1 & (1) \\ 0.22 & (2) \\ 0.31 & (2) \end{array}$

Table 5.3Fuel Gas to and Corresponding Flue Gas from the HC Fractionator Fired Heater

Notes:

(1) Assume all sulfur in the DMDS injection for HC catalyst sulfiding is left in the LP fuel

gas.

(2) Based on EPA AP-42 emission factors for uncontrolled natural gas fired process furnaces.

5.1.4 SRU/TGU Thermal Oxidizer Exhaust Air Pollutants Emission

Tail gas from the SCOT tailgas treating unit, together with couple of low pressure small vents are incinerated with supplemental natural gas in a thermal oxidizer. The total HHV of these streams corresponds to the supplemental natural gas HHV, which is 10 MMBtu/Hr. Exhaust from the thermal oxidizer is estimated based on Texaco's September 2001 Type C Package heat and material balances modified for exporting the recovered CO2 streams from Rectisol.

Table 5.4 is a listing of the estimated flows and compositions of the thermal oxidizer exhaust.

Emissions of NOx, CO, VOC and PM are calculated based on fuel gas HHV per EPA AP-42 Section 1.4 (Natural gas fired heater less than 100 MMBtu/Hr). The emission rates will be calculated assuming uncontrolled natural gas fired heaters. Based on a thermal oxidizer firing of 10 MMBtu(HHV)/Hr, the estimated emissions using published EPA factors are:

CO	0.0824 lbs/MMBtu (HHV)	10 x 0.0824 =	0.83 Lbs/Hr
NOx	0.098 lbs/MMBtu (HHV)	$10 \ge 0.098 =$	0.98 Lbs/Hr
VOC	0.0054 lbs/MMBtu (HHV)	10 x 0.0054 =	0.05 Lbs/Hr
PM	0.0075 lbs/MMBtu (HHV)	10 x 0.0075 =	0.08 Lbs/Hr

Total sulfur in the thermal oxidizer exhaust is per Texaco's heat & material balance, and is given as 0.07 moles/Hr of SO2. This roughly represents a 99.8% sulfur recovery in the SRU/TGU plant. Therefore SOx emission from the SRU/TGU tailgas is 0.07 x 64 = 4.5 Lbs/Hr as SO2.

Description	Thermal Oxidizer Exhaust
Туре	Flue Gas (1)
Heating Values: MMBtu/Hr (HHV) MMBtu/Hr (LHV) Btu(LHV)/SCF	3.9 0 0
Gas Flow Rates & Properties: MMSCFD LB/Hr Mole Wt	10.3 34,450 30.4
Gas Composition, Vol%:	
$N_{2} + Ar$ O_{2} CO_{2} $Water$ H_{2} $C_{1}'s$ $C_{2}'s$ $C_{3}'s$ $C_{4}'s$ $C_{5}+'s$ $H_{2}S + COS$ CO NOx SOx $Hydrocarbons$ $Particulates$	54.3 2.0 25.5 18.2 26 ppmV 19 ppmV 62 ppmV 1.5 ppmW 2.3 ppmW
Estimated Pollutant Emission, Lbs/Hr:	0.83 (2)
NOx	0.98 (2)
SOx	4.5
VOC	0.05 (2)
Particulates	0.08 (2)

Table 5.4Estimated Flow and Composition of Thermal Oxidizer Exhaust

Notes:

- (1) Per Texaco September 2001 gasification block H&M balance modified for exporting CO2.
- (2) Based on EPA AP-42 emission factors for uncontrolled natural gas fired process furnaces.

5.1.5 Truck Loading Vent Thermal Incinerator Exhaust Pollutants Emission

Displaced vents from truck loading are incinerated with supplemental natural gas in a Vent Thermal Incinerator. The Vent Thermal Incinerator is sized to handle the total design vents from all truck loading stations, which totals 187 ACFM (equivalent to displacing 48,000 BPSD of naphtha plus diesel) with a HHV of 3.76 MMBtu/hr. Since the truck loading only operates part of the time in eight hours each day and for five days each week, the daily average tank truck loading should be equivalent to the daily average FT diesel plus naphtha production rate which is roughly 5013 BPSD.

Supplemental natural gas firing is assumed to be continuous at the design rate of 6.6 MMBtu(HHV)/hr during the loading period, which has a daily average firing of 6.6 x 8 x 5 / 24 / 7 = 1.6 MMBtu(HHV)/hr.

Total daily average HHV of the displaced vent gas is estimated to be $3.76 \times 5013 / 48000 = 0.4$ MMBtu/hr. Total daily average HHV of displaced vapor plus supplemental natural gas is therefore 2.0 MMBtu/Hr.

Table 5.5 is a listing of the estimated average flows and compositions of the truck loading vent thermal incinerator exhaust.

Emissions of NOx, CO, VOC and PM are calculated based fuel gas HHV per EPA AP-42 Section 1.4 (Natural gas fired heater less than 100 MMBtu/Hr). The emission rates will be calculated assuming uncontrolled natural gas fired heaters. Based on a thermal incinerator firing of 2 MMBtu(HHV)/Hr, the estimated emissions using published EPA factors are:

CO	0.0824 lbs/MMBtu (HHV)	2 x 0.0824 =	0.16 Lbs/Hr
NOx	0.098 lbs/MMBtu (HHV)	$2 \ge 0.098 =$	0.20 Lbs/Hr
VOC	0.0054 lbs/MMBtu (HHV)	2 x 0.0054 =	0.01 Lbs/Hr
PM	0.0075 lbs/MMBtu (HHV)	2 x 0.0075 =	0.02 Lbs/Hr

Total sulfur in the truck loading vent thermal incinerator exhaust is equivalent to the total sulfur in the supplemental natural gas which is 10 grains/100 SCF or 160 ppmV as H2S. Total sulfur content of the daily average fired natural gas is roughly 1,600,000 / 1035 /379.5 x 160 /1000000 = 0.0007 moles/hr. Therefore SOx emission from the truck loading vent thermal incinerator exhaust is 0.0007 x 64 = 0.05 Lbs/Hr as SO2.

Table 5.5
Estimated Flow and Composition of Truck Loading Vent Thermal Incinerator Exhaust

Description	Truck Loading Vent Thermal Incinerator Exhaust
Туре	Flue Gas
Heating Values: MMBtu/Hr (HHV) MMBtu/Hr (LHV) Btu(LHV)/SCF	1.0 0 0
Gas Flow Rates & Properties: MMSCFD LB/Hr Mole Wt	5.5 17,100 28.5
Gas Composition, Vol%:	
$N_2 + Ar$ O_2 CO_2 Water H_2 C_1 's C_2 's C_3 's C_4 's C_5 +'s $H_2S + COS$ CO NOx SOx Hydrocarbons Particulates	75.1 11.2 4.8 8.9 10 ppmV 7 ppmV 1 ppmV 0.6 ppmW 1.2 ppmW
Estimated Pollutant Emission, I CO NOx SOx VOC Particulates	Lbs/Hr: 0.16 (2) 0.20 (2) 0.05 (1) 0.01 (2) 0.02 (2)

Notes:

(1) Estimated sulfur in supplemental natural gas.

(2) Based on EPA AP-42 emission factors for uncontrolled natural gas fired process furnaces.

5.1.6 Storage Tank Filling Displacement Vent Pollutants Emission

Displaced vents from internal floating roof storage tank filling are vented directly to atmosphere. Continuous average tank filling displacement is equal to the daily average FT diesel plus naphtha production rate of 5013 BPSD, or roughly 20 ACFM.

There are negligible emissions for NOx, CO, SOx and PM. The major pollutant is VOC. Based on four 23' diameter x 40' high naphtha storage tanks and four 39' diameter x 40' high diesel storage tanks, the estimated VOC emissions using EPA AP-42 (Internal Floating Roof Tank Emissions Report) method are:

Naphtha VOC	536 lbs/year/tank	536 x 4 / 7500	=	0.286	Lbs/Hr for 4 tanks
Diesel VOC	102 lbs/year/tank	102 x 4 / 7500		0.054	Lbs/Hr for 4 tanks
		Total	=	0.34	Lbs/Hr

Table 5.6 is a listing of the estimated flows and compositions of the average tank filling displacement vent. Because breathing air vent is not included in Table 5.6 while breathing VOC losses is included, VOC concentration shown should be conservative.

Description	Tank Filling Vent	2
Туре	Air	
Heating Values: MMBtu/Hr (HHV) MMBtu/Hr (LHV) Btu(LHV)/SCF	0 0	
Gas Flow Rates & Properties: MMSCFD LB/Hr Mole Wt	0.3 100 28.9	(1)
Gas Composition, Vol%:		
$N_2 + Ar$ O_2 CO_2 Water H_2 C_1 's C_2 's C_3 's C_4 's C_5 +'s $H_2S + COS$ CO NOx SOx Hydrocarbons Particulates	78.3 20.7 1.0 1.5	ppmw
Estimated Pollutant Emission, Lbs/Hr:		
NOX SOx		
VOC	0.05	(2)
Particulates		(-)

Table 5.6Estimated Flow and Composition of Average Tank Filling Displacement Vent

Notes:

(1) Average continuous tank filling displaced volume.

(2) Based on API RP-42 emission factors for internal floating roof storage tanks.

Section 6 Phase I Task 5 – Market Analysis

TASK COMPLETED.

Purvin & Gertz, Inc. completed this task under a subcontract to Texaco. Final report was delivered to WMPI. The report contains sensitivity business information that WMPI would prefer not to report it in writing. Under an agreement, DOE can review the report and its findings with WMPI.

Section 7 Phase I Task 6 – Preliminary Site Analysis

Under this task, WMPI will assess the site-specific project requirements to include:

- Raw material availability
- Site transportation accessibility
- Supporting utility services
- Land availability and cost
- Construction and skilled labor availability

As part of this Task 6, Nexant, with support from Bechtel personnel, helped with examining alternative modes of transporting large process vessels to the EECP site near the existing Gilberton cogen plant. Results were discussed in the July/September 2001 Quarterly Technical Progress Report. Sasol's slurry phase FT reactor is expected to be over 18 feet in diameter. Its dimensions and weight are important parameters governing how the vessel should be most cost effectively fabricated and transported to site.

A topical report, summarizing all Phase I, Task 6 activities is being drafted.

Section 8 Project Management

8.1 **BIWEEKLY PROJECT STATUS REPORT**

Informal Biweekly Project Status Reports are transmitted to keep the DOE Project Manager updated of all work in progress.

8.2 PROJECT MILESTONE PLAN AND LOG

Project schedule and milestone were revised with concurrence from DOE on August 15, 2002 to re-prioritize the remaining work scope in anticipation of WMPI's submittal of a proposal in response to the DOE Clean Coal Power Initiative solicitation, as a means of advancing the WMPI EECP concept to project EPC (engineering, procuremtn and construction) and demonstration. Figure 8.1 shows the revised project schedule.

Project Milestone Plan and Milestone Log are submitted on time as prescribed by the contract to keep DOE management informed of work-in-progress and accomplishments against major project milestones planned.

Section 8 Project Management

Figure 8.1

Section 9 Experimental

EXECUTIVE SUMMARY

- 9.1 EXPERIMENTAL
- 9.2 **RESULTS AND DISCUSSION**
- 9.3 CONCLUSION
- 9.4 **REFERENCE**

NOT APPLICABLE - The current project is a design feasibility and economics study, leading to detailed engineering, construction and operation of an EECP plant. It's not a typical research and development (R&D) project where a topical report format described in this section applied. There was no experimental work performed. This section is included only to fulfill DOE's prescribed reporting format.

List of Acronyms and Abbreviations

AGR	. Acid Gas Removal
API	. American Petroleum Institute
ASTM	American Standard Testing Methods
Bbls, bbls	Barrels
BEDD	. Basic Engineering Design Data
BOC	. British Oxygen Company
BOD	. Biological Oxygen Demand
BOP	. Balance Of Plant
BPD	. Barrel Per Day
BFW	. Boiler Feed Water
CFB	. Circulating Fluidized Bed
COD	. Chemical Oxygen Demand
СРІ	. Coalescing Plate Interceptor
DAF	Dissolved Air Floatation
DCS	Distributed Control System
DOE	.U.S. Department of Energy
EECP	Early Entrance Co-Production Plant
ft	. Feet
FT	. Fischer-Tropsch
GPM	. Gallons per Minute
GT	. Gas Turbine
HC	Hvdrocracking
HER	Heavy End Recovery
	High High Pressure
НР	High Pressure, Horse Power
HRSG	Heat Recovery Steam Generator
I/O	.Input/Output
IP	Intermediate Pressure
ISBL	Inside Battery Limits
KV	Kilo Volts
Lb/CF	Pounds per Cubic Feet
LCN	Logic Control Network
LHV	Lower-Heating Value
LP	. Low Pressure
LTFT	Low-Temperature Fischer-Tropsch
LTGC	Low-Temperature Gas Cooling
MMSCFD	Million Standard Cubic Feet Per Day
MW	Mega Watt
NETL	National Energy Technology Laboratory
OSBL	Outside Battery Limits
OSHA	US Occupational Safety and Health Administration
PMCC	Pensky-Martens Closed Cup
PPM	Parts per Million
PSA	Pressure Swing Absorption
1 Q1 1	. ressure o wing resorption

PSIG, psig	. Pounds per Squared Inch, gauge
PWU	. Product Work Up
RD&T	. Research, Development & Testing
RON	. Research Octane Number
RVP	. Reid Vapor Pressure
SCFM	. Standard Cubic Feet per Minute
SCR	. Selective Catalytic Reduction
SRU	. Sulfur Recovery Unit
STPD	. Short Tons Per Day
SWS	. Sour Water Stripper
TGTU	. Tail Gas Treating Unit
UBC	. Uniform Building Code
WMPI	. Waste Processors Management, Inc.
Wt%	. Weight Percent