

DOE/RA/50351-1300

**CROW TRIBE
OF
INDIANS**



**SYNFUELS FEASIBILITY
STUDY**

VOLUME II

**PROCESS DESIGN AND COST ESTIMATE
BOOK III: SECTIONS 6.5 THROUGH 6.9**

AUGUST, 1982

**PREPARED FOR THE DEPARTMENT OF ENERGY
UNDER GRANT NO. DE-FG01-81RA50351**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

NOTICE

Portions of this Report were prepared by Fluor Engineers and Constructors, Inc., solely for the benefit of the Crow Tribe of Indians and not for the purpose of reliance by any third party. Fluor makes no guarantees and assumes no liability to any third party with respect to any information contained herein. Third parties using information contained in this Report do so at their own risk, and any use thereof shall constitute a release to Fluor and the Crow Tribe from any liability in connection therewith whether arising in contract, tort, or otherwise, and regardless of the fault or negligence of Fluor or the Crow Tribe.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NOTICE

PORTIONS OF THIS REPORT ARE ILLLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

VOLUME IIPRELIMINARY DESIGN AND COST ESTIMATETABLE OF CONTENTS

<u>BOOK I</u>	<u>PAGE</u>
1.0 FEASIBILITY STUDY OVERVIEW	1-1
2.0 INTRODUCTION	2-1
3.0 SUMMARY	3-1
3.1 DESIGN CONSIDERATIONS	3-1
3.2 BASE CASE	3-3
3.3 COMPARISONS	3-4
3.3.1 Coal Feed Comparison	3-4
3.3.2 Product and Byproduct Summary	3-7
3.3.3 Capital Cost Summary	3-7
3.3.4 Operation and Cost Summary	3-11
4.0 SCOPE OF WORK	4-1
4.1 PROCESS DEVELOPMENT	4-1
4.2 UTILITY SYSTEMS DEVELOPMENT	4-3
4.3 OFFSITES DEVELOPMENT	4-4
4.4 SPECIAL PROCESS STUDY	4-5
4.5 CAPITAL AND OPERATING COSTS	4-5

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>	<u>PAGE</u>
5.0 CRITERIA, RATIONALE, AND ASSUMPTIONS	5-1
5.1 COAL ANALYSES	5-1
5.2 SITE DATA	5-5
5.2.1 Area Description	5-5
5.2.2 Sites Studied	5-5
5.2.3 Topographic Maps and Aerial Photographs	5-7
5.2.4 Site Reconnaissance	5-10
5.2.5 Meteorological and Design Data	5-10
5.2.6 Building Codes and Regulations	5-16
5.2.7 Description of Site 1	5-17
5.2.8 Description of Site 23	5-26
5.3 RAW WATER ANALYSIS	5-36
5.4 UTILITY DESIGN INFORMATION	5-38
5.5 PRODUCT AND BYPRODUCTS SPECIFICATIONS	5-40
5.5.1 Product Specifications	5-40
5.5.2 Byproducts and Ash Specifications	5-40

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>		<u>PAGE</u>
5.6	ECONOMIC CRITERIA - CAPITAL COSTS	5-42
5.6.1	Direct Field Cost Estimate	5-57
5.6.2	Indirect Field Cost Estimate	5-61
5.6.3	Office Cost Estimate	5-63
5.6.4	Material Transportation Cost Estimate	5-63
5.6.5	Other Capital Costs	5-64
5.6.6	Manpower Plans	5-70
5.7	ECONOMIC CRITERIA - OPERATING AND MAINTENANCE COSTS	5-71
5.7.1	Coal Cost	5-71
5.7.2	Catalysts and Chemicals	5-71
5.7.3	Plant Management Staff	5-71
5.7.4	Plant Operating Labor and Materials	5-72
5.7.5	Maintenance Labor and Materials	5-72
5.7.6	Water Pumping Costs	5-72
5.7.7	Solid Waste Disposal	5-73
5.7.8	Taxes and Insurance	5-73
5.7.9	Byproducts Credit	5-73

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>	<u>PAGE</u>
6.0 CONTENTS AND RESULTS	6-1
6.1 BASE CASE OVERALL PLANT DESCRIPTION	6-1
6.1.1 Introduction	6-1
6.1.2 Feed and Product Summary	6-5
6.1.3 Thermal Efficiency Calculation	6-8
6.1.4 Design Basis	6-10
6.1.5 Plant Units	6-17
6.1.6 Plant Train Philosophy	6-20
6.1.7 Plot Plan	6-28
6.1.8 Block Flow Diagrams	6-31
Overall Material Balance	6-31
Plant Water Balance	6-31
Sulfur Balance	6-35
Air Emissions	6-37
Solid Effluents	6-37
Steam Balance	6-40
6.1.9 Utility Summary	6-42
6.1.10 Catalyst and Chemicals Summary	6-44
6.1.11 Operating Manpower	6-51
6.1.12 Maintenance Manpower	6-53

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>		<u>PAGE</u>
6.2	BASE CASE PROCESS UNITS - ENGINEERING DATA	6-54
6.2.1	Unit 01 - Coal Screening	6-54
6.2.2	Unit 02 - Coal Distribution	6-62
6.2.3	Unit 03 - Ash Handling	6-68
6.2.4	Unit 10 - Coal Gasification	6-77
6.2.5	Unit 11 - Carbon Monoxide Shift	6-87
6.2.6	Unit 12 - Gas Cooling	6-94
6.2.7	Unit 13 - Rectisol	6-101
6.2.8	Unit 14 - Gas Liquor Separation	6-112
6.2.9	Unit 15 - Tar Distillation	6-121
6.2.10	Unit 16 - Naphtha Hydrotreating	6-128
6.2.11	Unit 17 - Phenosolvan	6-137
6.2.12	Unit 18 - Ammonia Recovery	6-147
6.2.13	Unit 19 - Sulfur Recovery	6-155
6.2.14	Unit 20 - Process Steam Superheating	6-177
6.2.15	Unit 21 - Methanol Synthesis	6-183
6.2.16	Unit 22 - Methanation	6-190
6.2.17	Unit 23 - SNG Purification and Compression	6-200
6.2.18	Unit 24 - Partial Oxidation	6-207
6.2.19	Unit 25 - PSA Hydrogen Production	6-215

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK II</u>		<u>PAGE</u>
6.3	BASE CASE UTILITY AND OFFSITE UNITS - ENGINEERING DATA	6-224
6.3.1	Unit 40 - Oxygen Production	6-224
6.3.2	Unit 41 - Steam Generation	6-233
6.3.3	Unit 42 - Power Generation	6-248
6.3.4	Unit 43 - Flue Gas Desulfurization	6-256
6.3.5	Unit 44 - Raw Water Treating	6-263
6.3.6	Unit 45 - Boiler Feedwater and Condensate Treating	6-273
6.3.7	Unit 46 - Air and Nitrogen Systems	6-293
6.3.8	Unit 47 - Process Cooling Water	6-304
6.3.9	Unit 48 - Utility Cooling Water	6-318
6.3.10	Unit 49 - Potable Water	6-328
6.3.11	Unit 50 - Utility Water	6-338
6.3.12	Unit 51 - Firewater	6-342
6.3.13	Unit 52 - Fuel Gas	6-349
6.3.14	Unit 53 - Flare	6-356
6.3.15	Unit 54 - Wastewater Treating	6-365
6.3.16	Unit 55 - Tank Farm and Dispatch	6-389
6.3.17	Unit 56 - Sanitary Waste Treatment System	6-419
6.3.18	Unit 57 - Interconnecting Pipeway	6-423
6.3.19	Unit 61 - Buildings	6-424

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

BOOK II

	<u>PAGE</u>
6.3.20 Unit 65 - Electrical Distribution	6-425
Appendix 6.3.20-1 Electrical Design Drawings	6-443
6.3.21 Unit 68 - Control Systems	6-468
6.3.22 Unit 71 - Site Preparation	6-494
6.3.23 Unit 75 - Site Improvements	6-495
6.4 POWER SELF-SUFFICIENCY CASE	6-497
6.4.1 Overall Plant Description	6-497
6.4.2 Feed and Product Summary	6-498
6.4.3 Thermal Efficiency Calculation	6-500
6.4.4 Design Basis	6-502
6.4.5 Plant Units	6-503
6.4.6 Plant Train Philosophy	6-504
6.4.7 Plot Plan	6-505
6.4.8 Block Flow Diagrams	6-506
6.4.8.1 Overall Material Balance	6-506
6.4.8.2 Plant Water Balance	6-506
6.4.8.3 Sulfur Balance	6-506
6.4.8.4 Air Emissions	6-510
6.4.8.5 Solid Effluent	6-510
6.4.8.6 Steam Balance	6-510

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

BOOK II

PAGE

6.4.9	Utility Summary	6-514
6.4.10	Catalyst and Chemicals Summary	6-517
6.4.11	Operating Manpower	6-522
6.4.12	Maintenance Manpower	6-523
6.4.13	Process Units Engineering Data	6-524
6.4.14	Utility and Offsites Units	6-528
6.4.15	Capacity Factors	6-546

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>		<u>PAGE</u>
6.5	COPRODUCTION CASE	6-549
6.5.1	Overall Plant Description	6-549
6.5.2	Feed and Product Summary	6-550
6.5.3	Thermal Efficiency Calculation	6-552
6.5.4	Design Basis	6-554
6.5.5	Plant Units	6-555
6.5.6	Plant Train Philosophy	6-556
6.5.7	Plot Plan	6-557
6.5.8	Block Flow Diagrams	6-560
6.5.9	Utility Summary	6-568
6.5.10	Catalyst and Chemical Summary	6-571
6.5.11	Operating Manpower	6-577
6.5.12	Maintenance Manpower	6-578
6.5.13	Process Units Engineering Data	6-579
6.5.13.1	Differences	6-579
6.5.13.2	Gas Cooling - Unit 12	6-580
6.5.13.3	Methanol Synthesis and Purification - Unit 21	6-589
6.5.13.4	Methanation - Unit 22	6-600
6.5.13.5	SNG Purification and Compression - Unit 23	6-608

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

BOOK III

PAGE

6.5.14	Utility and Offsite Units	6-627
6.5.15	Capacity Factors	6-646
6.6	SHELL COAL CASE	6-650
6.6.1	Overall Plant Description	6-650
6.6.2	Feed and Product Summary	6-651
6.6.3	Thermal Efficiency Calculation	6-653
6.6.4	Design Basis	6-655
6.6.5	Plant Units	6-656
6.6.6	Plant Train Philosophy	6-657
6.6.7	Plot Plan	6-658
6.6.8	Block Flow Diagrams	6-661
6.6.9	Utility Summary	6-669
6.6.10	Catalyst and Chemical Summary	6-671
6.6.11	Operating Manpower	6-676
6.6.12	Maintenance Manpower	6-677
6.6.13	Process Units Engineering Data	6-678
6.6.14	Utility and Offsite Units	6-700
6.6.15	Capacity Factors	6-722

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>		<u>PAGE</u>
6.7	PROCESS STUDIES	6-726
6.7.1	Steam Study	6-726
6.7.2	Flue Gas Desulfurization	6-738
	Appendix A	6-755
	Appendix B	6-763
6.7.3	Expanded Plant	6-766
6.8	DESIGN PLANS AND DRAWINGS	6-776
6.8.1	Site Preparation - Site 1	6-776
6.8.2	Roads - Site 1	6-786
6.8.3	Railroad - Site 1	6-796
6.8.4	Logistic Facilities - Site 1	6-798
6.8.5	Paving - Site 1	6-802
6.8.6	Foundations and Structures - Site 1	6-805
6.8.7	Buildings - Site 1	6-831
6.8.8	Ponds and Basins - Site 1	6-875
6.8.9	Site Preparation - Site 23	6-890
6.8.10	Roads - Site 23	6-895
6.8.11	Railroad - Site 23	6-899
6.8.12	Logistic Facilities - Site 23	6-900
6.8.13	Paving - Site 23	6-902
6.8.14	Foundations and Structures - Site 23	6-903

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>		<u>PAGE</u>
	6.8.15 Buildings - Site 23	6-904
	6.8.16 Ponds and Basins	6-906
6.9	COST ESTIMATES	6-907
	6.9.1 Capital Cost Summary	6-907
	6.9.2 Capital Cost Estimate	6-909
	6.9.3 Other Capital Cost Allowances	6-917
	6.9.4 Operating and Maintenance Cost Allowances	6-919
	6.9.5 Cash Flow Data	6-921

PREFACE

Volume II, Process Design and Cost Estimate, is a three book volume. Section 1.0 through 6.2 are presented in Book I. Book II contains sections 6.3 and 6.4, Base Case Utilities and Offsite Units - Engineering Data and The Contents and Results of the Power Self-Sufficiency Case. This book contains Section 6.5 through 6.9, Coproduction Case, Shell Coal Case, Process Studies, Design Plans and Drawings and Cost Estimate. The Table of Contents for Volume II is presented in total in each of the three books.

6.5 COPRODUCTION CASE

6.5.1 OVERALL PLANT DESCRIPTION

The principal difference in the design for the Coproduction Case is that methanol and substitute natural gas (SNG) are the major products as opposed to only SNG in the Base Case. The pure syngas is fed to a methanol synthesis unit producing methanol which is purified. The purge gas from the Methanol Synthesis unit is converted to SNG by methanation. Other process and utility/offsite units are similar to the Base Case except there is no requirement for a CO Shift unit and there is a slight variation in size of some units to accommodate the change in processing scheme.

Coal feed to gasification and boilers is identical to the Base Case. Feed and product rates for this case are given in Section 6.5.2. Other than the methanol and SNG products, the byproduct rates are only marginally different from the Base Case. Power available for export is less than the Base Case, due mainly to the additional energy consumed in the Methanol Synthesis unit.

6.5.2 FEED AND PRODUCT SUMMARY

Table 6.5.2-1 contains a summary of the raw materials used and the products and solid wastes generated in the Westmoreland Coal Coproduction Case.

TABLE 6.5.2-1

FEED AND PRODUCT SUMMARY⁽¹⁾

CASE: WESTMORELAND COAL - COPRODUCTION

	<u>UNITS</u>	<u>QUANTITY</u>
<u>Raw Material</u>		
Coal from Mine	ST/D	18,000
Lurgi Gasification Feed	ST/D	10,800
Boiler Feed	ST/D	7,200
<u>Bulk Materials</u>		
Liquids	ST/D	72
Solids	ST/D	150
Water	Acre-Ft/D	24.4
<u>Products⁽³⁾</u>		
SNG	MM SCF/D	67.35 ⁽²⁾
Aromatic Naphtha	BPSD	804
Anhydrous Ammonia	ST/D	76.7
Sulfur	ST/D	86.7
Methanol	ST/D	3,752
<u>Solid Wastes</u>		
Gasifier Ash (Dry)	ST/D	827.2
Boiler Ash (Dry)	ST/D	531.1
Gypsum	ST/D	387
Plant Refuse	ST/D	50
Raw Water Treatment Sludge	ST/D	20
Spent Catalyst	ST/D	0.02
Biotreating Incinerator Ash and Cooling Tower Sludge	ST/D	26

- NOTES: (1) All quantities per stream day
(2) SNG production equals 61.28 MM SCF/D calendar day basis
(3) Plant also produces 212.3 MW power for sales

6.5.3 THERMAL EFFICIENCY CALCULATION

Table 6.5.3-1 summarizes the overall thermal efficiency calculation for the Westmoreland Coal Coproduction Case.

TABLE 6.5.3-1

THERMAL EFFICIENCY CALCULATION

CASE: WESTMORELAND COAL - COPRODUCTION

<u>Feed Streams</u>	<u>Design Flow (1)</u>	<u>Mass Flow lb/hr</u>	<u>Energy Content HHV</u>	<u>MM Btu/hr</u>
Coal to Gasifiers	10,800 ST/D	900,000	8,612 Btu/lb	7,751
Coal to Boilers	7,200 ST/D	600,000	8,612 Btu/lb	5,167
			TOTAL	12,918
<u>Product Streams</u>				
SNG	67.35 MM SCFD	121,055	987 Btu/scf	2,770
Methanol	3,751.9 ST/D	312,657	9,740 Btu/lb	3,045
Aromatic Naphtha	804 BPSD	9,731	20,500 Btu/lb	199
Ammonia (99.5% liquid)	76.7 ST/D	6,389	9,030 Btu/lb	58
Sulfur (liquid)	86.7 ST/D	7,229	4,000 Btu/lb	29
Export Power	212.3 MW	212,300	3,414 Btu/kWh	725
			TOTAL	6,826

$$\text{Thermal Efficiency} = \frac{\text{Products}}{\text{Feed}} \times 100 = \frac{6,826}{12,918} \times 100 = 52.8\%$$

(1) Stream-day rates

6.5.4 DESIGN BASIS

The design of the Westmoreland Coal - Coproduction Case plant is based on the same coal feed rate as the Base Case plant. Coal feed to the gasifiers is 10,800 ST/SD, and the feed to the boilers is 7,200 ST/SD. The principal products in this case are chemical grade methanol and SNG instead of only SNG in the Base Case. All of the pure gas is fed to a conventional methanol synthesis loop and the purge gas is methanated.

Changes in process units are described in Section 6.5.13, and changes in utility and offsite units are described in Section 6.5.14.

6.5.5 PLANT UNITS

The plant units required for the Westmoreland Coal - Coproduction Case are the same as those required for the Base Case (Section 6.1.5) with the following exceptions:

Unit 11: CO Shift - deleted

Unit 21: Methanol Synthesis - changed to Methanol Synthesis and Purification.

6.5.6 PLANT TRAIN PHILOSOPHY

The train philosophy for the units in the Coproduction Case remains the same as established for the Base Case with the following exceptions:

<u>Unit No.</u>	<u>Unit Name</u>	<u>No. of Trains</u>
11	CO Shift	Unit deleted
21	Methanol Synthesis & Purification	2 x 50%

6.5.7 PLOT PLAN

The development of plot plans involves conforming to industry standard practices, in addition to economics, constructability and operability. The units are spaced to comply with risk insurers recommendations.

For the overall plot plan, the units are arranged as much as possible, in the same sequence as the process flow of the plant. Some units, however, are located out of sequence and adjacent to or near other units for economic reasons, such as minimizing long runs of large diameter or exotic piping. For example:

The Steam Generation (Unit 41) area is located adjacent to Oxygen Production (Unit 40) which requires large quantities of high pressure steam.

Sulfur Recovery (Unit 19) is located adjacent to Flue Gas Desulfuration (Unit 43) in order to utilize a common stack.

Oxygen Production (Unit 40) is located such that it is upwind of the rest of the plant (based upon the prevailing wind).

The cooling towers are located such that the water vapor plume does not interfere with the plant operation.

Ponds are, in general, grouped together and located in the low area of the plant.


The Flares (Unit 53) are located in the Solar Evaporation Pond (Unit 54B) to minimize plant acreage.

6.5.7 (Continued)



The main control building is centrally located.

Sufficient railroad switchyard is provided to allow for makeup of trains, switching, and sorting of incoming cars and storage of cars. A spur is also provided to the maintenance and warehouse area, and Flue Gas Desulfurization (Unit 43) for unloading of supplies.

The Plot Plan for the Coproduction Case, Drawing Number 835704-00-5-052 is on the following page.



REDUCED (FIRST SCALE)




MATCH LINE SEE DWG. NO. 00-1-08D

MATCH LINE SEE DWG. NO. 00-1-08D

MATCH LINE SEE DWG. NO. 00-1-08D

1/1	APPROVED FOR STUDY

SEE DWG. NO. 80-8-080



USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS IN THE NOTICE PAGE AT THE FRONT OF THIS REPORT

- 01 COAL SCREENING
- 03 ASH HANDLING
- 10 GASIFICATION
- 12 RAW GAS COOLING
- 13 RECTISOL
- 14 GAS LIQUOR SEPARATION
- 15 TAR DISTILLATION
- 16 NAPHTHA HYDROTREATING
- 17 PHENOBOLVAN
- 18 AMMONIA RECOVERY
- 19 SULFUR RECOVERY
- 20 PROCESS STEAM SUPERHEATING
- 21 METHANOL SYNTHESIS
- 22 METHANATION
- 23 SHG PURIFICATION & COMPRESSION
- 24 PARTIAL OXIDATION
- 26 HYDROGEN PRODUCTION
- 40 OXYGEN PRODUCTION
- 41 STEAM GENERATION
- 42 POWER GENERATION
- 43 FLUE GAS DESULFURIZATION
- 44 RAW WATER TREATING
- 45 BFW & CONDENSATE TREATING
- 46 AIR & NITROGEN SYSTEMS
- 47 PROCESS COOLING WATER
- 48 UTILITY COOLING WATER
- 49 POTABLE WATER
- 50 UTILITY WATER
- 51 FIREWATER
- 52 FLARES
- 53 STORM & OILY WATER AND WASTEWATER TREATING
- 54 SOLAR EVAPORATION POND
- 55 TANK FARM & DISPATCH
- 56 SANITARY SEWAGE TREATMENT
- 57 HYDROCONNECTING PIPEWAY

- LEGEND
- OVERHEAD PIPEWAY
 - CONVEYOR
 - RAILROAD
 - - - FUTURE



DWG. NO. 80-8-080

PROJECT	NO. 80-8-080	DATE	11/80
DESCRIPTION	AREA MAP		
DESIGNED BY	E. LINDHANA		
CHECKED BY	J. WITTE		
APPROVED BY	T. COFFIN		
DATE	11/80		
SCALE	1" = 200'		



PROJECT	NO. 80-8-080	DATE	11/80
DESCRIPTION	AREA MAP		
DESIGNED BY	E. LINDHANA		
CHECKED BY	J. WITTE		
APPROVED BY	T. COFFIN		
DATE	11/80		
SCALE	1" = 200'		

SITE #1 PLOT PLAN
ALTERNATE #2 CO-PRODUCTION
SYNTHESIS FEASIBILITY STUDY
CROW TRIBES OF INDIANS MONTANA
11/80
838704-00-8-082

6.5.8 BLOCK FLOW DIAGRAMS

6.5.8.1 OVERALL MATERIAL BALANCE

The overall material balance for the Westmoreland Coal - Coproduction Case is shown on Drawing No. 835704-00-4-301. The drawing shows the flow of materials through the process plant and the following utility/offsite units: Oxygen Production, Steam Generation, Power Generation, and Flue Gas Desulfurization.

The process differs from the Base Case in that there is no CO Shift and the entire pure gas stream enters the Methanol Synthesis and Purification Unit where the methanol product is produced. A purge system from Methanol Synthesis is methanated, purified, and compressed to SNG.

6.5.8.2 PLANT WATER BALANCE

Drawing No. 835704-00-R-302 is the Block Flow Diagram of the plant water balance for the Westmoreland Coal - Coproduction Case. The diagram shows the same overall management scheme as the Base Case.

The presence of the large Methanol Synthesis & Purification unit raises the vacuum condensate flow while reducing the process water flow from Methanation. These two combined streams are added to the 1500 psig boiler feed water upstream of the polishing filters and returned to the plant through the power generation turbines.

6.5.8.3 SULFUR BALANCE

The sulfur balance for the Westmoreland Coal - Coproduction Case is shown on Drawing No. 835704-00-4-304. The description of the drawing given in Section 6.1.8 also applies to this case.

6.5.8.4 AIR EMISSIONS


The air emissions diagram for the Westmoreland Coal - Coproduction Case is shown on Drawing No. 835704-00-4-305. The description of the drawing given in Section 6.1.8 also applies to this case.

6.5.8.5 SOLID EFFLUENT


The solid effluent diagram for the Westmoreland Coal - Coproduction Case is shown on Drawing No. 835704-00-4-306. The description of the drawing given in Section 6.1.8 also applies to this case.


6.5.8.6 STEAM BALANCE

The steam balance for the Westmoreland Coal - Coproduction Case is shown on Drawing No. 835704-00-R-307. The description of the drawing given in Section 6.1.8 also applies to this case.




UNIT	DESCRIPTION	STATUS
01	COAL SCREENING	OPERATING
02	COAL DISTRIBUTION	OPERATING
03	ASH HANDLING	OPERATING
04	COAL GASIFICATION	OPERATING
05	GAS LIQUOR SEPARATION	OPERATING
06	TAR DISTILLATION	OPERATING
07	PHENOLSOLVAN	OPERATING
08	AMMONIA RECOVERY	OPERATING
09	SULFUR RECOVERY	OPERATING
10	PROCESS STEAM SUPERHEATING	OPERATING
11	PARTIAL OXIDATION	OPERATING
12	POWER GENERATION	OPERATING
13	STEAM GENERATION	OPERATING
14	FLUE GAS DESULFURIZATION	OPERATING
15	OXYGEN PRODUCTION	OPERATING






PLEASE CHECK THE UNIT OPERATIONS
 IS SHOWN TO THE INSTRUMENTATION
 NOTICE PANEL AT THE FRONT OF THIS DECK



<p>REVISIONS</p> <table border="1"> <tr><th>NO.</th><th>DATE</th><th>DESCRIPTION</th></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </table>		NO.	DATE	DESCRIPTION										<p>FLUOR</p> <p>R. WHITE C.C. ABATEY D.O. BELWITZ J. McCARTHY R. LANG</p>	<p>BLOCK FLOW DIAGRAM PLANT WATER BALANCE</p> <p>CASE: WESTMORELAND COAL - CO-PRODUCTION SYNFUELS FEASIBILITY STUDY</p> <p>835704-00-R-302 MICROFILM FRAME 1 OF 2</p>	<p>001 35700302</p>
NO.	DATE	DESCRIPTION														




USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

- NOTES:
1. FLOWS SHOWN ARE LBS/HR OF SULFUR.
 2. DESIGN BASIS IS 750 T/HR COAL TO PLANT. GASIFIER FEED COAL = 450 T/HR. BOILER FEED COAL = 300 T/HR.
 3. FEED SULFUR REMOVAL EFFICIENCY IS 90%.
 4. MORE THAN 98% OF SULFUR ENTERING GASIFICATION IS RECOVERED.
 5. THE FLOW QUANTITIES SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT


		D. P. HALVERSON G. C. ABATAY R. D. BELMITO R. MCCARTHY R. L. LANO	BLOCK FLOW DIAGRAM SULFUR BALANCE CASE: WESTMORELAND COAL - CO-PRODUCTION CROW TRIBE OF INDIANS SYNTHESIS FEASIBILITY STUDY	NONE	835704-00-4-304	1	001 35700304
--	--	---	--	------	-----------------	---	--------------



NOTE: NUMBERS IN PARENTHESES REFER TO NOTES AT RIGHT.


	1	2	3	4 (3)	5 (4)	6	7	8 (7)	9 (8)
	COAL SCREENING	COAL DISTRIBUTION	GASIFICATION LOCK GAS VENT	GASIFIER START-UP VENT	HEATER FLUE GAS	SUPERHEATER FLUE GAS	BOILER FLUE GAS	HEATER FLUE GAS	PRODUCT STORAGE TANK FARM
O ₂	LBS/HR			CONFIDENTIAL	300	25,003	268,632	362	
N ₂	LBS/HR		1		7,358	324,284	3,627,712	3,132	
CO ₂	LBS/HR		263		1,774	651,751	1,112,320	2,144	
H ₂ O	LBS/HR		1		1,224	46,771	593,442	1,475	
SO ₂	LBS/HR					282	(5) 383		
N ₂ S	LBS/HR		2						
CO ₂	LBS/HR		TRACE						
NO _x	LBS/HR				6	192	2,584	7	
CO	LBS/HR		88		TRACE	4	300	TRACE	
CH ₄	LBS/HR		33						
H ₂	LBS/HR		15						
HYDROCARBONS	LBS/HR		5						5
PARTICULATES	LBS/HR	5	2				161 143		
TOTAL FLOW	LBS/HR	5	2	403	10,882	1,232,267	3,606,316	13,124	5
TOTAL FLOW	LBS/HR		19		389	34,640	203,438	468	
TEMPERATURE	°F	AMB.	AMB.		300	400	128	300	AMB.
ELEVATION OF RELEASE FT		75	150	200	1	100	625	625	100

DATE	REVISION




◇ (NOTE 1) COAL		◇ (NOTES 2 - 4) ASH		◇ (NOTE 5) FGD GYPSUM		◇ RAW WATER TREATMENT SLUDGE		◇ WATER TREATING	
TRACE ELEMENTS	PPM	MINERAL ASH ANALYSIS	WT%		WT%		WT%		WT%
ANTIMONY	0.67	SiO ₂	35.9	H ₂ O	23.0	CaCO ₃	33.5	SPENT ACTIVATED CARBON	41.7
ARSENIC	1.77	Al ₂ O ₃	19.2	CaSO ₄ ·2H ₂ O	75.0	Na(OH)	0.9	SPENT ION EXCHANGE RESIN	88.3
BARIUM	181.60	Fe ₂ O ₃	7.5	CoCl ₂	0.8	H ₂ O	40.0		
BERYLLIUM	1.25	H ₂ O	3.0	INERT SOLIDS	1.5	MISCELLANEOUS	3.6		
BORON	218.60	H ₂ O	0.18	Co(OH) ₂	TRACE				
BROMINE	18.35	Co	14.5	Co(COOH) ₂	TRACE				
CADMIUM	1.80	MnO	2.4						
CERTIUM	17.64	TiO ₂	1.2						
CHROMIUM	8.38	P ₂ O ₅	0.28						
COBALT	3.82	SO ₃	14.1						
COPPER	27.42	INDETERMINATE	1.74						
FLUORINE	227.40								
LEAD	3.30								
LITHIUM	35.80								
MANGANESE	202.00								
MERCURY	0.08								
NICKEL	7.42								
SELENIUM	1.30								
SILVER	0.09								
STRONTIUM	487.02								
THALLIUM	0.23								
URANIUM	1.43								
VANADIUM	18.48								
ZINC	15.78								
ZIRCONIUM	128.50								

- NOTES:**
- TRACE ELEMENT ANALYSIS FROM WESTMORELAND MINE ENVIRONMENTAL IMPACT STATEMENT.
 - MINERAL ASH ANALYSIS BASED ON LURDI DATA, WESTMORELAND MINE. CASIFIER ASH ALSO CONTAINS 4% CARBON.
 - AMOUNT OF CASIFIER ASH CALCULATED BASED ON 450 T/HR CASIFIER COAL CONSUMED.
 - AMOUNT OF BOILER ASH CALCULATED BASED ON 300 T/HR BOILER COAL CONSUMED.
 - TOTAL GYPSUM PRODUCED BASED ON FGD LICENSOR INFORMATION.
 - THE CLEAN STORM WATER PONDS ARE CLEANED AS NECESSARY. THE AMOUNT OF SOLIDS REMOVED FROM THESE PONDS IS INDETERMINATE.
 - THE COMPOSITIONS OF THE INCINERATOR WASTE AND UCT BLOWDOWN TREATMENT SLUDGE ARE NOT AVAILABLE.
 - THE FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.



DATE	BY	REV	DESCRIPTION



NO.	REVISION	DATE	BY	CHKD.

FLUOR


DESIGNED BY
R. WHITE
C. G. ARATAY
B. D'ARMENTO
R. M. CARLTON
R. LANG

**BLOCK FLOW DIAGRAM
 SOLID EFFLUENT**
CASE: WESTMORELAND COAL - CO - PRODUCTION
CROW TRIBE OF INDIANS **SYNTHESIS FEASIBILITY STUDY**
 NONE 835704-00-4-306 1


USE OR DISCLOSURE OF REPORT OR DATA IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT


001 835704006

5



6





100 PSIG/SAT'D STEAM GENERATION	
UNIT	100 LB/HR
10 GASIFICATION	369.6
19 SULFUR REC	24.2
24 PCX	48.1
TOTAL	536.7

60 PSIG/SAT'D STEAM GENERATION	
UNIT	100 LB/HR
12 GAS COOLING	174.2
13 SULFUR REC	7.7
TOTAL	181.8


540 PSIG/760°F CONDENSING TURBINES	
UNIT	100 LB/HR
21 AMON SYN AND PURIF.	312.2
TOTAL	312.2

60 PSIG/SAT'D BACK PUMP	
UNIT	100 LB/HR
41 STEAM	17.0
TOTAL	17.0

DRAWING NO.	REV.	FRAME
835104-00-H-307	1	2 OF 2

4

3



NOTES:
 1. THE TEMPERATURES, PRESSURES, AND FLOW QUANTITIES SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES.
 2. NO DISCUSSION OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE REVERSE PAGE AT THE FRONT OF THIS REPORT.

	R. WHITE C. C. ARATY J. D. BARNHART J. H. CARPENTIER R. L. LANG J. R. L. ADAMS	BLOCK FLOW DIAGRAM PLANT STEAM BALANCE CASE: WESTMORELAND COAL-CO-PRODUCTION CROW TRIBE OF INDIANS SYNTHESIS FEASIBILITY STUDY	001 35700307 1
	NONE	835704-00-R-307 MICROFILM FRAME 1 OF 2	
	2	1	
	1	1	

6.5.9 UTILITY SUMMARY

Table 6.5.9-1 indicates the utilities generated or consumed by each process or utility/offsite unit in the Westmoreland Coal - Coproduction Case.

CASE: WESTMO

UNIT	NO.	NAME	STEAM (M lb/h)			
			1500 lb 925°F	650 lb Sat'd	600 lb 760°F	100 lb Sat'd
	01	Coal Screening				
	02	Coal Distribution				
	03	Ash Handling				
	10	Coal Gasification			-1090.9	+566.6
	12	Gas Cooling				
	13	Rectisol				-38.5
	14	Gas Liquor Separation				
	15	Tar Distillation		-9.0		
	16	Naphtha Hydrotreating		-6.2		
	17	Phenosolvan		-3.6		-6.1
	18	Ammonia Recovery		-79.9		-142.1
	19	Sulfur Recovery				+24.2
	20	Process Steam		-357.8	+552.0	
		Superheating				
	21	Methanol Synthesis & Purification		-328.9 ^(**)	-312.2 ^(*)	-9.4
	22	Methanation		+135.6		
	23	SNG Compression & Purification				
	24	Partial Oxidation		+8.7		+49.1
	25	PSA Hydrogen Production				
	40	Oxygen Production	-1,256.4	+1,256.4		
	41	Steam Generation	+4,121.4	-4,138.1 ^(*)	+3860.5	-360.8
	42	Power Generation	-2,865.0	+2,865.0 ^(**)	-3009.4	-64.9
	43	Flue Gas Desulfurization				
	44	Raw Water Treating				

TABLE 6.5.9-1

UTILITY SUMMARY

WESTMORELAND COAL - COPRODUCTION

(M lb/hr)		Condensate (M lb/hr)	BFW (M lb/hr)	Steam & Condensate Loss (M lb/hr)	Cooling Water		Electric Power (MW)	Fuel Gas (MM Btu/hr)
100 lb Sat'd	60 lb Sat'd				(MM Btu/hr)	(gpm)		
							-1.00	
							-0.10	
							-0.70	
+566.6			-690.7	1,215.0	-8.27	-551	-2.40	-0.7
	+174.2		-176.0	1.8	-9.60	-640	-0.35	
-38.5	-75.6	+114.1	-33.8	33.8	-168.40	-11,127	-21.69	
					-89.13	-5,936	-0.69	
	-8.7	+17.7			-4.30	-285	-0.23	-14.5
	-21.1	+27.3			-1.88	-125	-0.12	(+0.9)
-6.1	-57.5	+57.9		9.3	-12.40	-627	-0.39	
-142.1		+222.0			-122.5	-8,157	-0.50	
+24.2	-21.6	+26.2	-32.1	3.3	-41.6	-2,780	-2.88	-11.1
			-196.2	2.0			-1.79	-176.8
* -9.4	-383.3	+704.9	-332.2	3.3	-392.9	-26,192	-1.46	+119.2
			-137.7	2.1	-4.5	-301	-1.19	(-11.9)
					-1.34	-90	-1.80	+21.5
+49.1			-101.9	44.1	-8.93	-595	-0.22	-0.1
					-0.38	-25.2	-0.62	+67.1
					-156.5	-10,400	-11.60	
-360.8	+477.1	-849.4	-3,126.1	15.4			-23.30	
-64.9		+3074.3			-1644.0	-109,800	+321.60	
							-5.07	
							-1.42	

USE ON DISK/TAPE OF REPORT DATA
 IN ACCORDANCE WITH THE RESTRICTIONS ON THE
 SOURCE PAGE OF THE FRONT OF THIS REPORT

CASE: WESTI

UNIT		STEAM (M D)			
NO.	NAME	1500 lb 925°F	650 lb Sat'd	600 lb 760°F	100 Sat'
45	BFW & Condensate Treating				
46	Air & Nitrogen Systems				
47	Process Cooling Water				
48	Utility Cooling Water				
49	Potable Water				
50	Utility Water				
51	Fire Water				
52	Fuel Gas				
53	Flare				
54	Waste Water Treating				
55	Tank Farm & Dispatch				-10
56	Sanitary Sewer				
	Steam Tracing				-7
	Export				
Total (Process Units)		0	+16.7	-851.1	+443
Total (Utility Units)		0	-16.7	+851.1	-443
TOTAL		0	0	0	0

Legend: () indicates intermittent use. Not included in totals.

+ indicates production.

- indicates consumption.

(*) The steam produced is 570 psig/sat'd. It is superheated within the Methanol Synthesis Unit.

(**) 650 psig/710°F steam

(***) Included in Wastewater Treating (Unit 54).

TABLE 6.5.9-1 (Continued)

UTILITY SUMMARY

WESTMORELAND COAL - COPRODUCTION

AM (M lb/hr)		Condensate (M lb/hr)	BFW (M lb/hr)	Steam & Condensate Loss (M lb/hr)	Cooling Water		Electric Power (MW)	Fuel Gas (MM Btu/hr)	
100 lb Sat'd	60 lb Sat'd				(MM Btu/hr)	(gpm)			
	-80.0	-4749.1	+4826.7	2.4			-6.72		
					-10.4	-700	-3.76		
					+1876.0	+125,085	-9.01		
					+715.0	+47,674	-3.28		
							-0.03		
							-0.03		
							-0.02		
							-		
							-0.03	-2.0	
	-2.5	+2.5					-6.26	-2.5	
-10.8	-1.0	+9.7		2.1	-1.1	-74	-0.68		
							(***)		
-7.3		+7.3							
1	+443.8	-393.6	+1170.1	-1700.6	1314.7	-778.8	-51,785	-38.13	+4.5
1	-443.8	+393.6	-2504.7	+1700.6	19.9	+778.8	+51,785	+250.39	-4.5
	0	0	-1334.6	0	+1334.6	0	0	+212.26	0

totals.

uperheated in the process steam superheater to 540 psig/760°F and used to drive turbine

6.5.10 CATALYST AND CHEMICAL SUMMARY

The catalysts and chemicals required for each unit in the Westmoreland Coal - Coproduction Case are shown in Table 6.5.10-1.

TABLE 6.5.10-1

CATALYST AND CHEMICAL SUMMARY

CASE: WESTMORELAND COAL - COPRODUCTION

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
03	Ash Handling Flocculent	150	1,760
13	Rectisol Propylene Caustic	32,300 -	45,700 79,100
16	Naphtha Hydrotreating Dimethyl Sulfide Confidential Catalyst	840 34,700	330 11,600
17	Phenosolvan Isopropylether Solvent Gravel Sand Filtrilur	274,100 1,530 3,400 110,400	95,100 190 420 13,800
18	Ammonia Recovery Phosphoric Acid (100%) Sodium Hydroxide (50% soln.)	155,500 479,700	74,500 159,800

TABLE 6.5.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: WESTMORELAND COAL - COPRODUCTION

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
19	Sulfur Recovery		
	Diisopropanolamine	6,580	3,250
	Claus Catalyst	18,500	6,180
	Shell 634 Catalyst	43,600	14,500
	Citric Acid	6,180	13,300
	ADA	62,000	132,400
	Caustic (50%)	5,870	(58,700) (1)
	Vanadium	48,900	-
21	Methanol Synthesis & Purification		
	Synthesis Catalyst	2,903,000 (2)	968,000 (2)
	Caustic	37,500 (2)	450,000 (2)
22	Methanation		
	Synthesis Catalyst	278,000 (3)	92,600 (3)
41	Steam Generation		
	Hydrazine Hydrate	870	9,540
	Sodium Phosphate	90	930
	Morpholine	7,440	82,400

TABLE 6.5.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: WESTMORELAND COAL - COPRODUCTION

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
43	Flue Gas Desulfurization		
	Lime (90% CaO)	24,700	1,120,000
	Formic Acid (90% soln.)	35,600	330,000
	Anti Foulant (Nalco 7319)	320	3,400
	HCl (30% soln.)	6,180	-
44, 45 & 49	Raw Water, BFW Treating & Potable Water		
	Poly-electrolyte	3,270	39,000
	Chlorine	3,770	45,500
	Quick Lime	2,700	6,530
	Soda Ash (Dense Bulk)	23,650	894,900
	Alum	2,600	4,240
	Hexametaphosphate	8,420	103,300
	Sulfuric Acid (93%)	23,400	101,500
	Caustic (50% soln.)	129,300	516,800
	Activated Carbon	67,500	33,000
	Hydrazine Hydrate	480	5,290
	Morpholine	3,970	44,000
	Chelant (EDTA)	920	10,100
46	Air & Nitrogen System		
	Activated Alumina	1,150	320

TABLE 6.5.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: WESTMORELAND COAL - COPRODUCTION

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
47	Process Cooling Water		
	Chlorine	4,640	54,500
	Sulfuric Acid (93%)	910	289,600
	Inhibitor	11,300	135,600
	Dispersant	3,080	36,900
	Biocide	12,700	61,000
	Nalprep	82,000	210
	Activated Carbon	48,000	24,000
	Hexametaphosphate	3,060	36,000
48	Utility Cooling Water		
	Chlorine	2,610	30,600
	Sulfuric Acid (93%)	11,600	137,500
	Inhibitor	4,400	52,600
	Dispersant	1,200	14,400
	Biocide	3,510	18,100
	Nalprep	24,000	70
	Poly-electrolyte	990	11,800
	Quick Lime	810	1,980
	Soda Ash (Dense Bulk)	7,050	270,000

TABLE 6.5.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: WESTMORELAND COAL - COPRODUCTION

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
54	Wastewater Treating		
	Caustic (50%)	162,100	3,637,500
	Sulfuric Acid (93%)	5,190	125,500
	Poly-electrolyte	220	26,600
	Phosphoric Acid (100%)	3,650	43,100
55	Tank Farm & Dispatch		
	SNG Odorant (Ethyl/Amyl Mercaptan)	70	830
	NaCl	<u>1,760</u>	<u>473,200</u>
TOTAL		\$5,243,950	\$10,994,870

NOTES:

- (1) First year only, not included in total
- (2) Methanol unit in this case is significantly larger than and different from that in the Base Case.
- (3) Methanation process scheme in this case is different from the Base Case and the unit is smaller.

6.5.11 OPERATING MANPOWER

The operating manpower for the Coproduction Case was determined in the same way as the Base Case manpower.

The total operating staff is 426. There are 59 shift operating positions for the Coproduction Case versus 58 for the Base Case.

6.5.12 MAINTENANCE MANPOWER

Annual maintenance cost is estimated as a percentage of the plant installed cost. The same procedure for determining maintenance cost as used on the Base Case (Section 6.1.12) was followed for the Coproduction Case yielding a cost of \$36,300,000, which is 60 percent materials and 40 percent labor.

The labor portion of \$14,500,000 is equivalent to 415 maintenance staff positions using the same assumptions as the Base Case.

6.5.13 PROCESS UNITS ENGINEERING DATA

6.5.13.1 DIFFERENCES

The process configuration for the Coproduction Case differs from the Base Case primarily in the processing of pure gas from Rectisol. The syngas (pure gas) is converted to methanol in the Methanol Synthesis and Purification Unit 21. The purge gas from the methanol synthesis reaction is methanated, purified, and compressed in the Methanation and SNG Purification and Compression Units 22 and 23. The H_2/CO ratio requirement for methanol synthesis is such that no CO Shift (Unit 11) is needed in this case. Due to the absence of the exothermic shift reaction and also due to differences in the heat recovery scheme employed, the Gas Cooling Unit 12 is different in this case. Because of the significant differences in the process configuration of the above units, 12, 21, 22, and 23, detailed information including Design Basis, Process Description, Process Flow Diagram, etc. are provided following this discussion.

The rest of the processing scheme is similar to the Base Case, although slight variations occur in the unit material balances which are included at the end of this section. Deletion of the CO shift eliminates consumption of reaction water, additional production of CO_2 , and hydrocracking of tars and oils. As a result, flows through gas liquor processing (Units 14, 17, and 18) and Lurgi liquids processing (Units 15, 16, and 24) are altered. Rectisol, Sulfur Recovery, and Process Steam Superheating units handle less CO_2 . The material balance tables provide the flow rates in detail.

6.5.13.2 GAS COOLING - UNIT 12

DESIGN BASIS

Purpose of the Unit

The purpose of the Gas Cooling Unit is to cool the hot gas stream leaving the Gasification Unit for feed to the Rectisol Unit and recover the aqueous and organic condensates for further processing.

The substantial amount of heat released from this unit is recovered for use in the plant by generating low pressure steam and heating tempered water and condensate.

Scope of Unit

The unit consists of two major sections: Waste Heat Recovery and Cooling. The waste heat recovery section includes low pressure steam generator and associated equipment, tempered water heater and associated equipment, and makeup water heater. The cooling section includes air cooler, C.W. trim coolers, and knockout drums.

General Criteria

The unit consists of two 50 percent capacity parallel trains. The unit is designed to process approximately 561.1 SCFD of dry gas containing 594,000 lb/hr of water and condensable organics. The design onstream factor is 91 percent, and all rotating equipment are motor driven.

6.5.13.2 (Continued)

Feed Streams

The composition, flow rate, and the process conditions of the feed stream to the Gas Cooling unit are as follows:

<u>Component</u>	<u>Mole %</u>
H ₂	40.27
N ₂	0.24
CO	18.00
CO ₂	30.10
CH ₄	10.28
C ₂	0.59
C ₃	0.12
C ₄	0.03
H ₂ S	0.36
COS	0.01

Flow Rate: Dry Gas, MM SCFD	561.11
Water and Heavier Hydrocarbon Compounds, lb/hr	594,000
Temperature, °F	355
Pressure, psig	417

6.5.13.2 (Continued)

Product Streams

The composition, flow rate, and process conditions of the cooled gas to Rectisol unit are as follows:

<u>Component</u>	<u>Mole %</u>
H ₂	40.67
N ₂	0.24
CO	18.00
CO ₂	29.44
CH ₄	10.37
C ₂	0.59
C ₃	0.12
C ₄	0.03
H ₂ S	0.35
COS	0.01

Flow Rate: Dry Gas, MM SCFD	554.82
Water and Heavier Hydrocarbon Compounds, lb/hr	7,800
Temperature, °F	100
Pressure, psig	397

The flow rate and process conditions of the gas liquor to the gas liquor separation are as follows:

Flow Rate, lb/hr	614,000
Temperature, °F	233
Pressure, psig	212

6.5.13.2 (Continued)

Miscellaneous Streams

The flow rate and inlet and outlet process conditions of the tempered water and makeup condensate are given below:

Stream Name	Inlet Conditions			Outlet Conditions		
	Flow Rate lb/hr	Temp. °F	Press. psig	Flow Rate lb/hr	Temp. °F	Press. psig
Tempered Water	1,150,000	200	445	1,150,000	300	435
Makeup Condensate	470,000	90	75	470,000	180	70

Utilities

Consumption

LP Boiler Feedwater, lb/hr	175,950
Cooling Water, gpm	640
Electric Power, kW	500

Production

LP Steam, lb/hr	174,186
-----------------	---------

PROCESS DESCRIPTION

The flow diagram is shown on Drawing No. 835704-12-4-301 and the material balance is on Table 6.5.13-1. The plot plan (Drawing No. 835704-12-5-051) and equipment list (Table 6.5.13-2) follow.


6.5.13.2 (Continued)

The crude gas from the Gasification unit is passed through a series of heat exchangers to recover heat. The first in the series is the waste heat boiler generating low pressure steam. It is followed by the tempered water heater and the makeup condensate heater. Heavy tarry products with higher boiling points are condensed out in these three heat exchangers.

The hot tempered water from the heat recovery section is pumped to the Methanol Synthesis and Purification unit to preheat the feed to the devolatilizing column. The devolatilizing reboller duty is also provided by the hot tempered water. The cooled tempered water is circulated back to the Gas Cooling Unit for heat recovery, keeping the tempered water system a close loop.

The cooled raw gas from the makeup condensate heater is further cooled by air cooling and finally by trim cooling before entering the Rectisol unit. The major portion of the gas liquor is condensed in the knockout drums downstream of the air cooler and the trim cooler. The gas liquor collected in the knockout drums and tarry liquor stream condensed out in the heat exchangers upstream of the air cooler are piped to the Gas Liquor Separation unit.

The plugging and fouling quality of the crude gas treated in this unit dictates that the shell and tube heat exchangers used be vertical type and the gas flow scheme be downwards. Rejection of the gas liquor in the final cooling stage provides washing of the heat exchanger tubes.



NO.	DATE	REVISION DESCRIPTION


TABLE 6.5.13-1
MATERIAL BALANCE
GAS COOLING - UNIT 12

Stream Number	12-1		12-2		12-3	
Stream Name	Combined Gas		Raw Gas to Rectisol		Oily Gas Liquor (2)	
Component	lb-mol/hr	Mol%	lb-mol/hr	Mol%	lb-mol/hr	Mol%
H ₂	24,811.8	40.27	24,772.1	40.67	39.7	5.75
N ₂	146.9	0.24	146.9	0.24	-	-
CO	11,088.3	18.00	11,071.7	18.18	16.6	2.40
CH ₄	6,334.1	10.28	6,318.9	10.37	15.2	2.20
C ₂	361.9	0.59	361.9	0.59	-	-
C ₃	72.4	0.12	72.4	0.12	-	-
C ₄	18.0	0.03	18.0	0.03	-	-
CO ₂	18,545.7	30.10	17,935.5	29.44	610.2	88.36
H ₂ S	221.7	0.36	213.6	0.35	8.1	1.17
COS	4.8	0.01	4.8	0.01	-	-
NH ₃ /HCN	0.8	-	-	-	0.8	0.12
	<u>100.00</u>		<u>100.00</u>		<u>100.00</u>	
Dry Gas, lb-mol/hr	61,606.4	67.06	60,915.8	99.78	690.6	2.24
H ₂ O Vapor, lb-mol/hr	30,264.7	32.94	136.7	0.22	30,128.0	97.76
Wet Gas, lb-mol/hr	91,871.1	100.00	61,052.5	100.00	30,818.6	100.00
Dry Gas, lb/hr	1,305,315		1,277,333		27,982	
H ₂ O, Vapor, lb/hr	545,249		2,463			
H ₂ O, Liquid, lb/hr					542,786	
Tons, lb/hr	12,947		-		12,947	
Oils, lb/hr	16,843		-		16,843	
Naphtha, lb/hr	5,275		5,275		-	
Phenols, lb/hr	5,095		-		5,095	
Fatty Acids, lb/hr	1,139		-		1,139	
Org. Sulfur, lb/hr	213		11		202	
Ammonia, lb/hr	6,773		-		6,773	
HCl	185		-		185	
TOTAL, lb/hr	1,899,034		1,285,082		613,952	
Pressure, psia	415		405		250	
Temperature, °F	355		100		233	

NOTES: (1) Flow quantities, pressure, and temperatures shown are for the total unit on a stream-day basis, are to be used solely for process design purposes, and are not necessarily the conditions which will be attained during actual operations.

(2) Represents net gas liquor flow from Gas Cooling to Gas Liquor Separation Unit.


INDICATED UNIT BASES



GAS COOLING
UNIT 12

GAS LIQUOR SE
UNIT 14

AREA BOUNDAR



DATE	1/11/74
BY	J. W. H.
APPROVED FOR STUDY	

