

to 82 percent SO₂ emission control efficiency at Site 1 to achieve the Class I PSD compliance.

The assumption of the de minimus GEP stack height regulation crediting a 213 feet (65m) allowance for modeling purposes is shown in Figure 4.6.1-8 to not impose any serious design constraints at Site 23 for the Case II scenario employing the Shell coal supply. Thus, an actual physical stack height of 213 feet could be utilized for this scenario at Site 23 provided a greater than or equal to 76.3 percent boiler SO₂ emission control efficiency is maintained as also shown in Figure 4.6.1-8. Since the currently attainable or BACT baseline for boiler SO₂ emission control for the Case II design utilizing the Shell coal supply is 84 percent, it can be concluded that SO₂ Class I PSD compliance at Site 23 does not present a major potential environmental impact problem area for currently envisioned plant design scenarios.


Potential Environmental Impacts for Air Quality Particulate Matter Emissions:

Site 1. Since Billings, Montana, is currently a nonattainment area for particulates and a Class II-designated air quality area for SO₂, these potential environmental impacts were evaluated for both the previously discussed case design scenarios at candidate Site 1 for both the Westmoreland and Shell coal supplies.

The terrain map for the preliminary air quality screening analysis utilizing the VALLEY complex terrain air dispersion model for the Billings area with respect to a coal gasification plant located at Site 1 is shown graphically in Figure 4.6.1-9 and has been previously presented in Table 4.6.1-10.

The results of the air quality dispersion analyses for potential SO₂ Class II PSD violations in the Billings area from candidate Site 1 scenarios confirmed that, for the most stringent or "worst case," Case II design scenario employing a Westmoreland coal supply and the fundamental assumptions for baseline SO₂ emission control efficiencies of 90 percent for boiler emissions and 98.6 percent for emissions from the vent gas incinerator with a physical stack height of 625 feet, the 24-hour SO₂ Class II PSD increment would not be exceeded. Table 4.6.1-6 shows that the allowable 24-hour SO₂ Class II PSD increment is 91 ug/m³, a factor of 18 higher than its Class I counterpart.

FIGURE 4.6.1-9
CROW POWER PLANT FEASIBILITY STUDY:
SITE 1, TERRAIN CONSIDERATIONS, BILLINGS AREA



Areas in the United States, such as Billings in this study, that presently have lower ambient air quality for a pollutant, such as particulate matter, than specified in the National Ambient Air Quality Standards (NAAQS), as shown in Table 4.6.1-12, are designated by the EPA as nonattainment areas. However, it must be recalled that particulate emissions from the plant are drastically reduced since an electrostatic precipitator (ESP), capable of achieving particulate matter removal efficiencies of 99.7 percent and in compliance with the NSPS requirement of 0.03 lb particulate matter/ 10^6 Btu, is specified as the major control or mitigation measure for the source particulate matter emissions emanating from the plant as previously presented in Tables 4.6.1.4 and 4.6.1-5 for the Case I and Case II design scenarios utilizing Westmoreland coal and the Case II design utilizing the Shell coal supplies.

Using the same design basis as the previously described Case II design with Westmoreland coal for the SO₂ Class II PSD increment analyses as the worst case scenario, it was found that particulate matter concentrations at representative receptor locations in the Billings area would be less than 0.1 ug/m³. Pollutant concentrations of less than 0.1 ug/m³ at a specific receptor location may be considered insignificant since the minimum level of precision for the VALLEY model in this type of analysis application is at least 0.1 ug/m³ or greater. Additionally, field monitoring measurements of particulate matter increments would most certainly not exhibit greater precision than the analysis criterion. Therefore, based upon the results of the dispersion modeling, it is concluded that particulates emissions emanating from the presently conceived coal gasification plant design scenarios at Site 1 would not violate the nonattainment status for particulates in the Billings area and, hence, would not impose any seriously adverse environmental air quality impacts.

Potential Environmental Impacts for Air Quality Particulate Matter Emissions:
Site 23. A VALLEY dispersion modeling analysis of the potential impact of particulate matter emissions from the worst-case Case II design scenario utilizing the Shell coal feed was performed at candidate Site 23 to confirm compliance with the Class I PSD increment requirements for the Northern Cheyenne Reservation. Results indicate that 24-hour particulate matter concentrations at receptor locations

TABLE 4.6.1-12
NATIONAL AMBIENT AIR QUALITY STANDARDS^a
(ug/m³)

Pollutant	Averaging Time	Primary Standard	Secondary Standard
SO ₂	Annual	80	—
	24 hour	365	—
	3 hour	—	1,300
Particulate matter	Annual	75	60
	24 hour	260	150
NO _x (as NO ₂)	Annual	100	100
O ₃	1 hour	240	240
CO	8 hour	10,000	10,000
Lead	Quarterly	1.5	1.5
HC (non CH ₄)	3 hour	160 ^b	160 ^b

^a40 CFR Part 50. Reference Conditions = 760 mm Hg and 25 C.


^bNot a standard; a guide to show achievement of the O₃ (ozone) standard.

within the Northern Cheyenne Reservation would be less than 0.1 ug/m³. Thus, it may be concluded that the proposed Crow coal gasification plant with an SNG production rate of 250 MM SCF/D would be in compliance with the Class I PSD particulate matter increment at Site 23, principally due to the stringent emission control invoked by an electrostatic precipitator with a 99.4 percent particulate removal efficiency which is presently considered as the upper limit for the control technology (BACT) within the time frame for this project.

The potential environmental air quality impacts in the Site 23 area from particulate matter would arise from fugitive dusts from the nearby proposed Shell mining operation since Site 23 represents a potential "minemouth" siting opportunity as previously discussed. Hence, the primary mitigation measure recalling that compliance with the stringent Class I PSD increment for particulates with respect to the Northern Cheyenne Reservation is the major constraint, would be strict procedural control by properly implemented water spraying of the affected mining areas and adjacent access roads to minimize potential dusting from vehicular traffic and heavy mining equipment. However, it must be emphasized that Class I regulatory compliance in this instance would be the separate responsibility of Shell as the mine operator.


4.6.1.2 Mitigation Measures: Potential Air Quality Impacts


Primary emphasis on the mitigation of potential adverse air quality impacts due to the proposed Crow coal gasification project has been placed on the implementation of engineered control devices within the plant design as shown schematically in Figures 4.6.1-10, 4.6.1-11, and 4.6.1-12 which represent, respectively, the final air emission process block flow diagrams for the Case I and Case II plant design scenarios utilizing the Westmoreland coal feed and the Case II design scenario employing Shell coal. Although the numerical values cited in the figures reflect a nominal design production rate of 125 MM SCF/D SNG for the half-size plant rating, they serve to illustrate the intended design implementation of control devices to mitigate the salient potential environmental impacts.



NOTE: NUMBERS IN PARENTHESES REFER TO NOTES AT RIGHT.

	1 COAL SCREENING	2 COAL DISTRIBUTION	3 CLASSIFICATION LOCK GAS VENT	13 CLASSIFIER START-UP VENT	3 (4) HEATER FLUE GAS	6 SUPERHEATER FLUE GAS	7 BOILER FLUE GAS	8 (7) HEATER FLUE GAS	9 PRODUCT STORAGE TANK, FARM
C ₂	LBS/AHR			CONFIDENTIAL	842	20,344	88,341	267	
N ₂	LBS/AHR		1		23,756	312,874	1,237,829	6,751	
CO ₂	LBS/AHR		233		4,870	936,730	343,321	6,410	
H ₂ O	LBS/AHR		1		4,717	89,834	193,012	2,338	
SO ₂	LBS/AHR					211	(51)	323	
H ₂ S	LBS/AHR		2						
CO ₂ S	LBS/AHR		TRACE						
NO	LBS/AHR				22	225	848	6	
CO	LBS/AHR		65		2	12	98	TRACE	
CH ₄	LBS/AHR		53						
H ₂	LBS/AHR		15						
HYDROCARBONS	LBS/AHR		5						5
PARTICULATES	LBS/AHR	4	2				(1)	47	
TOTAL FLOW	LBS/AHR	4	2	403	34,449	1,344,330	1,900,021	3,772	5
TOTAL FLOW	LEMBL/AHR			19	1,253	36,748	66,932	335	
TEMPERATURE	°F	AIR	AIR		300	400	128	300	AIR
ELEVATION OF RELEASE FT	73	150	200	7	100	423	623	100	40






NOTES:

1. BOILER DESIGN MEETS EPA CODE OF FEDERAL REGULATIONS-TITLE 40 EMISSION LIMITS:
SOX = 1.2 LB/MMBtu
NOx = 0.5 LB/MMBtu
PARTICULATES = 0.02 LB/MMBtu
2. BOILER FEED COAL = 96.6 TAREAS RECEIVED,
GASIFIER FEED COAL = 450 T/HR (AS RECEIVED).
3. COMPOSITION AND DURATION OF GASIFIER START-UP VENT ARE CONFIDENTIAL LURGI INFORMATION.
MAXIMUM EMISSIONS:
SO2 = 372 LB/MMBtu
HYDROCARBONS = 468.165 MMFAC
4. CATALYST REDUCTION REQUIRES FUEL GAS. FLOW SHOWN IS OF SHORT DURATION.
5. SO₂ VENTED IS BASED ON FGD REMOVAL EFFICIENCY OF 90%.
6. PARTICULATES VENTED ARE BASED ON AN EXIT CONCENTRATION OF 0.015 G/GFC. OVERALL REMOVAL EFFICIENCY IS 99.7%.
7. HEATER FLUE GAS EMISSIONS ESTIMATED BASED ON THE FOLLOWING HEATER OUTLET
TAR DISTILLATION = 12.2 MMST/HR
8. HYDROCARBON EMISSIONS FROM STORAGE TANKS BASED ON FLOATING ROOF DESIGN WITH SECONDARY SEALS AND VAPOR RECOVERY SYSTEMS UTILIZED ON CONE ROOF TANKS.
9. THE TEMPERATURES, FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.


FIGURE 4.6.1-10


FLUOR		D.P. HALVERSON C.G. BARATAY E.O. ALMIGHTY R.J. CANTRELL P.L. GALE	CASE 1 AIR EMISSIONS CASE: WESTMORELAND COAL-POWER SELF-SUFFICIENCY CHIEF TRIBES OF INDIANS STUDY OF FEASIBILITY STUDY	BLOCK FLOW DIAGRAM
None	835704-00-4-205	1	937100205	



NOTE: NUMBERS IN PARENTHESES REFER TO NOTES AT RIGHT.

	COAL SCREENING	LEAD DISTRIBUTION	GASIFICATION LOCK GAS VENT	CASIFIER START-UP VENT	CONFIDENTIAL	HEATER FLUE GAS	SUPERHEATER FLUE GAS	BOILER FLUE GAS	HEATER FLUE GAS	PRODUCT STORAGE TANK FARM
SO ₂	LBS/AHR				CONFIDENTIAL	842	20,544	266,832	267	
NO _x	LBS/AHR			1		23,796	312,874	3,827,712	6,751	
CO ₂	LBS/AHR			263		4,370	950,730	1,112,320	1,410	
H ₂ O	LBS/AHR			1		4,711	98,534	993,442	1,336	
SO ₃	LBS/AHR						211	151	963	
H ₂ S	LBS/AHR			2						
CO ₃	LBS/AHR			TRACE						
NO _x	LBS/AHR					22	229	2,584	6	
CO	LBS/AHR			85		2	12	300	TRACE	
CH ₄	LBS/AHR			33						
N ₂	LBS/AHR			13						
HYDROCARBONS	LBS/AHR			8						5
PARTICULATES	LBS/AHR	5	2					(6)	143	
TOTAL FLOW	LBS/AHR	3	2	403		34,449	1,344,530	5,806,316	8,772	3
TOTAL FLOW	LBS/LIN. AHR			11		1,253	36,748	203,438	355	
TEMPERATURE °F	Amb.	Amb.				300	400	126	300	Amb.
ELEVATION OF RELEASE FT	75	150	200	1		100	625	625	100	40






- NOTES:
1. BOILER DESIGN MEETS EPA CODE OF FEDERAL REGULATIONS-TITLE 40 EMISSION LIMITS:
SOX = 1.2 LB/MMBTU
NOX = 0.5 LB/MMBTU
PARTICULATES = 0.03 LB/MMBTU
 2. BOILER FEED COAL = 300 TMM (AS RECEIVED).
GASIFIER FEED COAL = 450 TMM (AS RECEIVED).
 3. COMPOSITION AND DURATION OF GASIFIER START-UP VENT ARE CONFIDENTIAL LURGI INFORMATION.
MAXIMUM EMISSIONS:
SO₂ = 372 LBS/HR
HYDROCARBONS = 458 LBS/HR
 4. CATALYST REDUCTION REQUIRES FUEL GAS. FLOW SHOWN IS OF SHORT DURATION.
 5. SO₂ VENTED IS BASED ON FED REMOVAL EFFICIENCY OF 95%.
 6. PARTICULATES VENTED ARE BASED ON AN EXIT CONCENTRATION OF 0.013 GR/SCF. OVERALL REMOVAL EFFICIENCY IS 95.7%.
 7. HEATER FLUE GAS EMISSIONS BASED ON THE FOLLOWING HEATER DUTY:
TAR DISTILLATION 12.2 MM BTU/HR
 8. HYDROCARBON EMISSIONS FROM STORAGE TANKS, JED ON FLOATING ROOF DESIGN WITH SECONDARY SEALS AND VAPOR RECOVERY SYSTEMS UTILIZED ON CONE ROOF TANKS.
 9. THE TEMPERATURES, FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.

FIGURE 4.6.1-11


PROJECT INFORMATION		SP-1	SP-2	BLOCK FLOW DIAGRAM	
				CASE 2 AIR EMISSIONS	
				CASE 2 WESTMORELAND COAL - 40% FINES - SHG	
				SYNTHETIC FUELS FEASIBILITY STUDY	
D.P. HALVERSON	C.G. ABAYAY				
V.D. BELLUTO					
P. McCARTHY	J.C. BROWN				
R. LANG	K.L. ALLEN				
NONE		835704-00-4-105			1
					001 EST00005



NOTE: NUMBERS IN PARENTHESES REFER TO NOTES AT RIGHT.

	① COAL SCREENING	② COAL DISTRIBUTION	③ GASIFICATION LOCK GAS VENT	④ (3) GASIFIER START-UP VENT	⑤ (4) HEATER FLUE GAS	⑥ SUPERHEATER FLUE GAS	⑦ BOILER FLUE GAS	⑧ (7) HEATER FLUE GAS	⑨ (8) PRODUCT STORAGE TANK FARM
D ₂	185 A/R			CONFIDENTIAL	349	23,910	278,752	448	
H ₂	185 A/R		2		24,226	313,695	3,958,360	11,437	
CO ₂	185 A/R		336		5,147	637,100	1,125,827	2,430	
H ₂ O	185 A/R		1		4,875	37,757	611,820	2,207	
SO ₂	185 A/R		1			90	151,719		
H ₂ S	185 A/R		1						
CO ₃	185 A/R		TRACE						
NO _x	185 A/R				22	222	2,667	10	
CO	185 A/R		112		2	11	293	1	
CH ₄	185 A/R		45						
N ₂	185 A/R		20						
HYDROCARBONS	185 A/R		8	TRACE					8
PARTICULATES	185 A/R	5	2				(6)	(4)	
TOTAL FLOW	185 A/R	8	2	923	35,021	1,332,385	9,882,584	16,533	8
TOTAL FLOW	LBM/HR			25	1,271	35,436	209,623	600	
TEMPERATURE	°F	AMBI.	AMBI.		300	400	120	300	AMBI.
ELEVATION OF RELEASE FT		75	150	200		100	250	100	40

1	2
3	4
5	6
7	8
9	10



- NOTES:**
1. BOILER DESIGN MEETS EPA CODE OF FEDERAL REGULATIONS-TITLE 40 EMISSION LIMITS:
SO₂ = 1.2 LB/MMBTU
NO_x = 0.9 LB/MMBTU
PARTICULATES = 0.03 LB/MMBTU
 2. BOILER FEED COAL = 793.3 TMM (45 RECEIVED);
CASSIPIE FEED COAL = 490 TMM (AS RECEIVED).
 3. COMPOSITION AND DURATION OF GAS-HEATER START-UP VENT ARE CONFIDENTIAL SOURCE INFORMATION.
MAXIMUM EMISSIONS:
SO₂ = 160 LB/MM
HYDROCARBONS = 334 LB/MM
 4. CATALYST REDUCTION REQUIRES FUEL GAS. FLOW SHOWN IS OF SHORT DURATION.
 5. SO₂ VENTED IS BASED ON FGD REMOVAL EFFICIENCY OF 84%.
 6. PARTICULATES VENTED ARE BASED ON AN EXIT CONCENTRATION OF 0.013 GR/SCF. OVERALL REMOVAL EFFICIENCY IS 99.4%.
 7. HEATER FLUE GAS EMISSIONS BASED ON THE FOLLOWING HEATER DUTY:
TAR DISTILLATION = 20.3 MM BTU/HR
 8. HYDROCARBON EMISSIONS FROM STORAGE TANKS BASED ON FLOATING ROOF DESIGN WITH SECONDARY SEALS AND VAPOR RECOVERY SYSTEMS UTILIZED ON CONE ROOF TANKS.
 9. THE TEMPERATURES, FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.

FIGURE 4.6.1-12

BLOCK FLOW DIAGRAM	
CASE 2 AIR EMISSIONS	
CASE: SHELL COAL - 40% FINES - SNG	
CROW TRIBE OF INDIANS SYNFUELS FEASIBILITY STUDY	
D.P. HALVERSON	835704-00-4-405
C.E. ABATAY	
E.D. BELMITO	
H. MCCARTHY	
R. LANG	
NONE	

FLUOR

NOTICE: This document has not been published nor is it the sole property of Fluor Corporation and its contractors. It is the sole property of the U.S. Environmental Protection Agency (EPA). All rights reserved by the U.S. Environmental Protection Agency. The document contains neither recommendations nor conclusions of the U.S. Environmental Protection Agency. It has been reviewed by the agency and approved that it is suitable for publication. Approval does not preclude subsequent changes by the agency or other responsible agency personnel if necessary. The document is being made available for general information purposes only. It is the property of the U.S. Environmental Protection Agency and may not be reproduced without prior written consent of the agency.

DOE-135704-005


Since the primary control device for the mitigation of plant air particulate emissions, the ESP, presents a lesser potential problem area in terms of this project based upon the results of the dispersion air modeling results, major emphasis has centered on the selection of control devices to mitigate the SO₂ emissions emanating from the plant process units.

Davy McKee FGD Unit. An evaluation of four potential vendor proposals for a FGD unit to attain a 90 percent SO₂ emission control efficiency for the boiler plant with a Westmoreland coal feed and 84 percent SO₂ emission control efficiency utilizing the alternate coal supply from Shell was conducted by Fluor as discussed in detail in Volumes II and V of this report. Summarily, the proposed Davy McKee FGD unit was selected primarily on the basis of process economics for purposes of this feasibility study. Additionally, the Davy McKee proposal was the only vendor to supply a firm price quotation for an FGD unit with SO₂ emission control efficiencies in excess of 90 percent.

The Davy S-H flue gas desulfurization process, shown in Figure 4.6.1-13, is a wet scrubbing process based on lime. Particulate removal with an electrostatic precipitator will be provided, as previously discussed, upstream of the FGD system.

The Davy S-H process has four main steps: SO₂ absorption, oxidation, lime addition, and solids separation. Calcium ions in the form of calcium hydroxide, Ca(OH)₂, calcium formate, Ca(COOH)₂, and calcium chloride, CaCl₂, in a clear solution are used to absorb sulfur dioxide from the flue gas. The resultant intermediate, water soluble calcium bisulfite, CA(HSO₃), is then oxidized to calcium sulfate dihydrate, CaSO₄ · 2H₂O, and precipitated from the system as a stable gypsum product. Calcium ions lost with the gypsum are continuously replaced by the addition of calcium oxide, CaO. The gypsum is recovered as a dry filter cake. A flue gas booster fan provides the energy required for pressure losses through the FGD system.

FIGURE 4.6.1-13
DAVY S-H PROCESS: FLUE GAS DESULFURIZATION



4-302

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

The flue gas is contacted in the ROTOPART absorbers concurrently with a washing fluid containing $\text{Ca}(\text{OH})_2$, $\text{Ca}(\text{COOH})_2$, and CaCl_2 . The absorbed SO_2 reacts as follows to form $\text{Ca}(\text{HSO}_3)_2$ which is water-soluble:



As OH^- ions from the solution are consumed in the absorption of SO_2 , an abundance of H^+ ions are made available.



The pH of the solution drops rapidly to about 5.0.

By reacting with H^+ ions to form formic acid, HCOOH , the formate ions act to control the pH drop, buffering the solution in the pH range 4.5 to 5.0, a range that assures formation of $\text{Ca}(\text{HSO}_3)_2$.



Equilibrium is shifted to the right as a result of excess H^+ ions. By controlling the drop in pH, a high SO_2 removal takes place in the pH range 4.0 to 5.8.

After the formate ion concentration decreases, the buffering effect is weakened and the pH of the scrubbing fluid drops to a pH of 4.0 which is the optimum for oxidation. No pH adjustment is required prior to oxidation.


The ROTOPART absorber consists of one or more absorber tubes sized on a residence time/velocity criteria basis. The velocity should be low enough to allow time for $\text{Ca}(\text{HSO}_3)_2$ formation. The residence time must be low enough to prevent oxidation of the intermediate $\text{Ca}(\text{HSO}_3)_2$ to $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ due to oxygen in the flue gas.

Washing fluid is introduced into each ROTOPART absorber tube by means of hollow cone spray nozzles arranged in one plane. The absorbing tubes function as spray

chambers but have one or more water-shedding rings (low pressure drop Venturi throats) to increase velocity and direct the washing fluid back to the center of the duct, thus preventing it from running down the walls as an inactive film.

The shedding rings increase the droplet surface area available for contact and provide the intimate mixing of gas and liquid phases necessary for mass transfer. The contact velocity and the number of water shedding rings required are determined by the SO_2 content of the feed gas and the degree of desulfurization required.

In the oxidizer, air is used to convert bisulfite ion to calcium sulfate dihydrate (gypsum) crystals.




The formation of sulfuric acid, H_2SO_4 , during oxidation further reduces the pH of the solution from 4.0 to about 3.5.

In the mixing channel, slurried lime, $\text{Ca}(\text{OH})_2$, is added to the scrubbing fluid to replenish calcium ions consumed by the formation of gypsum in the oxidizer and to adjust the pH value to that required for SO_2 absorption.



and



The sulfuric acid formed in the oxidizer is converted into additional gypsum.



A small amount of formic acid is added to make up for losses of calcium formate in the wet filter cake produced downstream and for traces of formic acid vapor with

the flue gas from the ROTOPART. Turbulence in the mixing channel provides adequate mixing of the added chemicals.

The gypsum crystals formed in the oxidizer and mixing channels are separated from the washing fluid in the thickener. The separation is achieved by reducing the fluid velocity below the solids settling velocity so that individual $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ crystals settle to the bottom. The crystals (10 to 30 percent slurry) are pumped from the bottom of the thickener to a vacuum filter. The vacuum filter produces a gypsum cake containing approximately 77 percent solids (23 percent free H_2O). The dry cake is a high grade gypsum (95 to 97 percent $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ with less than 0.5 percent $\text{CaSO}_3 \cdot 1/2\text{H}_2\text{O}$). The filtrate is recirculated to the thickener. The clear overflow from the top of the thickener is returned to the ROTOPART as washing fluid which normally provides a closed washing fluid loop.

A lime storage and slaking system is provided to prepare and distribute the lime consumed by the process. A lime day bin receives lime from a lime storage bin. A vibrating bin discharger feeds lime into a gravimetric feeder which controls lime addition to the lime slaker. A combination of clean make-up water and washing fluid are used to slake the lime to a 10 to 20 percent $\text{Ca}(\text{OH})_2$ slurry. A 15-minute buffer tank holds the lime slurry while it is pumped continuously to the 12-hour lime slurry surge tank. From the surge tank, the lime slurry is pumped to the mixing channel for mixing with the washing fluid.

Equipment packages are also included for storage and distribution of the following chemicals:

formic acid

antifoulant (for pH measurement system), and


flocculant (for use only with high fly ash particulate load).

Steam is listed as an import at 150 psig. Steam is used only during shutdown of a boiler or the FGD system to heat seal air for isolation dampers. Heating isolation dampers prevents acid mist condensation and subsequent corrosion on the metal damper surface.


Lurgi Classification Process: Major Gaseous Emission Control Units. The major units within the Lurgi coal gasification process design as conceived by Fluor that serve as both product SNG purification units and gaseous emission control devices within the overall gasification process are the ADIP, Claus, SCOT, and Stretford units as presented in the process flow diagrams denoted as Figures 4.6.1-14, 4.6.1-15, 4.6.1-16, and 4.6.1-17, respectively. Since these units constitute the principal substantiation of mitigation measures for reducing gaseous emissions to the ambient atmosphere from the gasification process a brief discussion of each process is presented (detailed discussion appears in Volume II of this report).


ADIP Process. The Shell ADIP process section, as shown in the process flow diagram denoted as Figure 4.1.6-14, employs a 25 to 35 percent aqueous solution of diisopropanolamine (DIPA) to selectively absorb the hydrogen sulfide (H_2S) gas stream discharged by the Rectisol process. Regeneration of this solution through the application of heat releases a concentrated H_2S gas suitable for operation of the Claus unit.

Claus Unit. The process flow diagram as shown in Figure 4.6.1-15 accepts process gas from the previously described ADIP section of the plant. A "split-stream" Claus process is employed as shown in the above process flow diagram and is typical of most coal conversion processes since the acid gas stream produced as a result of the aforementioned treatment generally will contain CO_2 in excess of 30 percent. In the split-stream process, the acid gas is split into two streams, one of which enters the combustion or reaction furnace (19HT-D21 in Figure 4.6.1-15) where H_2S is oxidized to SO_2 using an approximately stoichiometric quantity of air. Hot gases enter the combustion furnace where enough residence time is provided to allow for the Claus reaction to reach equilibrium. The gas is then passed through a waste heat boiler (19E-0121, Figure 4.6.1-15) where the elemental sulfur produced is removed. The product gas from the combustion reaction is then combined with the "uncombusted"



A	-	





19E-0121
WASTE HEAT BOILER


19DM-0121
STEAM DRUM

19E-0122
FIRST CONDENSER

19H-0122
FIRST REHEAT FURNACE

19RE-0121
FIRST CONVERTER

SEC



DRAWING NO. REV. FRAME
235704-19-N-102 1 2 OF 2





FIGURE 4



 FLUOR

D. P. HALVORSON
S. E. ABATA
3-35 MTC

DEFENDANT, THIS DEFENDANT HAS BEEN PREVIOUSLY
IN FLAMES DEFENDANT AND CONSPIRATOR,
DEFENDANT FOR THE SAME DEFENDANT HAS BEEN, AND
LAW OF THIS DEFENDANT HAS BEEN DEFENDANT
IN APPEAL DEFENDANT HAS DEFENDANT THAT IT IS
LAW OR OTHERWISE DEFENDANT OF DEFENDANT'S
LAST DEFENDANT DEFENDANT THAT THE DEFENDANT IS

19RE-0122
SECOND CONVERTER

19E-0124
THIRD CONDENSER

19HT-0124
THIRD REHEAT FURNACE

19RE-0123
THIRD CONVERTER

19E-0125
FOURTH CONDENSER

19TK-0121
SULFUR PIT





FIGURE 4.6.1-15

FLUOR		PROCESS FLOW DIAGRAM	
		SULFUR RECOVERY - CLAUS SECTION	
		UNIT 19	
		D.P. HALVERSON C.C. SRIVASTAV W.D. BELMONT B.M. PARTHY	CROW TRIBE OF INDIANS SYNFUELS FEASIBILITY STUDY
		835704-19-R-1021	
2		MIRCOFILM FRAME 1 OF 2	

19HT-0131
SCOT FURNACE

19RE-013
SCOT REACT




JUN-8131
SCOTT REACTOR

194L-0131
QUENCH COLUMN

19C-0121
TAILGAS BLOWER

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT




NOTES:

1. THIS DRAWING SHOWS ONE TRAIN OF A TWO TRAIN SECTION. CAPACITY OF EACH TRAIN IS 300 TONS/UNIT DESIGN.
 2. THIS DRAWING IS A SIMPLIFIED FLOW DIAGRAM OF A PROPRIETARY UNIT. STREAM CONFIGURATIONS AND/OR EQUIPMENT ARE NOT COMPLETELY REPRESENTED.
 3. THE FLOW QUANTITIES, TEMPERATURES AND PRESSURES REFERENCED BY DIAMONDS ARE SHOWN ELSEWHERE.

FIGURE 4.6.1-16

PROJECT DESCRIPTION	FLUOR	D.P. HALVERSON C.C. ABATAY W.D. BELWITO R.J. MCCARTHY R.L. LANG	PROCESS FLOW DIAGRAM SULFUR RECOVERY-SCOT SECTION UNIT 19	CROW TRIBE OF INDIANS SYNTHETIC FEASIBILITY STUDY
			NONE	835704-19-4-103
				100



19TK-0141
PUMPING TANK

19TK-0142
SULFUR SEPARATION
AND RECOVERY SYSTEM

19ME-0143
FIXED SALT RECOVERY SYSTEM

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT




FIGURE 4.6.1-17

PROJECT NUMBER		D.P. HALVORSON		PROCESS FLOW DIAGRAM	
		G.C. ABATAY		SULFUR RECOVERY-STRETFO RD SECTION	
		W.D. GEMMITO		UNIT 19	
19TK-0141	19TK-0142	CROSS TRIBE OF INDIANS	SYNUFLS FEASIBILITY STUDY		0033519104
19ME-0143		None	835704-19-4-104	I	

portion of the original input stream. The combined stream is then passed through a series of three reheater (19HT-0122, 19HT-0123, and 19HT-0124 in Figure 4.6.1-15) and catalytic converter stages (19RE-0121, 19RE-0122, and 19RE-0123) stages to recover about 93 percent of the sulfur that entered the Claus unit in the original feed stream. The tail gas stream then enters the SCOT section of the process as illustrated in Figure 4.6.1-15. Typical gas composition for the feed stream and tail gas stream for typical operating temperatures and pressures, and employing a split-flow mode Claus unit, are presented in Table 4.6.1-14.

SCOT Section. The Claus plant tail gas is combined with air from the sulfur recovery stream from the Claus unit and hydrogen reducing gas, from the H₂ production unit (25) within the plant and heated in the SCOT section furnace (19HT-0131) as shown in Figure 4.6.1-16. The exit gas from the SCOT furnace then enters the SCOT reactor (19RE-0131 in Figure 4.6.1-16) where catalytic reduction of the sulfur species to H₂S is effected by means of a cobalt/molybdate catalyst followed by removal and recovery of the H₂S in an alkanolamine (typically diisopropanolamine) scrubbing system (Quench Column, 19VL-0131 in Figure 4.6.1-16). The SCOT tailgas is then sent to the sulfury recovery section of the Stretford unit.

Stretford Unit. A total of six gas streams are processed through the Stretford unit prior to entering the vent gas incinerator (process steam superheating) and subsequent gaseous emission from the coal gasification plant to the ambient atmosphere. The aforementioned gas streams include the following: H₂S lean gas from the Rectisol unit, sour gas from the Naptha Hydrotreating unit, off gas from ammonia recovery, expansion gas from the Gas Liquor Separation unit, off gas from sulfur recovery within the ADIP section and tail gas from sulfur recovery within the SCOT section, as shown in the process flow diagram for the Stretford unit, Figure 4.6.1-17.

The combined raw gas stream is contacted countercurrently with the "Stretford solution," an aqueous solution of ADA (anthraquinone disulfonic acid), vanadium, anhydrous citric acid, and sodium carbonate. H₂S in the gas is oxidized to elemental

TABLE 4.6.1-14
SPLIT FLOW MODE CLAUS FEED AND TAIL GAS DATA^a


Component	Feed Stream	Tail Gas Stream
	Stream 1 Mole %	Stream 3 Mole%
COS	—	0.09
H ₂ S	19.72	0.26
SO ₂	—	0.10
CO ₂	78.68	65.04
N ₂	0.56	34.34
C ₁	0.66	—
C ₂	0.12	0.19
C ₃	0.08	0.03
C ₄ ⁺	0.18	—
C ₄	—	—
Temperature	313°K (105°F)	805°K (990°F)
Pressure	0.16 MPa (8.1 psig)	0.10 MPa (0.1 psig)

^aData were selected to represent Claus performance on low-H₂S, high-CO₂ gases which would be encountered in coal gasification applications.


Source: Draft Standards Support and Environmental Impact Statement. Volume I: Proposed Standards of Performance for Lurgi Coal Gasification Plants, EPA, November 1976.

sulfur by the vanadic salt while the salt is reduced to vanadous form.

The reactions involved are:



in the absorber and



and



in the holding tank. The reduced liquor flows to the oxidizers (19VL-0141 in Figure 4.6.1-17) where the vanadium is restored to the vanadic form by a redox reaction with the ADA. Air is blown through the oxidizers to reoxidize the ADA and separate the sulfur by froth flotation. This reaction is:



The sulfur float is sent to a centrifuge and separator where the product sulfur (99.5 percent purity) is obtained. Side reactions involving HCN and other (than H_2S) sulfur and nitrogen compounds require that a portion of the solution be blown down to prevent buildup of these contaminants.

Process Steam Superheating (Vent Gas Incinerator). The exit gas from the Stretford unit, containing approximately 1.4 weight percent sulfur, enters the process steam superheating unit or vent gas incinerator where the remaining sulfur is oxidized to SO_2 . As previously noted in Tables 4.6.1-8 and 4.6.1-9, air emissions data for the selected design scenarios employing the Westmoreland and Shell coal feeds, respectively, the vent gas incinerators also incorporate special burners to limit NO_x and hydrocarbon gaseous emissions from the Lurgi gasification process as previously

demonstrated in Table 4.4.1-1, Section 4.5.1. Summarily, the aforementioned SO₂ emission control devices result in high SO₂ emission control efficiencies of 98.7 percent or greater for both coal feeds and all design scenarios analyzed in the feasibility study. Thus, it is concluded that BACT for the Lurgi coal gasification units will effect excellent mitigation of potential gaseous emissions of the major pollutants. The mitigation measures to reduce NO_x and particulate emissions also drastically reduce the potential adverse impacts from visibility impairment since these two pollutants are the major contributors to visibility degradation from coal combustion process plants.

4.6.2 Water Resources Impact Assessment

Potential water-related environmental impacts to the Crow Reservation due to the operation of the proposed coal gasification facility may be related to impacts associated with possible disturbance to both quantity and quality of the water resource within reservation boundaries.

4.6.2.1 Water Quantity

Although the final process design for this feasibility study is based upon a SNG production rate of 125 MM SCF/D, the water requirements for the facility must ultimately be prefaced upon upgrading the plant to the 250 MM SCF/D SNG production rate. For the higher SNG production rate, plant water requirements dictate a firm plant supply flow rate of 14,000 gpm (31 cfs). Since the Yellowtail Reservoir (Bighorn Lake) and the Bighorn River currently constitute the only regulated supply of water on the reservation that will satisfy the design requirements on a continuing basis, the withdrawal of approximately 20,500 ac-ft/yr (332 plant operating days per calendar year) represents the only potential environmental impact from the operation of the proposed coal gasification plant on the surface water and groundwater resources with respect to overall reservation water budget or inventories at any of the proposed candidate siting areas.

The other major drainages on the Crow Reservation—the Little Bighorn River and Pryor Creek—are presently unregulated and, hence, could not meet the plant requirements during the minimum or low natural discharge rates occurring on a yearly seasonal basis (discussed earlier in the environmental baseline description of the water resources in Section 4.1.3).

4.6.2.2 Water Quality Impacts Assessment

Potential adverse water quality impacts to the Crow Reservation and the surrounding environs from the operation of the proposed Crow synfuels plant are closely interrelated to the properly implemented mitigation of the liquids and solids process waste residues. As previously inferred, the engineering design of the facility is predicated upon zero liquid discharge; i.e., having no direct discharge of liquid waste effluents to surface waters or groundwaters within the areas of the two selected candidate sites, Site 1 and Site 23. Hence, the major mitigation measures to preclude potential water quality impacts evolve quite naturally around the basic design of the process water management system regardless of the siting area as shown in the block flow diagram in Figure 4.6.2-1 and as discussed in greater detail in Volume II of this report. It must be emphasized that the process design details shown for the water management system are representative of the base case design for a production rate of 125 MM SCF/D SNG. The capability of water soluble ions or compounds to migrate or be transported externally from the immediate area of the plant site is dependent on (1) their increased mobility in the liquid (aqueous) state and (2) a continuous transport linkage, the liquid pathway in this instance, to an area of potential environmental impact.

Therefore, the ancillary containment features incorporated into the design of the external liquid-solid and solid process waste effluents constitute the primary mitigation measure necessary to prevent liquid contaminant migration into either surface waters or groundwaters. Thus the design philosophy of mitigation by containment either eliminates or minimizes one of the two conditions necessary to produce the contaminant transfer mechanism.


All water and process liquid waste effluents for the Crow synfuels plant are stored in a series of ponds located within the completely fenced plant siting areas as shown in Figures 4.6.2-2 and 4.6.2-3 for candidate sites 1 and 23, respectively. The details of the pond construction pertinent to the postulated liquid containment design approach are summarized in Table 4.6.2-1. The pond lining system details are illustrated in Figures 4.6.2-4 through 4.6.2-8.


The largest of the ponds (about 48 acres) in Table 4.6.2-1 and the recipient of the majority of potentially hazardous process liquid waste effluents, the solar evaporation pond, has the lining system shown as "Detail D" in Figure 4.6.2-5. The 100 mil high density polyethylene (HDPE) inner lining is followed by a 6-in. (minimum) thick drainage course, an additional 18-in. thick compacted clay liner and, finally, a compacted subgrade. Thus, the evaporation pond lining system incorporates, effectively, a multilayer containment barrier composed of relatively impervious lining materials, HDPE, and clay.


The other smaller repositories of possibly hazardous liquid waste effluents are outlined in Table 4.6.2-1. The wastewater equalization pond, the treated effluent pond, the diversion box and pond, and the oily stormwater pond also incorporate the foregoing lining system design.

Additional mitigation measures incorporated in the pond design include design provisions for adequate freeboard and pond embankment side slope to preclude potential surface runoff of the stored liquid waste effluents as a consequence of inadvertent natural occurrences such as tornadoes, heavy storms, or floods. The evaporation pond, for example, has a designated freeboard of 4 feet and a pond embankment slope of 3:1 as presented in Table 4.6.2-1 and Figures 4.6.2-7 and 4.6.2-8.

Provisions for leakage detection are also included in pond design for all the aforementioned possibly hazardous liquid waste storage repositories if the integrity of the lining system should be circumvented for any reason. Typical leakage detection details for the ponds, shown in Figure 4.6.2-6, would afford the plant








NOTES:

1. ALL FLOW RATES IN GALLONS PER MINUTE.
2. NUMBERS WITHOUT PARENTHESIS ARE NUMBERS INSIDE PARENTHESIS DIFFERENT FROM SUMMER TIME OF 1000 GPM.
3. REVERSE OSMOSIS INCLUDES WASH.
4. HIGH IS FOR HIGH TDS WASTE.
5. B.W. IS FOR BACKWASH.
6. B.D. IS FOR BACKDRAWD.
7. DURING WINTER, 180 GPM OF WATER HOLDING POOL ON THE



Flow Rates in gallons per minute.

WITHOUT PARENTHESES ARE FOR SUMMERTIME CASE;
INSIDE PARENTHESES ARE FOR WINTERTIME CASE IF
DIFFERENT FROM SUMMERTIME CASE.

OSMOISIS INCLUDES MICRON FILTRATION.

FOR HIGH TDS WASTE, LOW IS FOR LOW TDS WASTE.

FOR BACKWASH.


FOR BLOWDOWN.


WINTER, 160 GPM OF WATER IS STORED IN THE EXCESS
HOLDING POND FOR 10 DAYS FOR LATER USAGE.


REVISED CONSTRUCTION	
1	2
3	4
5	6
7	8
9	10
11	12
13	14
15	16
17	18
19	20
21	22
23	24
25	26
27	28
29	30
31	32
33	34
35	36
37	38
39	40
41	42
43	44
45	46
47	48
49	50
51	52
53	54
55	56
57	58
59	60
61	62
63	64
65	66
67	68
69	70
71	72
73	74
75	76
77	78
79	80
81	82
83	84
85	86
87	88
89	90
91	92
93	94
95	96
97	98
99	100
101	102
103	104
105	106
107	108
109	110
111	112
113	114
115	116
117	118
119	120
121	122
123	124
125	126
127	128
129	130
131	132
133	134
135	136
137	138
139	140
141	142
143	144
145	146
147	148
149	150
151	152
153	154
155	156
157	158
159	160
161	162
163	164
165	166
167	168
169	170
171	172
173	174
175	176
177	178
179	180
181	182
183	184
185	186
187	188
189	190
191	192
193	194
195	196
197	198
199	200
201	202
203	204
205	206
207	208
209	210
211	212
213	214
215	216
217	218
219	220
221	222
223	224
225	226
227	228
229	230
231	232
233	234
235	236
237	238
239	240
241	242
243	244
245	246
247	248
249	250
251	252
253	254
255	256
257	258
259	260
261	262
263	264
265	266
267	268
269	270
271	272
273	274
275	276
277	278
279	280
281	282
283	284
285	286
287	288
289	290
291	292
293	294
295	296
297	298
299	300
301	302
303	304
305	306
307	308
309	310
311	312
313	314
315	316
317	318
319	320
321	322
323	324
325	326
327	328
329	330
331	332
333	334
335	336
337	338
339	340
341	342
343	344
345	346
347	348
349	350
351	352
353	354
355	356
357	358
359	360
361	362
363	364
365	366
367	368
369	370
371	372
373	374
375	376
377	378
379	380
381	382
383	384
385	386
387	388
389	390
391	392
393	394
395	396
397	398
399	400

FLUOR

GENERAL CONTRACTOR
R. WHITE
K. BRAY
J. J. MURPHY
CASE STUDY
CROWNE TRUST COMPANY
NOVEMBER 1981










FIGURE 4.6.2-3

WAS USED FOR THE CIVIL COST ESTIMATE.
IN (DWO, #835704-00-A-081) WAS REVISED
DATE AND IS NOT REFLECTED IN THIS DRAWING.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

0 200 400 600 800 1000 FT.

FIGURE 4.6.2-3

TABLE 4.6.2-1
POND DETAILS OF CONSTRUCTION

Equipment Number	Description	Lining System Detail	DIMENSIONS (feet)			FBD	Side Slope	No. of Ponds	Leakage Detection?	
			X	Y	Z					
44-TK0101	Raw Water Pond	A	775	775	667	18	3:1	1	No	
44-TK0102	Raw Water Recovery	B	80	80	-	-	3:1.6 VERT.	1	No	
54-TK0116	Clean Stormwater	C	550	550	442	442	18	5:3:1	1	No
54-TK0117	Oily Stormwater	D	240	240	132	132	18	3:1	1	Yes
47-TK0104	P.C.T. Makeup Pond	A	660	660	552	552	18	3:1	1	No
54-TK0103	Wastewater Equilization Pond	D	120	120	30	80	15	2:3:1	1	Yes
54-TK0113	Treated Effluent Pond	D	380	380	272	272	18	3:1	1	Yes
54-TK0124	Evaporation Pond	D	1600	1300	1492	1192	18	4:3:1	1	Yes
54-TK0104A/B	Aeration Basin	E	240	240	-	-	12:2:1 VERT.	2	Yes	
54-TK0110	Waste Collection Sump	E	12	12	-	-	12:1:4 VERT.	1	Yes	
48-TK0102	U.C.T. Recovery Sump	B	24	24	-	-	12:1:9 VERT.	1	No	
54-TK0111	Diversion Pond	D	630	630	522	522	18	3:1	1	Yes
54-Tk0114	Diversion Box	B	30	30	-	-	12:1:4 VERT.	1	Yes	

Note: DWGS. 098A & 099B show the lining system details

DWG. 099 shows the typical leakage details

DWGS. 100A & 100B show the plan and section defining the dimensions.

NOTICE: THIS DRAWING HAS NOT BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR ENGINEERS AND CONSTRUCTORS, INC. AND EQUIVALENT TO THE
BORROWER FOR HIS CONFIDENTIAL USE ONLY; AND IN CONSIDERATION OF THE LOAN OF THIS DRAWING, THE BORROWER AGREES THAT IT SHALL NOT BE REPRODUCED, COPIED, LEANT OR OTHERWISE DISPOSED OF DIRECTLY OR INDIRECTLY,
NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS FURNISHED.




Figure 4.6.2-4

USE FOR DISCLOSURE OF REICR: DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT



FLUOR

D. Yamanot
M.D.
SURF.
A.Q.
SUP. ENG.
M. Duran

SCALE

NONE


DRAWING NUMBER

835704-00-1-098A


REV.

**POND DETAILS
LINING SYSTEM**

NOTICE: THIS DRAWING HAS NOT BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR ENGINEERS AND CONTRACTORS, INC. AND IS LENT TO THE BORROWER FOR HIS CONFIDENTIAL USE ONLY; AND IN CONSIDERATION OF THE LOAN OF THIS DRAWING, THE BORROWER PROMISES AND AGREES TO RETURN IT UPON REQUEST AND AGREES THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT OR OTHERWISE DISPOSED OF DIRECTLY OR INDIRECTLY, NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS FURNISHED.



DETAIL D




DETAIL E

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT


Figure 4.6.2-5

 FLUOR	DR <i>Clementino</i> CH <i>J.M.D.</i> SUPER <i>A.Q.</i> SUPER ENG. <i>M.John</i> SCALE <i>None</i>	POND DETAILS LINING SYSTEM DRAWING NUMBER 835704-00-1-098B REV. 1	
---	--	---	--


NOTICE: THIS DRAWING HAS NOT BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR ENGINEERS AND CONSTRUCTORS, INC. AND IS LENT TO THE BORROWER FOR HIS CONFIDENTIAL USE ONLY, AND IN CONSIDERATION OF THE LOAN OF THIS DRAWING, THE BORROWER PROMISES AND AGREES TO RETURN IT UPON REQUEST AND AGREES THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT OR OTHERWISE DISPOSED OF DIRECTLY OR INDIRECTLY NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS FURNISHED.



NOTICE: THIS DRAWING HAS NOT BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR ENGINEERS AND CONSTRUCTORS, INC. AND IS LENT TO THE BORROWER FOR HIS CONFIDENTIAL USE ONLY; AND IN CONSIDERATION OF THE LOAN OF THIS DRAWING, THE BORROWER AGREES TO RETURN IT UPON REQUEST AND AGREES THAT IT SHALL NOT BE REPRODUCED, COPIED, LEANT OR OTHERWISE DISPOSED OF DIRECTLY OR INDIRECTLY NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS FURNISHED.



PLAN



SECTION

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

Figure 4.6.2-7



FLUOR


J. Gammon
EN
M.D.
SUPER
A.Q
SUPER ENG.
m.D.
SCALE

POND DETAILS PLAN AND SECTION


DRAWING NUMBER
835704-00-1-100A

REV.
1

NOTICE: THIS DRAWING HAS NOT BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR ENGINEERS AND CONSTRUCTORS, INC. AND IS LEFT TO THE BORROWER FOR HIS CONFIDENTIAL USE ONLY, AND IN CONSIDERATION OF THE LOAN OF THIS DRAWING, THE BORROWER PROMISES AND AGREES THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT OR OTHERWISE DISPOSED OF DIRECTLY OR INDIRECTLY NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS FURNISHED.



PLAN



SECTION

USE OR DISCL'SHE OF REP R1 DATA
IS SUBJ. CT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

Figure 4.6.2-8



J. J. Jamison
CH
M.D.
SURN
A.G.
SURN CNG.
M.D.
SCALE
NONE

POND DETAILS PLAN AND SECTION

DRAWING NUMBER

835704-00-1-100B

REV.

1

operators a means of detecting any failures in the foregoing pond lining system and adequate time to employ corrective measures prior to the development of a potentially adverse environmental water quality impact.

It may be concluded that, under normal plant operating conditions and barring the occurrence of any catastrophic natural events (earthquakes, floods, tornadoes, etc.), the foregoing engineered containment design of liquid waste repositories for the Crow synfuels plant should prevent any major potentially adverse environmental impacts to the water quality of the Crow Reservation and the area adjacent to the reservation. However, it must be recognized that an ion material balance was not conducted for the major and trace liquid constituents comprising the liquid waste streams as part of this feasibility study. Hence, detailed identification and characterization of the process liquid waste stream constituents is not possible at this time. It is, therefore, recommended that if the Crow synfuels project proceeds to the next phase, the process liquid waste stream characterizations should be thoroughly evaluated in order to substantiate the long-term capability of the proposed multilayer liner system to contain the identifiable process liquid wastes.

A similar containment design approach to solid waste disposal has been developed for the proposed Crow synfuels plant. Since the quantities of solid wastes for a coal gasification plant are considerably more extensive than liquid wastes as previously demonstrated in Section 4.5.2 and the repositories are located external to the plant site boundaries, potentially more serious environmental water quality impacts than for liquid process waste residues could arise. Therefore, the next section of this report is devoted exclusively to an environmental impacts assessment of the solid wastes generated as a result of the operation of the Crow synfuels plant.

4.6.3 Solid Waste Disposal Impact Assessment

The Crow synfuels plant will produce a variety of solid wastes for disposal. The majority of the wastes consist of ash from the Lurgi coal gasification units, ash from the boilers, and sludge from the FGD unit. Other solid wastes from the plant include

water treatment sludges, spent catalysts, and general plant refuse. It is expected that general plant refuse will be at least qualitatively inspected prior to disposal at a local public waste disposal site to make certain that potentially hazardous process wastes are not inadvertently comingled. The quantification and environmental impact evaluation of the spent catalysts could not be adequately assessed due to a lack of essential proprietary information concerning their physical and chemical properties.


The proposed solid waste disposal plan was developed by Fluor as the base case for this study and, therefore, is specified for Site 1 assuming the Westmoreland coal feed. The ash and other solid wastes will be stored adjacent to the synfuels plant battery limits, as shown in Figure 4.6.3-1, since ash disposal at the existing Westmoreland Absaloka mine is not an economical option as discussed in greater detail in Volume V of this report. For the alternate Shell coal case at Site 23, the ash will be returned to the proposed Shell mine for disposal.

The ash mineral analysis, the trace element analyses, the FGD sludge composition, and the raw water treatment sludge composition are included in the block flow-diagrams for the solid effluents as presented in Figures 4.6.3-2, 4.6.3-3, and 4.6.3-4, respectively, for the previously discussed Case IA and Case IIA design scenarios utilizing a Westmoreland coal feed and the Case IIA design scenario employing a Shell coal feed. It must be emphasized that the block flow diagrams depict base case design scenarios for an initial 125 MM SCF/D SNG production rate recalling that the facility will have the capability of upgrading to the 250 MM SCF/D SNG production rate which represents "worst-case" design conditions in terms of potential environmental impacts. Therefore, design case scenarios I and II represent the proposed ultimate, upgraded plant design conditions.

4.6.3.1 Volume Requirements for Solid Waste Disposal

The volume requirements for solid waste disposal for Case I and Case II design scenarios utilizing a Westmoreland coal and the Case II design scenario employing a Shell coal feed are summarized in Table 4.6.3-1. The worst-case scenario, Case II,

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT



REDUCED PRINT SCALE

LEGEND

- BITE BOUNDARY
 ACCESS ROAD
 RAILROAD
 WATER LINE
 EXISTING RAILROAD
 PLANT BOUNDARY




FIGURE 4.6.3-1


SITE #1 VICINITY MAP

SYNFUELS FEASIBILITY STUDY

Y

ONTANA

FLUOR



1 COAL	2 ASH	3 FGD GYSUN	4 RAW WATER TREATMENT SLUDGE	5 WATER TREATING
TRACE ELEMENTS	MINERAL ASH ANALYSIS	WT%	WT%	WT%
ANTIMONY 0.67	SiO ₂	35.9	H ₂ O	53.5
ARSENIC 1.77	Al ₂ O ₃	19.2	CaSO ₄ ·2H ₂ O	53.0
SARTIN 161.8C	Fe ₂ O ₃	7.5	CaCl ₂	0.5
BERYLLIUM 1.25	Na ₂ O	3.0	INERT SOLIDS	1.3
BORON 216.50	K ₂ O	0.18	Ca(OH) ₂	TRACE
BROMINE 19.38	CaO	14.3	Ca(COOH) ₂	TRACE
CADMIUM 1.10	MnO	2.4		
CERIUM 17.64	TiO ₂	1.2		
CHROMIUM 6.38	P ₂ O ₅	0.28		
COBALT 3.62	SO ₃	14.1		
COPPER 21.42	INDETERMINATE	1.74		
FLUORINE 227.40				
LEAD 3.30				
LITHIUM 35.20				
MANGANESE 202.00				
MERCURY 0.04				
NICKEL 7.42				
SELENIUM 1.30				
SILVER 0.03				
STRONTIUM 497.02				
THALLIUM 0.23				
URANIUM 1.43				
VANADIUM 18.48				
ZINC 16.70				
ZIRCONIUM 128.00				

NOTES:

1. TRACE ELEMENT ANALYSIS FROM WESTMORELAND MINE ENVIRONMENTAL IMPACT STATEMENT.
2. MINERAL ASH ANALYSIS BASED ON LURGI DATA. WESTMORELAND MINE GASIFIER ASH ALSO CONTAINS 4% CARBON.
3. AMOUNT OF GASIFIER ASH CALCULATED BASED ON 450 T/HR GASIFIED COAL CONSUMED.
4. AMOUNT OF BOILER ASH CALCULATED BASED ON 98.6 T/HR BOILER COAL CONSUMED.
5. TOTAL GYPSUM PRODUCED BASED ON FGD LICENSOR INFORMATION.
6. THE CLEAN STORM WATER PONDS ARE CLEARED AS NECESSARY. THE AMOUNT OF SOLIDS REMOVED FROM THESE PONDS IS INDETERMINATE.
7. THE COMPOSITIONS OF THE INCINERATOR WASTE AND UCT BLOOMING TREATMENT SLURGE ARE NOT AVAILABLE.
8. THE FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.








FIGURE 4.6.3-2



1 COAL	2 ASH	3 FGD GYPSTUM	4 RAW WATER TREATMENT SLUDGE	5 WATER TREATING
TRACE ELEMENTS	PPM	MINERAL ASH ANALYSIS	WT%	WT%
ANTIMONY	0.67	SiO ₂	35.3	H ₂ O
ARSENIC	1.77	Al ₂ O ₃	19.2	CaSO ₄ ·2H ₂ O
BARIUM	181.60	Fe ₂ O ₃	7.8	CaCl ₂
BERYLLIUM	1.25	N ₂ O	3.0	INDRT SOLIDS
BORON	216.80	K ₂ O	0.18	Ca(OH) ₂
BROMINE	19.33	CaO	14.5	Ca(COOH) ₂
CADMIUM	1.80	MnO	2.4	
CERIUM	17.64	TiO ₂	1.2	
CHROMIUM	6.38	P ₂ O ₅	0.28	
COBALT	3.62	SO ₃	14.1	
COPPER	31.42	INDETERMINATE	1.74	
FLUORINE	227.40			
LEAD	5.30			
LITHIUM	35.20			
MANGANESE	202.00			
MERCURY	0.08			
MOLYBDENUM				

NOTES:

1. TRACE ELEMENT ANALYSIS FROM WESTMORELAND MINE ENVIRONMENTAL IMPACT STATEMENT.
 2. MINERAL ASH ANALYSIS BASED ON LURGI DATA: WESTMORELAND MINE GASIFIER ASH ALSO CONTAINS 45 CARBON.
 3. AMOUNT OF GASIFIER ASH CALCULATED BASED ON 450 T/HR GASIFIER COAL CONSUMED.
 4. AMOUNT OF BOILER ASH CALCULATED BASED ON 300 T/HR BOILER COAL CONSUMED.
 5. TOTAL GYPSUM PRODUCED BASED ON FCG LICENSING INFORMATION.
 6. THE CLEAN STORM WATER PONDS ARE CLEARED AS NECESSARY. THE AMOUNT OF SOLICS REMOVED FROM THESE PONDS IS INDETERMINATE.
 7. THE COMPOSITIONS OF THE INCINERATOR WASTE AND UCT BLLOWDOWN TREATMENT SOURCE ARE NOT AVAILABLE.
 8. THE FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.







FIGURE 4.6.3-3

PROJECT IDENTIFICATION	DATE MONTH YEAR	 FLUOR	OWNER R. WHITE C.C. ARATAY M.D. BERNITO R.M. MCGARRY H.L. LANG	GENERAL CONTRACTOR CASE 2A CASE: WESTMORELAND COAL - 40% FINES - SNG CROW TRIBE OF INDIANS SYNfuels FEASIBILITY STUDY	BLOCK FLOW DIAGRAM SOLID EFFLUENT NONE	PERIODIC 835704-00-4-106	001
NOTICE: THIS DRAWING HAS BEEN FURNISHED AND IS THE SOLE PROPERTY OF FLUOR CORPORATION AND ASSOCIATES, INC., AND IS RESTRICTED TO THE USE FOR WHICH IT WAS PROVIDED. NO COPIES SHALL BE MADE OR REPRODUCED BY THE RECIPIENT FOR HIS OWN USE, NOR SHALL IT BE USED OR REFERENCED IN THE DESIGN OF ANY OTHER PROJECT, WITHOUT THE WRITTEN CONSENT OF FLUOR CORPORATION AND ASSOCIATES, INC. IT IS HEREBY AGREED THAT THE RECIPIENT WILL NOT DISCLOSE THE INFORMATION CONTAINED HEREIN TO ANY PERSON, WHETHER ORGANIZED OR INDIVIDUAL, EXCEPT THOSE FOR WHOM IT IS FURNISHED.							



TRACE ELEMENTS	PPM	NOTE 12		NOTE 13		NOTE 14		NOTE 15	
		MINERAL ASH ANALYSIS	WTE	ASH	WTE	FCD GYPSUM	WTE	RAW WATER TREATMENT SLUDGE	WTE
ANTIMONY	0.69	SiO ₂	29.4	H ₂ O	23.0	CaCO ₃	35.5	SPENT ACTIVATED CARBON	41.9
ARSENIC	3.19	Al ₂ O ₃	16.1	CeO ₂ ·2H ₂ O	73.0	MnO ₂	0.3	SPENT ION EXCHANGE RESIN	36.1
BARIUM	89.09	Fe ₂ O ₃	6.2	CaCl ₂	0.3	H ₂ O	40.0		
BERYLLIUM	0.21	Na ₂ O	0.35	INERT SOLIDS	1.3	MISCELLANEOUS	3.6		
BORON	44.01	K ₂ O	0.36	Ca(OH) ₂	TRACE				
BROMINE	1.08	CaO	21.8	Ca(OOC) ₂	TRACE				
CADMIUM	0.38	MgO	7.3						
CERIUM	3.52	TiO ₂	1.6						
CHROMIUM	3.18	P ₂ O ₅	0.3						
COBALT	0.73	SO ₃	13.9						
COPPER	11.57	INDETERMINATE	2.62						
FLUORINE	95.29								
LEAD	1.87								
LITHIUM	8.89								
MANGANESE	20.46								
MERCURY	0.06								
NICKEL	2.19								
SELENIUM	0.52								
SILVER	0.14								
STRONTIUM	165.89								
THALLIUM	0.36								
URANIUM	1.43								
VANADIUM	11.63								
ZINC	9.76								
ZIRCONIUM	48.06								

NOTES:

- TRACE ELEMENT ANALYSIS FROM YOUNG'S CREEK AREA COAL.
- MINERAL ASH ANALYSIS BASED ON LURGI DATA; SMALL RESERVE.
- AMOUNT OF GASIFIER ASH CALCULATED BASED ON 440 T/HR GASIFIER COAL CONSUMED.
- AMOUNT OF BOILER ASH CALCULATED BASED ON 293 T/HR BOILER COAL CONSUMED.
- TOTAL GYPSUM PRODUCED BASED ON FCD LICENSOR INFORMATION.
- THE CLEAN STORM WATER PONDS ARE CLEANED AS NECESSARY. THE AMOUNT OF SOLIDS REMOVED FROM THESE PONDS IS INDETERMINATE.
- THE COMPOSITIONS OF THE INCINERATOR WASTE AND UGT BLOWDOWN TREATMENT SLUDGE ARE NOT AVAILABLE.
- THE FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.

A	1	2	3




FIGURE 4.6.3-4

REPORTING INFORMATION		FLUOR		CASE 2A		BLOCK FLOW DIAGRAM	
						SOLID EFFLUENT	
				CASE 1: SHELL COAL - 40% FINES - SNG		SYNFUELS FEASIBILITY STUDY	
R. WHITE	C.G. ABATAY	R. O'DELUITO	J. MCGARRY	NONE	835704-00-4-406	1	001557000406
G.C. ABATAY	R. O'DELUITO	J. MCGARRY	NONE				
R. LANGE	Z.Z. GARCIA						

TABLE 4.6.3-1
ANNUAL AND 25-YEAR SOLID WASTE DISPOSAL VOLUME REQUIREMENTS:
CROW SYNFUELS PLANT

Constituent	Westmoreland Coal			Shell Coal		
	Case I	Case IA	Case II	Case III	Case II	Case III
<u>Million cubic yards per year:</u>						
Boiler Ash	0.114	0.057	0.276	0.138	—	0.188
Gasifier Ash	0.543	0.271	0.542	0.271	—	0.294
FGD Sludge	0.053	0.027	0.159	0.080	—	0.041
Total	0.710	0.355	0.977	0.489	—	0.565
<u>Million cubic yards per 25-year plant life:</u>						
Boiler Ash	2.850	1.425	6.900	3.450	6.219	4.700
Gasifier Ash	13.575	6.775	13.550	6.775	12.205	7.350
FGD Sludge	1.325	0.675	3.975	2.000	3.584	2.075
Total	17.750	8.875	24.425	12.225	22.008	14.125
					7.562	12.718

Case I: 250 MM SCF/D SNG, power for internal needs only.
 Case IA: 125 MM SCF/D SNG, power for internal needs only.
 Case II: 250 MM SCF/D SNG, additional electrical power for sale.
 Case IIIA: 125 MM SCF/D SNG, additional electrical power for sale.
 Casen III: Five years at 125 MM SCF/D SNG and 20 years at 250 MM SCF/D SNG, additional electrical power produced for sale.

employing the Westmoreland coal that the proposed ultimate production rate of 250 MM SCF/D and producing additional electrical power above that required for internal plant consumption, is shown in Table 4.6.3-1 to produce 0.977 million cubic yards of major solid waste effluents on an annual basis or 24.4 million cubic yards of solid waste over a 25-year plant operating life. Similarly, the 125 MM SCF/D SNG Case II A design scenario counterpart of Case II, shown in Figure 4.6.3-4, produces approximately one-half of the volume of solid wastes, i.e., 0.489 million cubic yards per year or 12.2 million cubic yards in the 25-year plant operating lifetime. About 55.48 percent of the solid waste volume for the design Case II and II A scenario utilizing Westmoreland coal is the result of gasifier ash from the Lurgi process with ash and FGD sludges from the boiler operation representing about 28.25 percent and 16.27 percent, respectively, of the total solid waste volume both annually and cumulatively over 25 years as presented in Table 4.6.3-1. The design Case IA represents the lowest solid waste volume requirement for the designs using a Westmoreland coal feed. Solid waste volumes of 0.710 million cubic yards over 25 years are evidenced for design Case 1A in Table 4.6.3-1, with gasifier ash representing about 76.5 percent of the total solid waste volume. This result arises from the reduced requirement for the boilers, since the plant is designed to produce only enough power for internal facility needs.

A more realistic overall plan for long-term Crow synfuels plant operation is represented by the Case III scenarios as shown in Table 4.6.3-1. Case III scenarios assume cumulative 25-year solid waste volumes based upon a 5-year operation at the Case II A design level (125 MM SCF/D SNG) followed by a 20-year operation of the upgraded Case II plant design. Utilization of the excess coal fines to produce additional electrical power for sale to an electrical utility possibly represents a more economically viable mode of plant operation than other options evaluated in this feasibility study as discussed in Volume II in considerably more detail.

Table 4.6.3-1 indicates a 25-year solid waste volume commitment of approximately 22 million cubic yards for the foregoing Case III scenario utilizing Westmoreland coal supply. About 55.4 percent of the total solid waste resulting from Lurgi gasifier ash.

Design scenarios Case IIA and II employing the Shell coal feed result in considerably less solid waste disposal volume requirements due principally to lower ash content and also lower sulfur content of the Shell coal resulting in lower SO₂ emission control requirements (84 percent vs 90 percent) and, hence, less FGD sludge production for disposal.

Shell coal feed Cases IIA and II are shown in Table 4.6.3-1 to result in solid waste disposal volumes of 0.282 million cubic yards and 0.565 million cubic yards, respectively, on an annual basis; and 7.562 million cubic yards and 14.125 million cubic yards, respectively, over an assumed 25-year plant operating period for the previously cited Shell coal design Cases IIA and II.

4.6.3.2 Solid Waste Disposal Plan and Facility

The solid waste disposal plant design is based upon the cumulative 25-year solid waste disposal volume requirement of approximately 12 million cubic yards; i.e., the base Case IIA design (125 MM SCF/D SNG with additional electrical power production for external sales) with a Westmoreland coal supply. The solid waste disposal planned facility design as shown in Figure 4.6.3-1 promulgates a containment approach conceptually similar to the "zero discharge" design features employed to contain process liquid waste residues previously discussed in Section 4.6.2.

The site for disposal of the major process solids residues, specific to the Site 1 plant siting area, is shown in Figure 4.6.3-1 to be located approximately one-half mile northwest of the Site 1 boundary. Figures 4.6.3-1 and 4.6.3-5 demonstrate that the selected solids waste disposal site takes advantage of the natural topographic relief and the natural water drainage characteristics in the area, thereby reducing both the disturbed land surface area and excavation requirements for the facility.

The site development work is divided into two categories: (1) investment for the first 2 years, and (2) investment for the remaining 23 years. Table 4.6.3-2 lists the stepwise earthwork requirements for each investment.