

**Appendix 3A**  
**Summary Sheets for Phase III MCWM and DMC Testing**

## Summary Sheet Phase III MCWM Testing

### TEST/DESCRIPTION:

|                     | 4/28/98           | 4/29/98           | 5/21/98           | 5/28/98           |
|---------------------|-------------------|-------------------|-------------------|-------------------|
| Date                | 4/28/98           | 4/29/98           | 5/21/98           | 5/28/98           |
| Filtering device    | Fabric            | Fabric            | Ceramic           | Ceramic           |
| Coal seam           | Hiawatha          | Hiawatha          | Hiawatha          | Hiawatha          |
| Cleaning tech.      | Oil Agglomeration | Oil Agglomeration | Oil Agglomeration | Oil Agglomeration |
| Natural gas support | 31%               | 30%               | 30%               | 30%               |

### WATER/STEAM SIDE

|                                    |        |        |        |        |
|------------------------------------|--------|--------|--------|--------|
| Steam flow rate; lb/h              | 12,171 | 12,431 | 11,871 | 11,542 |
| Water temperature into boiler; ° F | 230    | 232    | 218    | 219    |
| Drum pressure; psig                | 227    | 226    | 228    | 228    |
| Calorimeter temperature; ° F       | 315    | 318    | 318    | 318    |
| Steam temperature; ° F             | 393    | 397    | 397    | 397    |
| Steam quality; %                   | 99.9   | 100.1  | 100.1  | 100.1  |
| Blowdown rate; lb/h                | 3,329  | 3,344  | 3,332  | 3,155  |

### Air, Fuel, Flue Gas Side

|  |            |            |            |            |
|--|------------|------------|------------|------------|
| Total firing rate; MM Btu/h              | 15.6       | 15.8       | 15.0       | 14.9       |
| Natural gas flow rate; lb/h; MM Btu/h    | 206; 4.8   | 194; 4.5   | 193; 4.    | 193; 4.5   |
| CWSF flow rate; lb/h; MM Btu/h           | 1,478;10.5 | 1,560;10.5 | 1,322;10.5 | 1,289;10.5 |
| Gas support (%)                          | 30.8       | 28.8       | 30.1       | 30.2       |
| Air temperature entering air heater; ° F | 163        | 165        | 175        | 179        |
| Air temperature leaving air heater; ° F  | 400        | 396        | 406        | 404        |
| Air temperature into boiler; ° F         | 385        | 385        | 397        | 395        |
| Furnace outlet temperature; ° F          | 596        | 591        | 594        | 596        |
| Gas temperature leaving air heater; ° F  | 385        | 383        | 384        | 387        |
| Bagfilter inlet temperature; ° F         | 389        | 385        | 381        | 386        |
| Bagfilter outlet temperature; ° F        | 344        | 338        | 354        | 367        |
| Ash content of fly ash;%                 | 48.99      | 41.66      | 54.62      | 55.5       |
| Combustion air flow; acfm                | 3,870      | 3,877      | 3,973      | 4,048      |
| Boiler draft; in. W.C.                   | -0.06      | -0.07      | -0.06      | -0.06      |
| Boiler efficiency; %                     | 76.71      | 76.74      | 79.57      | 79.39      |
| Atomizing air pressure; psig             | 135        | 135        | 135        | 135        |
| Atomizing air flow rate; lbs/h           | 756        | 657        | 756        | 720        |
| A/F ratio; lb/lb                         | 0.51       | 0.42       | 0.57       | 0.56       |
| CWSF temperature; ° F                    | 137        | 117        | 141        | 138        |
| Natural gas temperature; ° F             | 90         | 90         | 90         | 90         |
| Coal combustion efficiency; %            | 97.0       | 96.6       | 98.2       | 97.9       |
| Overall combustion efficiency; %         | 97.3       | 97.0       | 98.4       | 98.2       |

### EMISSIONS (Dry Basis)

|                       |      |      |      |      |
|-----------------------|------|------|------|------|
| O <sub>2</sub> ; %    | 3.8  | 3.5  | 3.5  | 3.8  |
| CO; ppm               | 15   | 44   | N/A  | N/A  |
| CO <sub>2</sub> ; %   | 13.0 | 12.8 | 14.0 | 13.9 |
| SO <sub>2</sub> ; ppm | 496  | 610  | N/A  | N/A  |
| NO <sub>x</sub> ppm   | 586  | 540  | 691  | 453  |

### FUEL ANALYSIS DATA

|                   |       |       |       |       |
|-------------------|-------|-------|-------|-------|
| Solids Content; % | 51.5% | 50.3% | 55.5% | 57.0% |
|-------------------|-------|-------|-------|-------|

## Summary Sheet Phase III MCWM Testing

### TEST/DESCRIPTION:

|                     | 6/1/98            | 6/3/98            | 6/9/98            | 6/16/98           |
|---------------------|-------------------|-------------------|-------------------|-------------------|
| Date                | 6/1/98            | 6/3/98            | 6/9/98            | 6/16/98           |
| Filtering device    | Fabric            | Fabric            | Fabric            | Fabric            |
| Coal seam           | Hiawatha          | Hiawatha          | Taggart           | Taggart           |
| Cleaning tech.      | Oil Agglomeration | Oil Agglomeration | Oil Agglomeration | Oil Agglomeration |
| Natural gas support | 30%               | 26%               | 30%               | 30%               |

### WATER/STEAM SIDE

|                                    |        |        |        |        |
|------------------------------------|--------|--------|--------|--------|
| Steam flow rate; lb/h              | 11,996 | 13,110 | 11,645 | 11,302 |
| Water temperature into boiler; ° F | 231    | 232    | 226    | 231    |
| Drum pressure; psig                | 232    | 234    | 231    | 229    |
| Calorimeter temperature; ° F       | 318    | 319    | 318    | 318    |
| Steam temperature; ° F             | 397    | 398    | 397    | 397    |
| Steam quality; %                   | 100.1  | 100.1  | 100.1  | 100.1  |
| Blowdown rate; lb/h                | 3,339  | 3,357  | 3,330  | 3,320  |

### Air, Fuel, Flue Gas Side

|  |             |             |             |             |
|--|-------------|-------------|-------------|-------------|
| Total firing rate; MM Btu/h              | 14.8        | 14.6        | 14.7        | 14.8        |
| Natural gas flow rate; lb/h; MM Btu/h    | 192; 4.5    | 168; 3.9    | 192; 4.5    | 194; 4.5    |
| CWSF flow rate; lb/h; MM Btu/h           | 1,332; 10.5 | 1,428; 11.0 | 1,178; 10.5 | 1,152; 10.5 |
| Gas support (%)                          | 30.4        | 26.7        | 30.7        | 30.5        |
| Air temperature entering air heater; ° F | 173         | 158         | 171         | 177         |
| Air temperature leaving air heater; ° F  | 413         | 410         | 415         | 415         |
| Air temperature into boiler; ° F         | 389         | 386         | 391         | 391         |
| Furnace outlet temperature; ° F          | 600         | 611         | 597         | 591         |
| Gas temperature leaving air heater; ° F  | 377         | 379         | 370         | 360         |
| Bagfilter inlet temperature; ° F         | 390         | 395         | 381         | 375         |
| Bagfilter outlet temperature; ° F        | 363         | 371         | 354         | 345         |
| Ash content of fly ash;%                 | 61.16       | 58.20       | 37.61       | 24.02       |
| Combustion air flow; acfm                | 4,259       | 4,438       | 3,732       | 3,835       |
| Boiler draft; in. W.C.                   | -0.05       | -0.04       | -0.05       | -0.05       |
| Boiler efficiency; %                     | 79.97       | 80.16       | 80.11       | 79.41       |
| Atomizing air pressure; psig             | 135         | 135         | 135         | 80          |
| Atomizing air flow rate; lbs/h           | 754         | 768         | 781         | 389         |
| A/F ratio; lb/lb                         | 0.57        | 0.54        | 0.66        | 0.34        |
| CWSF temperature; ° F                    | 141         | 147         | 141         | 155         |
| Natural gas temperature; ° F             | 89          | 82          | 86          | 93          |
| Coal combustion efficiency; %            | 98.7        | 98.4        | 97.7        | 95.1        |
| Overall combustion efficiency; %         | 98.9        | 98.6        | 98.0        | 95.8        |

### EMISSIONS (Dry Basis)

|                       |      |      |      |       |
|-----------------------|------|------|------|-------|
| O <sub>2</sub> ; %    | 3.7  | 3.2  | 3.7  | 3.4   |
| CO; ppm               | N/M  | N/M  | N/M  | 212.8 |
| CO <sub>2</sub> ; %   | 14.1 | 15.0 | 14.4 | 15.9  |
| SO <sub>2</sub> ; ppm | 669  | 828  | 599  | 368   |
| NO <sub>x</sub> ppm   | 242  | 224  | 188  | 488   |

### FUEL ANALYSIS DATA

|                   |       |       |       |       |
|-------------------|-------|-------|-------|-------|
| Solids Content; % | 55.5% | 56.4% | 59.5% | 59.9% |
|-------------------|-------|-------|-------|-------|

## Summary Sheet Phase III MCWM Testing

### TEST/DESCRIPTION:

|                     | 6/18/98           | 6/23/98           | 6/24/98           | 7/21/98          |
|---------------------|-------------------|-------------------|-------------------|------------------|
| Date                | 6/18/98           | 6/23/98           | 6/24/98           | 7/21/98          |
| Filtering device    | Fabric            | Ceramic           | Fabric            | Fabric           |
| Coal seam           | Taggart           | Hiawatha          | Hiawatha          | Taggart          |
| Cleaning tech.      | Oil Agglomeration | Oil Agglomeration | Oil Agglomeration | Froth Floatation |
| Natural gas support | 23%               | 30%               | 23%               | 30%              |

### WATER/STEAM SIDE

|                                    |        |        |       |        |
|------------------------------------|--------|--------|-------|--------|
| Steam flow rate; lb/h              | 11,143 | 11,476 | 9,446 | 10,073 |
| Water temperature into boiler; ° F | 231    | 231    | 231   | 229    |
| Drum pressure; psig                | 230    | 230    | 229   | 231    |
| Calorimeter temperature; ° F       | 318    | 318    | 316   | 318    |
| Steam temperature; ° F             | 397    | 397    | 397   | 398    |
| Steam quality; %                   | 100.1  | 100.1  | 100.0 | 100.1  |
| Blowdown rate; lb/h                | 3,322  | 3,327  | 3,320 | 3,332  |

### Air, Fuel, Flue Gas Side

|  |             |             |             |             |
|--|-------------|-------------|-------------|-------------|
| Total firing rate; MM Btu/h              | 15.0        | 14.7        | 14.0        | 14.5        |
| Natural gas flow rate; lb/h; MM Btu/h    | 150; 3.5    | 195; 4.5    | 145; 3.5    | 190; 4.5    |
| CWSF flow rate; lb/h; MM Btu/h           | 1,272; 11.5 | 1,353; 10.5 | 1,428; 11.6 | 1,200; 10.5 |
| Gas support (%)                          | 23.4        | 30.6        | 25.0        | 31.0        |
| Air temperature entering air heater; ° F | 179         | 180         | 184         | 186         |
| Air temperature leaving air heater; ° F  | 424         | 423         | 402         | 415         |
| Air temperature into boiler; ° F         | 398         | 399         | 379         | 391         |
| Furnace outlet temperature; ° F          | 597         | 600         | 559         | 582         |
| Gas temperature leaving air heater; ° F  | 372         | 378         | 359         | 370         |
| Bagfilter inlet temperature; ° F         | 381         | 388         | 368         | 442         |
| Bagfilter outlet temperature; ° F        | 353         | 366         | 344         | 347         |
| Ash content of fly ash;%                 | 29.00       | 52.27       | 48.30       | 20.84       |
| Combustion air flow; acfm                | 3,774       | 3,859       | 3,806       | 3,657       |
| Boiler draft; in. W.C.                   | -0.05       | -0.05       | -0.05       | -0.05       |
| Boiler efficiency; %                     | 79.13       | 77.86       | 76.95       | 76.75       |
| Atomizing air pressure; psig             | 135         | 135         | 135         | 135         |
| Atomizing air flow rate; lbs/h           | 761         | 728         | 573         | 628         |
| A/F ratio; lb/lb                         | 0.60        | 0.54        | 0.40        | 0.52        |
| CWSF temperature; ° F                    | 156         | 140         | 147         | 130         |
| Natural gas temperature; ° F             | 98          | 97          | 95          | 97          |
| Coal combustion efficiency; %            | 96.4        | 96.5        | 97.7        | 93.7        |
| Overall combustion efficiency; %         | 96.8        | 97.0        | 97.9        | 94.6        |

### EMISSIONS (Dry Basis)

|                       |      |       |      |      |
|-----------------------|------|-------|------|------|
| O <sub>2</sub> ; %    | 3.8  | 3.6   | 4.7  | 4.2  |
| CO; ppm               | N/M  | N/M   | N/M  | N/M  |
| CO <sub>2</sub> ; %   | 13.9 | 13.9  | 13.4 | 12.6 |
| SO <sub>2</sub> ; ppm | 204  | N/M   | N/M  | 250  |
| NO <sub>x</sub> ppm   | 584  | 610.2 | 525  | 227  |

### FUEL ANALYSIS DATA

|                   |       |       |       |       |
|-------------------|-------|-------|-------|-------|
| Solids Content; % | 60.3% | 54.3% | 56.0% | 59.1% |
|-------------------|-------|-------|-------|-------|

## Summary Sheet Phase III MCWM Testing

### TEST/DESCRIPTION:

|                     | 8/11/98          | 8/12/98          | 8/17/98          | 8/19/98          | 8/26/98           |
|---------------------|------------------|------------------|------------------|------------------|-------------------|
| Date                | 8/11/98          | 8/12/98          | 8/17/98          | 8/19/98          | 8/26/98           |
| Filtering device    | Fabric           | Fabric           | Fabric           | Fabric           | Fabric            |
| Coal seam           | Taggart          | Taggart          | Hiawatha         | Hiawatha         | Middle Kittanning |
| Cleaning tech.      | Froth Flootation | Froth Flootation | Froth Flootation | Froth Flootation | None              |
| Natural gas support | 30%              | 30%              | 30%              | 27%              | 30%               |

### WATER/STEAM SIDE

|                                    |        |        |        |       |        |
|------------------------------------|--------|--------|--------|-------|--------|
| Steam flow rate; lb/h              | 11,342 | 10,855 | 11,582 | 9,949 | 10,633 |
| Water temperature into boiler; ° F | 229    | 229    | 234    | 233   | 233    |
| Drum pressure; psig                | N/M    | 237    | 233    | 232   | 231    |
| Calorimeter temperature; ° F       | 319    | 317    | 319    | 317   | 318    |
| Steam temperature; ° F             | 398    | 398    | 398    | 397   | 397    |
| Steam quality; %                   | N/M    | 100.0  | 100.1  | 100.0 | 100.1  |
| Blowdown rate; lb/h                | 3,443  | 3,372  | 3,347  | 3,339 | 3,328  |

### Air, Fuel, Flue Gas Side

|  |             |             |             |             |             |
|--|-------------|-------------|-------------|-------------|-------------|
| Total firing rate; MM Btu/h              | 15.1        | 14.9        | 15.3        | 14.6        | 15          |
| Natural gas flow rate; lb/h; MM Btu/h    | 198; 4.6    | 192; 4.5    | 195; 4.5    | 174; 4.0    | 187; 4.5    |
| CWSF flow rate; lb/h; MM Btu/h           | 1,210; 10.5 | 1,182; 10.5 | 1,392; 10.5 | 1,440; 11.0 | 1,176; 10.5 |
| Gas support (%)                          | 29.8        | 30.2        | 29.4        | 27.3        | 30.0        |
| Air temperature entering air heater; ° F | 186         | 184         | 180         | 177         | 182         |
| Air temperature leaving air heater; ° F  | 421         | 412         | 419         | 410         | 419         |
| Air temperature into boiler; ° F         | 398         | 387         | 396         | 386         | 396         |
| Furnace outlet temperature; ° F          | 598         | 576         | 599         | 577         | 592         |
| Gas temperature leaving air heater; ° F  | 373         | 365         | 379         | 365         | 379         |
| Bagfilter inlet temperature; ° F         | 380         | 369         | 386         | 369         | 376         |
| Bagfilter outlet temperature; ° F        | 366         | 343         | 364         | 348         | 353         |
| Ash content of fly ash;%                 | 16.06       | 14.92       | 50.72       | 53.74       | 42.50       |
| Combustion air flow; acfm                | 3,775       | 3,610       | 3,979       | 3,943       | 3,885       |
| Boiler draft; in. W.C.                   | -0.05       | -0.05       | -0.05       | -0.06       | -0.05       |
| Boiler efficiency; %                     | 75.58       | 77.45       | 78.59       | 77.52       | 77.41       |
| Atomizing air pressure; psig             | 80          | 135         | 135         | 135         | 135         |
| Atomizing air flow rate; lbs/h           | 453         | 681         | 706         | 632         | 690         |
| A/F ratio; lb/lb                         | 0.38        | 0.58        | 0.51        | 0.44        | 0.59        |
| CWSF temperature; ° F                    | 158         | 152         | 141         | 110         | 152         |
| Natural gas temperature; ° F             | 98          | 94          | 96          | 89          | 99          |
| Coal combustion efficiency; %            | 90.9        | 92.5        | 97.5        | 97.4        | 93.6        |
| Overall combustion efficiency; %         | 92.1        | 93.6        | 97.8        | 97.7        | 94.5        |

### EMISSIONS (Dry Basis)

|                       |      |      |      |      |      |
|-----------------------|------|------|------|------|------|
| O <sub>2</sub> ; %    | 3.6  | 3.6  | 3.6  | 4.4  | 4.0  |
| CO; ppm               | N/M  | N/M  | N/M  | N/M  | N/M  |
| CO <sub>2</sub> ; %   | 14.1 | 14.2 | 13.9 | 12.6 | 13.2 |
| SO <sub>2</sub> ; ppm | 437  | 417  | 211  | 442  | 290  |
| NO <sub>x</sub> ppm   | 276  | 282  | 734  | 475  | N/M  |

### FUEL ANALYSIS DATA

|                   |       |       |       |       |       |
|-------------------|-------|-------|-------|-------|-------|
| Solids Content; % | 57.7% | 59.3% | 55.0% | 54.5% | 60.6% |
|-------------------|-------|-------|-------|-------|-------|

## Summary Sheet Phase III MCWM Testing

### TEST/DESCRIPTION:

|                     |                   |
|---------------------|-------------------|
| Date                | 9/9/98            |
| Filtering device    | Fabric            |
| Coal seam           | Taggart           |
| Cleaning tech.      | Oil Agglomeration |
| Natural gas support | 30%               |

### WATER/STEAM SIDE

|                                    |        |
|------------------------------------|--------|
| Steam flow rate; lb/h              | 10,474 |
| Water temperature into boiler; ° F | 234    |
| Drum pressure; psig                | 233    |
| Calorimeter temperature; ° F       | 317    |
| Steam temperature; ° F             | 397    |
| Steam quality; %                   | 100.0  |
| Blowdown rate; lb/h                | 3,348  |

### Air, Fuel, Flue Gas Side

|  |             |
|--|-------------|
| Total firing rate; MM Btu/h              | 14.8        |
| Natural gas flow rate; lb/h; MM Btu/h    | 186; 4.5    |
| CWSF flow rate; lb/h; MM Btu/h           | 1,170; 10.3 |
| Gas support (%)                          | 30.5        |
| Air temperature entering air heater; ° F | 168         |
| Air temperature leaving air heater; ° F  | 406         |
| Air temperature into boiler; ° F         | 383         |
| Furnace outlet temperature; ° F          | 570         |
| Gas temperature leaving air heater; ° F  | 359         |
| Bagfilter inlet temperature; ° F         | 354         |
| Bagfilter outlet temperature; ° F        | 339         |
| Ash content of fly ash;%                 | 16.40       |
| Combustion air flow; acfm                | 3,706       |
| Boiler draft; in. W.C.                   | -0.05       |
| Boiler efficiency; %                     | 77.99       |
| Atomizing air pressure; psig             | 80          |
| Atomizing air flow rate; lbs/h           | 370         |
| A/F ratio; lb/lb                         | 0.32        |
| CWSF temperature; ° F                    | 158         |
| Natural gas temperature; ° F             | 86          |
| Coal combustion efficiency; %            | 93.0        |
| Overall combustion efficiency; %         | 94.0        |

### EMISSIONS (Dry Basis)

|                       |     |
|-----------------------|-----|
| O <sub>2</sub> ; %    | 4.0 |
| CO; ppm               | N/M |
| CO <sub>2</sub> ; %   | N/M |
| SO <sub>2</sub> ; ppm | 150 |
| NO <sub>x</sub> ppm   | 490 |

### FUEL ANALYSIS DATA

|                   |       |
|-------------------|-------|
| Solids Content; % | 59.9% |
|-------------------|-------|

# Summary Sheet DMC Testing

| TEST/DESCRIPTION:  | 5/5/98 | 7/8/98 | 7/13/98 | 7/15/98 | 9/27/99                   | 9/28/99                   | 9/29/99                   | 9/30/99                   | 10/21/99 | 10/25/99                  | 10/26/99                  | 10/27/99                  |
|--|--------|--------|---------|---------|---------------------------|---------------------------|---------------------------|---------------------------|----------|---------------------------|---------------------------|---------------------------|
| Filtering Device:  |        |        |         |         | Sleeve 0.5<br>Center 1    | Sleeve 3.5<br>Center 0    | Sleeve 3.5<br>Center 0    | Sleeve 4.5<br>Center 0    |          | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Outer 7.5   | Sleeve 3.5<br>Center 0    |
| Burner Settings:   |        |        |         |         | Inner Max<br>Outer Max    | Inner 6.5<br>Outer        | Inner 6.5<br>Outer 7.5    | Inner Max<br>Outer Max    |          | Inner Max<br>Outer Max    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Inner 6.5    |
|  |        |        |         |         | Coal Gun +2<br>Gas Gun +2 | Coal Gun +2<br>Gas Gun +2 | Coal Gun +2<br>Gas Gun +2 | Coal Gun +2<br>Gas Gun +2 |          | Coal Gun +2<br>Gas Gun +2 | Coal Gun +2<br>Gas Gun +2 | Coal Gun +2<br>Gas Gun +2 |
|  |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |
| <b>WATER/STEAM SIDE</b>  |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |
| Steam flow rate; lb/h  | 11,700 | 11,505 | 11,066  | 11,360  | 10,867                    | 10,492                    | 11,107                    | 10,496                    | 10,809   | 10,875                    | 10,714                    | 10,067                    |
| Water temperature into boiler; °F  | 233    | 231    | 230     | 230     | 236                       | 236                       | 236                       | 236                       | 236      | 236                       | 236                       | 236                       |
| Drum pressure; psig  | 226    | 229    | 227     | 229     | 246                       | 244                       | 244                       | 245                       | 246      | 246                       | 244                       | 243                       |
| Calorimeter temperature; °F  | 318    | 318    | 317     | 318     | 319                       | 319                       | 319                       | 319                       | 319      | 319                       | 319                       | 320                       |
| Steam temperature; °F  | 397    | 398    | 398     | 398     | 402                       | 402                       | 402                       | 401                       | 402      | 402                       | 402                       | 401                       |
| Steam quality; %   | 100.1  | 100.1  | 100.0   | 100.1   | 100.3                     | 100.4                     | 100.3                     | 100.3                     | 100.3    | 100.3                     | 100.3                     | 100.4                     |
| Blowdown rate; lb/h  | 3,332  | 3,345  | 3,379   | 3,337   | 3,439                     | 3,425                     | 3,423                     | 3,429                     | 3,440    | 3,438                     | 3,429                     | 3,415                     |
| <b>AIR,FUEL, FLUE GAS SIDE</b>   |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |
| Coal flow rate; lb/h   | 1,080  | 1,080  | 1,080   | 1,080   | 1,050                     | 1,050                     | 1,044                     | 1,044                     | 1,080    | 1,050                     | 1,050                     | 1,050                     |
| Coal flow rate; MMBtu/h  | 14.9   | 15.5   | 15.4    | 15.5    | 15.0                      | 15.0                      | 14.9                      | 14.9                      | 15.5     | 15.1                      | 15.3                      | 14.9                      |
| Boiler outlet temperature; °F  | 614    | 605    | 604     | 612     | 612                       | 587                       | 602                       | 595                       | 586      | 602                       | 603                       | 604                       |
| Gas temperature leaving air heater; °F   | 384    | 382    | 380     | 386     | 369                       | 363                       | 367                       | 365                       | 360      | 364                       | 366                       | 358                       |
| Air temperature entering air heater; °F  | 173    | 182    | 179     | 186     | 166                       | 183                       | 178                       | 170                       | 171      | 166                       | 174                       | 171                       |
| Air temperature leaving air heater; °F   | 417    | 417    | 411     | 421     | 421                       | 428                       | 427                       | 420                       | 412      | 422                       | 430                       | 416                       |
| Air temperature into boiler; °F  | 403    | 405    | 397     | 409     | 400                       | 566                       | 545                       | 400                       | 390      | 400                       | 409                       | 395                       |
| Ash content of particulate; %  | 44.70  | 38.94  | 45.16   | 39.41   | 47.36                     | 47.66                     | 58.53                     | 47.84                     | 48.47    | 46.79                     | 45.23                     | 54.48                     |
| Coal combustion efficiency; %  | 94.6   | 92.4   | 95.6    | 94.1    | 95.2                      | 94.6                      | 96.6                      | 94.7                      | 96.0     | 95.7                      | 95.6                      | 95.5                      |
| Combustion air flow; acfm  | 3,208  | 3,227  | 3,234   | 3,120   | 3,082                     | 2,887                     | 3,126                     | 2,809                     | 3,029    | 2,956                     | 2,901                     | 3,022                     |
| Boiler draft; inches W.C.  | -0.06  | -0.06  | -0.09   | -0.09   | -0.08                     | -0.07                     | -0.07                     | -0.07                     | -0.07    | -0.06                     | -0.06                     | -0.06                     |
| Boiler efficiency; %   | 83.4   | 81.6   | 83.8    | 83.0    | 84.9                      | 85.0                      | 86.6                      | 84.6                      | 84.8     | 85.2                      | 84.9                      | 84.4                      |
| Mill air flow rate; acfm   | 401    | 405    | 396     | 400     | 397                       | 409                       | 403                       | 361                       | 402      | 403                       | 408                       | 382                       |
| Mill outlet temperature; °F  | 243    | 251    | 322     | 239     | 257                       | 239                       | 235                       | 220                       | 231      | 235                       | 235                       | 216                       |
| Filter type  | Fabric | Fabric | Ceramic | Ceramic | Fabric                    | Fabric                    | Fabric                    | Fabric                    | Ceramic  | Ceramic                   | Ceramic                   | Ceramic                   |
| Pressure drop; in W.C.   | 4.2    | 3.9    | 13.1    | 14.0    | 1.8                       | 1.5                       | 1.7                       | 1.6                       | 1.5      | 1.8                       | 2.1                       | 2.1                       |
| Filter inlet; °F   | 381    | 383    | 380     | 387     | 384                       | 377                       | 385                       | 384                       | 383      | 381                       | 389                       | 374                       |
| Filter outlet; °F  | 330    | 338    | 354     | 384     | 455                       | 461                       | 438                       | 460                       | 360      | 355                       | 387                       | 345                       |
| <b>EMISSIONS</b>   |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |
| O <sub>2</sub> %   | 3.4    | 3.9    | 4.0     | 3.4     | 4.0                       | 3.4                       | 3.9                       | 3.9                       | 3.2      | 3.3                       | 3.7                       | 4.5                       |
| CO ppm   | 40     | 79     | 26      | 69      | 169                       | 163                       | 228                       | 137                       | 214      | 348                       | 595                       | 384                       |
| CO <sub>2</sub> %  | 14.5   | 15.7   | 14.9    | 15.6    | 14.5                      | 15.0                      | 15.1                      | 14.3                      | 15.5     | 15.4                      | 15.3                      | 14.0                      |
| SO <sub>2</sub> ppm  | N/A    | 504    | 494     | 506     | 440                       | 362                       | 455                       | 357                       | 469      | 456                       | 475                       | 427                       |
| NO <sub>x</sub> ppm  | 413    | 355    | 375     | 397     | 192                       | 402                       | 411                       | 351                       | 399      | 336                       | 236                       | 306                       |
| <b>MISCELLANEOUS DATA</b>  |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |
| Maximum load<br>(based on 14,700 lb steam/h); %  | 79.6   | 78.3   | 75.3    | 77.3    | 73.9                      | 71.4                      | 75.6                      | 71.4                      | 73.5     | 74.0                      | 72.9                      | 68.5                      |
| <b>NOTES</b>   |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |
| Flue gas temperature leaving air heater and boiler efficiencies from 9/27/99 through 4/26/00 are incorrect. The expansion joint between the air heater and outlet ducting developed a leak and ambient air was drawn into the system. First noticeable leak was observed starting 9/27/99, second and more serious leak was observed starting 3/15/00, and expansion joint was replaced between the 4/27/00 and 5/15/00 testing. |        |        |         |         |                           |                           |                           |                           |          |                           |                           |                           |





## Summary Sheet DMC Testing

| TEST/DESCRIPTION:   | 4/6/00                    | 4/7/00                    | 4/11/00                   | 4/12/00                   | 4/18/00                   | 4/19/00                   | 4/20/00                   | 4/21/00                   | 4/24/00                   | 4/25/00                   | 4/26/00                   | 7/5/00                    |
|---|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Filtering Device:   | Sleeve 3.5<br>Center 1    | Sleeve 3.5<br>Center 1    | Sleeve 3.5<br>Center 1    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    |
| Burner Settings:  | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    | Inner Max<br>Outer Max    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    | Inner 6.5<br>Outer 7.5    |
|   | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -6 |
| <b>WATER/STEAM SIDE</b>   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Stream flow rate; lb/h  | 11,137                    | 11,397                    | 11,468                    | 11,540                    | 11,456                    | 11,863                    | 11,709                    | 11,698                    | 11,387                    | 11,383                    | 11,671                    | 10,477                    |
| Water temperature into boiler; °F   | 233                       | 233                       | 234                       | 234                       | 234                       | 233                       | 233                       | 233                       | 233                       | 233                       | 233                       | 231                       |
| Drum pressure; psig   | 231                       | 232                       | 226                       | 226                       | 222                       | 221                       | 219                       | 219                       | 225                       | 225                       | 222                       | 226                       |
| Calorimeter temperature; °F   | 318                       | 318                       | 317                       | 317                       | 317                       | 318                       | 319                       | 318                       | 318                       | 318                       | 319                       | 318                       |
| Steam temperature; °F   | 398                       | 396                       | 396                       | 396                       | 395                       | 394                       | 394                       | 394                       | 394                       | 396                       | 395                       | 396                       |
| Stream quality; %   | 100.3                     | 100.3                     | 100.2                     | 100.2                     | 100.2                     | 100.3                     | 100.3                     | 100.3                     | 100.3                     | 100.3                     | 100.3                     | 100.3                     |
| Blowdown rate; lb/h   | 3,329                     | 3,339                     | 3,294                     | 3,296                     | 3,264                     | 3,255                     | 3,241                     | 3,239                     | 3,283                     | 3,289                     | 3,267                     | 3,293                     |
| <b>AIR, FUEL, FLUE GAS SIDE</b>   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Coal flow rate; lb/h  | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,055                     | 1,080                     |
| Coal flow rate; MMbtu/h   | 14.3                      | 14.6                      | 14.7                      | 14.4                      | 14.5                      | 14.5                      | 14.5                      | 14.5                      | 14.4                      | 14.4                      | 14.4                      | 14.5                      |
| Boiler outlet temperature; °F   | 613                       | 619                       | 626                       | 625                       | 607                       | 618                       | 608                       | 635                       | 608                       | 626                       | 627                       | 602                       |
| Gas temperature leaving air heater; °F  | 320                       | 284                       | 266                       | 257                       | 263                       | 272                       | 274                       | 260                       | 277                       | 281                       | 287                       | 396                       |
| Air temperature entering air heater; °F   | 178                       | 166                       | 160                       | 157                       | 161                       | 167                       | 168                       | 161                       | 169                       | 175                       | 158                       | 191                       |
| Air temperature leaving air heater; °F  | 431                       | 430                       | 430                       | 429                       | 404                       | 415                       | 421                       | 423                       | 414                       | 426                       | 422                       | 424                       |
| Air temperature into boiler; °F   | 409                       | 408                       | 406                       | 407                       | 383                       | 395                       | 400                       | 404                       | 393                       | 406                       | 402                       | 404                       |
| Ash content of particulate; %   | 49.63                     | 50.71                     | 61.75                     | 68.90                     | 50.10                     | 61.02                     | 76.25                     | 78.38                     | 53.74                     | 56.27                     | 55.93                     | 61.89                     |
| Coal combustion efficiency; %   | 84.8                      | 94.8                      | 96.5                      | 97.6                      | 94.7                      | 96.6                      | 99.0                      | 98.6                      | 98.6                      | 95.5                      | 96.3                      | 96.5                      |
| Combustion air flow; acfm   | 3,051                     | 3,012                     | 3,149                     | 2,868                     | 3,147                     | 3,172                     | 3,253                     | 3,243                     | 3,267                     | 3,267                     | 3,306                     | 2,777                     |
| Boiler draft; inches W.C.   | -0.07                     | -0.07                     | -0.07                     | -0.06                     | -0.07                     | -0.06                     | -0.07                     | -0.06                     | -0.06                     | -0.07                     | -0.07                     | -0.07                     |
| Boiler efficiency; %  | 78.5                      | 87.0                      | 88.8                      | 90.1                      | 87.1                      | 88.3                      | 90.0                      | 90.1                      | 87.1                      | 87.1                      | 87.1                      | 83.7                      |
| Mill air flow rate; acfm  | 403                       | 405                       | 404                       | 401                       | 401                       | 401                       | 408                       | 404                       | 404                       | 404                       | 401                       | 317                       |
| Mill outlet temperature; °F   | 222                       | 224                       | 219                       | 221                       | 222                       | 228                       | 217                       | 223                       | 216                       | 220                       | 224                       | 224                       |
| Filter type   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Fabric                    | Fabric                    | Fabric                    | Fabric                    | Fabric                    | Fabric                    | Fabric                    | Ceramic                   |
| Pressure drop; in W.C.  | 6.2                       | 6.7                       | 7.2                       | 7.3                       | 2.8                       | 1.4                       | 1.4                       | 1.7                       | 1.2                       | 1.2                       | 1.2                       | 4.3                       |
| Filter inlet; °F  | 352                       | 343                       | 340                       | 335                       | 323                       | 328                       | 343                       | 335                       | 332                       | 339                       | 343                       | 296                       |
| Filter outlet; °F   | 354                       | 334                       | 327                       | 323                       | 287                       | 295                       | 308                       | 299                       | 299                       | 304                       | 306                       | 270                       |
| <b>EMISSIONS</b>  |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| O <sub>2</sub> %  | 3.7                       | 3.6                       | 3.8                       | 3.8                       | 4.0                       | 3.6                       | 3.8                       | 3.8                       | 4.0                       | 3.9                       | 3.7                       | 4.7                       |
| CO ppm  | 228                       | 236                       | 179                       | 100                       | 156                       | 179                       | 133                       | 116                       | 252                       | 306                       | 227                       | 849                       |
| CO <sub>2</sub> %   | 15.3                      | 15.4                      | 15.2                      | 15.3                      | 15.1                      | 15.6                      | 15.5                      | 15.3                      | 15.1                      | 15.2                      | 15.4                      | 12.4                      |
| SO <sub>2</sub> ppm   | 90                        | 88                        | 88                        | 253                       | 341                       | 426                       | 472                       | 526                       | 412                       | 442                       | 444                       | 30                        |
| NO <sub>x</sub> ppm   | 325                       | 339                       | 397                       | 419                       | 368                       | 425                       | 469                       | 469                       | 392                       | 436                       | 466                       | 374                       |
| <b>MISCELLANEOUS DATA</b>   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Maximum load<br>(based on 14,700 lb steam/h); %   | 75.8                      | 77.5                      | 78.0                      | 78.5                      | 77.9                      | 80.7                      | 79.7                      | 79.6                      | 77.5                      | 77.4                      | 79.4                      | 71.3                      |
| <b>NOTES</b>  |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Flue gas temperature leaving air heater and b. expansion joint between the air heater and on system. First noticeable leak was observed st 3/15/00, and expansion joint was replaced br |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |

# Summary Sheet DMC Testing

| TEST/DESCRIPTION:   | 7/6/00                    | 7/7/00                    | 7/10/00                   | 7/11/00                   | 7/13/00                   | 7/14/00                   | 7/17/00                   | 7/18/00                   | 7/19/00                   | 7/20/00                   | 7/21/00                   | 7/24/00                   |
|---|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Filtering Device:   | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    | Sleeve 3.5<br>Center 2    |
| Burner Settings:  | Inner 6.5<br>Outer 7.5    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    | Inner Max<br>Outer Max    |
|   | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -6 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 | Coal Gun -6<br>Gas Gun -2 |
|   | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     | Corning<br>Slipstream     |
| <b>WATER/STEAM SIDE</b>   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Steam flow rate; lb/h   | 11,278                    | 11,069                    | 11,360                    | 11,255                    | 7,849                     | 11,303                    | 11,613                    | 11,448                    | 11,179                    | 11,955                    | 11,605                    | 11,616                    |
| Water temperature into boiler; °F   | 231                       | 231                       | 231                       | 231                       | 222                       | 231                       | 231                       | 231                       | 231                       | 231                       | 231                       | 232                       |
| Drum pressure; psig   | 226                       | 226                       | 228                       | 225                       | 216                       | 218                       | 217                       | 217                       | 217                       | 214                       | 213                       | 214                       |
| Calorimeter temperature; °F   | 306                       | 318                       | 317                       | 318                       | 317                       | 317                       | 317                       | 317                       | 316                       | 318                       | 317                       | 317                       |
| Steam temperature; °F   | 396                       | 396                       | 397                       | 396                       | 393                       | 394                       | 394                       | 394                       | 393                       | 393                       | 393                       | 392                       |
| Steam quality; %  | 99.6                      | 100.3                     | 100.3                     | 100.3                     | 100.2                     | 100.2                     | 100.2                     | 100.2                     | 100.2                     | 100.2                     | 100.2                     | 100.2                     |
| Blowdown rate; lb/h   | 3,295                     | 3,285                     | 3,309                     | 3,289                     | 3,222                     | 3,235                     | 3,230                     | 3,228                     | 3,228                     | 3,205                     | 3,197                     | 3,202                     |
|   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| <b>AIR FUEL, FLUE GAS SIDE</b>  |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Coal flow rate; lb/h  | 1,080                     | 1,080                     | 1,080                     | 1,110                     | 1,110                     | 1,110                     | 1,110                     | 1,080                     | 1,101                     | 1,101                     | 1,101                     | 1,091                     |
| Coal flow rate; MMBtu/h   | 14.7                      | 14.6                      | 14.5                      | 15.0                      | 15.1                      | 15.0                      | 15.1                      | 14.6                      | 14.9                      | 15.1                      | 15.1                      | 14.4                      |
| Boiler outlet temperature; °F   | 617                       | 617                       | 625                       | 600                       | 548                       | 603                       | 614                       | 585                       | 589                       | 602                       | 613                       | 606                       |
| Gas temperature leaving air heater; °F  | 406                       | 406                       | 413                       | 396                       | 360                       | 392                       | 398                       | 383                       | 382                       | 391                       | 397                       | 392                       |
| Air temperature entering air heater; °F   | 186                       | 182                       | 188                       | 190                       | 202                       | 191                       | 191                       | 187                       | 182                       | 188                       | 188                       | 189                       |
| Air temperature leaving air heater; °F  | 429                       | 427                       | 432                       | 423                       | 412                       | 431                       | 438                       | 416                       | 419                       | 433                       | 438                       | 437                       |
| Air temperature into boiler; °F   | 407                       | 406                       | 411                       | 403                       | 388                       | 408                       | 414                       | 394                       | 396                       | 411                       | 416                       | 413                       |
| Ash content of particulate; %   | 62.03                     | 59.45                     | 52.39                     | 47.33                     | 39.28                     | 42.69                     | 42.52                     | 41.79                     | 34.88                     | 36.00                     | 38.98                     | 58.77                     |
| Coal combustion efficiency; %   | 96.6                      | 96.2                      | 94.6                      | 94.2                      | 91.7                      | 92.7                      | 92.2                      | 92.8                      | 89.4                      | 90.4                      | 92.0                      | 94.7                      |
| Combustion air flow; acfm   | 3,241                     | 3,160                     | 3,329                     | 3,186                     | 2,515                     | 3,060                     | 3,114                     | 3,133                     | 3,228                     | 3,111                     | 3,136                     | 2,983                     |
| Boiler draft; inches W.C.   | -0.06                     | -0.07                     | -0.07                     | -0.02                     | -0.08                     | -0.07                     | -0.07                     | -0.05                     | -0.05                     | -0.07                     | -0.07                     | -0.05                     |
| Boiler efficiency; %  | 85.1                      | 83.7                      | 80.2                      | 83.3                      | 79.4                      | 81.8                      | 81.6                      | 82.2                      | 79.7                      | 80.3                      | 81.4                      | 83.8                      |
| Mill air flow rate; acfm  | 400                       | 403                       | 402                       | 405                       | 294                       | 416                       | 418                       | 411                       | 414                       | 425                       | 422                       | 410                       |
| Mill outlet temperature; °F   | 242                       | 243                       | 257                       | 191                       | 125                       | 137                       | 140                       | 141                       | 141                       | 144                       | 143                       | 142                       |
| Filter type   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   | Ceramic                   |
| Pressure drop; in W.C.  | 6.5                       | 6.7                       | 6.6                       | 5.9                       | 3.9                       | 5.3                       | 5.4                       | 5.4                       | 5.4                       | 5.7                       | 6.3                       | 5.8                       |
| Filter inlet; °F  | 383                       | 386                       | 395                       | 377                       | 340                       | 372                       | 378                       | 363                       | 361                       | 375                       | 377                       | 372                       |
| Filter outlet; °F   | 353                       | 357                       | 363                       | 347                       | 321                       | 340                       | 345                       | 331                       | 329                       | 345                       | 347                       | 342                       |
| <b>EMISSIONS</b>  |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| O <sub>2</sub> %  | 3.9                       | 4.8                       | 8.5                       | 4.5                       | 8.9                       | 5.2                       | 4.2                       | 4.5                       | 4.5                       | 4.1                       | 4.5                       | 3.3                       |
| CO ppm  | 412                       | 811                       | 345                       | 275                       | 424                       | 424                       | 405                       | 273                       | 537                       | 405                       | 666                       | 463                       |
| CO <sub>2</sub> %   | 15.5                      | 13.9                      | 10.0                      | 14.8                      | 10.1                      | 14.1                      | 15.0                      | 14.4                      | 14.5                      | 15.0                      | 14.6                      | 15.7                      |
| SO <sub>2</sub> ppm   | 50                        | 94                        | 59                        | 105                       | 71                        | 98                        | 89                        | 88                        | 99                        | 88                        | 91                        | 97                        |
| NO <sub>x</sub> ppm   | 578                       | 330                       | 210                       | 417                       | 288                       | 409                       | 435                       | 419                       | 517                       | 499                       | 506                       | 620                       |
|   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| <b>MISCELLANEOUS DATA</b>   |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Maximum load<br>(based on 14,700 lb steam/h); %   | 76.7                      | 75.3                      | 77.3                      | 76.6                      | 53.4                      | 76.9                      | 79.0                      | 77.9                      | 76.0                      | 81.3                      | 78.9                      | 79.0                      |
| <b>NOTES</b>  |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |
| Flue gas temperature leaving air heater and boiler expansion joint between the air heater and boiler system. First noticeable leak was observed at 3/15/00, and expansion joint was replaced by |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |                           |



## Summary Sheet DMC Testing

| TEST/DESCRIPTION:   | 9/8/00   | 9/11/00  | 9/12/00  | 9/13/00  | 9/14/00  | 9/15/00  | 9/18/00  | 9/19/00  | 9/20/00  | 9/21/00  | 9/22/00  | 9/25/00  |  |
|---|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Filtering Device:   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   | Sleeve 3.5<br>Center 2   |  |
| Burner Settings:  | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner Max<br>Outer Max<br>Coal Gun -6<br>Gas Gun -2<br>Corning<br>Slipstream | Inner Max<br>Outer Max<br>Coal Gun -6<br>Gas Gun -2<br>Corning<br>Slipstream | Inner Max<br>Outer Max<br>Coal Gun -6<br>Gas Gun -2<br>Corning<br>Slipstream | Inner Max<br>Outer Max<br>Coal Gun -6<br>Gas Gun -2<br>Corning<br>Slipstream | Inner Max<br>Outer Max<br>Coal Gun -6<br>Gas Gun -2<br>Corning<br>Slipstream | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner 6.5<br>Outer 7.5<br>Coal Gun -6<br>Gas Gun -6<br>Corning<br>Slipstream | Inner Max<br>Outer Max<br>Coal Gun -6<br>Gas Gun -2<br>Corning<br>Slipstream |
| <b>WATER/STEAM SIDE</b>   |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Steam flow rate; lb/h   | 11,861   | 11,544   | 11,934   | 12,048   | 12,303   | 12,044   | 11,479   | 11,981   | 12,089   | 11,975   | 11,793   | 11,345   |  |
| Water temperature into boiler; °F   | 231  | 231  | 230  | 230  | 230  | 230  | 231  | 230  | 230  | 230  | 201  | 231  |  |
| Drum pressure; psig   | 213  | 211  | 209  | 211  | 219  | 214  | 213  | 212  | 211  | 212  | 201  | 211  |  |
| Calorimeter temperature; °F   | 318  | 318  | 318  | 318  | 318  | 318  | 318  | 318  | 317  | 318  | 314  | 317  |  |
| Steam temperature; °F   | 392  | 392  | 392  | 392  | 392  | 392  | 392  | 391  | 391  | 391  | 391  | 423  |  |
| Steam quality; %  | 100.3  | 100.3  | 100.3  | 100.3  | 100.3  | 100.3  | 100.3  | 100.2  | 100.3  | 100.2  | 100.0  | 100.2  |  |
| Blowdown rate; lb/h   | 1,246  | 3,184  | 3,168  | 3,184  | 3,197  | 3,206  | 3,199  | 3,191  | 3,181  | 3,190  | 3,082  | 3,186  |  |
| <b>AIR FUEL, FLUE GAS SIDE</b>  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Coal flow rate; lb/h  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  | 1,091  |  |
| Coal flow rate; MMBtu/h   | 14.1   | 14.3   | 14.5   | 14.5   | 14.6   | 14.6   | 14.4   | 14.5   | 14.4   | 14.5   | 14.4   | 14.5   |  |
| Boiler outlet temperature; °F   | 618  | 587  | 606  | 614  | 618  | 615  | 589  | 622  | 610  | 589  | 610  | 592  |  |
| Gas temperature leaving air heater; °F  | 409  | 388  | 406  | 408  | 410  | 404  | 386  | 401  | 406  | 407  | 389  | 385  |  |
| Air temperature entering air heater; °F   | 182  | 182  | 187  | 185  | 182  | 181  | 186  | 183  | 183  | 179  | 187  | 173  |  |
| Air temperature leaving air heater; °F  | 442  | 429  | 441  | 443  | 449  | 444  | 431  | 440  | 440  | 440  | 430  | 424  |  |
| Air temperature into boiler; °F   | 404  | 388  | 401  | 407  | 412  | 407  | 389  | 403  | 403  | 403  | 397  | 381  |  |
| Ash content of particulate; %   | 91.71  | 82.20  | 86.63  | 80.50  | 76.37  | 72.51  | 64.41  | 79.33  | 86.33  | 89.99  | 89.66  | 72.01  |  |
| Coal combustion efficiency; %   | 99.3   | 97.8   | 98.5   | 98.3   | 98.5   | 97.9   | 95.6   | 98.0   | 98.9   | 99.2   | 99.3   | 96.9   |  |
| Combustion air flow; acfm   | 3,189  | 3,032  | 3,150  | 3,183  | 3,232  | 3,239  | 3,047  | 3,125  | 3,217  | 3,219  | 2,840  | 3,071  |  |
| Boiler draft; inches W.C.   | -0.09  | -0.13  | -0.10  | -0.09  | -0.09  | -0.08  | -0.08  | -0.08  | -0.09  | -0.09  | -0.15  | -0.08  |  |
| Boiler efficiency; %  | 87.1   | 86.0   | 86.7   | 86.2   | 86.2   | 85.8   | 84.5   | 86.1   | 86.7   | 86.8   | 86.0   | 85.3   |  |
| Mill air flow rate; acfm  | 403  | 400  | 410  | 414  | 414  | 406  | 404  | 404  | 409  | 414  | 354  | 404  |  |
| Mill outlet temperature; °F   | 213  | 197  | 174  | 147  | 142  | 142  | 172  | 177  | 174  | 165  | 151  | 158  |  |
| Filter type   | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  | Ceramic  |  |
| Pressure drop; in W.C.  | 7.9  | 6.0  | 7.0  | 7.1  | 6.8  | 7.1  | 6.4  | 6.5  | 7.4  | 8.2  | 6.8  | 5.7  |  |
| Filter inlet; °F  | 391  | 368  | 386  | 388  | 390  | 383  | 369  | 385  | 390  | 388  | 388  | 367  |  |
| Filter outlet; °F   | 366  | 342  | 362  | 361  | 360  | 352  | 346  | 357  | 377  | 384  | 385  | 330  |  |
| <b>EMISSIONS</b>  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| O2 %  | 3.6  | 4.6  | 3.5  | 3.6  | 3.1  | 3.7  | 3.9  | 3.3  | 3.5  | 3.9  | 4.8  | 4.2  |  |
| CO ppm  | 9079   | 186  | 95   | 150  | 197  | 411  | 235  | 219  | 116  | 87   | 82   | 174  |  |
| CO2 %   | 15.5   | 14.6   | 15.6   | 15.7   | 16.1   | 15.5   | 15.3   | 15.9   | 15.7   | 15.6   | 13.3   | 15.0   |  |
| SO2 ppm   | 375  | 380  | 421  | 416  | 428  | 402  | 434  | 412  | 401  | 455  | 353  | 377  |  |
| NOx ppm   | 698  | 543  | 662  | 674  | 720  | 690  | 485  | 648  | 717  | 765  | 683  | 385  |  |
| <b>MISCELLANEOUS DATA</b>   |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Maximum load (based on 14,700 lb steam/h); %  | 80.7   | 78.5   | 81.2   | 82.0   | 83.7   | 81.9   | 78.1   | 81.5   | 82.3   | 81.5   | 80.2   | 77.2   |  |
| <b>NOTES</b>  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Flue gas temperature leaving air heater and boiler expansion joint between the air heater and boiler system. First noticeable leak was observed on 3/15/00, and expansion joint was replaced by |  |  |  |  |  |  |  |  |  |  |  |  |  |



## Summary Sheet DMC Testing

| TEST/DESCRIPTION:   | 5/1/01      | 5/3/01      | 5/9/01      | 5/15/01     | 5/17/01     | 5/22/01     | 5/24/01     | 5/31/01     | 6/5/01      | 6/12/01     | 4/26/02     | 4/29/02     |
|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Filtering Device:   | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  |
| Burner Settings:  | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    |
|   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   |
|   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   |
|   | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 |
|   | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  | Gas Gun -6  |
| <b>WATER/STEAM SIDE</b>   |             |             |             |             |             |             |             |             |             |             |             |             |
| Steam flow rate; lb/h   | 12,320      | 11,967      | 11,735      | 12,186      | 12,019      | 9,107       | 9,158       | 11,870      | 9,063       | 11,950      | 12,025      | 12,442      |
| Water temperature into boiler; °F   | 230         | 231         | 230         | 231         | 230         | 231         | 231         | 231         | 231         | 230         | 234         | 234         |
| Drum pressure; psig   | 210         | 210         | 211         | 210         | 210         | 214         | 214         | 215         | 212         | 211         | 234         | 229         |
| Calorimeter temperature; °F   | 316         | 317         | 316         | 316         | 316         | 316         | 316         | 317         | 316         | 317         | 319         | 320         |
| Steam temperature; °F   | 391         | 391         | 391         | 390         | 390         | 392         | 392         | 392         | 391         | 392         | 397.7       | 395.9       |
| Steam quality; %  | 100.1       | 100.1       | 100.1       | 100.1       | 100.1       | 100.0       | 100.0       | 100.1       | 100.0       | 100.1       | 100.0       | 100.0       |
| Blowdown rate; lb/h   | 3,176       | 3,177       | 3,180       | 3,176       | 3,178       | 3,208       | 3,208       | 3,211       | 3,190       | 3,183       | 3,351       | 3,317       |
| <b>AIR,FUEL, FLUE GAS SIDE</b>  |             |             |             |             |             |             |             |             |             |             |             |             |
| Coal flow rate; lb/h  | 1,091       | 1,091       | 1,091       | 1,091       | 1,091       | 830         | 829.8       | 1,091       | 830         | 1,091       | 1,158       | 1,158       |
| Coal flow rate; MMBtu/h   | 14.6        | 13.6        | 14.5        | 14.1        | 14.2        | 10.5        | 10.7        | 14.3        | 10.7        | 13.9        | 15.3        | 15.4        |
| Boiler outlet temperature; °F   | 599         | 592         | 587         | 598         | 598         | 591         | 575         | 602         | 569         | 615         | 598         | 596         |
| Gas temperature leaving air heater; °F  | 409         | 404         | 398         | 400         | 397         | 395         | 387         | 409         | 383         | 414         | 393         | 388         |
| Air temperature entering air heater; °F   | 442         | 433         | 429         | 435         | 428         | 442         | 439         | 428         | 421         | 448         | 168         | 148         |
| Air temperature leaving air heater; °F  | 401         | 395         | 387         | 393         | 388         | 396         | 394         | 389         | 390         | 409         | 381         | 374         |
| Ash content of particulate; %   | 75.78       | 77.61       | N.M.        | 77.20       | 79.96       | 80.82       | 80.71       | 83.38       | 80.90       | 76.03       | 74.30       | 65.00       |
| Coal combustion efficiency; %   | 96.9        | 96.1        | N.M.        | 97.1        | 97.6        | 97.3        | 97.8        | 98.2        | 97.5        | 96.6        | 97.2        | 96.1        |
| Combustion air flow; acfm   | 3,179       | 3,128       | 3,133       | 3,123       | 3,202       | 2,707       | 2,475       | 3,462       | 2,456       | 3,118       | 3,145       | 3,300       |
| Boiler draft; inches W.C.   | -0.08       | -0.09       | -0.1        | -0.09       | -0.09       | -0.09       | -0.09       | -0.11       | -0.09       | -0.09       | -0.09       | -0.09       |
| Boiler efficiency; %  | 84.9        | 84.2        | N.D.        | 85.3        | 85.6        | 85.0        | 85.9        | 85.8        | 85.8        | 83.5        | 85.3        | 84.2        |
| Mill air flow rate; acfm  | 406         | 404         | 402         | 403         | 391         | 393         | 355         | 406         | 403         | 402         | 404         | 403         |
| Mill outlet temperature; °F   | 171         | 163         | 159         | 161         | 163         | 165         | 170         | 179         | 172         | 175         | 184         | 185         |
| Filter type   | Ceramic     | Ceramic     | Ceramic     | Ceramic     | Fabric      | Fabric      | Fabric      | Fabric      | Fabric      | Ceramic     | Ceramic     | Ceramic     |
| Pressure drop; in W.C.  | 11.5        | 10.9        | 10.9        | 11.4        | 2.6         | 2           | 1.8         | 2.9         | 1.8         | 9.5         | 10.07       | 10.6        |
| Filter inlet; °F  | 390         | 387         | 380         | 382         | 380         | 378         | 370         | 394         | 366         | 397         | 370         | 364         |
| Filter outlet; °F   | 359         | 352         | 338         | 344         | 324         | 319         | 311         | 344         | 308         | 356         | 333.8       | 327         |
| <b>EMISSIONS</b>  |             |             |             |             |             |             |             |             |             |             |             |             |
| O2 %  | 3.8         | 3.8         | 3.6         | 3.4         | 3.9         | 4.8         | 3.3         | 5.0         | 3.7         | 6.5         | 3.3         | 3.5         |
| CO ppm  | 72          | 62          | 74          | 92          | 104         | 95          | 59          | 97          | 60          | 78          | 59          | 109         |
| CO2 %   | 15.4        | 15.5        | 15.5        | 15.6        | 15.2        | 14.7        | 15.8        | 14.4        | 15.4        | 12.4        | 14.7        | 14.4        |
| SO2 ppm   | 417         | 447         | 421         | 407         | 391         | 359         | 484         | 331         | 405         | 335         | N/A         | N/A         |
| NOx ppm   | 611         | 664         | N.M.        | 585         | 622         | 598         | 640         | 628         | 670         | 431         | N/A         | N/A         |
| <b>MISCELLANEOUS DATA</b>   |             |             |             |             |             |             |             |             |             |             |             |             |
| Maximum load (based on 14,700 lb steam/h); %  | 83.8        | 81.4        | 79.8        | 82.9        | 81.8        | 62.0        | 62.3        | 80.7        | 61.7        | 81.3        | 81.8        | 84.6        |
| <b>NOTES</b>  |             |             |             |             |             |             |             |             |             |             |             |             |
| Flue gas temperature leaving air heater and boiler expansion joint between the air heater and boiler system. First noticeable leak was observed on 3/15/00, and expansion joint was replaced by |             |             |             |             |             |             |             |             |             |             |             |             |

# Summary Sheet DMC Testing

| TEST/DESCRIPTION:   | 8/28/02     | 8/30/02     | 9/5/02      | 9/26/02     | 10/7/02     | 10/14/02    | 5/15/03     | 6/17/03     |
|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Filtering Device:   | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  | Sleeve 3.5  |
| Burner Settings:  | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    | Center 2    |
|   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   | Inner 6.5   |
|   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   | Outer 7.5   |
|   | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 |
|   | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 | Coal Gun -6 |
| <b>WATER/STEAM SIDE</b>   |             |             |             |             |             |             |             |             |
| Steam flow rate; lb/h   | 12,721      | 12,663      | 12,644      | 11,059      | 11,962      | 11,757      | 12,160      | 12,338      |
| Water temperature into boiler, °F   | 230         | 232         | 231         | 235         | 235         | 232         | 232         | 222         |
| Drum pressure; psig   | 225         | 223         | 221         | 223         | 231         | 229         | 228         | 223         |
| Calorimeter temperature; °F   | 317         | 319         | 314         | 318         | 319         | 318         | 319         | 319         |
| Steam temperature; °F   | 395.8       | 395         | 395         | 399         | 397         | 396         | 397         | 395         |
| Steam quality; %  | 100.0       | 100.0       | 100.0       | 100.0       | 100.0       | 100.0       | 100.0       | 100.0       |
| Blowdown rate; lb/h   | 3,279       | 3,271       | 3,262       | 3,388       | 3,334       | 3,317       | 3,309       | 3,274       |
| <b>AIR,FUEL, FLUE GAS SIDE</b>  |             |             |             |             |             |             |             |             |
| Coal flow rate; lb/h  | 1,164       | 1,164       | 1,164       | 1,164       | 1,152       | 1,152       | 1,152       | 1,152       |
| Coal flow rate; MMBtu/h   | 15.5        | 15.7        | 15.2        | 15.2        | 15.4        | 15.4        | 15.2        | 15.0        |
| Boiler outlet temperature; °F   | 606         | 620         | 608         | 620         | 613         | 616         | 630         | 618         |
| Gas temperature leaving air heater; °F  | 395         | 404         | 412         | 378         | 404         | 401         | 419         | 409         |
| Air temperature entering air heater; °F   | 177         | 166         | 182         | 157         | 169         | 150         | 177         | 168         |
| Air temperature leaving air heater; °F  | 418         | 436         | 439         | 407         | 426         | 426         | 447         | 432         |
| Air temperature into boiler; °F   | 376         | 396         | 402         | 366         | 391         | 388         | 406         | 391         |
| Ash content of particulate; %   | 64.01       | 62.70       | 73.30       | 60.21       | 68.20       | 65.40       | 69.50       | 70.90       |
| Coal combustion efficiency; %   | 95.2        | 95.7        | 96.8        | 94.3        | 95.9        | 94.7        | 96.6        | 96.5        |
| Combustion air flow; acfm   | 3,443       | 3,589       | 3,250       | 3,273       | 3,227       | 3,731       | 3,139       | 3,240       |
| Boiler draft; inches W.C.   | -0.09       | -0.09       | -0.09       | -0.09       | -0.09       | -0.09       | -0.07       | -0.09       |
| Boiler efficiency; %  | 83.0        | 83.0        | 84.8        | 83.2        | 83.9        | 82.9        | 83.4        | 84.0        |
| Mill air flow rate; acfm  | 399         | 400         | 406         | 397         | 404         | 402         | 401         | 406         |
| Mill outlet temperature; °F   | 188         | 180.2       | 182.8       | 164         | 174         | 163         | 172         | 189         |
| Filter type   | Ceramic     | Ceramic     | Ceramic     | Ceramic     | Ceramic     | Ceramic     | Ceramic     | Ceramic     |
| Pressure drop; in W.C.  | 10.3        | 9.4         | 9.8         | 9.8         | 9.8         | 9.7         | 10.8        | 11.2        |
| Filter inlet; °F  | 389         | 388         | 392         | 357         | 394         | N/A         | 396         | 393         |
| Filter outlet; °F   | 357         | 355         | 362         | 315         | 348         | 341         | 364         | 360         |
| <b>EMISSIONS</b>  |             |             |             |             |             |             |             |             |
| O2 %  | 4.3         | 4.7         | 3.3         | 4.0         | 3.5         | 3.7         | 3.3         | 3.5         |
| CO ppm  | 37          | 53          | 27          | 143         | 50          | 47          | 70          | 47          |
| CO2 %   | 14.1        | 13.4        | 15.2        | 14.4        | 14.5        | 14.7        | 14.7        | 14.4        |
| SO2 ppm   | 431         | 384         | 484         | 436         | 416         | 470         | 465         | 476         |
| NOx ppm   | 459         | 444         | 514         | 358         | 523         | 483         | 581         | 527         |
| <b>MISCELLANEOUS DATA</b>   |             |             |             |             |             |             |             |             |
| Maximum load (based on 14,700 lb steam/h); %  | 86.5        | 86.1        | 86.0        | 75.2        | 81.4        | 80.0        | 82.7        | 83.9        |
| <b>NOTES</b>  |             |             |             |             |             |             |             |             |
| Flue gas temperature leaving air heater and boiler expansion joint between the air heater and boiler system. First noticeable leak was observed on 3/15/00, and expansion joint was replaced by |             |             |             |             |             |             |             |             |

## **Appendix 3B**

### **Ceramic Filter Chamber Pressure Drop as a Function of Time Firing Coal**






Figure 3B-1 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 0 TO 50




Figure 3B-2 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 50 TO 100




Figure 3B-3 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 100 TO 150




Figure 3B-4 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 150 TO 200





Figure 3B-5 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 200 TO 250



**Figure 3B-6 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 250 TO 300**




Figure 3B-7 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 300 TO 350




Figure 3B-8 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 350 TO 400






Figure 3B-9 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 400 TO 450




Figure 3B-10 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 450 TO 500




Figure 3B-11 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 500 TO 550




Figure 3B-12 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 550 TO 600




Figure 3B-13 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 600 TO 650




Figure 3B-14 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 650 TO 700




Figure 3B-15 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 700 TO 750




Figure 3B-16 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 750 TO 800






Figure 3B-17 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 800 TO 850





Figure 3B-18 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 850 TO 900



**Figure 3B-19 CERAMIC FILTER PRESSURE DROP AS A FUNCTION OF TIME FIRING COAL FOR RUN HOURS 900 TO 950**

## Appendix 4A

### Market Penetration Model Source Code Listing

\$TITLE OPTIMAL ALLOCATION OF BOILER RETROFITS

\$OFFUPPER

\* This model determines the optimal allocation of retrofitted boilers  
 \* in the Indiana and Cambria county region among the installed base  
 \* of water tube boilers. The approach is to use a transportation model  
 \* that considers the costs to produce the boiler retrofit fuel, the costs  
 \* to transport MCWM to the retrofitted boilers, and the capital and  
 \* O&M costs of retrofitting. The transportation model framework minimizes  
 \* the costs to boiler owners given the location of each boiler, and its  
 \* individual characteristics, and the location of each possible source of  
 \* MCWM. The decision to retrofit is assumed to be made if the total costs  
 \* of retrofitting are less than the costs to continue firing oil or gas.

\*

\*

AUTHOR: A. Michael Schaal

\*

DATE: March 3, 1995

\*

Revised: April 17, 1995 - Updated MCWM and retrofit cost curve

\*

SETS

i fuel supply points / GAS, COAL1 \* COAL8 /  
 j boilers / BLR1 \* BLR18 /  
 k mine characteristics / ASH, SULFUR, OUTPUT /  
 l boiler locations / 15701, 15901, 16330, 15931 /

LABELS for boiler plant data

/ BSIZE boiler size in MMBtu per hour  
 UTIL average annual boiler utilization in %  
 PGAS boiler's price of gas  
 BLOC boiler location's zip code  
 TCR total capital requirement to retrofit boiler /

;

\*\*\*\*\* PARAMETER DECLARATION \*\*\*\*\*

SCALARS

|          |   |   |         |   |
|----------|---|---|---------|---|
| MFACT    | % additional mine output due to MCWM      | / | 100.0   | / |
| CMOIST   | coal moisture content in %                | / | 0.0     | / |
| PCOAL    | price of chunk coal f.o.b. mine           | / | 0.0     | / |
| CHHV     | coal higher heating value in Btu per lb   | / | 12810   | / |
| CWMHV    | MCWM higher heating value in Btu per lb   | / | 14000   | / |
| STHV     | heat content of steam in Btu per lb       | / | 1190    | / |
| ASHCST   | coal ash disposal cost in \$ per ton      | / | 5.60    | / |
| FXUNLD   | fixed cost to unload MCWM in \$ per MMBtu | / | 0.168   | / |
| VARUNLD  | transport cost in \$ per MMBtu per mile   | / | 0.00373 | / |
| ASHPER   | dry basis weight percent ash in MCWM      | / | 5.00    | / |
| PIFACT   | annual P+I on \$1000 at 4% and 20 years   | / | 73.582  | / |
| FXOMFACT | fixed O&M maint. cost as a % of capital   | / | 2.0     | / |

;

PARAMETERS

ASHCST ash disposal cost in \$ per MMBtu of coal burned

```

MINE(i)          annual mine coal output in tons
FS(i)           annual fuel available from each site in MMBtu
DIST(i,l)       distance from ith fuel source to lth town in miles
BDIST(i,j)      distance from ith fuel source to jth boiler in miles
BOILER(j,LABELS) boiler plant data
BQ(j)           annual boiler demand for fuel in MMBtu
ATCR(j)         annualized TCR to retrofit jth boiler
FUELFC(i,j)     non-transport costs less production costs in $ per MMBtu
PCOALM          price of chunk coal in $ per MMBtu
TCOST(i,j)      MCWM transport cost in $ per MMBtu
;

```

```

***** PARAMETER ASSIGNMENT *****

```

```

PARAMETER MINE(i)

```

```

*          tpy
  / COAL1 1686875
    COAL2  878230
    COAL3  870403
    COAL4  258030
    COAL5  188760
    COAL6  865017
    COAL7  485980
    COAL8  282732 /

```

```

TABLE DIST(i,l)

```

|       | 15701 | 15901 | 16330 | 15931 |
|-------|-------|-------|-------|-------|
| GAS   | 0     | 0     | 0     | 0     |
| COAL1 | 30    | 23    | 9     | 3     |
| COAL2 | 22    | 35    | 32    | 20    |
| COAL3 | 20    | 40    | 33    | 25    |
| COAL4 | 40    | 44    | 32    | 22    |
| COAL5 | 45    | 15    | 35    | 29    |
| COAL6 | 30    | 42    | 57    | 51    |
| COAL7 | 14    | 44    | 43    | 36    |
| COAL8 | 23    | 19    | 33    | 26    |

```

TABLE BOILER(j,LABELS)

```

```

*          BSIZE      UTIL      PGAS      BLOC      TCR
          MMBtu/hr    %         $/MMBtu   zip       $M
BLR1      68.0        60         3.62     15701     5.01
BLR2      50.4        53         3.62     15901     4.22
BLR3      50.4        53         3.62     15901     4.22
BLR4      50.4        53         3.62     15901     4.22
BLR5      50.4        53         3.62     15901     4.22
BLR6      68.0        60         3.62     15701     5.01
BLR7      19.4        50         3.62     15901     2.43
BLR8      19.4        50         3.62     15901     2.43
BLR9      11.6         5          4.50     15901     1.81
BLR10     11.6         5          4.50     15901     1.81
BLR11     27.7        30         3.62     16330     2.99
BLR12     27.7        30         3.62     16330     2.99
BLR13     27.7        30         3.62     16330     2.99
BLR14     11.6        30         3.62     15901     1.81
BLR15     11.6        30         3.62     15901     1.81
BLR16     11.6        30         3.62     15901     1.81
BLR17     53.2         1          3.62     15901     4.35
BLR18     94.5         5          3.62     15931     6.06
;

```

```

BDIST(i,j) $ (BOILER(j,"BLOC") EQ 15701) = DIST(i,"15701") ;
BDIST(i,j) $ (BOILER(j,"BLOC") EQ 15901) = DIST(i,"15901") ;

```

```

BDIST(i,j) $ (BOILER(j,"BLOC") EQ 16330) = DIST(i,"16330") ;
BDIST(i,j) $ (BOILER(j,"BLOC") EQ 15931) = DIST(i,"15931") ;
ASHBCST    = (10000 * ASHPER * ASHCST) / (2000 * CWMHV) ;
FS(i)      = (2000 * (MFACT/100) * MINE(i) * CHHV * (1-CMOIST/100)) / 1e6 ;
FS('GAS')  = 1e9 ;
BQ(j)      = BOILER(j,"BSIZE") * (BOILER(j,"UTIL")/100) * 24*365.25 ;
ATCR(j)    = PIFACT * BOILER(j,"TCR") * 1000 ;
FUELC(i,j) = ASHBCST + FXUNLD +
              ( ATCR(j) + (1e6*BOILER(j,"TCR")*FXOMFACT/100) )/BQ(j) ;
FUELC('GAS',j) = BOILER(j,'PGAS') ;
PCOALM     = 1e6*(PCOAL/(2000*CHHV)) ;
TCOST(i,j) = VARUNLD * BDIST(i,j) ;

OPTION BQ:0:0:1 ;
OPTION FS:0:0:1 ;
OPTION ATCR:4:0:1 ;
DISPLAY PCOALM, FS, BOILER, BDIST, TCOST, BQ, ASHBCST, ATCR, FUELC ;

```

```

##### VARIABLE DECLARATION #####

```

VARIABLES

```

PMCWM(i)          MCWM production cost at supply point i
QFUEL(i)          fuel demanded of zero marginal cost coal
FUELCOST(i,j)    fuel costs less transport costs
X(i,j)           annual flow of fuel from supply point i to boiler j
Z                total annual boiler costs
;

```

```

POSITIVE VARIABLES X, QFUEL, FUELCOST, PMCWM
;

```

```

##### VARIABLE INITIALIZATION #####

```

```

PMCWM.L('GAS')   = 0.0 ;
X.L(i,j)         = 0.0 ;
X.L('COAL8',j)  = BQ(j) ;
X.L('GAS',j)    = BQ(j) ;

```

```

##### EQUATION DECLARATION #####

```

EQUATIONS

```

COST              define objective function
FUELSPLY(i)      determine fuel demand for each supplier
SUPPLY(i)        observe supply limits
DEMAND(j)        satisfy boiler fuel demands
SPLYCST(i)       total fuel preparation cost at each mine
FUEL(i,j)        fuel cost less transportation
FUELG(i,j)       gas price
COALFX           coal mine fixed constraint
;

```

```

##### EQUATION DEFINITION #####
COST ..          Z =E= SUM((i,j), FUELCOST(i,j)*X(i,j) + TCOST(i,j)*X(i,j) ) ;

FUELSPLY(i) ..   QFUEL(i) =E= SUM(j, X(i,j)) ;
SUPPLY(i) ..     QFUEL(i) =L= FS(i) ;
DEMAND(j) ..     SUM(i, X(i,j)) =E= BQ(j) ;
SPLYCST(i)$MINE(i) .. PMCWM(i)*( (QFUEL(i)+1)**(0.969) ) -
                  0.6727*( (QFUEL(i)+1)**(0.969) ) =E= 211561 ;
FUEL(i,j)$MINE(i) .. FUELCOST(i,j) =E= PMCWM(i) + FUELFC(i,j) ;
FUELG('GAS',j) .. FUELCOST('GAS',j) =E= FUELFC('GAS',j) ;
COALFX ..        SUM( i, QFUEL(i)$MINE(i) ) - QFUEL('COAL8') =E= 0

MODEL RETROFIT /ALL/ ;

OPTION NLP = MINOS5 ;
OPTION ITERLIM = 4000 ;

SOLVE RETROFIT USING NLP MINIMIZING Z ;
SOLVE RETROFIT USING NLP MINIMIZING Z ;

DISPLAY X.L, PMCWM.L, QFUEL

```

## Appendix 4B

### MCWM Supply Cost Model

#### Introduction

This appendix describes basic economics for the supply of coal-based fuels for an industrial boiler that has been converted from firing fuel oil to firing a premium coal fuel. The boiler conversion technologies were studied by Penn State for DOE and DOD. The focus of Phase I activities were the development, design, and evaluation of two candidate technologies for boiler conversion. The boiler that was considered for conversion was a 25.2 MM Btu/h unit located at the Naval Surface Warfare Center at Crane, Indiana. The conversion technologies considered were to fire either, a micronized coal water mixture (MCWM) or a dry, micronized coal (DMC).

#### MCWM and DMC Conversion Technology Overview

The MCWM and DMC technologies utilize the particular form of the feed coal to minimize solids handling problems and minimize boiler derating. Both technologies require premium quality coal fuels, one difference between the two being the physical form of the fuel as delivered to the boiler. DMC is delivered to the boiler as a chunk coal (nominal 2" x 0) and reduced to the necessary micron size at the boiler site. MCWM, on the other hand, is transported, stored, handled, and fired in the boiler in slurry form. Both technologies use coal with the same basic qualities as listed in Table 4B-1.

The first three coal characteristics were determined by Penn State as minimums acceptable for either technology. The coal higher heating value (HHV) is an estimate for a coal of this quality. The estimated HHV is probably on the conservative side considering other DOE researchers use a value closer to 15,000 Btu/lb coal.

Table 4B-1 MCWM and DMC Coal Quality Specifications

|                      |                      |                        |
|----------------------|----------------------|------------------------|
| Ash Content          | ≤ 5                  | wt.% (dry basis, d.b.) |
| Sulfur Content       | ≤ 1                  | wt. % (d.b.)           |
| Volatile Matter      | > 30                 | wt. % (d.b.)           |
| Higher Heating Value | ≈ 14,000 Btu/lb coal | (d.b.)                 |

Sufficient reserves of acceptable coal sources have been identified by Penn State to exist in the immediate area of Crane (within a radius of 40 miles, or closer) for either technology.

#### Crane Boiler Characteristics

The Crane boiler that was evaluated for retrofit to fire coal is one of three, roughly equivalent, boilers located within the same boiler house. These boilers are presently used



for building heat, with occasional demands for process steam. The Phase I case study considered only six month operation of the retrofitted boiler corresponding to the heating season. The basic boiler retrofit requirements are listed in Table 4B-2.

Table 4B-2 Crane Boiler Specifications

|                              |       |                                 |
|------------------------------|-------|---------------------------------|
| Boiler Rated Capacity        | 25.2  | MM Btu/h                        |
| Annual Hours of Operation    | 4,383 | Hours                           |
| Boiler Load During Operation | 100   | %                               |
| Coal Requirement (Operating) | 0.9   | tons per hour (tph) coal (d.b.) |
| Annual Coal Requirement      | 3,945 | tons per year (tpy) coal (d.b.) |

The annual operating hours assumes that the retrofitted boiler is used during a typical six-month heating season at full rated capacity. Additional steam requirements for DOD users are met by adding boilers to the system. This arrangement of smaller, modular, boilers follows a normal DOD facilities planning philosophy that emphasizes maximization of system reliability under adverse conditions and standardized designs. Industrial- and commercial-scale boilers tend to be larger in order to minimize per unit cost of steam.

### MCWM Supply

The MCWM fuel form, as a slurry, has some potential advantages as compared to the DMC fuel. First, since the fuel is handled as a slurry it can be easily pumped into the system, stored, and sent to the burner for atomization into the boiler. Also, the slurried fines pose little problem in the generation of airborne dust (as long as splashing and spillage is avoided). Supply of the slurry may, potentially, come from a variety of relatively low cost sources as compared to other coal-forms. Since the slurry is delivered to the boiler at the proper size, the relatively capital and O&M cost intensive grinding mills for each boiler that is converted to fire the coal fuel are not necessary. Finally, cost advantages could be derived from the installation of a single slurry preparation system to supply several converted boilers.

One disadvantage of MCWM is that boiler derating tends to be more severe with slurry fuels, *ceteris paribus*, due to; 1) fuel atomization forming droplets consisting of several coal particles requiring longer residence times for burnout, 2) ash deposition and erosion on boiler tubes, and 3) heat losses (latent and sensible) associated with the higher moisture content of the fuel. Storage of the slurry can also be problematic due to a tendency of the solids in the slurry to settle and form a 'hard' or 'soft' pack. This settlement problem requires the development of specialized slurry preparation techniques and chemical additive packages. Minimizing boiler derating and improving the handleability and storage of the slurry were goals of the technology development effort by Penn State.

A basic difference governing the economics of fuel supply between MCWM and DMC technologies is that the form of the fuel delivered to the boiler is not readily

available from an existing market source. Coal is not generally produced for delivery to customers in slurry form. In fact, state-of-the-art production of a MCWM with the requisite handleability, storage, and atomizing qualities is limited in terms of total quantity produced annually and in the number of potential suppliers. In addition, there can be substantial variation in the quality of slurry produced by the different suppliers. For that reason, the MCWM retrofit option must consider the costs of production and delivery of slurry to the Crane boiler.

### **MCWM Factored Cost Estimate**

A factored cost estimate for the production and transportation of MCWM to the Crane boiler was developed to aid in comparing this fuel to DMC. At the present time, no specific coal source has been identified. The production and transportation analysis presented here is loosely based on using AMAX Coal Company's Minnehaha operation (located about 40 miles from the Crane boiler) to site the MCWM preparation plant.

Creation of a market for MCWM potentially addresses a problem faced by nearly every coal preparation plant operation, namely the disposition of coal fines. Coal fines are difficult to clean and dry to a level of acceptable moisture content. Even when recovered and dried to acceptable levels, conventional handling methods tend to cause fines to become easily airborne, representing both a loss of product and the creation of a potential health hazard. Both the above problems can be addressed by producing and transporting the fines in a slurried fuel. Bearing this in mind, the feed to a MCWM production process can come from a variety of sources including; 1) existing coal impoundment, 2) existing operational coal preparation plant, and 3) conventionally produced chunk coal.

Considerable uncertainty surrounds the recovery of coal from existing coal impoundments due to the difficulties of locating appropriate impoundments, the adequate characterization of the distribution of coal (and potential contaminants), and the higher expected costs associated with reclamation/dredging of the coal. An impoundment must be able to provide an inexpensive product possessing the rather stringent quality specifications. Mixtures of the desired coal with other coals and contaminants in the impoundment complicates the beneficiation and slurry production process.

The surest method of providing the MCWM fuel is from coal obtained from the market in chunk form that already possesses the desired quality specifications. The size reduction and slurring required can then be carried out in a straight-forward manner. The disadvantages of this method are the expected higher cost of coal, as compared to the alternatives, and the extra equipment and effort required to reduce the +2" x 0 coal the size required for MCWM.

A third option exists for producing MCWMs from slurry refuse streams in an existing coal preparation plant. Here, the characteristics of individual refuse streams in the conventional preparation plant can be utilized with little variation expected in the stream compositions over time (when cleaning the same coal). Since coal is recovered from process streams that would normally be discarded, the marginal cost of feed coal and refuse disposal for the slurry production plant would be zero. In fact, an economic benefit can be derived for reducing quantities of solids requiring disposal.

To date a particular site has not been selected, hence characterizing a preparation plant sufficiently to carry out a detailed design of the slurry preparation plant is not

possible. The MCWM production plant speculated here, however, makes use of this last scenario by providing what may be considered typical slurry preparation plant equipment. A MCWM production plant for the Crane boiler may be sized as described in Table 4B-3.

Table 4B-3 MCWM Production Plant Characteristics

|                                     |        |                  |
|-------------------------------------|--------|------------------|
| MCWM Plant Production Rate          | 2      | tph (d.b.)       |
| Slurry Plant Annual Operating Hours | 1,972  |                  |
| Annual Production (Crane)           | 3,945  | tons coal (d.b.) |
| Annual Maximum Rated Capacity       | 14,026 | tons slurry      |

As can be seen from Table 4B-3, the slurry plant is oversized relative to the boiler requirement. The MCWM sizing reflects, 1) difficulties associated with the problems in differentiating between processes of a capacity in the range of one to three tph, 2) a built-in margin for both the large uncertainty in the capital equipment requirement, and 3) a production rate sufficient to provide for preparation plant down time while the boiler operates 24 hours per day, seven days a week. The MCWM production plant maximum annual capacity assumes a plant availability of 80 percent and the existence of a market for all of the production.

A simple factored capital cost estimate is provided in \$90.6/ton coal (d.b.) or \$3.23/MM Btu. This cost includes all capital, operation and maintenance charges.

*Table 4B-4.* The equipment list provides allowances for a single mill, conventional flotation cells, spirals (or the equivalent in other cleaning equipment), pumps, and a 25,000 gallon slurry storage tank sized for a three day supply of Crane, with an additional 10% allowance for miscellaneous equipment items. The electrical load of the equipment was estimated at 94 horsepower. The estimated equipment costs and electrical loads were generated after reviewing several sources and applying standard cost estimation methodologies to account for inflation, at 4%, and scale. The slurry plant described here purposely avoids the use of advanced fine coal cleaning methods reflecting an emphasis upon locating refuse streams that require minimum efforts to recover coal fines of the required quality.

The total capital requirement is estimated to be \$993 thousand dollars. As can be seen from the equipment list, by far the largest capital requirement is represented by the mill. This item also represents the greatest proportion of the estimated horsepower due to the demanding grinding regime expected. The equipment list, and associated costs, is considered speculative due to the incomplete knowledge regarding potential feed stream characteristics.

The plant cost factor used for determining the installed plant cost was generated using the Chilton method. The selection of this method was due to ease of use and consideration of the fact that the MCWM plant is an addition to an existing coal preparation facility. That advantage, along with the simple to implement approach, is somewhat offset by the relatively small size of the plant and the speculative nature of

estimate. The factor derived and presented above of 3.39 is less than the simpler Lang factor of 3.63 for solid-fluid plants.

Annualized capital and operation & maintenance (O&M) costs are presented in the Table 4B-5. The MCWM cost, f.o.b. slurry preparation plant, is estimated to be \$90.6/ton coal (d.b.) or \$3.23/MM Btu. This cost includes all capital, operation and maintenance charges.

Table 4B-4 MCWM Factored Capital Costs (\$K '93)

|                              |                      |
|------------------------------|----------------------|
| Mill                         | 176                  |
| Flotation Cells              | 30                   |
| Spirals                      | 14                   |
| Pumps                        | 13                   |
| Tankage                      | 33                   |
| Miscellaneous Items (@ 10%)  | 27                   |
| Equipment Cost (Delivered)   | <u>\$293</u>         |
| Cost Factor (Chilton Method) | 3.39                 |
| Total Installed Plant Cost   | <u><u>\$993K</u></u> |

Table 4B-5 MCWM Annualized Capital and O&M Costs (\$ '93)

|  | Annual Cost<br>\$ | \$/ton<br>Clean Coal<br>(d.b.) | \$/MM Btu   |
|--|-------------------|--------------------------------|-------------|
| FIXED O&M COSTS:                         |                   |                                |             |
| O&M Labor                                | 39,447            | 10.00                          | 0.36        |
| Maintenance Materials & Supplies         | 39,708            | 10.07                          | 0.36        |
| VARIABLE O&M COSTS:                      |                   |                                |             |
| Feed Coal                                | -                 | -                              | -           |
| Refuse Disposal                          | -                 | -                              | -           |
| Grinding Media                           | 1,341             | 0.34                           | 0.01        |
| Flotation Reagents Allowance             | 2,209             | 0.56                           | 0.02        |
| Additive Package                         | 30,453            | 7.72                           | 0.28        |
| Electrical Power                         | 5,509             | 1.40                           | 0.05        |
| Capital Charges:                         | 238,606           | 60.49                          | 2.16        |
| <b>TOTAL O&amp;M AND CAPITAL CHARGES</b> | <b>357,273</b>    | <b>90.57</b>                   | <b>3.23</b> |

O&M labor is assumed to be marginal to the existing coal preparation plant operation. An allowance of one person at \$20/h is provided. Maintenance materials and supplies are estimated at four percent of total plant cost. Both feed and refuse disposal costs are considered as marginal to the existing preparation plant operation and therefore equal to zero (no benefit assumed to be derived from avoided disposal to an impoundment pond). Consumption of grinding media is estimated to be 0.68 lb media per ton coal (d.b.) at \$0.50/lb. An allowance is made for flotation reagents at \$0.16/ton flocculant and 2 lb fuel oil per ton of coal at \$0.20/lb. Electrical power consumption for the state of Indiana is taken at 4 cents/KWh. Capital charges are calculated at a 15% cost of capital with a payback period of 7 years. At this level of the analysis, the use of government funds to build the MCWM plant (and a 4% discount rate) is not assumed in order to provide an additional margin, and to allow for sizing the plant for multiples of Crane (as discussed below).

The additive package costs primarily consists of a dispersant to avoid the formation of agglomerates that pose problems for storage and atomization of the slurry by the burner. The dispersant is estimated as 0.6 wt.% to coal at a cost of \$0.55/lb (active ingredient). A base is also used in conjunction with the dispersant in order to correct slurry pH. The costs for using the base are estimated as 0.4 wt.% to coal at a cost of \$0.14/lb. It is recognized that several additive packages exist which may provide acceptable results. Physical slurry preparation techniques may also substantially reduce the amount of dispersant required.

A sensitivity analysis of MCWM costs, f.o.b. slurry preparation plant, was conducted using a methodology similar to that accomplished for the Crane base case. It was shown that the \$/MM Btu cost of coal decreases substantially with an increasing number of oil-designed boilers converted over to fire MCWM. At a coal requirement equivalent to 10 boilers the size of Crane, the MCWM cost is \$1.03/MM Btu and drops to \$0.67/MM Btu at 50 Crane boiler equivalents. The analysis presented here does not imply that this many boiler conversions are undertaken. Indeed, only a few industrial or commercial-sized boilers would need to be converted to create an equivalent level of demand.

It should be noted that throughout the analysis of MCWM costs the capital charges are not amortized over a significant fraction of maximum rated slurry plant capacity. Since the demand is assumed to be only for a six month heating season, the slurry plant with all its capital equipment, sits idle for half of the year, regardless of the type of fuel supply. An interesting analysis might be to size the preparation plant for the anticipated annual demand and compare the benefit of a reduced plant capital cost to the added storage costs of slurry.

Another consideration of using MCWM as a boiler fuel is the relatively high costs of transport that range from 0.87 to 1.45 \$/MM Btu. A significant factor in the slurry transportation costs is the weight and bulk penalty of transporting up to 40 wt.% of water with coal. Any slurry fuel system that reduces weight being transported from the source to the point of use would reduce slurry transportation charges. Consideration might be given to transporting MCWM with the highest solids loading possible and then adding the necessary quantity of water at the boiler site. This fuel form also tends to higher charges due the necessity of using tanker versus dry bulk trucks. Extending the previous

concept, the MCWM might be transported in covered trucks as filter cake and then slurried at the boiler site.

## Appendix 4C

### MCWM Retrofit Technology Cost Model

Table 4C-1 MCWM Cost Estimate to Retrofit a 25.2 MM Btu/h Boiler

| Ref.<br>No             | Item Description             | Material<br>Cost | Installation<br>Hours |
|------------------------|------------------------------|------------------|-----------------------|
| General Equipment      |                              |                  |                       |
| 116                    | FD FAN w/vfd                 | \$14,000         | 60                    |
| 117                    | Air Preheater 'steam'        | \$4,715          | 40                    |
| 118                    | Air Heater (Q-Tube)          | \$85,000         | 80                    |
| 119                    | Air Heater Sootblower        | \$2,700          | 24                    |
| 120                    | Bag House                    | \$49,734         | 160                   |
| 121                    | ID Fan w/vfd                 | \$18,750         | 80                    |
| 122                    | Boiler Mods                  | \$0              | 0                     |
| 123                    | Stack                        | \$45,000         | 100                   |
| 124                    | Floor Air Blast System       | \$4,200          | 160                   |
| 125                    | Air Dryer                    | \$8,000          | 24                    |
| 126                    | Oil/Water Separator Equip    | \$4,000          | 24                    |
| 127                    | Air Receiver Tanks           | \$1,500          | 24                    |
| 128                    | Pitot Grid-Comb. Air         | \$3,000          | 16                    |
| 129                    | Underground Building         | \$20,000         | 1000                  |
| 130                    | Compressor Building          | \$4,000          | 160                   |
| 131                    | Retaining Wall               | \$4,500          | 430                   |
| 132                    | Excavation                   | \$1,000          | 120                   |
| 133                    | Concrete Slab                | \$11,500         | 600                   |
| 134                    | Air and FG Ductwork          | \$28,500         | 560                   |
| 135                    | A.H. Support Steel           | \$4,500          | 40                    |
| 136                    | Valves and Instrumentation   | \$80,000         | 800                   |
| 137                    | Controls                     | \$100,000        |                       |
| 138                    | Electrical Work              | \$70,000         | 1200                  |
| 139                    | Run-Off Drain                | \$400            | 24                    |
| 140                    | Concrete Pipeway             | \$650            | 100                   |
| 141                    | A.H. Sootblower Piping       | \$2,200          | 220                   |
|                        | Subtotal                     |                  |                       |
| Ash Handling Equipment |                              |                  |                       |
| 142                    | Pneumatic Conveying System   | \$7,390          | 120                   |
| 143                    | Ash Silo                     | \$18,034         |                       |
| 144                    | Ash Silo Bin Vent Filter     | \$3,508          | 40                    |
| 145                    | Rotary Valve                 | \$4,382          | 24                    |
| 146                    | Ash Unloading Screw Conveyor | \$16,614         | 120                   |

| Ref.<br>No                  | Item Description                          | Material<br>Cost   | Installation<br>Hours |
|-----------------------------|---|--------------------|-----------------------|
| Slurry Feed Equipment       |   |                    |                       |
| 147                         | MCWSF Transfer Pump (2)                   | \$4,000            | 24                    |
| 148                         | MCWSF Storage Tank                        | \$52,000           | 120                   |
| 149                         | MCWSF Mixer                               | \$34,000           |                       |
| 150                         | Strainer (3 Sets) @ 1500 each             | \$4,500            | 32                    |
| 151                         | MCWSF Injection Pump (2)                  | \$13,400           | 32                    |
| 152                         | MCWSF Heater                              | \$16,000           | 60                    |
| 153                         | Flush Water Booster Pump                  | \$1,200            | 24                    |
| 154                         | Waste Processing Tank                     | \$5,200            | 24                    |
| 155                         | MCWSF Burner                              | \$66,000           | 80                    |
| 156                         | Air Compressor                            | \$33,000           | 80                    |
| 157                         | Slurry Building                           | \$7,500            | 400                   |
| 158                         | Slurry & Flush Water Piping               | \$26,000           | 600                   |
| 159                         | Waste Processing Equipment                | \$27,500           | 80                    |
| 160                         | Power Station                             | \$21,500           | 64                    |
|                             |   | <u>\$929,577</u>   | <u>7970</u>           |
| Direct Construction Costs   |   |                    |                       |
|                             | Total Materials                           | \$929,577          |                       |
|                             | Total Installation Hours Cost (@ \$40/hr) | \$318,800          |                       |
| Construction Indirect Costs |   |                    |                       |
|                             | Field Supervision (15% of Labor hours)    | \$47,820           |                       |
|                             | Construction Overhead and Fee (20%)       | \$249,675          |                       |
| Other Project Costs         |   |                    |                       |
|                             | Frieght (6%)                              | \$55,775           |                       |
|                             | Taxes, Permits (7%)                       | \$65,070           |                       |
|                             | Subtotal Subcontractor and Equipment      | \$1,666,717        |                       |
|                             | Estimating Accuracy Allowance (10%)       | \$166,672          |                       |
|                             | Total Subcontractor and Equipment         | <u>\$1,833,389</u> |                       |
|                             | Engineering (15% of project)              | \$376,724          |                       |
|                             | Project Management (4% of project)        | \$100,460          |                       |
|                             | Construction Management (6% of project)   | \$150,690          |                       |
|                             | Start up (2% of project)                  | \$50,230           |                       |
|                             | Subtotal Project                          | <u>\$2,511,492</u> |                       |
|                             | Contingencies (about 15%)                 | \$374,212          |                       |
|                             | Total Project Cost w/contingency          | <u>\$2,885,704</u> |                       |



## Appendix 4D

### ***ELECTRIC POWER IN YOUR COMMUNITY***

In this survey we are interested in how you feel an electric power plant could affect you and your community. Because we are asking how you feel, there are no right or wrong answers. You do not need to know anything about electricity or how it is produced to answer the questions in this survey. Just answer the questions according to what you know, your own personal experiences, and attitudes. Please answer every question.

Throughout this survey, think of a risk as something that may or may not happen and an impact as the result that actually happens. An impact can be either good or bad.

**Q1.** Below is a list of technologies and types of facilities common in today's society. With a 1 meaning "not at all risky" and a 5 meaning "very risky," indicate how risky you feel each item is to you and your family.

(Circle appropriate number for each item.)

|                               | NOT AT ALL<br>RISKY |   | SOMEWHAT<br>RISKY |   | VERY<br>RISKY |
|-------------------------------|---------------------|---|-------------------|---|---------------|
| PESTICIDES                    | 1                   | 2 | 3                 | 4 | 5             |
| X-RAYS                        | 1                   | 2 | 3                 | 4 | 5             |
| NUCLEAR POWER PLANT           | 1                   | 2 | 3                 | 4 | 5             |
| ASBESTOS                      | 1                   | 2 | 3                 | 4 | 5             |
| TRAFFIC                       | 1                   | 2 | 3                 | 4 | 5             |
| QUARRY OR MINE                | 1                   | 2 | 3                 | 4 | 5             |
| SEWAGE TREATMENT PLANT        | 1                   | 2 | 3                 | 4 | 5             |
| NATURAL GAS-FIRED POWER PLANT | 1                   | 2 | 3                 | 4 | 5             |
| MANUFACTURING PLANT           | 1                   | 2 | 3                 | 4 | 5             |
| LANDFILL                      | 1                   | 2 | 3                 | 4 | 5             |
| COAL-FIRED POWER PLANT        | 1                   | 2 | 3                 | 4 | 5             |
| GROUNDWATER CONTAMINATION     | 1                   | 2 | 3                 | 4 | 5             |

Many human activities, including the production of electricity, have both good and bad effects on your life and on the community in which you live. We want to learn how individuals like you feel about power plants that burn either coal or natural gas to produce electricity and how you feel electricity production could affect the quality of your life.

**Q2.** Are you aware of any facilities near your home or in your community that produce electricity?  
(Circle appropriate number.)

1. NO
2. YES (GO TO Q2A)
3. NOT SURE

**Q2A.** Approximately how far away from your home is the nearest power plant?

\_\_\_\_\_ MILE(S)

**Q3.** Do you know what fuel is burned to produce the electricity that supplies your community with its electricity needs? (Circle appropriate number.)

1. NO
2. YES - PLEASE SPECIFY: \_\_\_\_\_
3. NOT SURE

**Q4.** Do you feel that the amount of electricity that your household consumes is less than, about equal to, or greater than the amount of electricity consumed by other households in your community?  
(Circle appropriate number.)

1. LESS THAN AVERAGE
2. ABOUT EQUAL TO THE AVERAGE
3. GREATER THAN AVERAGE

**Q5.** What is the average amount that you pay for your electricity each month?  
If you are not the person in your household who pays the electricity bill, please indicate about how much you think your electricity bill is each month.  
(Write in dollar amount.)

\$ \_\_\_\_\_

## *A Coal-Fired Power Plant in Your Community*

As the population in the United States grows, more electricity will be needed for the extra homes, businesses, and industries. We are interested in how you feel you will be affected if a coal-burning power plant were to be built and operate near your home. We would like you to consider a hypothetical situation in which a coal-burning power plant has been proposed for your community.

In the following pages, you will be asked how you feel the proposed coal-fired power plant will create risks to your health, the environment, and the aesthetic quality of your community. In addition, we will ask how you feel the proposed power plant could affect your community's economy.

### **4.1 CONSIDER THE FOLLOWING PROPOSAL:**

|                                     |  |
|-------------------------------------|--|
| YOU AND YOUR COMMUNITY              | <ul style="list-style-type: none"> <li>• You have lived in your community for 5 years and plan to live there permanently.</li> <li>• You rely on electricity for all of the heating, lighting, and cooking in your home. In other words, your household does not have a woodstove, an oil furnace, or a hook-up to a natural gas pipeline.</li> </ul>  |
| NEED FOR ELECTRICITY                | <ul style="list-style-type: none"> <li>• Because of the growth in the area in which you live, the public utility that supplies your community with its electricity has announced that the proposed power plant is greatly needed.</li> <li>• The price you pay for your electricity will remain the same after the new coal power plant is in operation.</li> </ul>  |
| GENERAL FEATURES OF THE POWER PLANT | <ul style="list-style-type: none"> <li>• The coal power plant will produce 180 megawatts of electricity per year. This will be enough power to supply the growth in your area for the next 30 years.</li> <li>• The power plant will be built on a 40-acre plot of land near a local river.</li> <li>• The site for the proposed coal-fired power plant is 3 miles away from your home.</li> <li>• The life span of the power plant is projected to be at least 30 years.</li> </ul> |
| REGULATORY COMPLIANCE               | <ul style="list-style-type: none"> <li>• All local, state, and federal regulations will be obeyed during the construction and operation of the plant.</li> </ul>   |

ANSWER THE FOLLOWING QUESTIONS  
AS IF YOU WERE TRULY FACING THIS SITUATION.

### ***The Coal-Fired Power Plant and Your Health***

Human health impacts are due to changes in the air you breath and the water you drink. To answer the following questions, consider how you feel the proposed coal-fired power plant could affect your health and the health of others that live in your community. Please think only of the potential health impacts as you answer the questions on this page.

**Q6.** Do you feel that there might be health impacts as a result of the coal-fired power plant described on **page 4D-3?** (Circle appropriate number.)

1. NO
2. YES

**Q7.** Indicate below how positive or negative you feel that the impact(s) to your health could be from the proposed coal-fired power plant. (Circle appropriate number.)

| VERY NEGATIVE<br>IMPACT |    |    |    | NO<br>IMPACT |   |   | VERY POSITIVE<br>IMPACT |   |  |
|-------------------------|----|----|----|--------------|---|---|-------------------------|---|--|
| -4                      | -3 | -2 | -1 | 0            | 1 | 2 | 3                       | 4 |  |

**Q8.** How serious do you feel the risks to your health could be from the proposed coal-fired power plant? (Circle appropriate number.)

| NOT AT ALL<br>SERIOUS |   | SOMEWHAT<br>SERIOUS |   |   |   | VERY<br>SERIOUS |  |
|-----------------------|---|---------------------|---|---|---|-----------------|--|
| 1                     | 2 | 3                   | 4 | 5 | 6 | 7               |  |

**Q9.** What do you feel is the chance or likelihood that the coal plant will affect your health some time in the future? (Circle percentage.)

| NO CHANCE<br>HEALTH WILL BE<br>AFFECTED |     |     |     | MAY OR<br>MAY NOT AFFECT<br>HEALTH |     |     |     | DEFINITELY<br>WILL AFFECT<br>HEALTH |     |      |  |
|---|-----|-----|-----|------------------------------------|-----|-----|-----|-------------------------------------|-----|------|--|
| 0%                                      | 10% | 20% | 30% | 40%                                | 50% | 60% | 70% | 80%                                 | 90% | 100% |  |

**Q10.** How would you describe your feelings when you think about the health risks from the proposed power plant? (Circle appropriate number.)

| I FEEL AFRAID<br>AND DREADFUL |    |    | MY FEELINGS ARE<br>NEUTRAL |   |   |   | I FEEL HAPPINESS<br>AND COMFORT |   |  |
|-------------------------------|----|----|----------------------------|---|---|---|---------------------------------|---|--|
| -4                            | -3 | -2 | -1                         | 0 | 1 | 2 | 3                               | 4 |  |

**The Coal-Fired Power Plant and Your Local Economy**

Economic impacts may be caused by changes in the local employment level, tax revenues and tax payments, property values, prices, and overall changes in the business activity in your community. To answer the following questions, consider how you feel the proposed coal-fired power plant could affect your local economy. Please think only of the potential impacts on your community's economy as you answer the questions on this page.

**Q11.** Do you feel that there might be economic impacts as a result of the coal-fired power plant described on **page 4D-3**? (Circle appropriate number.)

- 1. NO
- 2. YES

**Q12.** Indicate below how positive or negative you feel the impact(s) on your local economy could be from the proposed coal-fired power plant. (Circle appropriate number.)

|                         |              |    |    |   |   |   |                         |   |
|-------------------------|--------------|----|----|---|---|---|-------------------------|---|
| VERY NEGATIVE<br>IMPACT | NO<br>IMPACT |    |    |   |   |   | VERY POSITIVE<br>IMPACT |   |
| -4                      | -3           | -2 | -1 | 0 | 1 | 2 | 3                       | 4 |

**Q13.** How significant do you feel the impacts on your local economy could be from the proposed coal-fired power plant? (Circle appropriate number.)

|                           |                         |   |   |   |                     |   |
|---------------------------|-------------------------|---|---|---|---------------------|---|
| NOT AT ALL<br>SIGNIFICANT | SOMEWHAT<br>SIGNIFICANT |   |   |   | VERY<br>SIGNIFICANT |   |
| 1                         | 2                       | 3 | 4 | 5 | 6                   | 7 |

**Q14.** What do you feel is the chance or likelihood that the coal plant will affect your local economy some time in the future? (Circle percentage.)

|  |                                     |     |     |     |     |     |                                      |     |     |      |
|--|-------------------------------------|-----|-----|-----|-----|-----|--------------------------------------|-----|-----|------|
| NO CHANCE<br>ECONOMY WILL BE<br>AFFECTED | MAY OR<br>MAY NOT AFFECT<br>ECONOMY |     |     |     |     |     | DEFINITELY<br>WILL AFFECT<br>ECONOMY |     |     |      |
| 0%                                       | 10%                                 | 20% | 30% | 40% | 50% | 60% | 70%                                  | 80% | 90% | 100% |

**Q15.** How would you describe your feelings when you think about the economic impacts associated with the proposed coal plant? (Circle appropriate number.)

|                               |                            |    |    |   |   |                                 |   |   |  |
|-------------------------------|----------------------------|----|----|---|---|---------------------------------|---|---|--|
| I FEEL AFRAID<br>AND DREADFUL | MY FEELINGS ARE<br>NEUTRAL |    |    |   |   | I FEEL HAPPINESS<br>AND COMFORT |   |   |  |
| -4                            | -3                         | -2 | -1 | 0 | 1 | 2                               | 3 | 4 |  |

### ***The Coal-Fired Power Plant and Your Environment***

Environmental impacts could be caused by changes in the air quality, water quality, plants and wildlife, and how the land in your community is used. To answer the following questions, consider how you feel the proposed power plant may be a risk to the environment, and how serious you feel the actual environmental impact(s) could be from the coal-fired power plant. Please think only of the potential impacts on environmental quality as you answer the questions on this page.

**Q16.** Do you feel that there might be environmental impacts as a result of the coal-fired power plant described on **page 4D-3**? (Circle appropriate number.)

1. NO
2. YES

**Q17.** Indicate below how positive or negative you feel that the impact(s) to the environment could be from the proposed coal-fired power plant. (Circle appropriate number.)

| VERY NEGATIVE<br>IMPACT | NO<br>IMPACT |    |    |   |   | VERY POSITIVE<br>IMPACT |   |   |
|-------------------------|--------------|----|----|---|---|-------------------------|---|---|
| -4                      | -3           | -2 | -1 | 0 | 1 | 2                       | 3 | 4 |

**Q18.** How serious do you feel the risks to the environment could be from the proposed coal-fired power plant? (Circle appropriate number.)

| NOT AT ALL<br>SERIOUS | SOMEWHAT<br>SERIOUS |   |   |   | VERY<br>SERIOUS |   |
|-----------------------|---------------------|---|---|---|-----------------|---|
| 1                     | 2                   | 3 | 4 | 5 | 6               | 7 |

**Q19.** What do you feel is the chance or likelihood that the coal plant will affect the environment some time in the future? (Circle percentage.)

| NO CHANCE THE<br>ENVIRONMENT WILL<br>BE AFFECTED | MAY OR<br>MAY NOT AFFECT<br>THE ENVIRONMENT |     |     |     |     | DEFINITELY WILL<br>WILL AFFECT THE<br>ENVIRONMENT |     |     |     |      |
|--|---|-----|-----|-----|-----|---|-----|-----|-----|------|
| 0%   | 10%   | 20% | 30% | 40% | 50% | 60%   | 70% | 80% | 90% | 100% |

**Q20.** How would you describe your feelings when you think about the environmental risks from the proposed power plant? (Circle appropriate number.)

| I FEEL AFRAID<br>AND DREADFUL | MY FEELINGS ARE<br>NEUTRAL |    |    |   |   | I FEEL HAPPINESS<br>AND COMFORT |   |   |
|-------------------------------|----------------------------|----|----|---|---|---------------------------------|---|---|
| -4                            | -3                         | -2 | -1 | 0 | 1 | 2                               | 3 | 4 |

***The Coal-Fired Power Plant and Aesthetic Quality***

The aesthetic quality of your community is how pleasant your community is to live in. Many people think of the noise, sights, and smells around their community when they think of its aesthetic quality. To answer the following questions, consider how you feel the proposed coal-fired power plant could be a risk to the aesthetic quality of your community. Please think only of the potential impacts on the aesthetic quality as you answer the questions on this page.

**Q21.** Do you feel that there might be aesthetic impacts as a result of the coal-fired power plant described on **page 4D-3**? (Circle appropriate number.)

1. NO
2. YES

**Q22.** Indicate below how positive or negative you feel that the impact(s) on the aesthetic quality of your community could be from the proposed coal-fired power plant. (Circle appropriate number.)

|                         |    |    |              |   |   |   |                         |   |  |
|-------------------------|----|----|--------------|---|---|---|-------------------------|---|--|
| VERY NEGATIVE<br>IMPACT |    |    | NO<br>IMPACT |   |   |   | VERY POSITIVE<br>IMPACT |   |  |
| -4                      | -3 | -2 | -1           | 0 | 1 | 2 | 3                       | 4 |  |

**Q23.** How serious do you feel the aesthetic risks could be from the proposed coal-fired power plant? (Circle appropriate number.)

|                       |   |                     |   |   |   |                 |  |
|-----------------------|---|---------------------|---|---|---|-----------------|--|
| NOT AT ALL<br>SERIOUS |   | SOMEWHAT<br>SERIOUS |   |   |   | VERY<br>SERIOUS |  |
| 1                     | 2 | 3                   | 4 | 5 | 6 | 7               |  |

**Q24.** What do you feel is the chance or likelihood that the coal plant will affect your community's aesthetic quality some time in the future? (Circle percentage.)

|   |     |     |     |   |     |     |     |  |     |      |
|---|-----|-----|-----|---|-----|-----|-----|--|-----|------|
| NO CHANCE<br>AESTHETIC QUALITY<br>WLL BE AFFECTED |     |     |     | MAY OR MAY<br>NOT AFFECT<br>AESTHETIC QUALITY |     |     |     | DEFINITELY<br>WILL AFFECT<br>AESTHETIC QUALITY |     |      |
| 0%  | 10% | 20% | 30% | 40%   | 50% | 60% | 70% | 80%  | 90% | 100% |

**Q25.** How would you describe your feelings when you think about the aesthetic risks from the proposed power plant? (Circle appropriate number.)

|                               |    |    |                            |   |   |   |                                 |   |  |
|-------------------------------|----|----|----------------------------|---|---|---|---------------------------------|---|--|
| I FEEL AFRAID<br>AND DREADFUL |    |    | MY FEELINGS ARE<br>NEUTRAL |   |   |   | I FEEL HAPPINESS<br>AND COMFORT |   |  |
| -4                            | -3 | -2 | -1                         | 0 | 1 | 2 | 3                               | 4 |  |

Consider the “overall concern” you have about the proposed coal-burning power plant. We are interested in how much of your concern is due to each of the four types of impacts covered in the last four pages.

**Q26.** In the spaces below, write in the percentage of the overall concern that you have for each type of potential impact from the proposed coal power plant. Please make sure your answers add up to 100%.

|   |                     |
|---|---------------------|
| POTENTIAL HEALTH IMPACTS                            | _____%              |
| POTENTIAL ENVIRONMENTAL IMPACTS                     | _____%              |
| POTENTIAL ECONOMIC IMPACTS                          | _____%              |
| POTENTIAL AESTHETIC IMPACTS                         | _____%              |
| OTHER POTENTIAL IMPACTS<br>(PLEASE DESCRIBE: _____) | _____%              |
| _____ )   | <b>TOTAL = 100%</b> |

Consider how you feel the proposed coal-burning power plant will affect your health, your local economy, the environment and the aesthetic quality of your community.

**Q27.** Would you vote in favor of or against the coal-burning power plant proposed for your community?

1. I WOULD VOTE IN FAVOR OF THE COAL POWER PLANT
2. I WOULD VOTE AGAINST THE COAL POWER PLANT
3. DON'T KNOW
4. I WOULDN'T VOTE - PLEASE EXPLAIN: \_\_\_\_\_  
\_\_\_\_\_



Suppose that your electricity supplier proposed to build the coal-fired power plant described on **page 4D-3**. We would like you to imagine that you live in the community in which the coal power plant is being proposed. If the supplier is not able to build this power plant, it will have to increase the price you pay for electricity because the much needed electricity must be purchased at a higher cost from other power producers elsewhere in the state.


Think of how much more money you would be willing to pay on your monthly electricity bill in order to prevent the coal-burning power plant from being built in your community. When answering the following question, please consider your household income, your average monthly electricity bill, and how much extra you can actually afford to pay to prevent the coal-fired power plant.

**Q28.** Circle the dollar value closest to the largest amount you would be willing to pay extra each month on your electricity bill to prevent the coal-fired power plant from being built in your community.


|          |          |          |          |          |          |
|----------|----------|----------|----------|----------|----------|
| \$0.00   | \$0.10   | \$0.25   | \$0.50   | \$0.75   | \$1.00   |
| \$1.25   | \$1.50   | \$2.00   | \$3.00   | \$4.00   | \$5.00   |
| \$6.00   | \$8.00   | \$11.00  | \$14.00  | \$19.00  | \$22.00  |
| \$26.00  | \$30.00  | \$35.00  | \$40.00  | \$45.00  | \$50.00  |
| \$55.00  | \$60.00  | \$70.00  | \$80.00  | \$90.00  | \$100.00 |
| \$110.00 | \$120.00 | \$140.00 | \$160.00 | \$220.00 | \$300.00 |

OTHER: \$ \_\_\_\_\_

**If You Answered \$0.00 in Question 28, Go To Page 4D-11.**



**If You Answered \$0.00 in Question 28, Go To Page 4D-11.**



- Q29.** Think of the amount you would pay to prevent the coal-burning power plant from being built in your community (**Q28.**) About what percent of that amount would be to ensure ....  
(Write in percentage.)

THAT MY HOUSEHOLD WILL NOT BE AFFECTED  
AT ALL BY THE POTENTIAL IMPACTS FROM THE  
COAL -FIRED POWER PLANT. \_\_\_\_\_ %

THAT OTHER HOUSEHOLDS WILL NOT BE  
AFFECTED AT ALL BY THE POTENTIAL IMPACTS  
FROM THE COAL-FIRED POWER PLANT. \_\_\_\_\_ %

THAT FUTURE GENERATIONS WILL NOT BE  
AFFECTED AT ALL BY THE POTENTIAL IMPACTS  
FROM THE COAL-FIRED POWER PLANT. \_\_\_\_\_ %

THAT COAL-FIRED POWER PLANTS SHOULD BE  
PREVENTED EVEN IF NO ONE WILL HAVE TO LIVE  
NEAR THEM. \_\_\_\_\_ %

REASONS OTHER THAN THESE  
(PLEASE DESCRIBE: \_\_\_\_\_  
\_\_\_\_\_ ) \_\_\_\_\_ %

**TOTAL = 100%**

PLEASE MAKE SURE YOUR ANSWERS ADD UP TO 100%.

## *A Natural Gas-Fired Power Plant in Your Community*

As the population in the United States grows, more electricity will be needed for the extra homes, businesses, and industries. We are interested in how you feel you will be affected if a natural gas-burning power plant were to be built and operate near your home. We would like you to consider a hypothetical situation in which a natural gas-burning power plant has been proposed for your community.

In the following pages, you will be asked how you feel the proposed natural gas-fired power plant will create risks to your health, the environment, and the aesthetic quality of your community. In addition, we will ask how you feel the proposed power plant could affect your community's economy.

### **CONSIDER THE FOLLOWING PROPOSAL:**

|   |  |
|---|--|
| YOU AND YOUR<br>COMMUNITY                 | <ul style="list-style-type: none"> <li>• You have lived in your community for 5 years and plan to live there permanently.</li> <li>• You rely on electricity for all of the heating, lighting, and cooking in your home. In other words, your household does not have a woodstove, an oil furnace, or a hook-up to a natural gas pipeline.</li> </ul>  |
| NEED FOR<br>ELECTRICITY                   | <ul style="list-style-type: none"> <li>• Because of the growth in the area in which you live, the public utility that supplies your community with its electricity has announced that the proposed power plant is greatly needed.</li> <li>• The price you pay for your electricity will remain the same after the new natural gas power plant is in operation.</li> </ul>   |
| GENERAL FEATURES<br>OF THE<br>POWER PLANT | <ul style="list-style-type: none"> <li>• The natural gas power plant will produce 180 megawatts of electricity per year. This will be enough power to supply the growth in your area for the next 30 years.</li> <li>• The power plant will be built on a 40-acre plot of land near a local river.</li> <li>• The site for the proposed natural gas-fired power plant is 3 miles away from your home.</li> <li>• The life span of the plant is projected to be at least 30 years.</li> </ul> |
| REGULATORY<br>COMPLIANCE                  | <ul style="list-style-type: none"> <li>• All local, state, and federal regulations will be obeyed during the construction and operation of the plant.</li> </ul>   |

ANSWER THE FOLLOWING QUESTIONS  
AS IF YOU WERE TRULY FACING THIS SITUATION.

**The Natural Gas-Fired Power Plant and Your Health**

Human health impacts are due to changes in the air you breath and the water you drink. To answer the following questions, consider how you feel the proposed natural gas-fired power plant could have an affect on your health and the health of others that live in your community. Please think only of the potential health impacts as you answer the questions on this page.

**Q30.** Do you feel that there might be health impacts as a result of the natural gas -fired power plant described on **page 4D-11**? (Circle appropriate number.)

- 1. NO
- 2. YES

**Q31.** Indicate below how positive or negative you feel that the impact(s) to your health could be from the proposed natural gas-fired power plant. (Circle appropriate number.)

|                         |    |    |    |   |   |              |   |   |  |  |  |                         |
|-------------------------|----|----|----|---|---|--------------|---|---|--|--|--|-------------------------|
| VERY NEGATIVE<br>IMPACT |    |    |    |   |   | NO<br>IMPACT |   |   |  |  |  | VERY POSITIVE<br>IMPACT |
| -4                      | -3 | -2 | -1 | 0 | 1 | 2            | 3 | 4 |  |  |  |                         |

**Q32.** How serious do you feel the risks to your health could be from the proposed natural gas-fired power plant? (Circle appropriate number.)

|                       |   |   |   |                     |   |   |  |                 |
|-----------------------|---|---|---|---------------------|---|---|--|-----------------|
| NOT AT ALL<br>SERIOUS |   |   |   | SOMEWHAT<br>SERIOUS |   |   |  | VERY<br>SERIOUS |
| 1                     | 2 | 3 | 4 | 5                   | 6 | 7 |  |                 |

**Q33.** What do you feel is the chance or likelihood that the natural gas plant will affect your health some time in the future? (Circle percentage.)

|   |     |     |     |     |     |                                    |     |     |     |      |  |                                     |
|---|-----|-----|-----|-----|-----|------------------------------------|-----|-----|-----|------|--|-------------------------------------|
| NO CHANCE<br>HEALTH WILL BE<br>AFFECTED |     |     |     |     |     | MAY OR<br>MAY NOT AFFECT<br>HEALTH |     |     |     |      |  | DEFINITELY<br>WILL AFFECT<br>HEALTH |
| 0%                                      | 10% | 20% | 30% | 40% | 50% | 60%                                | 70% | 80% | 90% | 100% |  |                                     |

**Q34.** How would you describe your feelings when you think about the health risks from the proposed power plant? (Circle appropriate number.)

|                               |    |    |    |   |   |                            |   |   |  |  |  |                                 |
|-------------------------------|----|----|----|---|---|----------------------------|---|---|--|--|--|---------------------------------|
| I FEEL AFRAID<br>AND DREADFUL |    |    |    |   |   | MY FEELINGS ARE<br>NEUTRAL |   |   |  |  |  | I FEEL HAPPINESS<br>AND COMFORT |
| -4                            | -3 | -2 | -1 | 0 | 1 | 2                          | 3 | 4 |  |  |  |                                 |

**The Natural Gas-Fired Power Plant and Your Local Economy**

Economic impacts may be caused by changes in the local employment level, tax revenues and tax payments, property values, prices, and overall changes in the business activity in your community. To answer the following questions, consider how you feel the proposed natural gas-fired power plant could affect your local economy. Please think only of the potential impacts on your community's economy as you answer the questions on this page.

**Q35.** Do you feel that there might be economic impacts as a result of the natural gas -fired power plant described on **page 4D-11**? (Circle appropriate number.)

- 1. NO
- 2. YES

**Q36.** Indicate below how positive or negative you feel the impact(s) on your local economy could be from the proposed natural gas-fired power plant. (Circle appropriate number.)

|                         |    |    |    |   |   |              |   |   |  |  |  |                         |
|-------------------------|----|----|----|---|---|--------------|---|---|--|--|--|-------------------------|
| VERY NEGATIVE<br>IMPACT |    |    |    |   |   | NO<br>IMPACT |   |   |  |  |  | VERY POSITIVE<br>IMPACT |
| -4                      | -3 | -2 | -1 | 0 | 1 | 2            | 3 | 4 |  |  |  |                         |

**Q37.** How significant do you feel the impacts on your local economy could be from the proposed natural gas-fired power plant? (Circle appropriate number.)

|                           |   |   |   |                         |   |   |  |                     |
|---------------------------|---|---|---|-------------------------|---|---|--|---------------------|
| NOT AT ALL<br>SIGNIFICANT |   |   |   | SOMEWHAT<br>SIGNIFICANT |   |   |  | VERY<br>SIGNIFICANT |
| 1                         | 2 | 3 | 4 | 5                       | 6 | 7 |  |                     |

**Q38.** What do you feel is the chance or likelihood that the natural gas plant will affect your local economy some time in the future? (Circle percentage.)

|  |     |     |     |     |     |                                     |     |     |     |      |  |                                      |
|--|-----|-----|-----|-----|-----|-------------------------------------|-----|-----|-----|------|--|--------------------------------------|
| NO CHANCE<br>ECONOMY WILL BE<br>AFFECTED |     |     |     |     |     | MAY OR<br>MAY NOT AFFECT<br>ECONOMY |     |     |     |      |  | DEFINITELY<br>WILL AFFECT<br>ECONOMY |
| 0%                                       | 10% | 20% | 30% | 40% | 50% | 60%                                 | 70% | 80% | 90% | 100% |  |                                      |

**Q39.** How would you describe your feelings when you think about the economic impacts associated with the proposed natural gas plant? (Circle appropriate number.)

|                               |    |    |    |   |   |                            |   |   |  |  |  |                                 |
|-------------------------------|----|----|----|---|---|----------------------------|---|---|--|--|--|---------------------------------|
| I FEEL AFRAID<br>AND DREADFUL |    |    |    |   |   | MY FEELINGS ARE<br>NEUTRAL |   |   |  |  |  | I FEEL HAPPINESS<br>AND COMFORT |
| -4                            | -3 | -2 | -1 | 0 | 1 | 2                          | 3 | 4 |  |  |  |                                 |

**The Natural Gas-Fired Power Plant and Your Environment**

Environmental impacts could be caused by changes in the air quality, water quality, plants and wildlife, and how the land in your community is used. To answer the following questions, consider how you feel the proposed power plant may be a risk to the environment, and how serious you feel the actual environmental impact(s) could be from the natural gas-fired power plant. Please think only of the potential impacts on environmental quality as you answer the questions on this page.

**Q40.** Do you feel that there might be environmental impacts as a result of the natural gas -fired power plant described on **page 4D-11**? (Circle appropriate number.)

- 1. NO
- 2. YES

**Q41.** Indicate below how positive or negative you feel that the impact(s) to the environment could be from the proposed natural gas-fired power plant. (Circle appropriate number.)

|                         |    |    |    |   |   |              |   |   |  |  |  |                         |
|-------------------------|----|----|----|---|---|--------------|---|---|--|--|--|-------------------------|
| VERY NEGATIVE<br>IMPACT |    |    |    |   |   | NO<br>IMPACT |   |   |  |  |  | VERY POSITIVE<br>IMPACT |
| -4                      | -3 | -2 | -1 | 0 | 1 | 2            | 3 | 4 |  |  |  |                         |

**Q42.** How serious do you feel the risks to the environment could be from the proposed natural gas-fired power plant? (Circle appropriate number.)

|                       |   |   |   |                     |   |   |  |                 |
|-----------------------|---|---|---|---------------------|---|---|--|-----------------|
| NOT AT ALL<br>SERIOUS |   |   |   | SOMEWHAT<br>SERIOUS |   |   |  | VERY<br>SERIOUS |
| 1                     | 2 | 3 | 4 | 5                   | 6 | 7 |  |                 |

**Q43.** What do you feel is the chance or likelihood that the natural gas plant will affect the environment some time in the future? (Circle percentage.)

|  |     |     |     |     |     |   |     |     |     |      |  |   |
|--|-----|-----|-----|-----|-----|---|-----|-----|-----|------|--|---|
| NO CHANCE THE<br>ENVIRONMENT WILL<br>BE AFFECTED |     |     |     |     |     | MAY OR<br>MAY NOT AFFECT<br>THE ENVIRONMENT |     |     |     |      |  | DEFINITELY WILL<br>WILL AFFECT THE<br>ENVIRONMENT |
| 0%   | 10% | 20% | 30% | 40% | 50% | 60%   | 70% | 80% | 90% | 100% |  |   |

**Q44.** How would you describe your feelings when you think about the environmental risks from the proposed power plant? (Circle appropriate number.)

|                               |    |    |    |   |   |                            |   |   |  |  |  |                                 |
|-------------------------------|----|----|----|---|---|----------------------------|---|---|--|--|--|---------------------------------|
| I FEEL AFRAID<br>AND DREADFUL |    |    |    |   |   | MY FEELINGS ARE<br>NEUTRAL |   |   |  |  |  | I FEEL HAPPINESS<br>AND COMFORT |
| -4                            | -3 | -2 | -1 | 0 | 1 | 2                          | 3 | 4 |  |  |  |                                 |

**The Natural Gas-Fired Power Plant and Aesthetic Quality**

The aesthetic quality of your community is how pleasant your community is to live in. Many people think of the noise, sights, and smells around their community when they think of its aesthetic quality. To answer the following questions, consider how you feel the proposed natural gas-fired power plant could be a risk to the aesthetic quality of your community. Please think only of the potential impacts on the aesthetic quality as you answer the questions on this page.

**Q45.** Do you feel that there might be aesthetic impacts as a result of the natural gas-fired power plant described on **page 4D-11**? (Circle appropriate number.)

- 1. NO
- 2. YES

**Q46.** Indicate below how positive or negative you feel that the impact(s) on the aesthetic quality of your community could be from the proposed natural gas-fired power plant. (Circle appropriate number.)

|                         |    |    |    |   |              |   |   |   |  |                         |
|-------------------------|----|----|----|---|--------------|---|---|---|--|-------------------------|
| VERY NEGATIVE<br>IMPACT |    |    |    |   | NO<br>IMPACT |   |   |   |  | VERY POSITIVE<br>IMPACT |
| -4                      | -3 | -2 | -1 | 0 | 1            | 2 | 3 | 4 |  |                         |

**Q47.** How serious do you feel the aesthetic risks could be from the proposed natural gas-fired power plant? (Circle appropriate number.)

|                       |   |   |   |                     |   |   |  |                 |
|-----------------------|---|---|---|---------------------|---|---|--|-----------------|
| NOT AT ALL<br>SERIOUS |   |   |   | SOMEWHAT<br>SERIOUS |   |   |  | VERY<br>SERIOUS |
| 1                     | 2 | 3 | 4 | 5                   | 6 | 7 |  |                 |

**Q48.** What do you feel is the chance or likelihood that the natural gas plant will affect your community's aesthetic quality some time in the future? (Circle percentage.)

|   |     |     |     |     |   |     |     |     |     |  |
|---|-----|-----|-----|-----|---|-----|-----|-----|-----|--|
| NO CHANCE<br>AESTHETIC QUALITY<br>WLL BE AFFECTED |     |     |     |     | MAY OR MAY<br>NOT AFFECT<br>AESTHETIC QUALITY |     |     |     |     | DEFINITELY<br>WILL AFFECT<br>AESTHETIC QUALITY |
| 0%  | 10% | 20% | 30% | 40% | 50%   | 60% | 70% | 80% | 90% | 100%   |

**Q49.** How would you describe your feelings when you think about the aesthetic risks from the proposed power plant? (Circle appropriate number.)

|                               |    |    |    |   |                            |   |   |   |  |                                 |
|-------------------------------|----|----|----|---|----------------------------|---|---|---|--|---------------------------------|
| I FEEL AFRAID<br>AND DREADFUL |    |    |    |   | MY FEELINGS ARE<br>NEUTRAL |   |   |   |  | I FEEL HAPPINESS<br>AND COMFORT |
| -4                            | -3 | -2 | -1 | 0 | 1                          | 2 | 3 | 4 |  |                                 |

Consider the “overall concern” you have about the proposed natural gas-burning power plant. We are interested in how much of your concern is due to each of the four types of impacts covered in the last four pages.

**Q50.** In the spaces below, write in the percentage of the overall concern that you have for each type of potential impact from the proposed natural gas power plant. Please make sure your answers add up to 100%.

|                                 |                     |
|---------------------------------|---------------------|
| POTENTIAL HEALTH IMPACTS        | _____%              |
| POTENTIAL ENVIRONMENTAL IMPACTS | _____%              |
| POTENTIAL ECONOMIC IMPACTS      | _____%              |
| POTENTIAL AESTHETIC IMPACTS     | _____%              |
| OTHER POTENTIAL IMPACTS         | _____%              |
| (PLEASE DESCRIBE: _____)        |                     |
|                                 | <b>TOTAL = 100%</b> |

Consider how you feel the proposed natural gas-burning power plant will affect your health, your local economy, the environment and the aesthetic quality of your community.

**Q51.** Would you vote in favor of or against the natural gas-burning power plant proposed for your community?

1. I WOULD VOTE IN FAVOR OF THE NATURAL GAS POWER PLANT
2. I WOULD VOTE AGAINST THE NATURAL GAS POWER PLANT
3. DON'T KNOW
4. I WOULDN'T VOTE - PLEASE EXPLAIN: \_\_\_\_\_



Suppose that your electricity supplier proposed to build the natural gas-fired power plant described on **page 4D-11**. We would like you to imagine that you live in the community in which the natural gas power plant is being proposed. If the supplier is not able to build this power plant, it will have to increase the price you pay for electricity because the much needed electricity must be purchased at a higher cost from other power producers elsewhere in the state.

Think of how much more money you would be willing to pay on your monthly electricity bill in order to prevent the natural gas-burning power plant from being built in your community. When answering the following question, please consider your household income, your average monthly electricity bill, and how much extra you can actually afford to pay to prevent the natural gas-fired power plant.

**Q52.** Circle the dollar value closest to the largest amount you would be willing to pay extra each month on your electricity bill to prevent the natural gas-fired power plant from being built in your community.

|          |          |          |          |          |          |
|----------|----------|----------|----------|----------|----------|
| \$0.00   | \$0.10   | \$0.25   | \$0.50   | \$0.75   | \$1.00   |
| \$1.25   | \$1.50   | \$2.00   | \$3.00   | \$4.00   | \$5.00   |
| \$6.00   | \$8.00   | \$11.00  | \$14.00  | \$19.00  | \$22.00  |
| \$26.00  | \$30.00  | \$35.00  | \$40.00  | \$45.00  | \$50.00  |
| \$55.00  | \$60.00  | \$70.00  | \$80.00  | \$90.00  | \$100.00 |
| \$110.00 | \$120.00 | \$140.00 | \$160.00 | \$220.00 | \$300.00 |

OTHER: \$ \_\_\_\_\_

**If You Answered \$0.00 in Question 52, Go To Page 19.**



If You Answered \$0.00 in Question 52, Go To Page 19.



- Q53.** Think of the amount you would pay to prevent the natural gas-burning power plant from being built in your community (**Q52.**) About what percent of that amount would be to ensure .... Please make sure your answers add up to 100%.  
(Write in percentage.)

THAT MY HOUSEHOLD WILL NOT BE AFFECTED  
AT ALL BY THE POTENTIAL IMPACTS FROM THE  
NATURAL GAS-FIRED POWER PLANT. \_\_\_\_\_ %

THAT OTHER HOUSEHOLDS WILL NOT BE  
AFFECTED AT ALL BY THE POTENTIAL IMPACTS  
FROM THE NATURAL GAS-FIRED POWER PLANT. \_\_\_\_\_ %

THAT FUTURE GENERATIONS WILL NOT BE  
AFFECTED AT ALL BY THE POTENTIAL IMPACTS  
FROM THE NATURAL GAS-FIRED POWER PLANT. \_\_\_\_\_ %

THAT NATURAL GAS-FIRED POWER PLANTS  
SHOULD BE PREVENTED EVEN IF NO ONE WILL  
HAVE TO LIVE NEAR THEM. \_\_\_\_\_ %

REASONS OTHER THAN THESE  
(PLEASE DESCRIBE: \_\_\_\_\_  
\_\_\_\_\_ ) \_\_\_\_\_ %

**TOTAL = 100%**

***Your Preferences for the Use of Either Coal or Natural Gas  
in the Proposed Power Plant***

Suppose that your electricity supplier has already received local, state, and federal approval to build a power plant for your community. Assume that a power plant will be built in your community, but the type of fuel that it will burn has not yet been determined.

**Q54.** Based upon your current knowledge, feelings, and opinions, what type of fuel would you prefer that the plant burn to produce electricity - coal or natural gas?

1. COAL
2. NATURAL GAS

Think of how much more money you would be willing to pay on your monthly electricity bill to make sure that the power plant uses the fuel type that you circled above in **Q54**. When answering the following question, please consider your household income, your average monthly electricity bill, and how much extra you can actually afford to pay so the plant burns the fuel that you prefer.

**Q55.** How much would you be willing to pay each month, in addition to your current electricity bill, to ensure that the plant burns the fuel that you prefer (**Q54**)?

Circle the dollar amount closest to the amount you would be willing to pay extra each month.

|          |          |          |          |          |          |
|----------|----------|----------|----------|----------|----------|
| \$0.00   | \$0.10   | \$0.25   | \$0.50   | \$0.75   | \$1.00   |
| \$1.25   | \$1.50   | \$2.00   | \$3.00   | \$4.00   | \$5.00   |
| \$6.00   | \$8.00   | \$11.00  | \$14.00  | \$19.00  | \$22.00  |
| \$26.00  | \$30.00  | \$35.00  | \$40.00  | \$45.00  | \$50.00  |
| \$55.00  | \$60.00  | \$70.00  | \$80.00  | \$90.00  | \$100.00 |
| \$110.00 | \$120.00 | \$140.00 | \$160.00 | \$220.00 | \$300.00 |

OTHER: \$ \_\_\_\_\_

## **ABOUT YOU AND YOUR HOUSEHOLD**

**PLEASE REMEMBER THAT ALL INFORMATION  
IS ENTIRELY CONFIDENTIAL**

**H1.** Your gender:

1. FEMALE
2. MALE

**H2.** Your age:

\_\_\_\_\_ YEARS

**H3.** Including yourself, how many members in your household are in each age group? (If none, write "0".)

\_\_\_\_\_ UNDER 18 YEARS OF AGE  
 \_\_\_\_\_ 18-35  
 \_\_\_\_\_ 35-60  
 \_\_\_\_\_ 60 AND OVER

**H5.** How would you describe your racial or ethnic background?  
(Circle one.)

1. WHITE OR CAUCASIAN
2. BLACK OR AFRICAN AMERICAN
3. HISPANIC OR MEXICAN AMERICAN
4. ASIAN OR PACIFIC ISLANDER
5. NATIVE AMERICAN INDIAN
6. OTHER - PLEASE SPECIFY: \_\_\_\_\_

**H4.** How many years of education have you completed?  
A high school education = 12 years.  
(Circle number of years.)

|    |    |    |    |    |    |     |
|----|----|----|----|----|----|-----|
| 6  | 7  | 8  | 9  | 10 | 11 | 12  |
| 13 | 14 | 15 | 16 | 17 | 18 | 19  |
| 20 | 21 | 22 | 23 | 24 | 25 | 25+ |

**H6.** What is your present employment status?  
(Circle the best answer.)

- |                        |                             |
|------------------------|-----------------------------|
| 1. LABORER             | 7. SERVICE EMPLOYEE         |
| 2. TEACHER             | 8. SELF-EMPLOYEED           |
| 3. FULL TIME HOMEMAKER | 9. STUDENT                  |
| 4. PROFESSIONAL        | 10. RETIRED                 |
| 5. GOVERNMENT EMPLOYEE | 11. UNEMPLOYED              |
| 6. SECRETARY/CLERICAL  | 12. OTHER - PLEASE SPECIFY: |
- 

**H7.** What is your total annual household income before taxes and other deductions?  
(Circle best answer.)

- |                      |                         |
|----------------------|-------------------------|
| 1. UNDER \$9,999     | 9. \$80,000 - 89,999    |
| 2. \$10,000 - 19,999 | 10. \$90,000 - 99,999   |
| 3. \$20,000 - 29,999 | 11. \$100,000 - 119,999 |
| 4. \$30,000 - 39,999 | 12. \$120,000 - 139,999 |
| 5. \$40,000 - 49,999 | 13. \$140,000 - 159,999 |
| 6. \$50,000 - 59,999 | 14. \$160,000 - 179,000 |
| 7. \$60,000 - 69,999 | 15. \$180,000 - 199,999 |
| 8. \$70,000 - 79,999 | 16. \$200,000 AND OVER  |

**H8.** How active have you been active in community related issues during the past two years?  
(Circle appropriate number.)

| NOT AT ALL<br>ACTIVE |   | SOMEWHAT<br>ACTIVE |   | VERY<br>ACTIVE |
|----------------------|---|--------------------|---|----------------|
| 1                    | 2 | 3                  | 4 | 5              |

**Appendix 4E**  
**Sector Definition**

| Sector | Name   | BEA Code          |
|--------|--|-------------------|
| 1      | Agriculture                                    | 1-4               |
| 2      | Iron Mining                                    | 5                 |
| 3      | Non-Iron Mining                                | 6                 |
| 4      | Other Mining                                   | 9,10              |
| 5      | Coal Mining                                    | 7                 |
| 6      | Petroleum Mining                               | 8                 |
| 7      | Construction                                   | 11,12             |
| 8      | Manufacturing                                  | 13-30,33,34,39-64 |
| 9      | Petroleum Refining                             | 41                |
| 10     | Plastics                                       | 32                |
| 11     | Glass  | 35                |
| 12     | Stone  | 36                |
| 13     | Steel  | 37                |
| 14     | Metal Manufacturing                            | 38                |
| 15     | Transportation                                 | 65                |
| 16     | Communication                                  | 66,67             |
| 17     | Electric Utilities                             | 68.01             |
| 18     | Gas Utilities                                  | 68.02             |
| 19     | Trade & Finance                                | 69,70             |
| 20     | Services (including Water & Sanitary Services) | 71-79,68.03       |

Notes: Sectors 5, 6, 9, 17, and 18 from the energy aggregate.