

Process Engineering Division

Transport Gasifier IGCC Base Cases

PED-IGCC-98-006

September 1998
Latest Revision June 2000



PREFACE

This report presents the results of an analysis of two Transport Gasifier IGCC Base Cases. The analyses were performed by W. Shelton and J. Lyons of EG&G.

EXECUTIVE SUMMARY

1. Process Descriptions
 - 1.1 Transport Gasifier
 - 1.2 Gasifier Oxidant Supply
 - 1.3 Chloride Guard Bed / Fine Particulate Removal
 - 1.4 Transport Desulfurization HGCU
 - 1.5 Sulfator
 - 1.6 Gas Turbine
 - 1.7 Steam Cycle
 - 1.8 Power Production
2. Simulation Development
3. Cost of Electricity Analysis
 - 3.1 Coal Preparation
 - 3.2 Limestone Handling and Receiving
 - 3.3 Oxygen Plant – Case 2
 - 3.4 Transport Gasifier
 - 3.5 Gas Conditioning
 - 3.6 Desulfurization Section
 - 3.7 Ash Handling/Disposal
 - 3.8 Sulfator
 - 3.9 Gas Turbine Section
 - 3.10 HRSG/Steam Turbine Section
 - 3.11 Bulk Plant Items

Appendix A COE Spreadsheets

Appendix B Modifications made to 1998 IGCC Process System Study

TRANSPORT HGCU GASIFIER IGCC BASE CASES

EXECUTIVE SUMMARY

ASPEN PLUS (version 10.1) Simulation Models and the Cost of Electricity (COE) have been developed for two IGCC cases based on the Transport gasification process. The objective was to establish base cases for commercially available (or nearly available) power plant systems having a nominal size of 400 megawatts (MWe). The simulation models are based on previous simulations (ASPEN Archive CMS Library), available literature information, and published reports. The COE estimates were based on data from the EG&G Cost Estimating Notebook and several contractor reports. These cases can be used as starting points for the development and analysis of proposed advanced power systems.

Both cases include the following process sections:

- Transport Gasifier with in-bed sulfur capture.
- Sulfator with the exhaust gas combined with the gas turbine exhaust.
- Chloride guard reactor and a Transport Desulfurizer hot gas cleanup section.
- □G□ gas turbine -W501G modified for coal derived fuel gas.
- Three pressure level subcritical reheat Steam Cycle
- (1800 psia/1050°F/342 psia/1050°F/ 35 psia).

The oxidant used in the gasifier accounts for the major difference between the cases. Case 1 is an air-blown gasifier system while Case 2 is an oxygen-blown system. The raw fuel gas cooler section following the gasifier (and integrated with the gasifier and other heat exchangers) is used for generating high-pressure superheated steam. This section is followed by a ceramic filter that captures particulates for recycle to the gasifier and a chloride guard bed. The fuel gas then enters a hot gas cleanup unit (HGCU) using a transport absorber/regenerator process. The sulfur dioxide rich waste stream from the HGCU is sent to a sulfator. Power is recovered for both cases using a modified W501G gas turbine and a three-pressure level reheat steam cycle.

Process flow diagrams and material and energy balances summaries are shown in Figures 1 - 4 and COE summaries are given in Appendix A. In Table 1 the overall results obtained for power generation, process efficiency, and COE are compared for the cases.

Table 1: Transport Gasifier IGCC Base Cases Summary

| | CASE 1 | CASE 2 |
|-------------------------------------|----------------------------|----------------------------|
| Gasifier | Transport Air-Blown | Transport Oxygen-Blown |
| Sulfur Removal | In-Bed Sulfur Capture/HGCU | In-Bed Sulfur Capture/HGCU |
| Gas Turbine Power (MWe) | 272.6 | 272.6 |
| Steam Turbine Power (MWe) | 162.6 | 142.4 |
| Misc./Ax Power (MWe) | -20.0 | -31.3 |
| Total Plant Power (MWe) | 415.4 | 383.7 |
| Efficiency, HHV (%) | 49.8 | 47.1 |
| Efficiency, LHV (%) | 51.7 | 48.8 |
| Total Capital Requirement, (\$1000) | 484,062 | 496,722 |
| \$/kW | 1165 | 1295 |
| Net Operating Costs (\$1000) | 45,388 | 47,294 |
| COE (mills/kWh) | 38.1 | 41.9 |




FIGURE 1A
 TRANSPORT GASIFIER/SULFATOR/HGCU/W501G GT
 (85% in-bed Sulfur Capture)

FIGURE 1B

TRANSPORT GASIFIER / SULFATOR / HGCU / W501G GT / 3 PRES LEVEL STEAM CYCLE

SUMMARY:

| POWER | MWe | EFFICIENCY | % |
|---------------|-------|------------|------|
| GAS TURBINE | 272.8 | HHV | 49.8 |
| STEAM TURBINE | 162.6 | LHV | 51.7 |
| MISCELLANEOUS | 7.2 | | |
| AUXILIARY | 12.8 | | |
| NET POWER | 415.4 | | |

| STREAM | 1 | 2 | 3 | 4 | 5 | 6 | 8 | 11 | 12 | 13 | 14 | 15 | 16 | 17 |
|-----------------|--------|--------|--------|--------|--------|--------|---------|---------|--------|--------|-------|--------|------|--------|
| FLOW (LB/HR) | 243937 | 228222 | 30634 | 77596 | 6484 | 657280 | 5775676 | 4781947 | 994045 | 994045 | 45884 | 948161 | 2294 | 954722 |
| TEMPERATURE (F) | 59 | 200 | 200 | 630 | 1338.2 | 650 | 1657.9 | 1647.9 | 1657.9 | 1004 | 1004 | 1004 | 1000 | 1000 |
| PRESSURE (PSIA) | 14.7 | 14.7 | 14.7 | 400 | 356 | 400 | 395.2 | 400 | 395.2 | 385.2 | 367 | 367 | 362 | 362 |
| H (MM BTU/HR) | 303.8 | 406.8 | -159.2 | -429.8 | -1.8 | 67.2 | -4864.1 | -4224.8 | -664.6 | -895 | -53.4 | -841.7 | -2.7 | -848.3 |

| STREAM | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 |
|-----------------|--------|--------|--------|--------|-------|-------|-------|-------|-------|--------|---------|---------|---------|---------|
| FLOW (LB/HR) | 121 | 954042 | 953588 | 14367 | 14367 | 14367 | 4310 | 8907 | 1149 | 944560 | 4084656 | 4611765 | 4320000 | 4320000 |
| TEMPERATURE (F) | 1047.9 | 997.6 | 1050 | 1047.9 | 450 | 490.3 | 565.3 | 565.3 | 565.3 | 1047.3 | 2584.2 | 1128 | 59 | 59 |
| PRESSURE (PSIA) | 337 | 357 | 347 | 337 | 327 | 375 | 750 | 750 | 750 | 336 | 268.5 | 15.2 | 14.7 | 14.6 |
| H (MM BTU/HR) | -0.1 | -848.4 | -852.3 | -12.9 | -15.7 | -15.5 | -4.5 | -9.4 | -1.2 | -845 | -565.2 | -2273 | -186.5 | -186.5 |

| STREAM | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 |
|-----------------|--------|--------|--------|---------|--------|--------|--------|------|--------|--------|--------|--------|---------|--------|
| FLOW (LB/HR) | 527109 | 527109 | 663316 | 3116096 | 663316 | 663316 | 663316 | 6036 | 111073 | 48299 | 110052 | 55803 | 4721818 | 555540 |
| TEMPERATURE (F) | 809.7 | 600 | 809.7 | 809.7 | 365.8 | 128 | 203 | 640 | 161.1 | 1005.1 | 1200 | 300 | 1129.7 | 465.8 |
| PRESSURE (PSIA) | 282.2 | 276.6 | 282.2 | 282.2 | 281.2 | 275 | 405 | 362 | 25 | 337 | 16 | 14.7 | 15.2 | 15.2 |
| H (MM BTU/HR) | 76.3 | 47.7 | 96 | 450.9 | 20.8 | -19.8 | -6.6 | 0.6 | -2.1 | -56.2 | -42.3 | -145.7 | -2315.3 | -373 |

| STREAM | 46 | 47 | 48 | 49 | 77 | 78 | 79 |
|-----------------|---------|--------|--------|---------|--------|-------|--------|
| FLOW (LB/HR) | 649300 | 72144 | 71697 | 1675038 | 70000 | 70000 | 24000 |
| TEMPERATURE (F) | 1030 | 1030 | 1338.2 | 1050 | 607.3 | 1050 | 602 |
| PRESSURE (PSIA) | 347 | 347 | 357 | 352 | 350 | 342 | 350 |
| H (MM BTU/HR) | -2233.1 | -248.1 | -248.7 | -3330.2 | -388.6 | -372 | -133.2 |




FIGURE 2A
TRANSPORT GASIFIER IGCC - STEAM CYCLE

FIGURE 3B

TRANSPORT GASIFIER / SULFATOR /HGCU /W501G GT /3 PRES LEVEL STEAM CYCLE
(O2-BLOWN, 85% GASIFIER SULFUR CAPTURE)

SUMMARY:

| POWER | MWe | EFFICIENCY | % |
|---------------|-------|------------|------|
| GAS TURBINE | 272.6 | HHV | 47.1 |
| STEAM TURBINE | 142.4 | LHV | 48.8 |
| MISCELLANEOUS | 19.4 | | |
| AUXILIARY | 11.9 | | |
| NET POWER | 383.7 | | |

| STREAM | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 |
|-----------------|--------|--------|--------|---------|--------|--------|--------|---------|-------|-------|---------|---------|---------|-------|
| FLOW (LB/HR) | 238434 | 223074 | 29943 | 211920 | 6477 | 147764 | 147764 | 5006006 | 74122 | 74122 | 4393306 | 612682 | 612682 | 42158 |
| TEMPERATURE (F) | 59 | 200 | 200 | 630 | 1290.6 | 60 | 180.3 | 1659.9 | 59 | 159.9 | 1650 | 1659.9 | 1004 | 1004 |
| PRESSURE (PSIA) | 14.7 | 14.7 | 14.7 | 400 | 356 | 92 | 400 | 395.2 | 14.7 | 25 | 400 | 395.2 | 385.2 | 367 |
| H (MM BTU/HR) | -0.8 | 119 | -155.6 | -1173.8 | -1.8 | -0.7 | 3 | -5825.7 | -3.1 | -1.3 | -4379.1 | -1465.9 | -1653.3 | -53.4 |

| STREAM | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 28 | 29 |
|-----------------|---------|-------|---------|--------|---------|---------|--------|-------|-------|-------|-------|-------|---------|---------|
| FLOW (LB/HR) | 570524 | 2108 | 579252 | 111 | 578587 | 578143 | 17498 | 17498 | 17498 | 5250 | 10849 | 1400 | 567183 | 4030258 |
| TEMPERATURE (F) | 1004 | 995.5 | 995.5 | 1079.5 | 992.5 | 1084.3 | 1079.5 | 487.1 | 549.4 | 549.4 | 549.4 | 549.4 | 1078.3 | 2582.2 |
| PRESSURE (PSIA) | 367 | 362 | 362 | 337 | 357 | 347 | 337 | 375 | 750 | 750 | 750 | 750 | 337 | 268.5 |
| H (MM BTU/HR) | -1599.9 | -2.7 | -1630.6 | -0.1 | -1630.6 | -1640.7 | -49.7 | -54.3 | -53.9 | -16.2 | -33.4 | -4.3 | -1611.3 | -1144.9 |

| STREAM | 30 | 31 | 32 | 33 | 34 | 35 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 |
|-----------------|---------|---------|--------|--------|--------|---------|--------|--------|--------|--------|-------|-------|--------|---------|
| FLOW (LB/HR) | 4557367 | 4320000 | 527109 | 527109 | 316809 | 3462603 | 310772 | 309448 | 620220 | 620220 | 44377 | 70424 | 54552 | 4627791 |
| TEMPERATURE (F) | 1136.6 | 59 | 812.7 | 600 | 812.7 | 812.7 | 59 | 203.6 | 512.8 | 190 | 1000 | 1200 | 300 | 1137.6 |
| PRESSURE (PSIA) | 15.2 | 14.6 | 282.2 | 276.6 | 282.2 | 282.2 | 14.7 | 280 | 280 | 277 | 335 | 16 | 14.7 | 15.2 |
| H (MM BTU/HR) | -2849.8 | -180.3 | 76.8 | 48 | 46.1 | 504.2 | -13 | 5.1 | 50.3 | 0.5 | -56.2 | -12 | -142.4 | -2861.8 |

| STREAM | 45 | 46 | 47 | 48 | 49 | 77 | 78 | B1 | B2 | B3 | B4 | W1 | W2 |
|-----------------|--------|---------|--------|--------|---------|--------|-------|-------|-------|-------|-------|--------|------|
| FLOW (LB/HR) | 548866 | 649300 | 72144 | 71705 | 1299592 | 70000 | 70000 | 6037 | 6037 | 6037 | 6037 | 469758 | 3551 |
| TEMPERATURE (F) | 461.5 | 1030 | 1030 | 1290.6 | 1084.3 | 607.3 | 1050 | 812.1 | 120 | 171.3 | 166.8 | 61.5 | 40 |
| PRESSURE (PSIA) | 15.2 | 347 | 347 | 357 | 352 | 350 | 342 | 280.2 | 275.2 | 371 | 362 | 91 | 58.5 |
| H (MM BTU/HR) | -442.1 | -2233.1 | -248.1 | -249.4 | -4113.2 | -388.6 | -372 | 0.9 | -0.2 | -0.1 | -0.1 | -5 | -0.1 |

FIGURE 4B

TRANSPORT GASIFIER / SULFATOR / HGCU / W501G GT / 3 PRES LEVEL STEAM CYCLE
(O2-BLOWN, 85% GASIFIER SULFUR CAPTURE)

STEAM CYCLE / HRSG STREAMS

| STREAM | 44 | 45 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 |
|-----------------|---------|--------|---------|---------|--------|---------|---------|---------|---------|---------|-------|-------|---------|---------|
| FLOW (LB/HR) | 4627791 | 548866 | 4078925 | 923678 | 254912 | 172898 | 733826 | 243795 | 254912 | 254912 | 11117 | 11006 | 172898 | 172898 |
| TEMPERATURE (F) | 1137.6 | 461.5 | 259.7 | 205 | 217.3 | 217.3 | 217.3 | 286 | 217.4 | 286 | 286 | 420 | 218.2 | 286 |
| PRESSURE (PSIA) | 15.2 | 15.2 | 15 | 17 | 16.3 | 16.3 | 16.3 | 76.3 | 80.3 | 76.3 | 76.3 | 68.9 | 410.6 | 390 |
| H (MM BTU/HR) | -2861.8 | -442.1 | -3499.7 | -6182.2 | -1703 | -1155.1 | -4902.5 | -1611.7 | -1702.9 | -1685.2 | -73.5 | -61.9 | -1154.8 | -1142.9 |

| STREAM | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 |
|-----------------|---------|--------|--------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| FLOW (LB/HR) | 172898 | 171169 | 171169 | 733826 | 733826 | 733826 | 224421 | 509405 | 509405 | 504311 | 504311 | 224421 | 728732 | 516812 |
| TEMPERATURE (F) | 420 | 432.3 | 620 | 221.1 | 286 | 420 | 420 | 420 | 620 | 629.3 | 1050 | 1050 | 1049.3 | 607.3 |
| PRESSURE (PSIA) | 370.5 | 352 | 350 | 2345.6 | 2228.3 | 2116.9 | 2116.9 | 2116.9 | 2011.1 | 1910.5 | 1815 | 1815 | 1800 | 350 |
| H (MM BTU/HR) | -1118.6 | -969.2 | -948.9 | -4895.9 | -4848.2 | -4746.2 | -1451.5 | -3294.7 | -3169.2 | -2885.5 | -2700.8 | -1201.9 | -3902.7 | -2868.8 |

| STREAM | 76 | 77 | 78 | 80 | 81 | 82 | 83 | 86 | 88 | 89 | 90 | 91 | 92 | 94 |
|-----------------|---------|--------|-------|---------|---------|---------|---------|---------|--------|---------|---------|---------|---------|-------|
| FLOW (LB/HR) | 211920 | 70000 | 70000 | 446811 | 617980 | 617980 | 687980 | 698985 | 53292 | 870385 | 645694 | 645694 | 870385 | 6934 |
| TEMPERATURE (F) | 638.3 | 607.3 | 1050 | 607.3 | 610.8 | 1050 | 1050 | 484.3 | 380.1 | 140.4 | 88.8 | 87.9 | 80.7 | 213 |
| PRESSURE (PSIA) | 400 | 350 | 342 | 350 | 350 | 342 | 342 | 35 | 20 | 19 | 0.7 | 0.7 | 20 | 15 |
| H (MM BTU/HR) | -1173.4 | -388.6 | -372 | -2480.3 | -3429.2 | -3284.4 | -3656.4 | -3906.4 | -300.4 | -5881.8 | -3771.8 | -4397.2 | -5933.6 | -43.5 |

| STREAM | 95 | 96 | 97 | 98 | 99 | G1 | G2 | G3 | G5 | G6 | G7 | G8 | G9 |
|-----------------|---------|-------|-------|-------|--------|---------|---------|---------|---------|---------|---------|---------|---------|
| FLOW (LB/HR) | 224692 | 5837 | 111 | 1729 | 5094 | 4627791 | 4627791 | 4627791 | 4627791 | 4627791 | 4078925 | 4078925 | 4078925 |
| TEMPERATURE (F) | 60 | 217.3 | 305.3 | 432.3 | 629.3 | 1137.6 | 887.7 | 690.4 | 573.8 | 461.5 | 342.5 | 332.9 | 259.7 |
| PRESSURE (PSIA) | 14.7 | 16.3 | 72.5 | 352 | 1910.5 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15 |
| H (MM BTU/HR) | -1536.4 | -33.4 | -0.7 | -11.2 | -31.6 | -2861.8 | -3191.2 | -3443.3 | -3589.1 | -3727.2 | -3412.2 | -3422.4 | -3499.7 |

1. Process Descriptions

Two IGCC Base Cases have been developed based on the Transport gasification process. The cases differ primarily in the oxidant used for the gasification section. Both cases use a raw gas cooler (which is integrated with the gasifier and other heat exchangers) to generate high pressure superheated steam and a ceramic filter to remove particulates, which are recycled to the gasifier. The syngas leaves the gas cooler at 1004°F for both Cases. The fuel gas enters a chloride guard bed that is followed by a hot gas cleanup unit (HGCU) using a transport absorber/regenerator process. The sulfur dioxide rich waste stream from the HGCU is sent to a sulfator. Power is recovered for both cases using a modified W501G gas turbine and a three-pressure level reheat steam cycle.

The composition for the as-received Illinois #6 Coal used in the process is listed below. This coal is dried to approximately 5 % moisture in the coal prep section before being fed to the gasifier.

| <u>Proximate</u> | | | <u>Ultimate</u> | | |
|------------------|----------------|---------------------|------------------|----------------|---------------------|
| <u>Analysis:</u> | <u>(Wt. %)</u> | <u>(Wt. %, dry)</u> | <u>Analysis:</u> | <u>(Wt. %)</u> | <u>(Wt. %, dry)</u> |
| Moisture | 11.12 | | Moisture | 11.12 | |
| Ash | 9.70 | 10.91 | Carbon | 63.75 | 71.72 |
| Volatiles | 34.99 | 39.37 | Hydrogen | 4.50 | 5.06 |
| Fixed Carbon | <u>44.19</u> | <u>49.72</u> | Nitrogen | 1.25 | 1.41 |
| | 100 | 100 | Chlorine | 0.29 | 0.33 |
| | | | Sulfur | 2.51 | 2.82 |
| HHV (Btu/lb) | 11,666 | 13,126 | Ash | 9.70 | 10.91 |
| | | | Oxygen | <u>6.88</u> | <u>7.75</u> |
| | | | | 100 | 100 |

The composition for the sorbent used for sulfur capture in the gasifier is:

| | <u>(Wt. %)</u> |
|-------|----------------|
| CaCO3 | 97.45 |
| MgCO3 | 1.58 |
| Inert | <u>0.97</u> |
| | 100.00 |

Additional features for the both cases are given in following sections. In Table 2, the processes used are compared.

Table 2 : Transport IGCC Base Cases Process Section Comparison

| PROCESS SECTION | CASE 1 | CASE 2 |
|--|--|-----------------------------|
| Gasifier Exit Temp / Press Oxidant | 1658 ° F/ 395 psia Air | 1656 °F/ 395 psia Oxygen |
| Solid Waste Particulates | Sulfator Cyclones, Ceramic Filters | same as Case 1 |
| Chloride/NH3 Removal | Chloride Guard Bed | same as Case 1 |
| Sulfur Removal | HGCU - Transport Desulfurization, Sulfator | same as Case 1 |
| Clean Fuel Gas / Gas Addition | Steam | None |
| Gas Turbine - Power (MWe): - PR / TIT (°F): | Modified W501G 272 (target) 19.37 / 2583 | same as Case 1 |
| Steam Cycle - Turb Press: HP/IP/LP - Superheat/Reheat - Exhaust LP Turb - HRSG Stack Temp | 3 Pressure Level/Reheat 1800 / 342 / 35 (psia) 1050°F/ 1050°F 0.67 psia 260 °F | same as Case 1 |

1.1 Transport Gasifier

The Transport Gasifier is a circulating-bed reactor concept, which uses finely pulverized coal and limestone that is proposed by M.W. Kellogg. The gasifier is currently in a development stage, which hopefully will lead to a commercial scale design. It is expected that the small particle size of the coal and limestone will result in a high level of sulfur capture. This may reduce or even eliminate the need for a hot gas cleanup section. Additionally, the small particle size will increase the throughput compared to a KRW gasifier, thereby potentially reducing the required number of gasifier trains (or the gasifier size) and the economic cost.

The Transport Gasifier is conceptually envisioned as consisting of a mixing section, a riser section and a solids recirculation section. The mixing section has a combustion zone and a coal devolatilization zone. The combustion zone is fed with recirculating solids (char, ash, sorbent), oxidant and steam. Sufficient char is burned to provide the heat necessary for the devolatilization of fresh coal and later gasification reactions. The fresh coal and sorbent are injected above the combustion zone and are rapidly heated by the circulating solids and combustion gases in a devolatilization zone. The resulting gas and entrained solids enter the riser section where additional residence time allows the char gasification, methane/steam reforming, water gas shift and sulfur capture reactions to occur. Following the riser section, a solids recirculation section, which includes primary and secondary cyclones, separates the solids into a standpipe system connected with the mixing section. The exiting fuel stream from the secondary cyclone is sent through a raw gas cooler where it is cooled to 1004°F. The heat recovered in the cooler is used in the generation and superheating of high-pressure steam for the steam cycle.

Case 2 differs from Case 1 in that oxygen is used as the oxidant. Because of the much lower flow rate of oxygen compared to air, additional steam is added to maintain the bed circulation and to control the temperature. The steam flowrate used for Case 2 was based on obtaining a maximum combustion zone temperature of approximately 2000°F. Figures 1 and 3 illustrate the gasification section and major process streams relationship to other process sections. In Table 3, gasifier conditions are listed for both of the Transport IGCC cases.

Table 3. Transport IGCC Base Cases - Gasifier Conditions

| | CASE 1 Air-Blown | CASE 2 Oxygen-Blown |
|-------------------------------------|---------------------|------------------------|
| Coal Flowrate (tons/day) | | |
| - to Prep Plant | 2927 | 2861 |
| - to Gasifier | 2739 | 2677 |
| Coal Moisture (wt. %) | | |
| - to Prep Plant | 11.12 | 11.12 |
| - to Gasifier | 5.00 | 5.00 |
| Gasifier Conditions | | |
| - Exit Pressure (psia) | 395 | 395 |
| - Exit Temp (°F) | 1658 | 1660 |
| - Max. Combustion Temp (°F) | 1873 | 1994 |
| - Ave Riser Temp (°F) | 1710 | 1723 |
| - Carbon Conversion (%) | 96.8 | 98.9 |
| - Sulfur Capture (%) | 85.0 | 85.0 |
| - Residence Time (sec) | 3.00 | 3.00 |
| Flowrates (lb/hr) | | |
| - Coal Feed | 228,222 | 223,074 |
| - Oxidant | 657,280 (Air) | 147,764 (95% O2) |
| - Steam | 77,596 | 211,920 |
| - Sorbent | 30,634 | 29,943 |
| - Solids Recycle | 4,781,947 | 4,393,306 |
| - Unrecycled Fines | 48,299 | 44,377 |
| - Raw Fuel Gas | 954,045 | 578,587 |
| Gasifier Flow Ratio: | | |
| - Oxidant/Coal | 2.880 | 0.662 |
| - Steam/Coal | 0.340 | 0.950 |
| - Sorbent/Coal | 0.134 | 0.134 |
| - Recycled Carbon/ Feed Carbon | 3.143 | 1.358 |
| - Recycled Solids/ Feed Solids | 18.47 | 17.364 |
| Heating Value(from gasifier) | | |
| - LHV (Btu/Scf) | 145 | 199 |

1.2 Gasifier Oxidant Supply

For both Case 1 and Case 2, the oxidant supply required for the gasifier is integrated with the W501G gas turbine. For Case 1, air is bled from the gas turbine compressor exhaust and sent to an air boost compressor. The boost compressor provides the air both for the gasifier and for the regenerator in the HGCU section.

For Case 2, an advanced high pressure cryogenic oxygen plant that takes advantage of the air (278 psia) extracted from the W501G gas turbine supplies oxygen (95% purity) to the gasifier. This advanced design is available due to recent improvements made to the conventional air separation technology which operates efficiently only to about an air supply pressure of 170 psia. The advanced ASU by operating at a higher pressure results in the oxygen and nitrogen products being available from the cold box at higher pressures than in a conventional ASU. This reduces costs for the further compression of these streams. For operational flexibility, (in startup and turndown), the present case considers that the air is supplied, in equal amounts (50%), from a bleed from the gas turbine compressor exhaust and as air supplied directly using a boost compressor. The nitrogen stream produced by the ASU is vented to the atmosphere or available for plant purge nitrogen. (Since a large amount of steam is used in the gasifier for Case 2, a nitrogen recycle to the gas turbine was not required to obtain the desired gas turbine power production of 272 MWe.) Table 4 lists some of the key parameters.

Table 4. Transport IGCC Base Cases - Oxidant Supply Summary

| | Case 1 Air-Blown | Case 2 Oxygen-Blown |
|--|---------------------|------------------------|
| Air to ASU | | |
| - % from Gas Turbine | N/A | 50 |
| - % from Boost Compressor | N/A | 50 |
| - Flowrate (lb/hr) | N/A | 620,220 |
| Air to Boost Compressor | | |
| - % from the Gas Turbine | 100 | N/A |
| - Flowrate (lb/hr) | 663,316 | N/A |
| Oxidant Stream to Gasifier | | |
| - Flowrate (lb/hr) | 657,280 | 147,764 |
| - Purity (mole % O ₂) | 20.7 | 95.0 |
| - ASU O ₂ Exit Press (psia) | N/A | 92 |
| - Pressure to Gasifier (psia) | 400 | 400 |
| Power Requirements (MWe) | | |
| - Boost Air Compressor* | 3.9 | 13.5 |
| - O ₂ Boost Compressor | N/A | 2.8 |

*(Case 1 uses a single stage for air sent to the gasifier, Case 2 uses a five stage intercooled compressor to supply 50% of the air required for the ASU (50%).)

1.3 Chloride Guard Bed / Fine Particulate Removal

The raw fuel gas exits the gas cooler (at 1004°F) and is sent to a cyclone and a gas filter to remove any particulates. This system cleans the gas, leaving the moisture content unchanged, and sends the stream to a chloride guard bed for hydrogen chloride removal. These guard beds containing commercial grade Nahcolite capture the chloride and any other halogens. The beds will require periodic treatment and operate with several on-line while others are being renewed. The resulting fuel gas stream is sent to the HGCU section for sulfur removal. An additional gas filter is used following the HGCU section to guard against any fine particulates left (or generated in HGCU) in the clean fuel gas sent to the gas turbine. A recycle of a small portion of clean fuel gas from the HGCU section is compressed and used for pressurizing gas filters.

1.4 Transport Desulfurization HGCU

The representation for this section was based on information provided by L. Bissett (FETC). FETC is currently developing an on-site (Morgantown) pilot plant to test this HGCU option for a number of sorbents. Since in-bed sulfur capture (85%) was used in the Transport Gasifier, this section serves as a polishing section for sulfur capture. In the HGCU section, the transport absorber operates at an inlet pressure of 357 psia. A zinc titanate sorbent is used. The reaction occurs as a simple exchange between the ZnO portion of the sorbent and the sulfur. The cleaned fuel gas exits and enters a gas filter to capture any particulates before being sent to the gas turbine combustor. (A small portion of the cleaned filtered fuel gas is recycled and pressurized for use in the gas filter.)

The absorber consists of a riser reaction section, a solids/gas separation vessel, and a solids return dipleg. The riser operates at a high void fraction of approximately 95 percent. The large amount of sorbent recirculation results in only a small change in the sorbent sulfur content through this section. A slip stream of approximately 10 percent of the sorbent stream exiting the separation vessel is sent to a regenerator riser, while the remaining portion is combined with regenerated sorbent and sent back for the next absorber cycle. The regenerator is assumed to remove only a portion of the absorbed sulfur. This removal matches the sulfur that is removed from the raw fuel gas that enters the absorber. Since only a small amount of sulfur reacts, the regenerator exit temperature can be controlled to a value less than 1400°F by adjusting the amounts of air (from GT) used. In both cases, the regenerator waste gas stream is sent to the sulfator for disposal. HGCU conditions are listed in Table 5.

1.5 Sulfator

Any SO₂ in the regeneration waste gases, along with any calcium sulfide in the solids from the gasifier, react in the sulfator to form calcium sulfate. Additionally, any unconverted carbon

remaining in these streams is oxidized to CO₂. The solid stream, now in an environmentally acceptable form, is cooled for disposal. The sulfator is operated at low pressure (25 psia) with sufficient excess air (10 - 20% excess) supplied directly using an air blower. Heat recovered in the sulfator section is used to generate steam. The exhaust gas from the sulfator is added to the exhaust gas from the gas turbine before entering the steam cycle.

Table 5. Transport Gasifier IGCC Base Case - HGCU Conditions

| Sulfur Balance Information: | | | | |
|---|----------------------|----------------------|-----------------|---------------------|
| Flowrate (lb/hr) | CASE 1 | | CASE 2 | |
| Sulfur in Raw Fuel Gas | 917.16 | | 896.54 | |
| Sulfur in Regenerator Waste | 892.98 | | 877.24 | |
| Sulfur in Clean Fuel Gas | 12.73 | | 9.52 | |
| (ASPEN Convergence Error Sulfur %) | 1.2 | | 1.09 | |
| PPMV of Sulfur in Raw Fuel Gas | 717.8 | | 944.0 | |
| PPMV of Sulfur in Clean Fuel Gas | 9.9 | | 9.9 | |
| HGCU Sulfur Capture Eff. (weight %) | 97.4 | | 97.8 | |
| Mole % SO ₂ in Regenerator Waste | 14.3 | | 14.0 | |
| Regenerator Exit Gas Temp (°F) | 1338 | | 1291 | |
| Regenerator Air Temp (°F) | 640 | | 167 | |
| HGCU Solids: | | | | |
| | Case 1 | | Case 2 | |
| | Flowrate | Utilization* | Flowrate | Utilization* |
| | (1000 lbs/hr) | (1000 lbs/hr) | | |
| To Absorber Rise | 721.00 | 0.4435 | 721.00 | 0.4436 |
| From Absorber Separator | 721.44 | 0.4500 | 721.44 | 0.4500 |
| To Regenerator Riser | 72.14 | 0.4500 | 72.14 | 0.4500 |
| From Regenerator Separator | 71.70 | 0.3849 | 71.71 | 0.3861 |
| Ratio: Solids | | | | |
| - to Absorber/to Regenerator | 9.99 | | 9.99 | |

* Sorbent utilization = moles of ZnS/total moles of ZnX compounds

1.6 Gas Turbine

Both cases were based on using a modified W501G gas turbine. In Case 1 (air-blown gasifier), 15.2% of the compressor discharges is sent to a boost compressor to provide air for the transport gasifier and the HGCU regenerator. In Case 2 (oxygen-blown gasifier), 7.5% of the compressor discharge is used to furnish 50% of the high pressure inlet air for the air

separation plant (ASU) and all of the air for the HGCU regenerator. For both Case 1 and Case 2, an additional bleed, 14% of the compressor discharge air, is chilled to 600°F and used for cooling in the turbine expander. Heat recovered from the air cooler is used in the steam cycle. The remainder of the compressor discharge air is used to combust the clean fuel gas. For Case 1, steam is added to increase the flowrate and the power generated in the turbine expander. The steam flowrate is set by requiring that the gas turbine power generated equals approximately 272 MWe. For Case 2, no additional gas (either steam or nitrogen from the ASU) was required to obtain the desired gas turbine power. This is due to a large amount of steam being added directly to the gasifier which is still in the fuelgas stream. In both Case 1 and Case 2, combustor duct cooling is accomplished using intermediate pressure steam supplied from the steam bottoming cycle. This reheated steam is returned to the steam cycle. The combustor exhaust gases enter the expander (2583°F, 269 psia), where energy is recovered to produce power.

The original turbine design specifications are based on a natural gas fuel rather than a coal derived syngas. The syngas’s significantly lower heating value when compared to natural gas requires a higher flow rate to obtain the desired turbine firing temperature. To allow for the higher flow rate, an increase in the first nozzle areas will be required. The original combustor will also be replaced with a modified design to handle the lower BTU syngas. In the cases considered, the syngas composition varies depending on the fuel processing prior to the gas turbine and the amount of steam added. In Table 6, the fuel gas composition for each case is listed. In Table 7, the gas turbine conditions are listed for the both Cases.

Table 6. Transport IGCC Base Cases - Fuel Gas Composition (Mole %)

| Transport Gas Cleaning | CASE 1 Air-Blown | CASE 2 Oxygen-Blown |
|--------------------------------------|-------------------------|----------------------------|
| Mole %: | | |
| N ₂ | 44.84 | 0.66 |
| Ar | 0.53 | 0.46 |
| H ₂ | 19.35 | 38.51 |
| CO | 21.11 | 19.26 |
| CO ₂ | 9.03 | 21.66 |
| H ₂ O | 2.63 | 16.36 |
| CH ₄ | 2.46 | 3.02 |
| H ₂ S/COS | 9.5 ppmv | 9.9 ppmv |
| NH ₃ | 0.05 | 0.07 |
| Heating Value (HHV) (Btu/Scf) | 155 | 217 |

Table 7. Transport IGCC Base Cases - W501G Gas Turbine Conditions

| Transport Gas Cleaning | CASE 1 Air-Blown | CASE 2 Oxygen-Blown |
|--------------------------------|-------------------------|----------------------------|
| Pressure (psia) | | |
| - to Filter | 14.7 | *(Same as Case 1) |
| - Compressor inlet | 14.57 | |
| - Compressor outlet | 282 | * |
| - Combustor exit | 269 | * |
| - Expander exhaust | 15.2 | * |
| Pressure Ratio | 19.4 | * |
| Flowrates (lb/hr) | | |
| - Compr inlet Air | 4,320,000 | * |
| - Fuel Gas | 944,560 | 576,183 |
| - Steam | 24,000 | N/A |
| - Bleed Air to Gasifier | 657,280 | N/A |
| - Bleed Air to HGCU | 6,036 | 6,037 |
| - Bleed Air to ASU | N/A | 310,772 |
| - Air Cooling Bleed | 527,109 | * |
| - Air Compr Leakage | 13,478 | * |
| - Steam Combustor Duct Cooling | 70,000 | * |
| - Expander Exhaust | 4,611,765 | 4,557,367 |
| - Gas to HRSG | 4,721,818 | 4,627,791 |
| Temperature (°F) | | |
| - Inlet Air | 59 | * |
| - Compressor outlet | 810 | * |
| - Steam | 602 | N/A |
| - Fuel Gas | 1047 | 1078 |
| - Combustor exhaust | 2613 | 2611 |
| - Turbine inlet | 2584 | 2582 |
| - Turbine exhaust | 1128 | 1137 |
| Power (MWe) | | |
| - Compressor | -237.8 | -237.2 |
| - Expander | 514.5 | 513.7 |
| - Generator Loss | -3.9 | -3.9 |
| - Net Gas Turbine | 272.8 | 272.6 |

1.7 Steam Cycle

The steam cycle used for the Cases is based on a design by D. Turek (ABB Power Plant Laboratories). Pressure drops and steam turbine isentropic efficiencies were based on information from a study by Bolland¹. The cycle is a three-pressure level reheat process. Major components include a heat recovery steam generator (HRSG), steam turbines (high, intermediate, and low pressure), condenser, steam bleed for gasifier steam, steam bleed for gas turbine cooling, recycle water heater, and deaerator. The major difference between Case 1 and Case 2 is related to the amount of steam bleed for the transport gasifier. Case 1 (air-blown gasifier) uses 0.34 lb Steam/lb Coal, while in Case 2 (oxygen-blown gasifier) steam usage increases to 0.95 lb Steam/lb Coal. This results in the net steam power generation being reduced by 20.2 MWe in Case 2 when compared to Case 1. An additional difference is that steam is sent to the gas turbine combustor (24,000 lb/hr at 350 psia) to increase the mass flowrate in the expander to obtain the target of 272 MWe for the gas turbine power production.

In Figures 2 and 4 the steam cycle and process flows are provided for the cases. The primary heat recovered is from the exhaust gas stream of the gas turbine, the sulfator section, and the syngas cooler for the raw fuel gas exiting the gasifier. Additionally, heat is integrated from the gas turbine cooling air chiller, from recycle gas coolers, and from several gasifier island gas coolers. Steam generation occurs at the three pressure levels of 72.5 psia, 353 psia, and 1911 psia in the HRSG. The cycle includes a parallel superheating/reheating section that raises the temperature to 1050°F for both the high-pressure steam and for the combined intermediate pressure steam and high-pressure turbine exhaust steam. Gasifier steam is provided using a bleed from the HP turbine at a pressure of 400 psia. Steam for the gas turbine combustor duct cooling is extracted from the HP turbine at a pressure of 350 psia. The return steam from the gas turbine combustor is combined with reheat steam and sent to the IP steam turbine. The LP steam turbine discharges at 89°F and 0.67 psia. The steam cycle conditions are summarized in Table 8.

¹

“A Comparative Evaluation of Advanced Combined Cycle Alternatives,” Transactions of the ASME, April 1991.

Table 8. Transport IGCC Base Cases - Steam Cycle Conditions

HRSG Stack Gas Temperature: 260 °F
 Deaerator Vent: 0.5% of inlet flowrate
 LP,IP, and HP drum blowdown: 1.0% of inlet flowrate
 Pressure drops: 5% of inlet (except IP superheater - 2 psia and line
 Drop before HP turbine - 15 psia)
 High Pressure Turbine Inlet: 1800 psia / 1050 °F
 Intermediate Pressure Turbine Inlet: 342 psia / 1050 °F
 Low Pressure Turbine Inlet: 35 psia
 Low Pressure Turbine Exhaust: 0.67 psia

| Pressure Level | Steam Conditions | | HRSG Approach | |
|----------------|------------------|----------------------|------------------------|------------------------|
| | Pressure (psia) | Saturation Temp (°F) | Delta Temp (°F) CASE 1 | Delta Temp (°F) CASE 2 |
| Low | 72.5 | 305 | 30 | 28 |
| Intermediate | 352 | 432 | 34 | 30 |
| High | 1911 | 629 | 62 | 61 |

| Power Production (MWe) | CASE 1 Air-Blown | CASE 2 Oxygen-Blown |
|------------------------|------------------|---------------------|
| Steam Turbines | 165.1 | 144.6 |
| Generator Loss | -2.5 | -2.1 |
| Net Steam Turbines | 162.6 | 142.4 |
| Pump | -2.1 | -2.2 |

1.8 Power Production

An auxiliary power consumption is assumed as 3 percent of the total power production by the Gas Turbine and the Steam Turbines minus the power consumed by the miscellaneous pumps, expanders, compressors, and blowers. The power production and the overall process efficiency are listed in Table 9 for the both Transport IGCC cases.

Table 9. Transport IGCC Base Cases - Power Production

| | CASE 1 | CASE 2 |
|--------------------------------------|------------------|---------------------|
| | Air-Blown | Oxygen-Blown |
| Gas Turbine (MWe) | 272.8 | 272.6 |
| Steam Turbine (MWe) | 162.6 | 142.4 |
| Miscellaneous (MWe) | -7.2 | -19.4 |
| Auxiliary (MWe) | -12.8 | -11.9 |
| Plant Total (MWe) | 415.4 | 383.7 |
| Overall Process Efficiency (HHV, %): | 49.8 | 47.1 |
| Overall Process Efficiency (LHV, %): | 51.7 | 48.8 |

2. Simulation Development

The major question in the simulation development was the representation of the transport gasification process that is currently in the research stage and is not commercially available. The model used was developed by (S. Venkatesan and M. Jarvis, EG&G, 1995) and is a Fortran code that is incorporated into the ASPEN simulations as a “USER” block. This code was validated using limited data made available from M. W. Kellogg (MWK):

- Pressurized Fluid-Bed Combustion Alternative Advanced Concepts, MWK, Final Report, DOE/MC/25000-2934.
- Gasification & Combustion of Coals and Chars in Kellogg’s Transport Reactor Test Unit (TRTU). MWK, Test Report, Vol. 1 Results & Discussion, DOE/DE-FC21-90MC25140.
- Private Communication, MWK, August-October 1994. (See “Transport Reactor Model, Topical Report” by S.Venkatesan & M. Jarvis, 1995, DOE/DE-AC21-90MC26328)

The models for the gas turbine (W501G) and the steam cycle were based on previously developed ASPEN simulations. The remaining process sections (i.e. HGCU, CGCU, Acid Plant) were based on representations available in a number of earlier studies. A search of the ASPEN Archive CMS Library will provide example cases for these process sections.

The ASPEN PLUS (version 10.1) simulation codes are stored in the EG&G’s Process Engineering Team Library.

3. Cost of Electricity Analysis

The cost of electricity for the Transport cases was performed using data from the EG&G Cost Estimating notebook and several contractor reports. The format follows the guidelines set by EPRI TAG. Details of the individual section costs are described below and are based on capacity-factored techniques. The COE spreadsheets are included in Appendix A. All costs are reported in 1st Quarter 1999 dollars.

3.1 Coal Preparation

The coal preparation section includes costs for the receiving, conveying, pulverizing and drying systems. The coal flow rate in Case 1 is 2927 tons per day (Illinois #6 coal), resulting in a section cost of \$16.7 million. The coal flow rate for Case 2 is 2861 tons per day, resulting in a cost of \$16.4 million.

3.2 Limestone Handling and Receiving

The cost for the limestone handling and receiving section includes hoppers, feeders, conveyors and storage silos. The limestone flow rate is 368 tons/day in Case 1, resulting in a cost of \$6.8 million. For Case 2, the limestone flow rate is 358 tons/day, with a resulting cost of \$6.7 million.

3.3 Oxygen Plant

The cost for the oxygen plant includes the air separation unit, the air precoolers, the oxygen compressors, and the air compressors. The system uses a high-pressure air separation unit. The oxygen plant for Case 2 produces 1773 tons per day oxygen with a total cost of \$35.7 million.

3.4 Transport Gasifier

The cost for the gasification section includes the gasifier and the raw gas cooler. Case 1, with 2 gasifier trains, has a cost of \$57.6 million. No similar case was found for the oxygen-blown case and the cost was scaled based on the volumetric flow rate of gas entering the gasifier. Case 2, also with 2 process trains, has a cost of \$44.0 million. A process contingency of 20 percent was added to the total plant cost based on the development of the gasifier.

3.5 Gas Conditioning

The gas conditioning section includes cyclone, two gas filters and chloride guard beds. The cost for Case 1 is \$20.2 million and is based on 2 process trains. The cost for Case 2 is \$16.3 million and is based on 2 process trains. A process contingency of 15% was added to the total plant cost based on the development of the gas conditioning components.

3.6 Desulfurization Section

The cost for the transport desulfurization section was derived from a previous report². This includes costs for sorbent hoppers, transport desulfurizer and cyclones. The amount of sorbent used was based information from the Separations and Gasification Engineering Division of NETL. The cost for the HGCU for Case 1 is \$13.6 million and is based on 2 process trains. The cost for the HGCU for Case 2 is \$12.1 million and is based on 2 process trains. A process contingency of 15% was added to the total plant cost based on the development of the desulfurization sections.

3.7 Ash Handling/Disposal

The cost for the ash handling and disposal includes conveyors, separators and storage silo. Case 1 has an ash flow of 664 tons/day, resulting in the cost of \$4.7 million. Case 2 has an ash flow of 653 tons/day, resulting in the cost of \$4.7 million.

3.8 Sulfator

The cost for the sulfator includes hoppers, feeder, sulfator, cyclones and fines combustor. The total cost for Case 1 is \$13.7 million. The total cost for Case 2 is \$11.4 million. A process contingency of 15% was added to the total plant cost based on the development of the sulfation section.

3.9 Gas Turbine Section

The cost for the W501G gas turbine was derived from the Gas Turbine World 96 Handbook³. The cost from the handbook was \$185/kW and included all the basic turbine components. A factor of 7% was added for modifications and installation. The gas turbine powers of 272.8 MW_e and 272.6 MW_e, for Case 1 and Case 2, respectively, resulted in an approximate cost of \$54 million. A process contingency of 5% was added to the total plant cost based on the development of the modified gas turbines.

² □Advanced Technology Repowering,□ Final Report, Prepared for the U.S. Department of Energy, Morgantown Energy Technology Center, Prepared by Parsons Power Group, Inc. May 1997

³ Gas Turbine World Performance Specifications, annual issue, Pequot Publishing Inc., Fairfield Connecticut.

3.10 HRSG/ Steam Turbine Section

The cost for the steam cycle is based on a three-pressure level steam cycle. Case 1 steam turbine power is 162.6 MW_e, with a combined section cost of \$47.2 million. Case 2 steam turbine power is 142.4 MW_e, with a combined section cost of \$44.2 million.

3.11 Bulk Plant Items

Bulk plant items include water systems, civil/structural/architectural, piping, control and instrumentation, and electrical systems. These were calculated based on a percentage of the total installed equipment costs. The following percentages were used in this report.

| <u>Bulk Plant Item</u> | <u>% of Installed Equipment Cost</u> |
|--------------------------------|--------------------------------------|
| Water Systems | 5.1 |
| Civil/Structural/Architectural | 9.2 |
| Piping | 5.1 |
| Control and Instrumentation | 2.6 |
| <u>Electrical Systems</u> | <u>8.0</u> |
| Total | 30.0 |

Table 10, Table 11, and Table 12 show the assumptions used in this COE analysis. The total capital requirement for Case 1 is \$484,062,000 or \$1165/kW, compared to \$496,722,000 or \$1295/kW for Case 2. The levelized cost of electricity for Case 1 in constant dollars is 38.1 mills/kWh, compared to 41.9 mills/kWh for Case 2.

Table 10. Capital Cost Assumptions

| | |
|---------------------------------|--------------------------|
| Engineering Fee | 10% of PPC* |
| Project Contingency | 15% of PPC |
| Construction Period | 4 Yrs |
| Inflation Rate | 3% |
| Discount Rate | 11.2% |
| Prepaid Royalties | 0.5% of PPC |
| Catalyst and Chemical Inventory | 30 Dys |
| Spare Parts | 0.5% of TPC** |
| Land | 200 Acres @ \$6,500/Acre |
| <u>Start-Up Costs</u> | |
| Plant Modifications | 2% of TPI*** |
| Operating Costs | 30 Dys |
| Fuel Costs | 7.5 Dys |
| <u>Working Capital</u> | |
| Coal | 60 Dys |
| By-Product Inventory | 30 Dys |
| O&M Costs | 30 Dys |

- * PPC = Process Plant Cost
- ** TPC = Total Plant Cost
- *** TPI = Total Plant Investment

Table 11. Operating & Maintenance Assumptions

Consumable Material Prices

| | |
|---|------------------|
| Illinois #6 Coal | \$29.40/Ton |
| Raw Water | \$0.19 /Ton |
| MDEA Solvent | \$1.45/Lb |
| Claus Catalyst | \$470/Ton |
| SCOT Activated Alumina | \$0.067/Lb |
| Sorbent | \$6,000/Ton |
| Nahcolite | \$275/Ton |
| Off-Site Ash/Sorbent Disposal Costs | \$8.00/Ton |
| Operating Royalties | 1% of Fuel Cost |
| Operator Labor | \$34.00/hour |
| Number of Shifts for Continuous Operation | 4.2 |
| Supervision and Clerical Labor | 30% of O&M Labor |
| Maintenance Costs | 2.2% of TPC |
| Insurance and Local Taxes | 2% of TPC |
| Miscellaneous Operating Costs | 10% of O&M Labor |
| Capacity Factor | 85% |

Table 12. Investment Factor Economic Assumptions

| | | | |
|---------------------------------------|--------------|------------|--------------------|
| Annual Inflation Rate | | | 3% |
| Real Escalation Rate (over inflation) | | | |
| O&M | 0% | | |
| Coal | | | -1.1% |
| Discount Rate | | | 11.2% |
| Debt | 80% of Total | 9.0% Cost | 7.2% Return |
| Preferred Stock | 0% of Total | 0.0% Cost | 0% Return |
| Common Stock | 20% of Total | 20.0% Cost | <u>4.0% Return</u> |
| | | | 11.2% Total |
| Book Life | | | 20 Yrs |
| Tax Life | | | 20 Yrs |
| State and Federal Tax Rate | | | 38% |
| Investment Tax Credit | | | 0% |
| Number of Years Levelized Cost | | | 10 Yrs |

Appendix A

Air-Blown Transport HGCU IGCC CASE 1

415 MW POWER PLANT
1st Q 1999 Dollar

| Total Plant Investment | | PROCESS | PROCESS | COST, K\$ |
|--|--------------------------------|--------------------------|-----------|------------|
| AREA NO | PLANT SECTION DESCRIPTION | CONT, % | CONT, K\$ | W/O CONT |
| 11 | Coal Preparation | 0 | \$0 | \$16,686 |
| 11 | Limestone Receiving/Handling | 0 | \$0 | \$6,809 |
| 12 | Transport Gasifier (2) | 20 | \$11,522 | \$57,609 |
| 12 | Recycle Gas Compression (2) | 5 | \$76 | \$1,520 |
| 12 | Air Boost Compressor | 0 | \$0 | \$6,808 |
| 14 | Gas Conditioning (2) | 15 | \$3,032 | \$20,216 |
| 14 | Transport Desulfurizer (2) | 15 | \$2,035 | \$13,565 |
| 15 | Gas Turbine System | 5 | \$2,707 | \$54,136 |
| 15 | HRSG/Steam Turbine | 0 | \$0 | \$47,192 |
| 16 | Ash Handling System | 0 | \$0 | \$4,722 |
| 16 | Sulfator | 15 | \$2,061 | \$13,738 |
| 18 | Water Systems | 0 | \$0 | \$11,452 |
| 30 | Civil/Structural/Architectural | 0 | \$0 | \$20,658 |
| 40 | Piping | 0 | \$0 | \$11,452 |
| 50 | Control/ Instrumentation | 0 | \$0 | \$5,838 |
| 60 | Electrical | 0 | \$0 | \$17,963 |
| Subtotal, Process Plant Cost | | | | \$310,364 |
| Engineering Fees | | | | \$31,036 |
| Process Contingency (Using cont. listed) | | | | \$21,433 |
| Project Contingency, | 15 | % Proc Plt & Gen Plt Fac | | \$46,555 |
| Total Plant Cost (TPC) | | | | \$409,388 |
| Plant Construction Period, | 4.0 | Years (1 or more) | | |
| Construction Interest Rate, | 11.2 | % | | |
| Adjustment for Interest and Inflation | | | | \$51,390 |
| Total Plant Investment (TPI) | | | | \$460,778 |
| Prepaid Royalties | | | | \$1,552 |
| Initial Catalyst and Chemical Inventory | | | | \$508 |
| Startup Costs | | | | \$11,428 |
| Spare Parts | | | | \$2,047 |
| Working Capital | | | | \$6,449 |
| Land, | 200 | Acres | | \$1,300 |
| Total Capital Requirement (TCR) | | | | \$484,062 |
| | | | | \$/kW 1165 |

ANNUAL OPERATING COSTS – CASE 1

| | | | | |
|-----------------------------|-------|-----------------|---------------------------------|-----------------------|
| Capacity Factor = | 85 | % | | |
| COST ITEM | | QUANTITY | UNIT \$ | ANNUAL |
| Coal (Illinois #6) | 2,927 | T/D | \$29.40 /T | COST, K\$ \$26,698 |
| Consumable Materials | | | | |
| Water | 1,072 | T/D | \$0.19 /T | \$63 |
| HGCU Sorbent | 0.13 | T/D | \$6,000 /T | \$238 |
| Limestone | 367.6 | T/D | \$16.25 /T | \$1,853 |
| Nahcolite | 2.4 | T/D | \$275 /T | \$205 |
| Ash/Sorbent Disposal Costs | 664 | T/D | \$8.00 /T | \$1,647 |
| Plant Labor | | | | |
| Oper Labor (incl benef) | 14 | Men/shift | \$34.00 /Hr. | \$4,158 |
| Supervision & Clerical | | | | \$2,328 |
| Maintenance Costs | 2.2% | | | \$9,007 |
| Royalties | | | | \$267 |
| Other Operating Costs | | | | \$776 |
| | | | Total Operating Costs | \$45,388 |
| By-Product Credits | | | | |
| | 0.0 | T/D | \$0.00 /T | \$0 |
| _____ | 0.0 | T/D | \$0.00 /T | \$0 |
| _____ | 0.0 | T/D | \$0.00 /T | \$0 |
| _____ | 0.0 | T/D | \$0.00 /T | \$0 |
| | | | Total By-Product Credits | \$0 |
| | | | Net Operating Costs | \$45,388 |

BASES AND ASSUMPTIONS – CASE 1

A. CAPITAL BASES AND DETAILS

| | | QUANTITY | UNIT \$ PRICE | COST, K\$ |
|------------------------------|----|---------------------------------------|------------------|-----------|
| Initial Cat./Chem. Inventory | | | | |
| Water | | 27336 T | \$0.19 /T | \$5 |
| HGCU Sorbent | | 56 T | \$6,000 /T | \$334 |
| Limestone | | 9374 T | \$16.25 /T | \$152 |
| Nahcolite | | 61 T | \$275 /T | 17 |
| | | Total Catalyst and Chemical Inventory | | \$508 |
| Startup costs | | | | |
| Plant modifications, | 2 | % TPI | | \$9,216 |
| Operating costs | | | | \$1,567 |
| Fuel | | | | \$645 |
| | | Total Startup Costs | | \$11,428 |
| Working capital | | | | |
| Fuel & Consumables inv | 60 | days supply | | \$5,619 |
| By-Product inventory | 30 | days supply | | \$0 |
| Direct expenses | 30 | days | | \$829 |
| | | Total Working Capital | | \$6,449 |

B. ECONOMIC ASSUMPTIONS

| | | | | | |
|--|-------|----------------|--------|-----------------|--------|
| Project life | 20 | Years | | | |
| Book life | 20 | Years | | | |
| Tax life | 20 | Years | | | |
| Federal and state income tax rate | 38.0 | % | | | |
| Tax depreciation method | | MACRS | | | |
| Investment Tax Credit | 0.0 | % | | | |
| Financial structure | | | | | |
| | % of | Current Dollar | | Constant Dollar | |
| Type of Security | Total | Cost, % | Ret, % | Cost, % | Ret, % |
| Debt | 80 | 9.0 | 7.25.8 | 4.6 | |
| Preferred Stock | 0 | 3.0 | 0.00.0 | 0.0 | |
| Common Stock | 20 | 20.0 | 4.0 | 16.5 | 3.3 |
| Discount rate (cost of capital) | | | 11.2 | | 7.9 |
| Inflation rate, % per year | | 3.0 | | | |
| Real Escalation rates (over inflation) | | | | | |
| Fuel, % per year | | | -1.1 | | |
| Operating & Maintenance, % per year | | 0.0 | | | |

C. COST OF ELECTRICITY – CASE 1

The approach to determining the cost of electricity is based upon the methodology described in the Technical Assessment Guide, published by the Electric Power Research Institute. The cost of electricity is stated in terms of 10th year levelized dollars.

| | Current \$ | Constant \$ |
|----------------------------------|------------|-------------|
| Levelizing Factors | | |
| Capital Carrying Charge, 10th yr | 0.179 | 0.148 |
| Fuel, 10th year | 1.091 | 0.948 |
| Operating & Maintenance, 10th yr | 1.151 | 1.000 |
| | | |
| Cost of Electricity - Levelized | mills/kWh | mills/kWh |
| Capital Charges | 28.0 | 23.2 |
| Fuel Costs | 9.4 | 8.2 |
| Consumables | 1.5 | 1.3 |
| Fixed Operating & Maintenance | 5.2 | 4.5 |
| Variable Operating & Maintenance | 0.9 | 0.8 |
| By-product | 0.0 | 0.0 |
| | | |
| Total Cost of Electricity | 45.1 | 38.1 |

| | | | | |
|--|--------------------------------|--------------------------|-----------|-------------------|
| Oxygen-Blown Transport HGCU IGCC CASE 2 | | | 384 | MW POWER PLANT |
| | | | | 1st Q 1999 Dollar |
| Total Plant Investment | | PROCESS | PROCESS | COST, K\$ |
| AREA NO | PLANT SECTION DESCRIPTION | CONT, % | CONT, K\$ | W/O CONT |
| 11 | Coal Preparation | 0 | \$0 | \$16,421 |
| 11 | Limestone Receiving/Handling | 0 | \$0 | \$6,695 |
| 12 | Oxygen Plant | 0 | \$0 | \$35,695 |
| 12 | Transport Gasifier (2) | 20 | \$8,807 | \$44,036 |
| 12 | Recycle Gas Compression (2) | 5 | \$102 | \$2,037 |
| 14 | Gas Conditioning (2) | 15 | \$2,441 | \$16,273 |
| 14 | Air Boost Compressor | 0 | \$0 | \$173 |
| 14 | Transport Desulfurizer (2) | 15 | \$1,821 | \$12,137 |
| 15 | Gas Turbine System | 5 | \$2,705 | \$54,096 |
| 15 | HRS/Steam Turbine | 0 | \$0 | \$44,156 |
| 16 | Ash Handling System | 0 | \$0 | \$4,679 |
| 16 | Sulfator | 15 | \$1,710 | \$11,400 |
| 18 | Water Systems | 0 | \$0 | \$12,638 |
| 30 | Civil/Structural/Architectural | 0 | \$0 | \$22,797 |
| 40 | Piping | 0 | \$0 | \$12,638 |
| 50 | Control/ Instrumentation | 0 | \$0 | \$6,443 |
| 60 | Electrical | 0 | \$0 | \$19,824 |
| Subtotal, Process Plant Cost | | | | \$322,139 |
| Engineering Fees | | | | \$32,214 |
| Process Contingency (Using cont. listed) | | | | \$17,585 |
| Project Contingency, | 15 | % Proc Plt & Gen Plt Fac | | \$48,321 |
| Total Plant Cost (TPC) | | | | \$420,259 |
| Plant Construction Period, | 4.0 | Years (1 or more) | | |
| Construction Interest Rate, | 11.2 | % | | |
| Adjustment for Interest and Inflation | | | | \$52,755 |
| Total Plant Investment (TPI) | | | | \$473,013 |
| Prepaid Royalties | | | | \$1,611 |
| Initial Catalyst and Chemical Inventory | | | | \$432 |
| Startup Costs | | | | \$11,891 |
| Spare Parts | | | | \$2,101 |
| Working Capital | | | | \$6,373 |
| Land, | 200 | Acres | | \$1,300 |
| Total Capital Requirement (TCR) | | | | \$496,722 |
| | | | | \$/kW |
| | | | | 1295 |

ANNUAL OPERATING COSTS – CASE 2

| | | | | |
|-----------------------------|-------|---------------------------------|----------------|-----------------|
| Capacity Factor = | 85 | % | | |
| COST ITEM | | QUANTITY | UNIT \$ | ANNUAL |
| Coal (Illinois #6) | 2,861 | T/D | \$29.40 /T | COST, K\$ |
| | | | | \$26,094 |
| Consumable Materials | | | | |
| Water | 2,822 | T/D | \$0.19 /T | \$166 |
| HGCU Sorbent | 0.10 | T/D | \$6,000 /T | \$180 |
| Limestone | 358.2 | T/D | \$16 /T | \$1,806 |
| Nahcolite | 2.4 | T/D | \$275 /T | \$205 |
| Ash/Sorbent Disposal Costs | 653 | T/D | \$8.00 /T | \$1,620 |
| Plant Labor | | | | |
| Oper Labor (incl benef) | 15 | Men/shift | \$34.00 /Hr. | \$4,455 |
| Supervision & Clerical | | | | \$2,446 |
| Maintenance Costs | 2.2% | | | \$9,246 |
| Royalties | | | | \$261 |
| Other Operating Costs | | | | \$815 |
| | | Total Operating Costs | | \$47,294 |
| By-Product Credits | | | | |
| | | T/D | \$0.00 /T | \$0 |
| _____ | 0.0 | T/D | \$0.00 /T | \$0 |
| _____ | 0.0 | T/D | \$0.00 /T | \$0 |
| _____ | 0.0 | T/D | \$0.00 /T | \$0 |
| | | Total By-Product Credits | | \$0 |
| | | Net Operating Costs | | \$47,294 |

BASES AND ASSUMPTIONS – CASE 2

A. CAPITAL BASES AND DETAILS

| | | | UNIT \$ | |
|------------------------------|----|---------------------------------------|------------|-----------|
| | | QUANTITY | PRICE | COST, K\$ |
| Initial Cat./Chem. Inventory | | | | |
| Water | | 71958 T | \$0.19 /T | \$14 |
| HGCU Sorbent | | 42 T | \$6,000 /T | \$253 |
| Limestone | | 9134 T | \$16 /T | \$148 |
| Nahcolite | | 61 T | \$275 /T | \$17 |
| | | Total Catalyst and Chemical Inventory | | \$432 |
| Startup costs | | | | |
| Plant modifications, | 2 | % TPI | | \$9,460 |
| Operating costs | | | | \$1,800 |
| Fuel | | | | \$631 |
| | | Total Startup Costs | | \$11,891 |
| Working capital | | | | |
| Fuel & Consumables inv | 60 | days supply | | \$5,502 |
| By-Product inventory | 30 | days supply | | \$0 |
| Direct expenses | 30 | days | | \$871 |
| | | Total Working Capital | | \$6,373 |

B. ECONOMIC ASSUMPTIONS

| | | | | | |
|--|-------|----------------|--------|-----------------|--------|
| Project life | 20 | Years | | | |
| Book life | 20 | Years | | | |
| Tax life | 20 | Years | | | |
| Federal and state income tax rate | 38.0 | % | | | |
| Tax depreciation method | | MACRS | | | |
| Investment Tax Credit | 0.0 | % | | | |
| Financial structure | | | | | |
| | % of | Current Dollar | | Constant Dollar | |
| Type of Security | Total | Cost, % | Ret, % | Cost, % | Ret, % |
| Debt | 80 | 9.0 | 7.25.8 | 4.6 | |
| Preferred Stock | 0 | 3.0 | 0.00.0 | 0.0 | |
| Common Stock | 20 | 20.0 | 4.0 | 16.5 | 3.3 |
| Discount rate (cost of capital) | | | 11.2 | | 7.9 |
| Inflation rate, % per year | | 3.0 | | | |
| Real Escalation rates (over inflation) | | | | | |
| Fuel, % per year | | | -1.1 | | |
| Operating & Maintenance, % per year | | 0.0 | | | |

C. COST OF ELECTRICITY – CASE 2

The approach to determining the cost of electricity is based upon the methodology described in the Technical Assessment Guide, published by the Electric Power Research Institute. The cost of electricity is stated in terms of 10th year levelized dollars.

| | Current \$ | Constant \$ |
|----------------------------------|------------|-------------|
| Levelizing Factors | | |
| Capital Carrying Charge, 10th yr | 0.179 | 0.148 |
| Fuel, 10th year | 1.091 | 0.948 |
| Operating & Maintenance, 10th yr | 1.151 | 1.000 |
| | | |
| Cost of Electricity - Levelized | mills/kWh | mills/kWh |
| Capital Charges | 31.1 | 25.8 |
| Fuel Costs | 10.0 | 8.7 |
| Consumables | 1.6 | 1.4 |
| Fixed Operating & Maintenance | 5.9 | 5.1 |
| Variable Operating & Maintenance | 1.0 | 0.9 |
| By-product | 0.0 | 0.0 |
| | | |
| Total Cost of Electricity | 49.6 | 41.9 |

Appendix B

Modifications made to 1998 IGCC Process System Study

Modifications made to the 1998 IGCC Process System Study

The attached summaries show the results obtained previously for the 1998 IGCC Process System Study and the results obtained based on the changes listed below to the economic analysis and the process simulations.

Economics

The following changes were made to the economic section of the 1998 System Study cases done by EG&G for the Gasification Technologies Product Team.

- The costs were brought to 1st Quarter 1999 dollars.
- The contingencies for several sections were changed to reflect advancements in technology development.
- The operating and maintenance costs were lowered to reflect recent technology improvements and competitive pressure (Annual Energy Outlook 2000).
 - The number of operators was lowered.
 - The maintenance costs were lowered. This is based on a percentage of the Total Plant cost.
- The cost for the Air Separation Units were updated to reflect recent price quotes from a supply vendor.
- The cost and attrition rate for the sorbent in the Hot Gas Cleanup cases were updated to reflect improvements in the state of the art sorbent development. The Separations and Gasification Engineering Division of NETL provided this information.
- The escalation rate of coal was updated to -1.1% from -0.9% and the price of coal was updated to \$29.40/ton from \$30.60/ ton per the Annual Energy Outlook 2000 projections.
- Some equipment costs were updated after viewing recent publications and talking to technical experts at NETL.

Process Simulations

The following changes were made to the process simulation section of the 1998 System Study done by EG&G for the Gasification Technologies Product Team.

- For Oxygen-blown gasifiers, the Air Separation Unit (ASU) uses an advanced cryogenic plant designed to take advantage of air being provided from a high pressure gas turbine. This resulted in the nitrogen and oxygen streams from the ASU being sent to boost compressors at higher pressures. This reduces power requirements for these compressors.
- Process Efficiencies for boost compressors and air compressors were based on industry recommended values. This resulted in isentropic stage efficiencies for air and nitrogen compressors of 83% compared with 85-87% being used in the 1998 study. Additionally, the oxygen boost compressor stage efficiency was set at 74% compared to 85% used previously. These modifications increased power requirements and partially eliminated the advantage (for

oxygen-blown systems) of the above change.

- Simulation Codes are all available for use in ASPEN PLUS Version 10.1. (Some of the 1998 cases were in version 9.3).
- The databank for pure component information was changed to “Pure10” which is ASPEN PLUS latest release. Only minor changes in some stream information resulted from this change.
- The ASPEN representation for boost compressors and the air compressor was changed from a series of compressor + intercoolers (ASPEN Blocks “COMPR” and “HEATX”) to a multi-stage intercooled compressor (ASPEN Block “MCOMPR”). The low quality heat available from intercoolers was not used in the steam cycle. This had a minimal effect since most cases have excess low quality heat available.

FY 2000 IGCC Systems Summary Update

* (Contingencies on Hot Gas Cleanup Sections: Gas Conditioning 15/10%, Transport Desulfurizer 15%, Sulfator 15%)

| | Texaco | | | Shell | | Destec | | British Gas/ Lurgi | |
|--------------------------------|----------------|-----------------------------------|-----------|-----------|-----------|-----------|-----------|-----------------------|-----------|
| | Quench CGCU | Radiant + Convective CGCU HGPU | | CGCU | HGPU | CGCU | HGPU | CGCU | HGPU |
| | CASE 1 | CASE 2 | CASE 3 | CASE 1 | CASE 2 | CASE 1 | CASE 2 | CASE 1 | CASE 2 |
| Gas Turbine Power (MWe) | 272.7 | 272.4 | 272.1 | 272.3 | 272.5 | 272.8 | 272.6 | 272.6 | 272.5 |
| Steam Turbine Power (MWe) | 152.3 | 191.7 | 183.8 | 188.9 | 187.6 | 172.2 | 171.1 | 133.4 | 130.3 |
| Misc./Aux. Power (MWe) | 42.0 | 51.3 | 46.3 | 48.3 | 47.8 | 44.4 | 43.3 | 31.1 | 30.7 |
| Total Plant Power (MWe) | 382.9 | 412.8 | 409.6 | 412.8 | 412.4 | 400.6 | 400.4 | 374.9 | 372.1 |
| Efficiency, HHV (%) | 39.7 | 43.5 | 46.5 | 45.7 | 48.0 | 45.0 | 47.6 | 45.3 | 49.4 |
| Efficiency, LHV (%) | 41.2 | 45.1 | 48.3 | 47.4 | 49.8 | 46.7 | 49.4 | 47.0 | 51.3 |
| Total Cap Requirement (\$1000) | \$500,599 | \$594,053 | \$561,229 | \$566,101 | \$564,963 | \$546,993 | \$538,933 | \$533,664 | \$503,640 |
| \$/kW | \$1,307 | \$1,439 | \$1,370 | \$1,371 | \$1,370 | \$1,365 | \$1,346 | \$1,423 | \$1,354 |
| Net Operating Costs (\$1000) | \$48,411 | \$49,422 | \$43,426 | \$46,969 | \$42,562 | \$46,487 | \$41,888 | \$46,445 | \$40,416 |
| COE (mills/kW-H) | 42.5 | 44.3 | 41.1 | 42.1 | 40.7 | 42.3 | 40.4 | 44.5 | 41.1 |

| | KRW Air-Blown | | | KRW Oxygen Blown | | Transport Air-Blown | | Transport Oxygen-Blown | |
|-------------------------------|---------------|--------------|---------------------|---------------------|------|------------------------|-----------|---------------------------|-----------|
| | With HGPU | /out CGCU | In-Bed Sulf HGPU | CGCU | HGPU | CGCU | HGPU | CGCU | HGPU |
| | CASE 1 | CASE 2 | CASE 3 | | | CASE 1 | | CASE 2 | |
| Gas Turbine Power (MWe) | 272.6 | 272.4 | 272.8 | | | | 272.8 | | 272.6 |
| Steam Turbine Power (MWe) | 184.8 | 177.0 | 174.3 | | | | 162.6 | | 142.4 |
| Misc./Aux. Power (MWe) | 24.5 | 25.3 | 25.5 | | | | 20.0 | | 31.3 |
| Total Plant Power (MWe) | 432.9 | 424.1 | 421.6 | | | | 415.4 | | 383.7 |
| Efficiency, HHV (%) | 48.4 | 44.3 | 46.3 | | | | 49.8 | | 47.1 |
| Efficiency, LHV (%) | 50.2 | 45.9 | 48.0 | | | | 51.7 | | 48.8 |
| Total Cap Requirement (x1000) | \$566,641 | \$544,961 | \$550,305 | | | | \$484,062 | | \$496,722 |
| \$/kW | \$1,309 | \$1,285 | \$1,305 | | | | \$1,165 | | \$1,295 |
| Net Operating Costs (x1000) | \$54,059 | \$48,032 | \$43,740 | | | | \$45,388 | | \$47,294 |
| COE (mills/kW-H) | 42.4 | 40.3 | 39.5 | | | | 38.1 | | 41.9 |

FY 1998 IGCC Systems Summary

| | Texaco | | | Shell | | Destec | | British Gas/ Lurgi | |
|--------------------------------|----------------|-------------------|--------------------|---------|---------|---------|---------|-----------------------|---------|
| | Quench CGCU | Radiant + CGCU | Convective HGPU | CGCU | HGPU | CGCU | HGPU | CGCU | HGPU |
| | CASE 1 | CASE 2 | CASE 3 | CASE 1 | CASE 2 | CASE 1 | CASE 2 | CASE 1 | CASE 2 |
| Gas Turbine Power (MWe) | 271.9 | 272.5 | 271.2 | 273.0 | 271.6 | 273.0 | 271.1 | 272.4 | 272.1 |
| Steam Turbine Power (MWe) | 154.1 | 192.4 | 184.9 | 188.3 | 189.2 | 173.5 | 172.0 | 131.2 | 130.7 |
| Misc./Aux. Power (MWe) | 44.4 | 54.5 | 49.2 | 54.3 | 53.1 | 48.1 | 46.3 | 34.0 | 33.4 |
| Total Plant Power (MWe) | 381.7 | 410.4 | 406.9 | 407.1 | 407.7 | 398.5 | 396.9 | 369.5 | 369.3 |
| Efficiency, HHV (%) | 39.6 | 43.4 | 46.3 | 45.4 | 47.5 | 44.8 | 47.4 | 45.4 | 49.1 |
| Efficiency, LHV (%) | 41.1 | 45.0 | 48.1 | 47.0 | 49.3 | 46.5 | 49.1 | 47.1 | 50.9 |
| Total Cap Requirement (\$1000) | 519,625 | 596,034 | 593,781 | 596,811 | 588,502 | 551,179 | 552,513 | 559,717 | 528,069 |
| \$/KW | 1,361 | 1,452 | 1,459 | 1,466 | 1,443 | 1,383 | 1,392 | 1,515 | 1,430 |
| Net Operating Costs (\$1000) | 67,128 | 69,832 | 70,836 | 67,876 | 69,445 | 65,711 | 67,279 | 65,889 | 64,710 |
| COE (mills/KW-H) | 47.2 | 48.1 | 48.8 | 47.9 | 48.0 | 46.2 | 47.0 | 50.3 | 48.5 |

| | KRW Air-Blown | | | KRW Oxygen Blown | | Transport Air-Blown | | Transport Oxygen-Blown | |
|--------------------------------|---------------|---------------------|---------------------|---------------------|------|------------------------|---------|---------------------------|---------|
| | With HGPU | /out In-Bed CGCU | Sulf Captur HGPU | CGCU | HGPU | CGCU | HGPU | CGCU | HGPU |
| | CASE 1 | CASE 2 | CASE 3 | | | CASE 1 | | CASE 2 | |
| Gas Turbine Power (MWe) | 271.8 | 271.7 | 272.9 | | | | 271.4 | | 272.1 |
| Steam Turbine Power (MWe) | 181.0 | 172.7 | 170.8 | | | | 160.1 | | 141.9 |
| Misc./Aux. Power (MWe) | 23.8 | 24.5 | 24.7 | | | | 19.5 | | 32.7 |
| Total Plant Power (MWe) | 429.0 | 419.9 | 419.1 | | | | 412.0 | | 381.3 |
| Efficiency, HHV (%) | 48.4 | 44.2 | 46.3 | | | | 49.9 | | 46.9 |
| Efficiency, LHV (%) | 50.2 | 45.8 | 48.0 | | | | 51.7 | | 48.7 |
| Total Cap Requirement (\$1000) | 607,771 | 582,832 | 601,760 | | | | 520,051 | | 538,369 |
| \$/KW | 1,417 | 1,388 | 1,436 | | | | 1,262 | | 1,412 |
| Net Operating Costs (\$1000) | 75,562 | 68,706 | 71,722 | | | | 64,417 | | 67,551 |
| COE (mills/KW-H) | 48.3 | 46.1 | 48.0 | | | | 43.6 | | 48.4 |


COE Summary IGCC Systems Study 2000 Update

| | |
|--------------------------|------|
| Transport HGCU (Air) | 38.1 |
| KRW HGCU (W/out capture) | 39.5 |
| KRW CGCU (W/outcapture) | 40.3 |
| Destec HGCU | 40.4 |
| Shell HGCU | 40.7 |
| Texaco R&C HGCU | 41.1 |
| BGL HGCU | 41.1 |
| Transport HGCU (Oxygen) | 41.9 |
| Shell CGCU | 42.1 |
| Destec CGCU | 42.3 |
| KRW HGCU (With capture) | 42.4 |
| Texaco Quench | 42.5 |
| Texaco R&C CGCU | 44.3 |
| BGL CGCU | 44.5 |

COE Summary IGCC Systems Study 1998

| | |
|--------------------------|------|
| Transport HGCU (Air) | 43.6 |
| KRW CGCU (W/outcapture) | 46.1 |
| Destec CGCU | 46.2 |
| Destec HGCU | 47.0 |
| Texaco Quench | 47.2 |
| Shell CGCU | 47.9 |
| KRW HGCU (W/out capture) | 48.0 |
| Shell HGCU | 48.0 |
| Texaco R&C CGCU | 48.1 |
| KRW HGCU (With capture) | 48.3 |
| Transport HGCU (Oxygen) | 48.4 |
| BGL HGCU | 48.5 |
| Texaco R&C HGCU | 48.8 |
| BGL CGCU | 50.3 |

IGCC Base Case COE Comparison



END