

10-2

Tom 132

726

1.

Item 10
Claus Oven Operation

Hydrogen Sulfide	m ³ /hr	1100-1500
Air Blast	"	1760-2400
Wash-CO ₂	"	495-520
Water Spray above	l/hr	60-90
Water Spray below	l/hr	360-425
Before Filter:		
H ₂ S	%	1.38-2.15
SO ₂	%	0.46-0.64
After Filter		
H ₂ S	%	1.13
SO ₂	%	0.69
Pressures before Contact I	mm WS	480-730
Intermediate	"	360-570
Multiclone E	"	330-530
" A	"	270-420
After Cont. II	"	270-420
Oven exit	"	180-290
After H ₂ S Blower	"	1600-1710
After Air Blower	"	1500-1600
Wash Tower E	"	160-260
Wash Tower A	"	160-260

Temperatures:


Boiler Exit	OC.	280-300
Before Contact I	"	275-295
In Contact I	"	345-355
Under Grate I	"	330-345
Multiclone Entrance	"	280-295
" exit	"	255-270
Before Contact II	"	255-260
In " "	" "	270-280
Under " "	" "	270-290
Under Grate II	"	270-285
Liquid Sulfur	"	130-135
Oven exit	"	135-150
Filter Entrance	"	140-155
Filter Exit	"	140-150
CO ₂	"	172-174
Water Spray	"	136-147
Under Steam Super Heater	"	420-460
Water Lower Preheater below	OC.	315-355
" top	"	305-325

Waste Heat Boiler Installation

Water Pressure before reulator	OC.	18.5-19.5 atm.
Temperature before preheater	"	129-160
Temperature after preheater	"	170-202
Steam pressure in boiler	"	14.5-16.0 atm.
Temperature	"	325-365
Quantity	t/hr	1.5-2.2
Hydrogen sulfide boiler burner	m ³ /hr	500-600
Aux. burner	"	20
Wind air boiler burner	"	825-1010
Aux. burner	"	40
Water spray oven 1 a	l/hr	50-76
Water spray oven 1 b	"	91-102
Before filter:		
H ₂ S	%	1.12-1.48
SO ₂	%	0.60-0.70
After filter:		
H ₂ S	%	1.01
SO ₂	%	0.46
Pressure after blower	mm WS	1600-1710
Pressure before contact oven 1 a	"	930-1040
Pressure after contact oven 1 a	"	620-740
Pressure before contact oven 1 b	"	630-740
Pressure after contact oven 1 b	"	240-330
Pressure exit oven 1 b	"	220-310
Entrance Wash tower	"	160-260
Exit wash tower	"	160-260
Temperature boiler burner	OC.	950-975
Under superheater	"	390-415
Under lower preheater	"	380-405
Under upper preheater	"	240-270
Boiler exit	"	280-305
Before contact I	"	275-300
Middle of contact I	"	340-365
Under of contact I	"	345-364
Liquid sulfur oven 1 a	"	220-245
Oven exit	"	230-250
Auxiliary burner	"	585-650
Before contact II	"	245-250
Middle of contact II	"	260-290
Under contact II	"	260-290
Liquid sulfur oven 1 b	"	120-155
Filter entrance	"	120-140
Filter exit	"	115-130
Wash tower entrance	"	130
Wash tower exit	"	25-29
Waste heat boiler	Atu	18.8-20.0
Feed water pressure from regulator	OC.	94-118
Temperature before preheater	"	195-200
Temperature after preheater	"	
Steam pressure in boiler	Atu	14-15.8
Steam quantity	t/hr	0.66-0.86


Claus Oven : Heats of reaction

Claus oven-Reaction:




$$1 \text{ Nm}^3 \text{ H}_2\text{S} = 2390 \text{ Kcal.}$$

Burning:




$$1 \text{ Nm}^3 \text{ H}_2\text{S} = 5587 \text{ Kcal.}$$

Conversion with SO₂:



$$1 \text{ Nm}^3 \text{ H}_2\text{S} = 790 \text{ Kcal.}$$

Boiler Reaction:



$$1 \text{ Nm}^3 \text{ H}_2\text{S} = 2230 \text{ Kcal.}$$

Claus Oven Operation


Boiler reaction $\text{H}_2\text{S} + \frac{1}{2} \text{O}_2 = 0.7 \text{S} + 0.8 \text{H}_2\text{O} + 0.2 \text{H}_2\text{S} + 0.1 \text{SO}_2$
 Air Requirements at various percentages of Alkacid-sulfur

H ₂ S %	Auf 1 Vol. O ₂	H ₂ S Vol. Luft
100	0.5	2.38
90	0.45	2.14
80		1.91
70		1.67
60		1.43
50		1.19
40		0.95
30		1.713

Factor for theoretical setting:

$$\frac{\% \text{H}_2\text{S}}{100} \cdot 2.38 = \frac{\text{m}^3 \text{luft}}{\text{m}^3 \text{Alkacid H}_2\text{S}}$$

Vol. air to 1 vol. Alkacid H₂S
 Practically not used, but rather the exhaust gas analyses.



Claus Oven-Proposition (self contained)

2000 m³/hr (735 mm and 15°C.) 60% alkacid-H₂S (Remainder CO₂) are to be converted to sulfur. Assume radiation and conduction losses of:

in boiler 20%
in oven 30% bzw. 20%
feed water Temp: 140°C.

Water spray temperature 140°C.

Reaction gases shall leave the boiler at 300°C. the oven at 150°C. and the sulfur flow out at 150°C.

The conversion of H₂S with SO₂ in a contact oven will be 90% complete. Description of: Air requirements

Steam production- 15 atmospheres, 325°C.
Quantity water spray
Sulfur yield

Air Requirements (15°, 735.5 mm):

1 m³ Alkacid-H₂S for boiler reaction.

H₂S + 0.5 O₂ = 0.73 R 0.8 H₂O + 0.2 H₂S + 0.1 SO₂ + 49.5 Kcal.

$$\frac{60}{100} \cdot 2.38 = 1.43 \text{ m}^3 \text{ Air}$$

2000 m³ Alkacid-H₂S need 2860 m³ air, = 2860 · 0.902 = 2580 Nm³ Air

Steam production in boiler:

Heat of the boiler reaction 1 Nm³ H₂S 2230 Kcal.

2000 m³ Alkacid-H₂S 15°C. 735 2000 · 0.902 = 1804 Nm³ H₂S

1084 Nm³ H₂S contain 60% = 1080 Nm³ H₂S and 724 Nm³ CO₂

1080 Nm³ H₂S develop 1080 x 2230 = 2,410,000 Kcal/hr.

Boiler exhaust gas: Temperature 300°C.

Exhaust gas composition
Nm³

	Nm ³		Vol. %		Spec heat of wet gases 0.021
	Dry	Wet	Dry	Wet	
H ₂ S	216	-	7.0	5.4	0.012
SO ₂	103	-	3.5	2.7	0.080
CO ₂	724	-	23.5	18.0	0.157
N ₂	2040	-	36.0	50.4	0.088
H ₂ O	-	999	-	23.5	0.358
	<u>3088</u>	<u>4027</u>	<u>100.0</u>	<u>100.0</u>	

From wet gas H₂O g/Nm³ 13.8 Nm³ total: $1804 \cdot \frac{13.8}{1000} \cdot \frac{22.4}{18} = 31$
 From wet air " " 13.8 Nm³ " : $2580 \cdot \frac{13.8}{1000} \cdot \frac{22.4}{18} = 44$
 Reaction water " " 1080 . 0.8 = $\frac{864}{939}$

Total " "
 Sensible heat of the 300°C. hot exhaust gas:
 $300.4027 \cdot 0.358 = 432,000$ Kcal. of the sulfur vapor in exhaust gas.

$(1080 \cdot 0.7 \cdot 1.43 = 1080 \text{ kgs})$
 350 g S/Nm^3
 $300 \cdot 1080 \cdot 0.28 = 90,700$


Total 522,700 Kcal.

With H₂S burning, heat developed is : 2,410,000 Kcal.
 Lost from boiler in the exhaust gas 522,700 "
 As radiant and conduction losses, estimated 432,000 "
 Remaining for steam production 1,405,300 "
 Heat content of steam 15 atu, 325°C. : 737 Kcal/Kg
 Feed water temperature 140°C 140 Kcal/Kg

Total heat for
 1 kg superh. steam 597 Kcal/kg
 There are produced in waste heat boiler $\frac{1405000}{597} = 2360 \text{ kg} = 2.36 \text{ t}$

Water spray quantities

- a. For extracting heat of condensation from the sulfur vapor
- b. For cooling reaction gases to temp. of the contact oven, 150°C.
- c. For extracting heat of reaction $2 \text{ H}_2\text{S} + \text{SO}_2 = 3 \text{ S} + 2\text{H}_2\text{O}$
 for 90% conversion



$216 \cdot 0.9 \cdot 790 = 151,700$ Kcal
 Heat content of steam 100°C. 639 Kcal/kg
 Heat content of water spray at 140°C. 140 Kcal/kg

Used for vaporization 499 Kcal/kg
 Superheating 150°C.
 $(150-100) 10,437 = 23 \text{ Kcal/kg}$

Quantity water spray Total 522 Kcal/kg
 291 Kg

After conversion with SO₂ as before.

	Nm ³	Vol. %	Spec. heat of the wet gases.
H ₂ S	22	0.6	0.002
SO ₂	11	0.3	0.001
CO ₂	724	19.4	0.086
N ₂	2040	54.7	0.171
H ₂ O	939	25.0	0.093
	<u>3736</u>	<u>100.0</u>	<u>0.353</u>

Sensible heat of the 300° hot exhaust gas	522,700 Kcal
of the 150° hot exhaust gas	198,000 "
150 . 3736 . 0.353	

By water spray must be taken	324,700 Kcal
Quantity water	620 kg.
Sulfur vapor from boiler 1080 kg 300° sensible heat	90,700 Kcal
Resulting heat of condensation	

10 Kcal/Mol.
3.1 Kcal/kg.

1080 . 3.1 = 3350 Kcal
Resulting from conversion with SO₂

196 . 1.5 . 1.43 = 420 kg S
Heat of condensation 420 . 3.1

Total 3350 + 1300 = 4650 Kcal
Cooling from 300° tp 150°

1080
420
1500 . 0.3 (300-150) =

1,300 Kcal

75,000 Kcal

4,600 "

Total 79,600 "

152 kg

Spray water quantity
Spray water

a) 152 kg 14.3%
b) 620 kg 58.3%
c) 291 " 27.4%

Total 1063 kg.

If we count on losses in the oven, by radiation and conduction, of 30%

744 kg spray water are required 1063 . 0.70 = 744 kg
with only 20% radiation and conduction losses, 850 kg

Sulfur yield

Boiler reaction 1080 kg S
Oven conversion 420

1500 kg S

1540 kg S

Actually in the H₂S

97.3%