

Mr Wiley

1547

T-227

UNITED STATES
DEPARTMENT OF THE INTERIOR
BUREAU OF MINES
COAL TO OIL DEMONSTRATION BRANCH
LOUISIANA, MISSOURI

IRON FOR REPAIRS IN HYDROELECTRIC PLANTS

May 17, 1948

Alpen Messure Experimente Innovationsplan, I.	January 13, 1944 Kg/yr	Iron consumption 1000 RM rep. 250 kg iron	Repair costs RM/te/ann.	Iron consumption 1000 RM rep. 250 kg iron
1). Our estimate from the costs of repairs: Installation costs RM/te/ann.				
700 a.m. diam. coal plant	1,200.-- (1.5 gasol.)	48.--	12 kg Fe/te/ann gasoline	
300 " brown coal plant	1,050 "	42.--	10.5 "	
Brown coal 1.1 t.o. per DHD plant	540.0 "	22.--	5.3 "	
	70.-- (DHD gasol.)	7.--	1.75 "	
2). A distribution of the installation costs among hydrogenation, hydrogen production, power production, auxiliary installations and special requirements will be found in appendix 1. Costs supplied by the different works on the consumption of iron for repairs: Celsiusberg mine of 1/10/44 Reports for 1943				
" " 1/19/44 Costs of repairs, 1942/1943				
" " 1/11/44 at least 1/3, i.e. at least 20 kg/te	45 - 48 RM/te VT 705 is 15.-- to 16.-- RM/te VT 705/iron material. Iron requirements: VT 705 + DHD + T 52 gasoline (LPG not included)	16.4 kg/te gasoline, " 11.5 " " gasoline + LPG		
" " 1/9/44 Iron consumption, " allotment, 1943	43 12.5 kg/te liquid products. 8.5 " "			
" " 1/10/44 Iron consumption, " allotment, 1942	44.7 kg/te liquid product + LPG + SS oil + T 52 (no DHD) 53.50 RM for hydrogenation + H2 + power + LPG + SS oil			
" " 1/10/44 Repair costs, 1942	45.50 RM for hydrogenation + H2 + power + LPG + SS oil + T 52 (no DHD), i.e. 1000 RM repair costs = 250 kg Fe			
" " 1/10/44				
3000 a.m. diam. coal plant	Iron consumption	10 kg/te liquid products		
3000 " brown coal plant	" "	7.3 "		
3000 " brown coal 1.1 t.o. per DHD plant	" "	9.1 "		
As estimate of the total repair iron requirements are found in appendix 2.				

January 13, 1944

Appendix I.

Installation and Repair Costs in Hydrogenation Plants

	<u>Install. costs</u> <u>per te/ann.</u> <u>gasoline</u>	<u>Repairs</u> <u>%</u>	<u>Repairs costs</u> <u>Rs/te/ann.</u> <u>ann.</u>
<u>Blt. coal to L gasoline</u>			
Hydrogenation proper	422.-	± 0.065 =	27.40
H ₂	172.-	± 0.065 =	11.40
Power	225.-	± 0.02 =	4.55
Amr. inst.	222.-	± 0.02 =	4.45
Add. capital investment	167.-	-	
	<u>1211.-</u>		<u>47.80</u>
<u>Brown coal to L gasoline</u>			
Hydrogenation proper	300.-	± 0.065 =	25.40
H ₂	144.-	± 0.065 =	9.40
Power	184.-	± 0.02 =	3.70
Amr. inst.	195.-	± 0.02 =	3.90
Add. capital investment	136.-		
	<u>1049.-</u>		<u>42.40</u>
<u>Brown coal tar to L gasol.</u>			
Hydrogenation proper	209.-	± 0.065 =	13.60
H ₂	70.50	± 0.065 =	4.60
Power	90.50	± 0.02 =	1.80
Amr. inst.	99.-	± 0.02 =	2.-
Add. capital investment	70.50		
	<u>539.50</u>		<u>22.80</u>
<u>DMD</u>			
DMD	59.-	± 0.1 =	5.90
Power	17.-	± 0.02 =	- .35
Amr. inst.	7.50	± 0.02 =	- .15
Add. capital investment	5.-		
	<u>88.50</u>		<u>6.40 = about 7.-</u>

January 10, 1944

Appendix 2.

Iron Requirements in Hydroelectric Works

Works	Production	Installation costs ²⁾	Iron const. ⁹⁾	Yearly iron requirements
	te/ann.	Mill. M.	1000 te	1000 te
Leuna 8)	600 000.-	295	188	6.5 ⁶⁾
Schulzen	215 000	167	131	2.0
Gelsenberg	335 000	200	200	4.0 ⁷⁾
Rheinsbrunn	210 000	183	150	2.0 ⁵⁾
Pöhlitz	600 000	350	234	3.84
Böhlen	200 000			
Ingelburg	220 000	210	215	3.5
Zeitz	230 000			
St. 3)	600 000	375	402	4.35
Blackhammer	500 000	635	420	0.87
Waldheim	130 000	95	75	1.33
Litzkendorf	50 000 ⁴⁾	40	32	0.33
	2 800 000 te/ann.	2687 Mill. M.	2186 000 te	28 720 te

/s/ v. Hochstetter

1) 1.- repair costs = 0.25 kg iron. Calculated from the total repair costs assumed as 4% of the installation cost.

2) No "additional capital investment".

3) Including low temperature carbonization

4) Theoretical production

5) Data given by the works: 12.5 kg iron/te liq. prod. = 2.6×10^3 te.

6) " " " " " 14.7 " " " " " = 8.8×10^3 "

7) " " " " " 23.5 " " " " " = 1.2×10^3 "

8) In this case the repair costs are assumed to be 8% because of the older and more cheaply-built plant.

9) Estimated values.