

*Mr. Wiley*

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
BUREAU OF MINES  
OFFICE OF SYNTHETIC LIQUID FUELS  
LIGONIA, MISSOURI

1587

2000 1000 10, Aug 2043, Revised 453-458

10-458

W. M. Rosenberg  
April 9, 1943

Revised, July 15, 1943

REDUCTION OF FUSED IRON CATALYST FOR  
A 10,000 cc/yr. PLANT

The total amount of catalyst to be reduced for 5 reactors of 10  
csm capacity and 2 reactor of 3 csm capacity, with a 4 months life  
of the catalyst amounts to 3 x 60 = 180 csm catalyst per year. With  
a bulk weight of 1.7, this represents 307 lb iron per year corres-  
ponding to 465 lb of unreduced iron, or with a bulk weight of 2.0 it  
would represent 360 csm of unreduced catalyst (assumed to be Fe<sub>2</sub>O<sub>3</sub>).

The reduction will require 180,000 csm H<sub>2</sub> per year, assuming the  
efficiency of hydrogen utilization to be 80%, and this will represent  
22 csm hydrogen per hour. (1 yr. assumed to be equal to 8760 hours).

The hydrogen must be very pure, in particular very free from sulfur.  
We will first describe the reduction installation in No. 100 (Fig. 1).  
The hydrogen enters at E, is heated to 120° in the preheater VI  
(using high pressure steam) and then enters the circuit through the  
towers A1, A2 filled with 100 coke. The circuit consists of the  
towers B1, B2, the preheater V2, the reducing chamber B, the cooler  
C1, the ammonia cooler K and the two silica gel towers H1 and H2  
installed in parallel. Part of the hydrogen is lead off through the  
bleed-off valve J. At the reduction temperature of about 440° almost  
all the water produced is absorbed in the silica gel towers, because

under the existing conditions the low point of water is just reached behind the H<sub>2</sub> cooler, and the towers are cooled by the circuit consisting of the high pressure steam preheater H6, cooler H3 and blower G5.

Mass and gas balance of the present installation:

Space utilization 1:2500. Time of reaction: 50 hours. Pressure on the suction side of the blower 300 to 350 mm of water. Nominal capacity of the blowers is 300 cfm each. The 2 blowers produce however together only 450 cfm per hour of the heated gas against 100 mm Hg. The diameter of the reaction chamber is 1/160 m. The resistance of the catalyst layer is 1/160 m thick with the smallest particle size that can be considered (0.5-1 mm) is 100 mm Hg. The capacity of each silica gel tower is 500 lb of gel. Hydrogen leaving the ammonia cooler at 4° and the silica gel tower at about 45° because of the heat of adsorption which has been set free. The whole system operates discontinuously and must therefore be preheated, cooled, purged with inert gas, and as a result only some 20 cfm of catalyst can be reduced in the present installation per year.

The following installation is recommended for the above mentioned 500 cfm of catalyst (see sketch 2).

(Equipment used for the ammonia synthesis as in sketch 1, is used in the same way). The distillation of a continuous method of operation does not seem to be desirable in view of the high temperature required for the reduction and the introduction of cooling parts (catalyst stabilizers). The installation is therefore to be with 2 parallel


connected alternately operated reduction vessels (R1 and R2) with 5000 hours per year and reduction time of 56 hours, 1.6% cost should be reduced in one charge. The resistance of the beds limits the catalyst height to 1 m, and the reducer must have a diameter of 1.5-2 m. The blower capacity (G1) should be 3240 cm<sup>3</sup> per hour. The grate in this installation, which supports the catalyst is composed of 2 parts which can be rotated on a shaft located in the middle of the reducer. This arrangement is desirable primarily because of the large weight of the catalyst, but also because of the poor packing properties of the latter. A proper kind of grate remains yet to be constructed. The second reducer must be cooled during the 56 hours required for the reduction of one charge, flushed with CO<sub>2</sub>, emptied, filled, and again flushed with H<sub>2</sub>. The cooling in the sketch is suggested by using some of the circulation hydrogen after branching it off at Z. The hydrogen is cooled in an additional cooler K3 and reenters the circuit behind Z. The flushing with CO<sub>2</sub> can be done after the reducer temperature has dropped to 60°C, and the CO<sub>2</sub> required in the flushing as well as during the filling of the synthesis reactor must be free from sulfur, and dry (longer storage of the catalyst must be done in an atmosphere of H<sub>2</sub>). The CO<sub>2</sub> coming from the CO<sub>2</sub> separator is used after being desulfurized with lumps of the lanta mass (red mud from sludge production) mixed with poly. The lanta mass is regenerated with air. Up to 50 cm<sup>3</sup> per hour of CO<sub>2</sub> is required, but it is only used occasionally (for the flushing of the reducers). The desulfurizing requires 2 containers with about

1 cm cross section and 1 cm content for the pea size lava mass. To desulfurize  $CO_2$  it must be heated to 30-35°. In connection with manufacturing 2 silica gel towers are required, each holding 100 lb. of the gel, which must be alternately dried, preferably with  $CO_2$ . In the filling of the reactor a manhole is needed of sufficient size and best located in front, through which the catalyst may be readily introduced and uniformly distributed. In this case the  $H_2$  should best be introduced through the circuit pipeline similar to that of the  $H_2$  outlet. For safety sake the  $H_2$  and  $CO_2$  supply and removal must be closed off with blinds or some similar arrangements. After the charge has been introduced, the  $CO_2$  is driven out by  $H_2$  to the open and the container started.

The following changes have been made against the other installations: A reduction temperature of 500° must be reached. A heat exchanger is provided. The  $H_2$  outlet is preferably arranged in front of the  $H_2$  towers. The preheater for the drying of the  $H_2$  towers is provided with a by-pass, because the towers must be cooled after drying. The  $H_2$  towers in the present installation have been designed somewhat too small in size and should be increased about 1.5 times. Otherwise these conditions are properly designed and can be carried over into the new installation with the same proportion. The present heating gas and air blowers must be operated to capacity.

1591

453



1592

